



**re: Geotechnical Recommendations – Pavement Structure
Above Podium Deck**

**Proposed Residential Development
729 to 753 Ridgewood Avenue - Ottawa**

to: Brigil - Mr. Philip Thibert - Pthibert@Brigil.com

date: July 4, 2022

file: PG5172-MEMO.03

Further to your request and authorization, Paterson Group (Paterson) prepared the current memorandum to provide geotechnical recommendations regarding the pavement structure to be used overlying the underground parking structure. The memorandum should be read in conjunction with Paterson Report PG5172-1 Revision 1 dated June 21 , 2021.

The pavement structures provided in Tables 1 and 2 below are recommended where the proposed pavement structure is to be located overlying the concrete podium deck.

Table 1 - Recommended Asphalt Pavement Structure - Access Lanes/Heavy Loading Parking Areas	
Thickness (mm)	Material Description
40	Wear Course - Superpave 12.5 Asphaltic Concrete
50	Binder Course - Superpave 19.0 Asphaltic Concrete
150	BASE - OPSS Granular A Crushed Stone
SUBGRADE – protection board and/or rigid insulation over concrete podium deck	

Table 2 - Recommended Asphalt Pavement Structure - At-Grade Parking Areas	
Thickness (mm)	Material Description
50	Wear Course - Superpave 12.5 Asphaltic Concrete
150	BASE - OPSS Granular A Crushed Stone
SUBGRADE – protection board and/or rigid insulation over concrete podium deck	





Minimum Performance Graded (PG) 58-34 asphalt cement should be used for this project. The pavement granular base and subbase should be placed in maximum 300 mm thick loose lifts and compacted to a minimum of 99% of the material's SPMDD using suitable vibratory equipment.

We trust that the current submission meets your requirements.

Best Regards,

Paterson Group Inc.

Kevin A. Pickard, EIT



David J. Gilbert, P.Eng.

