

March 22, 2023

Our File No.: 23003

VIA EMAIL

3055 Richmond Holdings Inc.
1886 Merivale Rd
Ottawa, ON K2G 1E6

Attention: Mr. Fernando Matos

**Reference: 3055 Richmond Rd, 4-Storey Residential Building - Site Plan Application
Lighting Control Letter**

Dear Fernando:

We write this letter to confirm that the new site lighting design from the site plan application for the above project will not exceed 0.5 fc (5.38 lux) maintained on the adjacent properties at grade level.

Furthermore, all new light fixtures proposed on the aforementioned site plan will meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES).

Please call if you require any additional information.

Yours truly,

ALFA+ PROJECT LEADERS INC.



Al Salah, P.Eng.