



69 Lesmill Road Toronto, Ontario Canada M3B 2T8
T: (416) 444.9263 F: (416) 444.1463 E: dwg@hamjof.com

March 8, 2016

Planning Approvals, Outer Urban
Planning and Growth Management Department
City of Ottawa
110 Laurier Avenue West
Ottawa, Ontario
K1P 1J1

Attention: Mr. Prescott McDonald,

Re: SCE Phase 2 (Costco)
2012 Ogilvie Road
Gloucester, Ottawa
Our Reference #13-504C

Dear Sir;

With respect to the site lighting plan prepared for site plan application, we advise

- Lighting has been designed using Full Cut-Off (Sharp cut-off) Classification as recognized by IESNA or IES.
- Lighting has been designed to minimize lighting spillage onto adjacent properties with a maximum of 0.5FC allowable as per City of Ottawa requirements.

Please do not hesitate to contact us for any further clarification.

Yours very truly,

HAMMERSCHLAG + JOFFE INC.

Mark Hammerschlag, P. Eng.
/kl

