

Civil and Municipal  
Engineering

# ARK Engineering and Development

**Serviceability Report:**  
**Potable Water Supply Assessment, Sewage,  
Stormwater Management and Grading**

7564 Village Centre Place  
Block 63  
Plan 4M-1398  
Greely Village Centre  
Ottawa (Greely), Ontario

Prepared For  
Greely Family Farm Inc.

ARK Engineering  
and Development  
2343 Lorraine St.  
Rockland, Ontario  
Tel: (613) 858-6443  
ARKEngineering@rogers.com

August 2019



**POTABLE WATER SUPPLY ASSESSMENT, SEWAGE,  
STORMWATER MANAGEMENT AND GRADING**

**Serviceability Report**

**Table of Content**

<b>1.0 BACKGROUND</b>	
1.1 General .....	1
1.2 Existing Services .....	1
<b>2.0 PROPOSED SERVICES</b> .....	<b>2</b>
2.1 Potable Water Supply Assessment.....	2
2.1.1 Background.....	2
2.1.2 Supplemental Potable Water Assessment .....	3
2.1.3 Water Quality .....	7
2.2 Sewage .....	9
2.3 Stormwater Management .....	10
2.4 Site Grading.....	11
<b>3.0 CONCLUSION</b> .....	<b>12</b>

**Appendix "A"**

SK-1	Location Map
Pond Sizing	Excerpt from J.F. Sabourin

**Appendix "B"**

MOE Well Record
Eurofins Laboratory Subdivision Package Results
Drawdown Plot
Langelier Saturation Index

---

## SERVICEABILITY REPORT

### 1.0 BACKGROUND

#### 1.1 General

The proposed site plan amendment situated on Block 63 with the Water's Edge Subdivision 4M-1398 consists of approximately 0.3049ha and is located on the Eastern side of the intersection of Village Centre Place and Vista Villagio St. (refer to the location map SK-1 in appendix A). The proposed site plan will consist of an additional 6,000ft<sup>2</sup> retail building. It will be serviced by an existing private sanitary sewer and well along with existing roadside drainage ditches.

#### 1.2 Existing Services

This area of commercial development in Greely has no City sanitary and watermain to service this proposed site plan. The proposed sanitary and water service will be privately owned. As for the storm service the existing roadside ditches will serve as an outlet for this development.

An internal Road Network as shown on the location map in Appendix A, will provide this site plan with one main connection access point from Bank St. An alternate access is located off of Parkway Rd.

All utilities (Hydro, Bell Cable and Gas) are available and have been installed up to the property line.

## 2.0 PROPOSED SERVICES

### 2.1 Potable Water Supply Assessment

ARK Engineering was retained by Greely Family Farm Inc. to provide a verification of water supply yield and well location for a proposed site plan application amendment to a commercial development located at 7564 Village Centre Place, Ottawa (Greely), Ontario, Block 63 Plan 4M-1398

The pump test was conducted in general accordance with Ontario Ministry of the Environment and Climate Change (MOECC) guidance document Procedure D-5-5: Technical Guideline for Private Wells: Water Supply Assessment (MOEE, 1996).

The scope of the report is limited to the description of the potential yield quantity and quality of the bedrock water supply aquifer intercepted by a drilled well, as it relates to the future servicing potential for the proposed building development within the area of the subject site.

#### 2.1.1 Background

There is a currently a City approved Consolidated Terrain Analysis and Hydrogeological Study Report dated October 8, 2008 by the Paterson Group for the plan of subdivision 4M-1398 in which this said Block 63 forms part of. Both the water quantity and quality have already been analyzed and deemed to be excellent for this development. Also, all new well construction recommendations within this plan of subdivision (either residential or commercial), along with required casing lengths have been determined and accepted and are registered on title for this Block.

It should also be noted that in Appendix 3, page 24 of this approved report Paterson Group concluded the following:

- 1) A suitable water supply aquifer exists within the sandstone formation underlying the limestone formation at the subject site.
- 2) The sandstone water supply aquifer has an aeral extent such that all portions of the site can access it.
- 3) The sandstone water supply aquifer has ample quantities of water available for utilization by both the proposed residential and commercial portions of the site and has excellent water quality.

- 4) The sandstone water supply aquifer possesses significant upwards gradient that remains largely unaffected by maximum water taking estimates at the site and as agreed to by experts at the Ontario Municipal Board Hearing, is hydrogeologically isolated from surface activity.
- 5) The sandstone aquifer is considered to be an excellent aquifer for this development.

### 2.1.2 Supplemental Potable Water Supply Assessment

As part of the commercial phasing within plan 4M-1398 for Block 65-64-63 another proposed building will be developed and serviced by a private well. The following will demonstrate once again that the targeted aquifer is more than adequate to support this new commercial phase.

The scope of the report is limited to the description of the potential yield quantity and quality of the bedrock water supply aquifer intercepted by a drilled well, as it relates to the future servicing potential for the proposed development within the area of the subject site.

A new drilled well (designated TW1, refer to Appendix "B" for MOE well record) was installed at the site on July 23, 2019 by D & R Drilling of St-Albert, Ontario (Well Contractor License No.3773). The new well was drilled to a total depth of 104.54 m. Steel casing was installed to a depth of approximately 70m. The test well was constructed in general conformance with the well construction requirements for the adjacent development within plan 4M-1398. As per the approved "Consolidated Terrain Analysis and Hydrogeological Study Report", which requires all wells to be cased "through the limestone formation and extend into the sandstone formation".

**Table 1:** Test Well summary

Well ID	Year Drilled	Depth to Bedrock (m)	Depth of Water Bearing Fractures (m)	Total Depth (m)	Recommended Pumping Rate (L/min)
A258630	2019	7.87	103.63	104.54	45.0

The pump test was conducted in general accordance with Ontario Ministry of the Environment, Conservation and Parks (MECP) guidance document Procedure D-5-5: Technical Guideline for Private Wells: Water Supply Assessment (MOEE, 1996).

A pumping test at TW1 on July 23, 2019 was conducted. A pumping rate of 64 L/min was selected with the expectation that the rate would stress the aquifer enough to result in a demonstrable reduction in potentiometric head (i.e. a lowering of the static water level) within the test well. The pumping test was carried out for a 8 hour duration.

During the test the pumping rate was monitored at regular intervals to ensure the rate of discharge remained constant (i.e. < 5% variation). Drawdown observations during pumping and recovery were recorded using manual measurements taken with an electronic water level tape.

Drawdown observations during the pumping and recovery were recorded using manual measurements using an electronic water level tape. Over the course of the pumping test, the water level in the well dropped by 0.38m within minutes then it maintained its level through out the 8 hours in which it was then allowed to recover. No real recovery data was collected for the well following the completion of pumping since the 95% recovery was achieved almost immediately.

Field testing for chlorine was carried out at the time of sampling. Groundwater samples were collected in laboratory supplied bottles and preserved in the field using established sampling protocol. The samples were stored in a dedicated sample cooler maintained at a temperature between 4 and 10 degrees Celsius. The water samples were submitted to the Eurofins within one (1) hour of collection for standard "Sub. Package", refer to Appendix "B".

Turbidity measurements were taken using a Hanna C114 turbidity meter at the well head at regular intervals during the pumping test and the reading at the time of the sampling (8 hour mark) was below 1.0 NTU. Free chlorine residual measurements were taken using a Hach™ Pocket Colorimeter IITM handheld unit immediately prior to the collection of each groundwater sample.

**Table 1: Testing Results**

Parameters	Results
Pumping Rate (L/min)	64.0
Static Water Level at start of test (m)	3.21
Static Water Level at end of test (m)	3.59
Total Drawdown during test (m)	0.38
Available Drawdown (m)	101.33
% Drawdown during pumping test	0.38%
Transmissivity	153
Specific Capacity (L/min/m)	168

The pumping test drawdown plot for TW1 is provided in Appendix "B". As for the recovery data since it was practically instantaneous no data was able to be recorded. The drawdown data provided was measured with reference to the top of the well casing at the test well location.

The pumping test data for the test well was analyzed using the method of Cooper and Jacob (1946). This method provides a reasonable estimate of the aquifer transmissivity.

Transmissivity was calculated using the following relationship:

$$T = \frac{2.3Q}{4\pi ds}$$

Where:

- Q = pump rate, m<sup>3</sup>/day
- ds = change in drawdown over one time log cycle, m
- T = transmissivity, m<sup>2</sup>/day

Based on the pumping test drawdown data the transmissivity of the aquifer is estimated to be about **153m<sup>2</sup>/day**.



For the new proposed commercial building the daily water demands have been estimated based on Section 4.4.1.2 of the City guidelines, Appendix 4-A. In accordance to Appendix 4-A, the proposed development would have a demand of 1.98 L/min. Refer to Section 2.2 Sewage for a summary of the estimated sewage flow.

This is approximately 97% less than the rate utilized during the pumping test (64 L/min.). Given that the well totally recovered practically immediately of termination of pumping at a rate of 64 L/min, the water supply aquifer intercepted will provide the necessary well yield without mining the aquifer in the long term.

Based on the above there is water of sufficient quantity present in the water supply aquifer beneath the site to support the new 6,000ft<sup>2</sup> commercial building.

### 2.1.3 Water Quality

Water quality analysis data from TW1 is summarized in Table 2 (below). Laboratory certificates of analysis are included in Appendix "B".

Table 2: Groundwater Geochemistry - TW1

PARAMETER	UNITS	ODWS		6045 Bank St.	6075 Bank St.	NEW
		TYPE	LIMIT	Ex. Well*	Ex. Well**	TW1
<b>MICROBIOLOGICAL PARAMETERS</b>						
Escherichia Coli	ct/100 mL	MAC	0	0	0	0
Faecal Coliforms	ct/100 mL	-	-	0	0	0
Heterotrophic Plate Count	ct/100 mL	-	-	21	0	0
Total Coliforms	ct/100 mL	MAC	0	0	0	0
<b>CHEMICAL PARAMETERS (HEALTH)</b>						
F	mg/L	MAC	2.4	0.28	0.39	0.39
N-NO2	mg/L	MAC	10	<0.10	<0.10	<0.10
N-NO3 (Nitrate)	mg/L	MAC	10	<0.10	<0.10	<0.10
<b>CHEMICAL PARAMETERS WITH AESTHETIC OBJECTIVES/OPERATIONAL GUIDELINES</b>						
Alkalinity	mg/L	OG	500	223	226	213
Cl	mg/L	AO	250	127	122	120
Colour	TCU	AO	5	<2	<2	<2
DOC	mg/L	AO	5	1.2	1.3	<0.5
pH		OG	6.5-8.5	8.0	8.5	8.49
SO4	mg/L	AO	500	82	78	89
Hardness	mg/L	OG	100	298	297	275
Na	mg/L	AO	200	76	84	80
Fe	mg/L	AO	0.30	0.20	0.66	0.64
Mn	mg/L	AO	0.05	0.03	0.03	0.05
TDS	mg/L	AO	500	606	625	565
Turbidity (lab)	NTU	AO/MAC	5/1	2.1	1.3	1.5
S2-	mg/L	AO	0.05	<0.02	<0.01	<0.01

\* water results from 6045 Bank St. - Potable Water Supply Assessment prepared by Paterson Group

\*\* water results from 6075 Bank St. - Potable Water Supply Assessment prepared by ARK Engineering

The water results of this targeted aquifer are well in line with the results from the 6045 and 6075 Bank St. Potable Water Supply Assessment.

The analytical results show that water quality at the subject site is acceptable and that there are no exceedances of the applicable **health related parameter limits of the Ontario Drinking Water Standards (ODWS)**.

With respect to aesthetic objectives and operational guidelines, the analytical results indicate the following exceedances:

- Hardness
- TDS
- Iron

#### **Hardness**

Hardness, an operational guideline, does not appear in the ODWS. Rather it appears in the Technical Support Documents for Drinking Water Standards, Objectives, Guidelines (Technical Support Documents) as a parameter with an operational guideline of 100 mg/L. At the measured concentrations, the water is considered to be very hard, however it is below the reasonable treatment limit of 500 mg/L specified in Table 3 of the guidance document, titled, "Procedure D-5-5 Technical Guideline for Private Wells: Water Supply Assessment", published by MOECC (MOE, 1995).

#### **TDS**

Total dissolved solids (TDS) refers to the concentration of inorganic substances dissolved in water. The main constituents are typically chloride, sulphates, calcium, magnesium and bicarbonates. Procedure D-5-5 does not provide a 'treatability limit' for TDS, but it does require written rationale that corrosion, encrustation, or taste problems will not occur.

The Langelier Saturation Index is used to predict the calcium carbonate stability of water. It indicates whether the water will precipitate, dissolve, or be in equilibrium with calcium carbonate. The results of the Langelier calculation (LSI = +0.72) indicate that the water is supersaturated with respect to calcium carbonate (CaCO<sub>3</sub>) and scale forming may occur but non corrosive. Refer to Appendix "B".

#### **Iron**

The iron level at TW1 after the eight hours of pumping was 0.64mg/L, which exceeds the ODWS aesthetic objective of 0.30 mg/L. The iron level is well within the MOE treatability limit of 5.0 milligrams per litre using a water softener.

#### **Sodium**

The sodium level in the water was reported to be 80 mg/L. The ODWSOG states that *"the local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/l so that this information may be communicated to local physicians for their use with patients on sodium restricted diets."*

#### **Well Water Treatment**

The water within the bedrock aquifer displays slightly elevated hardness and iron. Installation of a standard commercial grade water softener will reduce the concentrations of hardness to acceptable levels. Some softeners can remove iron alternatively an iron filter can also be installed. Conventional water softeners introduce sodium into the water supply, so it may be appropriate to bypass the water softener with a separate tap for drinking water.

## 2.2 Sewage

The entire commercial development will be serviced by an existing private sanitary sewage treatment facility and an existing underground gravity sewer system all in accordance to MOE reference #2418-AVJRJ5.

As mentioned above, in order to determine the sanitary flows for this proposed building Section 4.4.1.2 of the City guidelines, Appendix 4-A was consulted.

	Area (m <sup>2</sup> )	Flows	L/day
Building	565	5 L/day per 1.0m <sup>2</sup>	2,825

0.033 L/s

### 2.3 Stormwater Management

The following is to demonstrate that the proposed site plan application for 7564 Village Center Place meets the SWM criteria previously approved in the J.F Sabourin report SWM Pond Design Brief - Commercial Phase Ultimate Conditions.

It is important to note, that the subject land (Blocks 65, 64 and 63) on the Registered Plan of Subdivision 4M-1398 - Water's Edge Subdivision was clearly included in all of the subdivision reports.

On the first table found in Appendix C, of the approved J.F. Sabourin report (refer to Appendix A for this table), the author applied an impervious value of 69% for entire rural commercial area identified as COM-1. Applying a total impervious of 69% is a conservative approach in calculating runoff generated by different storm events for commercial development since it assumed a weighted runoff coefficient of C=0.70.

The Tables 1 and 2 summarizes the modeled/approved conditions vs the proposed conditions of the imperviousness for these Blocks.

Table 1: Modeled Impervious for Block 65, 64 and 63

Hard (m <sup>2</sup> )	Soft (m <sup>2</sup> )	Area (m <sup>2</sup> )
-	-	8,579
<b>Runoff Coefficient</b>		<b>0.70</b>
<b>Total Impervious</b>		<b>69.0%</b>

Table 2: Proposed Impervious for Block 65, 64 and 63

Hard (m <sup>2</sup> )	Soft (m <sup>2</sup> )	Total (m <sup>2</sup> )
5,364	3,215	8,579
<b>Runoff Coefficient</b>		<b>0.64</b>
<b>Total Impervious</b>		<b>63.0%</b>

As shown above, once developed these blocks will still yield a "total impervious" below the value of 69% applied in the modeling. Thus, this will have no impact on stormwater management, since the ditches and pond have been designed and sized to accommodate this portion of the development.

## 2.4 Site Grading

The installation of concrete curbs in a rural development which has no underground storm sewer as an outlet will definitely create problematic ponding areas especially in the vicinity of the depressed curb outlets where snow will block these outlets during the freeze thaw cycles in Winter/Spring. This ice built-up and unwanted ponding runoff will become a safety hazard to the public. Therefore, in order to properly grade this site and to provide multiple drainage outlets via overland sheet drainage to all four corners of the site, no concrete curb are proposed along the perimeter of the parking. This will allow for runoff to simply sheet drain on a larger surface

This will allow for the surface runoff to drain away from the curbs and will promote infiltration/percolation as it reaches the edge of the asphalt onto the sodded or landscaped surface areas instead of concentrating all the precipitation towards narrow depressed curbs.

That being said, a Geotechnical investigation for this proposed site has been conducted which states that grade raises up to 1.5m would be permissible, which would in turn prevent any future possible settlement.


### 3.0 CONCLUSION

From the above statements the following can be concluded:


- i) This entire site can be serviced as proposed above.
- ii) The buildings will be serviced by a private sanitary sewer and well.
- iii) The proposed site will drain overland towards the existing roadside ditch which ultimately discharges into an existing SWM pond which will provide adequate protection to the site and the environment.
- iv) The Geotechnical report revealed a permissible grade raise of up to 1.5m.

Prepared by:

**ARK Engineering and Development**



Daniel Payer, P.Eng.  
President








**APPENDIX "A"**

SK-1  
Pond Sizing

Location Map  
Excerpt from J.F. Sabourin



Completed By: ARK ENGINEERING AND DEVELOPMENT		Drawing No.: <b>SK-1</b>	
		Scale: NTS	Date: JUL 2013
LOCATION MAP  CITY OF OTTAWA - Formerly TOWNSHIP OF OSGOODE			

**Project:** Greely Village Centre - Commercial Phase  
**Project No.:** 64707

**Quality Pond Sizing**

**Date:** May 28, 2008  
**By:** JHF

POND CMRC  
**Lands to be developed**  
 (Final Conditions)  
 (All land is developed)

Catchment No.	Description	Drainage Area (ha)	Imp. (%)	Area incl.	Area (ha)	Imp (ha)
COM-1	Commercial lands	14.64	69	X	14.64	10.10
RES-1	Residential lands (Phase 1)	5.83	21			
RES-2	Residential lands (Phase 2 incl. Phase 1)	9.34	21			
POND-1	Pond block (Phase 1)	3.57	48			
POND-2	Pond block (Phase 2)	5.03	47			
PK-1	Green space	4.26	0			
UND-1	Undeveloped Lands (Phase 1 & 2)	6.85	0			
EX4	Existing Residential (EX4)	0.50	22	X	0.50	0.11
POND-C	Pond block (Commercial)	1.57	66	X	1.57	1.04
<b>Totals=</b>		<b>16.71</b>	<b>11.25</b>			

Avg Imp= 67.31 %

**As per MOEE,**  
 Req'd Pond Vol.= 219 cu.m/ha  
 Total Pond Volume : 3655 cu.m  
 Permanent Pool= 2987 cu.m  
 Ext.Det. Volume= 668 cu.m



**J.F. Sabourin and Associates Inc.**  
 Water Resources and Environmental Consultants  
 Ottawa, Ontario WWW.JFSA.COM

JFSA Inc. Ref: 647-07  
 Client: Arel Engineering Ltd  
 Dec-08



**APPENDIX "B"**

MOE Well Record  
Eurofins Laboratory Subdivision Package Results  
Drawdown Plot  
Langelier Saturation Index



Measurements recorded in:  Metric  Imperial

A258630

Well Owner's Information

First Name: Greely Family Farm, Last Name / Organization: Greely Family Farm, Mailing Address: 1705 Old Prescott St, Greely, ON, K4P1M8, Telephone No: 613 946 1422

Well Location

Address of Well Location: Bank St, Township: Ossodes, City/Town/Village: Greely, County/District/Municipality: OTTAWA City, Province: Ontario, Postal Code: K4P1M8, UTM Coordinates: NAD 83 184956910 9012172, Municipal Plan and Sublot Number: Plan No. 4M-139P, Other: Bloc 63

Overburden and Bedrock Materials/Abandonment Sealing Record

Table with columns: General Colour, Most Common Material, Other Materials, General Description, Depth (m/ft) From, To. Rows include: Brown Sand, Boulders, Loose, 0 to 1.30; Grey Sand, Clay, Soft, 1.30 to 6.06; Grey Gravel, Soft, 6.06 to 7.87; Grey Limestone, Sandstone, Hard, 7.87 to 104.59.

Annular Space table with columns: Depth Set at (m/ft) From, To, Type of Sealant Used (Material and Type), Volume Placed (m³/ft³). Row: 0 to 69.69 Quik Gouts And Bentonite 30 Bags, 10 Bags.

Method of Construction and Well Use checkboxes. Method of Construction: Rotary (Reverse) IR, Drilling. Well Use: Commercial, Municipal, Test Hole, Cooling & Air Conditioning.

Construction Record - Casing table with columns: Inside Diameter (cm/in), Open Hole OR Material, Wall Thickness (cm/in), Depth (m/ft) From, To, Status of Well. Row: 15.55 Steel 0.48, 0.60 to 69.69.


Construction Record - Screen table with columns: Outside Diameter (cm/in), Material, Slot No., Depth (m/ft) From, To.

Water Details table with columns: Water found at Depth (m/ft), Kind of Water (Fresh, Untested, Gas, Other). Rows: 23.63 (m/ft) Gas, 0 (m/ft) Gas, 0 (m/ft) Gas.

Well Contractor and Well Technician Information. Business Name: D.R. WATER WELL DRILLING, Well Contractor's License No: 7526, Business Address: 1763-Route 800 West, Municipality: NATION, Province: ON, Postal Code: K0A3C0.

Well Technician information. Name: Monette Koval, Well Technician's License No: 37173, Signature: [Signature], Date Submitted: 08/19/2012.

Results of Well Yield Testing table. Columns: Draw Down (Time, Water Level), Recovery (Time, Water Level). Rows show pumping rate of 64.00 GPM, duration of 1 hr 00 min, and various draw down and recovery levels.



Ministry Use Only section. Date Package Delivered: 20190723, Date Work Completed: 20190723, Audit No: 2299803.

Client: Sunset Lakes Development Corp.  
 6598 Pebble Trail Way  
 Greely, ON  
 K4P 0B6  
 Attention: Mr. Daniel Payer

Report Number: 1913301  
 Date Submitted: 2019-07-25  
 Date Reported: 2019-08-06  
 Project: TW1  
 COC# 96089

PO#: Invoiced to: Sunset Lakes Development Corp.


Group	Analyte	MRL	Units	LAB I.D. Sample Matrix Sample Type Sample Date: Sample ID:
Anions	Cl	1	mg/L	1443661 Water
	F	0.10	mg/L	120
	N-NO2	0.10	mg/L	0.39
	N-NO3	0.10	mg/L	<0.10
General Chemistry	SO4	1	mg/L	<0.10
	Alkalinity as CaCO3	5	mg/L	89
	Colour	2	TCU	213
	Conductivity	5	uS/cm	<2
Hardness	pH	1.00		869
	S2-	0.1	mg/L	8.49
	TDS (COND-CALC)	1	mg/L	<0.01
	Hardness as CaCO3	1	NTU	565*
Indices/Calc Metals	Ion Balance	1	mg/L	1.5
	Ca	0.01		275*
	Fe	1	mg/L	0.96
	K	0.03	mg/L	64
Subcontract-Inorg	Mg	1	mg/L	0.64*
	Mn	0.01	mg/L	7
	Na	2	mg/L	28
	DOC	0.5	mg/L	0.05
Guideline = ODWSOG	N-NH3	0.01	mg/L	80
	Phenols	0.001	mg/L	<0.5
	Tannin & Lignin	0.1	mg/L	0.45
	Total Kjeldahl Nitrogen	0.1	mg/L	<0.001
				0.2
				0.4

Guideline = ODWSOG \* = Guideline Exceedence

Results relate only to the parameters tested on the samples submitted.  
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline,  
 MAC = Maximum Allowable Concentration, IMAC = Interim Maximum Acceptable Concentration,  
 STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality  
 Objective, TDR = Typical Desired Range

TW1 - Well Drawdown vs Time





# Langelier Saturation Index Calculator

This calculator helps you determine the scaling potential of the water by using the Langelier Saturation Index.

Give the values of your water analysis. All the fields with \* are required.

**Table 1: Input table**

pH	<input type="text" value="8.49"/>	*
Conductivity / TDS	<input type="text" value="565"/>	mg/L <input type="button" value="v"/>
[Ca <sup>2+</sup> ]	<input type="text" value="64"/>	mg/L <input type="button" value="v"/>
[HCO <sub>3</sub> <sup>-</sup> ]	<input type="text" value="275"/>	mg/L <input type="button" value="v"/>
Water temperature	<input type="text" value="9"/>	degree C <input type="button" value="v"/>

If you do not have a water analysis you can use table 2. Click on a button at the bottom of table 2

**Table 2 : Additional data**

pH =	7.7	8	8.6
TDS =	20	34483	273
[Ca <sup>2+</sup> ]	5	400	49
[HCO <sub>3</sub> <sup>-</sup> ]	10	140	121
T =	20	20	20

**Table 3: Results Langelier Saturation Index**

pH <sub>s</sub>	<input type="text" value="7.8"/>
LSI	<input type="text" value="0.72"/>
Indication based on Langelier (1936)	Water is supersaturated with respect to calcium carbonate (CaCO <sub>3</sub> ) and
Indication based on improved Langelier by Carrier (1965)	Scale forming but non corrosive.

The Langelier Saturation Index formula is

$$LSI = pH - l$$

For an explanation of the formula click here.

< to top  
▼