

E-MAIL



Antares Engineering Group Inc.

Professional Mechanical, Electrical, Testing and Research Engineers

159 Colonnade Road South, Unit 1, Ottawa, Ontario, Canada, K2E 7J4

Phone 613-723-6034 • Fax 613-723-5749 • mail@antaresengineering.ca

DATE:	12 February 2020	# PAGES (including cover):	1
ATTENTION:	Maria Martinez	FROM:	Slavo J. Samel
Tel:	(613) 739 1327 Ext: 226	TEL:	(613) 723-6034
COMPANY: PBC Management Group		PROJECT No:	Antares Eng. 19-693
REFERENCE:	JHS - 289 Carling Avenue Ottawa, Ontario K1S 4K5		

Attn: Ms. Martinez

**Regarding: Consolidation of Engineering Related Comments (Item #5)
NFPA Compliance & "FUS" Guidelines for Sprinkler System.**

The building sprinkler system will meet the requirements of a fully supervised system as per the NFPA to support applying the maximum sprinkler protection credit to the FUS method.

Please do not hesitate to contact us if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Slavo J. Samel".

ANTARES Engineering Group Inc.
Slavo J. Samel
Senior Project Manager

