



**Goodkey, Weedmark
& Associates Limited**

Consulting Engineers

1688 Woodward Dr.
Ottawa, ON
Canada
K2C 3R8

Tel. 613-727-5111
Fax 613-727-5115
info@gwal.com

Principals & Associates

A. Bogdanowicz, P.Eng.
M.G. Carriere, C.E.T.
R.J. McIntyre, P.Eng.
F.W.A. Bann, P.Eng.
R. Lefebvre, P.Eng.
D.R. Vyas, P.Eng., MIEEE
S. Hamilton, P.Eng.
J. Moffat, P.Eng.
E. Pérusse, P.Eng., ing.
R. Boivin, P.Eng., ing.
R. Leonard, P.Eng.
M. Sarasin, P.Eng.

January 30, 2020

VIA E-MAIL

Brigil
98 Lois Street
Gatineau, Quebec
J8Y 3R7

ATTENTION: MR. TIM MOORE, DIRECTOR OF ARCHITECTURE

**SUBJECT: SITE PLAN CONTROL APPROVAL APPLICATION
99 PARKDALE AVENUE, TOWER 2
FILE # D07-12-19-0176
OUR PROJECT NO. 2019-544**

Dear Sir:

We have designed the site lighting for the new 28-storey mixed use building, located at 99 Parkdale Avenue, in accordance with the following guidelines as requested by the City of Ottawa:

1. It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;
2. It must result in minimal light spillage onto adjacent properties. As a guideline, 0.5 fc is normally the maximum allowable spillage.

Yours very truly,

GOODKEY, WEEDMARK & ASSOCIATES LIMITED



Divyakant (Raj) Vyas, P.Eng., MIEEE
Associate Partner

DRV/cb

e.c.: James Gerwin (RLA / Architecture Inc.)

