

JLR No.: 25205-100.1  
Revision: 3

June 30, 2020

Prepared for:

**BRIGIL**  
98 Lois Street  
Gatineau, QC  
J8Y 3R7

Prepared by:

**J.L. RICHARDS & ASSOCIATES LIMITED**  
1565 Carling Avenue  
Ottawa, ON  
K1Z 8R1

# Site Servicing Report Addendum

## 99 Parkdale Avenue





# Site Servicing Report Addendum

## 99 Parkdale Avenue

---

### Table of Contents

---

1.0	INTRODUCTION.....	1
1.1	Background.....	1
1.2	Purpose of Addendum .....	1
1.3	Proposed Servicing Revisions .....	2
	1.3.1 Water Servicing.....	2
	1.3.2 Wastewater Servicing .....	2
2.0	WATER SERVICING .....	3
2.7	Headloss Calculations .....	3
	2.7.1 Peak Hour Demand .....	3
	2.7.2 Maximum Day Demand plus Fire Flow .....	3
	2.7.3 High Pressure Check .....	3
	2.8 Summary and Conclusions .....	4
3.0	WASTEWATER SERVICING.....	5
	3.3 Theoretical Sanitary Peak Flow and Proposed Sanitary Servicing.....	5
	3.4 Summary and Conclusions .....	5

# Site Servicing Report Addendum 99 Parkdale Avenue

---

## List of Appendices

---

APPENDIX A	Site Servicing (Approved on March 13, 2020)
APPENDIX B	Site Servicing (June 24, 2020)
APPENDIX C	Headloss Calculations

# Site Servicing Report Addendum

## 99 Parkdale Avenue

---

### 1.0 INTRODUCTION

---

#### 1.1 Background

In 2019, J.L. Richards & Associates Limited (JLR) was retained by Brigil, under their umbrella company 11034936 Canada Inc., to prepare engineering documents in support of a Site Plan Application for a Condominium Tower sited at 99 Parkdale Avenue. These documents consisted of a Site Servicing Report and Engineering Drawings that addressed water, sanitary, storm and stormwater management servicing associated with the development of a Condominium Tower on Parkdale Avenue. Since then, several submissions were made and subsequently Approval was granted to the City of Ottawa. The approved documents consisted of the Site Servicing Report (March 20, 2020) and Engineering Drawings sealed on March 13, 2020 and May 6, 2020.

#### 1.2 Purpose of Addendum

The approved Site Servicing Report and associated Engineering Drawings presented detailed servicing strategies for wastewater, water and storm/stormwater management. The water and wastewater servicing which was approved was based on achieving the following municipal requirements:

Ottawa Sewer Design Guidelines (October 2012) complete with the following Technical Bulletins:

- ISTB-2012-01;
- ISTDB-2014-01;
- ISTDB-2016-01;
- ISTDB-2018-01;
- ISTDB-2019-01; and
- ISTDB-2019-02;

City of Ottawa Water Distribution Guidelines complete with the following Technical Bulletins:

- ISTDB-2010-02;
- ISTDB-2014-02; and
- ISTDB-2018-02.

Since the Approval of the 5<sup>th</sup> design submission, additional coordination was undertaken with the Owner's architect and Mechanical Engineer to confirm municipal servicing to the mechanical room and to complete the preparation of the Water Data Card.

During the coordination with the mechanical engineer, JLR was informed that although servicing met municipal requirements, it was not consistent with the requirements of the Ontario Building Code (OBC). Specifically, changes were to be made for water and wastewater servicing. As a result, the approved Servicing Drawing S1 (March 13, 2020) was to be revised. Refer to Drawing S1 for a copy of the approved Servicing Drawing. Given the proposed changes, the City advised

# Site Servicing Report Addendum

## 99 Parkdale Avenue

---

that the updated servicing was to be documented in a Site Servicing Report Addendum. Therefore, the purpose of this Site Servicing Report Addendum is to document the revised servicing for both water and wastewater, and to discuss any impacts.

### 1.3 Proposed Servicing Revisions

#### 1.3.1 Water Servicing

Due to the building size, the OBC requires that water servicing consists of a 200 mm diameter watermain for the purpose of fire protection. Given the requirement for watermain reliability, the approved twin 150 mm diameter watermains (refer to Appendix A) are proposed to be revised to twin 200 mm diameter watermains as depicted on the revised Servicing Drawing (refer to Appendix B for copy of revised S1, dated June 24, 2020).

The headloss calculations shown in Section 2.7 of the Approved Site Servicing Report (March 20, 2020) have been revised from the twin 150 mm diameter watermains to twin 200 mm diameter watermains. Section 2.7 (below) shows the updated headloss calculations associated with twin 200 mm diameter watermains. Given that Section 2.1 to 2.6 remain unchanged, they have not been repeated in the water servicing section below.

#### 1.3.2 Wastewater Servicing

Due to the building size, the OBC requires that wastewater servicing consists of a 300 mm diameter sanitary sewer. Consequently, the approved 150 mm diameter sanitary sewer (refer to Appendix A) is proposed to be revised to a 300 mm diameter sanitary sewer as depicted on the revised Servicing Drawing (refer to Appendix B for copy of revised S1, dated June 24, 2020). Given the larger sanitary sewer size, a maintenance hole is now being proposed to be constructed at the connection point with the existing 375 mm diameter sanitary sewer as the proposed sewer size is greater than 50% of the diameter of the mainline concrete pipe. The revised Servicing Drawing (Drawing S1) included in Appendix B shows the proposed manhole addition.

The capacity verification shown in Section 3.3 of the Approved Site Servicing Report (March 20, 2020) have been revised from a 150 mm diameter sanitary sewer to a 300 mm diameter sanitary sewer. Section 3.3 (below) shows the updated capacity calculations associated with the proposed 300 mm diameter sanitary sewer. Given that Section 3.1 to 3.2 remain unchanged, they have not been repeated in the wastewater servicing section below.

# Site Servicing Report Addendum

## 99 Parkdale Avenue

---

### 2.0 WATER SERVICING

---

#### 2.7 Headloss Calculations

The revised servicing as presented on Drawing S1 (Appendix B) was evaluated under domestic (peak hour and maximum HGL pressure check) as well as during a maximum day combined to a fire flow demand condition. The twin 200 mm diameter watermain service laterals are  $\pm 9.4$  m in length and as such, the headloss calculations were based on a 10 m long service lateral. Sections 2.7.1 to 2.7.3 summarizes the headloss calculations and associated findings.

##### 2.7.1 Peak Hour Demand

The headloss was calculated along one of the proposed 200 mm diameter water service laterals (refer to S1, Appendix B), from the existing Parkdale Avenue 200 mm diameter watermain to 99 Parkdale. Based on a total peak hour demand of 6.32 L/s, a headloss of 0.0045 m in total was estimated (Appendix C). When this headloss is subtracted from the Parkdale Avenue supply HGL of 107.5 m, a residual HGL of 47.496 m was calculated at the building face (Appendix C).

The calculated HGL of 107.496 m represents a pressure of 466 kPa (67.6 psi). Consequently, the calculated pressure exceeds the minimum pressure constraint of 275 kPa (40 psi) based on the peak demand drawn from one of the twin 200 mm diameter watermains. It should be noted that given the height of the Condominium Tower, a booster pump is to be sized by the Owner's mechanical engineer to deliver the domestic demands to the users.

##### 2.7.2 Maximum Day Demand plus Fire Flow

The headloss was calculated under a maximum day of 4.21 L/s combined to a fire flow (69.2 L/s) to demonstrate that one of the proposed twin 200 mm diameter watermains can deliver the flows to the building (Appendix C). Based on the combined demand of 73.41 L/s (4.21 L/s + 69.20 L/s), this overall demand will generate a headloss of 0.4188 m on one of the twin 200 mm diameter watermains (Appendix C).

When the headloss of 0.4188 m is subtracted from the Parkdale Avenue supply HGL of 106.0 m, a residual HGL of 105.581 m was calculated at the building face, representing a pressure of 447 kPa (64.8 psi). Consequently, the minimum pressure constraint of 140 kPa (20 psi) is met by one of the proposed twin 200 mm diameter watermains. From that point, a fire pump is to be sized by the Owner's mechanical engineer to supply the domestic demands and flows to the fire suppression system.

##### 2.7.3 High Pressure Check

The OBC requires that a high-pressure check (maximum hydraulic grade elevation) be performed on the proposed system to ensure that the maximum pressure constraint of 552 kPa (80 psi) of the Ontario Code & Guide for Plumbing is not exceeded. To verify this criterion, a minimum hour demand of 0.37 L/s was used based on the peaking factor of 0.275 in accordance with Table 3-3 of the MOE Design Guidelines.

## Site Servicing Report Addendum 99 Parkdale Avenue

---

Based on the HGL of 115.0 m (at the Parkdale Avenue 200 mm diameter watermain), the pressure at the Tower is 55 m (115.0 m – 60.0 m) based on a calculated headloss of 0.000023 m (Appendix C). This corresponds to a pressure of 540 kPa (78.3 psi). Consequently, the calculated pressure does not exceed the maximum pressure constraint of 552 kPa and the installation of a pressure reducing valve (PRV) in the mechanical room is not warranted. It is proposed that the mechanical engineer confirms whether a PRV is warranted.

### 2.8 Summary and Conclusions

Based on the revised calculations for the proposed twin 200 mm diameter watermains, the pressure and flow criteria have been met. It is, therefore, recommended that proposed twin 200 mm diameter watermains, as shown on the revised Site Servicing (Drawing S1 – Appendix B), be constructed to provide water servicing for the proposed Condominium Tower recognizing that domestic and fire pumps will be sized by the Owner's mechanical engineer.



# Site Servicing Report Addendum

## 99 Parkdale Avenue

---

### 3.0 WASTEWATER SERVICING

---

#### 3.3 Theoretical Sanitary Peak Flow and Proposed Sanitary Servicing

Wastewater flows from the 99 Parkdale Avenue Condominium Tower will outlet into the municipal system (Parkdale Avenue 375 mm diameter sanitary sewer) via a proposed 300 mm diameter sanitary sewer. Based on the proposed densities for apartment buildings (as recommended by the OSDG), the peak wastewater flows were calculated based on the design value of 280 L per capita per day and population of 412. A peak wastewater flow of 5.39 L/s was calculated for 99 Parkdale based on the following parameters:

- i) Residential average unit flow rate of 280 L per capita per day;
- ii) Theoretical population of 412;
- iii) Peaking factor of 4.00, calculated in accordance with the Harmon formula;
- iv) Total infiltration allowance of 0.05 L/s (0.1372 ha x 0.33 L/s) in accordance with the OSDG and ISTB-2018-01.

It should be noted that the above calculated peak flow of 5.39 L/s for the 99 Parkdale is marginally higher than the previous calculated peak flow of 5.17 L/s (4%) estimated and approved as part of the July 2012 Site Plan Control Application. The calculated peak flow of 5.39 L/s was used as the design target for the purpose of sizing the proposed sanitary service lateral.

#### Proposed Sanitary Service Lateral Sizing

To accommodate the above design flow target of 5.39 L/s, a proposed 300 mm diameter sanitary sewer is proposed at a minimum slope of 1.0% (refer to Drawing S1, Appendix B), which is capable in accommodating the sanitary peak design flow. The proposed 300 mm diameter sewer at 1.0% will provide a free-flowing capacity of  $\pm 100$  L/s. It should also be noted that the proposed theoretical peak wastewater flow of 5.39 L/s represents less than 5% of the total capacity of the 375 mm diameter sanitary sewer (based on a sewer section with the flatter slope) along Parkdale Avenue.

#### 3.4 Summary and Conclusions

Based on the above wastewater servicing details, it is recommended that the proposed wastewater servicing shown on the Site Servicing (Drawing S1, Appendix B) be implemented to provide wastewater servicing for the proposed Condominium Tower.

# Site Servicing Report Addendum 99 Parkdale Avenue

---

J.L. RICHARDS & ASSOCIATES LIMITED

Prepared by:



Steve Picken  
Civil Designer

Prepared by:

Guy Forget, P.Eng.  
Senior Water Resources Engineer



[www.jlrichards.ca](http://www.jlrichards.ca)

---

# Appendix A

Drawing S1(March 13, 2020)

**GENERAL CONSTRUCTION NOTES :**



1. ALL MATERIALS AND CONSTRUCTION TO BE IN ACCORDANCE WITH CURRENT CITY OF OTTAWA (COA) STANDARDS AND ONTARIO PROVINCIAL STANDARDS AND SPECIFICATIONS (OPSS & OPSD); SEWER AND WATERMAIN MATERIAL TYPES AND DISINFECTION.
2. SUPPLY AND CONSTRUCT ALL SEWERS AND APPURTENANCES IN ACCORDANCE WITH CURRENT CITY OF OTTAWA (COA) STANDARDS AND ONTARIO PROVINCIAL STANDARDS AND SPECIFICATIONS (OPSS & OPSD); ROADS AND PUBLIC WORKS.
3. VALVES TO BE OPERATED BY CITY OF OTTAWA STAFF ONLY.
4. NO CONNECTION TO EXISTING WATER NETWORK SHALL BE COMPLETED UNTIL A WATER PERMIT IS OBTAINED FROM THE CITY OF OTTAWA (COO). COA FORCES TO COMPLETE WATERMAIN CONNECTIONS, EXCAVATION, BACKFILLING AND REINSTATEMENT TO BE COMPLETED BY CONTRACTOR.
5. UNLESS OTHERWISE NOTED, DIMENSIONS FROM STREET LINE ARE TO THE CENTRELINE OF SEWER OR MANHOLE.
6. THE INSIDE DIAMETER OF PIPES ARE REFERRED TO IN PLAN VIEW.
7. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING LOCATES FROM ALL UTILITY COMPANIES TO LOCATE EXISTING UTILITIES PRIOR TO EXCAVATION.
8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EXCAVATION, BACKFILL, REINSTATEMENT OF ALL AREAS DISTURBED DURING CONSTRUCTION AND ALL ASSOCIATED WORKS TO THE SATISFACTION OF THE ENGINEER AND CITY OF OTTAWA.
9. THE CONTRACTOR SHALL BE RESPONSIBLE TO DETERMINE, VIA EXCAVATION, THE EXACT LOCATION AND ELEVATION OF THE EXISTING WATERMANS, SEWERS AND UNDERGROUND STRUCTURES AS REQUIRED FOR ALL CONNECTIONS, RELOCATIONS AND BLANKINGS.
10. 99 PARKDALE AVENUE SERVICING DESIGN DRAWINGS TO BE READ IN CONJUNCTION WITH THE SERVICING REPORT (FEBRUARY 2020) PREPARED BY J.L. RICHARDS & ASSOCIATES.
11. ALL WATERMANS AND WATER SERVICES LESS THAN 2.4m FROM A STORM SEWER, CATCH BASIN OR MANHOLE SHALL BE INSULATED IN ACCORDANCE WITH THE CITY OF OTTAWA'S REQUIREMENTS AS SET OUT IN CITY'S OF OTTAWA SPECIFICATION F-7014.
12. AT ALL CONNECTION POINTS, REINSTATE SURFACES TO EXISTING CONDITION OR BETTER. -ASPHALT RESTORATION SHALL BE IN ACCORDANCE WITH CITY OF OTTAWA STANDARD DRAWING No. R10. -THICKNESS OF GRANULARS AND ASPHALT LAYERS SHALL MATCH EXISTING. REFER TO ARCHITECTURAL DRAWINGS FOR SITE LAYOUT.
13. BENCHMARK: TOP OF SPINDLE OF FIRE HYDRANT LOCATED ON EAST SIDE OF PARKDALE AVENUE WITH ELEVATION = +61.07m. AS PROVIDED BY ANNIS, O'SULLIVAN, VOLLEBEKK LTD. (AOV). BENCHMARK IS VALID UNTIL HYDRANT IS RELOCATED. BENCHMARK IS TO BE TRANSFERRED BY AOV PRIOR TO RELOCATING THE HYDRANT.
15. INSULATE FULL LENGTH OF 2008 STORM SERVICE AS PER CITY OF OTTAWA W22.

NORTH WATERMAIN TABLE- Sta. 1+000 to 1+010.5			
PVC DR-18 CL-150			
STATION ALONG WM	DETAIL	FINISHED GRADE	TOP OF WM
1+000	TAPPING VALVE & SLEEVE	59.80	57.40
1+007.3	VALVE & VB	60.09	57.69
1+007.8	FACE OF UNDERGROUND PARKING STRUCTURE	60.09	57.69

SOUTH WATERMAIN TABLE- Sta. 2+000 to 2+010.5			
PVC DR-18 CL-150			
STATION ALONG WM	DETAIL	FINISHED GRADE	TOP OF WM
2+000	TAPPING VALVE & SLEEVE	60.10	57.70
2+007.3	VALVE & VB	60.30	57.90
2+007.8	FACE OF UNDERGROUND PARKING STRUCTURE	60.30	58.00

ASPHALT PAVEMENT STRUCTURE FOR REAR LANE	
150mm (MIN) GRAN 'B' TYPE II	REFER TO GEOTECHNICAL REPORT
150mm GRAN 'A'	
50mm SP19.0	
40mm SP12.5	

\* GRANULAR 'B' THICKNESS TO BE CONFIRMED BY GEOTECHNICAL ENGINEER AT TIME OF CONSTRUCTION AND/OR SUBGRADE PREPARATION.



**LEGEND**

- EXISTING CATCH BASIN
- PROPOSED WATERMAIN & VALVE
- EXISTING WATERMAIN, VALVE & HYDRANT
- EXISTING SANITARY SEWER & MANHOLE
- PROPOSED SANITARY SEWER
- PROPOSED STORM SEWER & MANHOLE
- RETAINING WALL
- FF+104.48 FINISHED FLOOR ELEVATION
- WATER METER
- REMOTE WATER METER
- SIAMISE CONNECTION
- PROPOSED BUILDING ENTRANCE
- OVERFLOW ROOF SCUPPER
- PROPERTY LINE
- OUTLINE OF UNDERGROUND PARKING LEVELS

No.	ISSUE / REVISION	DD/MM/YY
03	ISSUED TO CITY FOR REVIEW - THIRD SUBMISSION	13/03/2020
02	ISSUED TO CITY FOR REVIEW - SECOND SUBMISSION	07/02/2020
01	ISSUED TO CITY FOR REVIEW - FIRST SUBMISSION	22/10/2019

This drawing is copyright protected and may not be reproduced or used for purposes other than execution of the described work without the express written consent of J.L. Richards & Associates Limited.

VERIFY SHEET SIZE AND SCALES. BAR TO THE RIGHT IS 25mm IF THIS IS A FULL SIZE DRAWING.

SCALE: 1:100

CLIENT:

**BRIGIL**

CONSULTANT: www.jlrichards.ca

CONSULTANT:

**J.L. Richards**  
ENGINEERS - ARCHITECTS - PLANNERS

PROFESSIONAL STAMP

**W. N. L. DALRYMPLE**  
PROVINCE OF ONTARIO

PROJECT:

**99 PARKDALE AVENUE**

OTTAWA ONTARIO

DRAWING:

**S1**

DESIGN: SP  
DRAWN: SP  
CHECKED: LD  
JLR #: 25205-100

File Location: P:\25205\25205-100 - Brigil - 99 Parkdale Avenue-Production\1-Client\25205-100 & S1.dwg

City File No: D07-12-19-0176 Plan No: 18067

---

## **Appendix B**

Drawing S1 (June 24, 2020)

**GENERAL CONSTRUCTION NOTES :**

1. ALL MATERIALS AND CONSTRUCTION TO BE IN ACCORDANCE WITH CURRENT CITY OF OTTAWA (COA) STANDARDS AND ONTARIO PROVINCIAL STANDARDS AND SPECIFICATIONS (OPSS & OPSD), SEWER AND WATERMAIN MATERIAL TYPES AND DISINFECTION.
2. SUPPLY AND CONSTRUCT ALL SEWERS AND APPURTENANCES IN ACCORDANCE WITH CURRENT CITY OF OTTAWA (COA) STANDARDS AND ONTARIO PROVINCIAL STANDARDS AND SPECIFICATIONS (OPSS & OPSD), ROADS AND PUBLIC WORKS.
3. VALVES TO BE OPERATED BY CITY OF OTTAWA STAFF ONLY.
4. NO CONNECTION TO EXISTING WATER NETWORK SHALL BE COMPLETED UNTIL A WATER PERMIT IS OBTAINED FROM THE CITY OF OTTAWA (COO). COA FORCES TO COMPLETE WATERMAIN CONNECTIONS, EXCAVATION, BACKFILLING AND REINSTATEMENT TO BE COMPLETED BY CONTRACTOR.
5. UNLESS OTHERWISE NOTED, DIMENSIONS FROM STREET LINE ARE TO THE CENTRELINE OF SEWER OR MANHOLE.
6. THE INSIDE DIAMETER OF PIPES ARE REFERRED TO IN PLAN VIEW.
7. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING LOCATES FROM ALL UTILITY COMPANIES TO LOCATE EXISTING UTILITIES PRIOR TO EXCAVATION.
8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EXCAVATION, BACKFILL, REINSTATEMENT OF ALL AREAS DISTURBED DURING CONSTRUCTION AND ALL ASSOCIATED WORKS TO THE SATISFACTION OF THE ENGINEER AND CITY OF OTTAWA.
9. THE CONTRACTOR SHALL BE RESPONSIBLE TO DETERMINE, VIA EXCAVATION, THE EXACT LOCATION AND ELEVATION OF THE EXISTING WATERMANS, SEWERS AND UNDERGROUND STRUCTURES AS REQUIRED FOR ALL CONNECTIONS, RELOCATIONS AND BLANKINGS.
10. 99 PARKDALE AVENUE SERVICING DESIGN DRAWINGS TO BE READ IN CONJUNCTION WITH THE SERVICING REPORT (FEBRUARY 2020) PREPARED BY J.L. RICHARDS & ASSOCIATES.
11. ALL WATERMANS AND WATER SERVICES LESS THAN 2.4m FROM A STORM SEWER, CATCH BASIN OR MANHOLE SHALL BE INSULATED IN ACCORDANCE WITH THE CITY OF OTTAWA'S REQUIREMENTS AS SET OUT IN CITY'S OF OTTAWA SPECIFICATION F-7014.
12. AT ALL CONNECTION POINTS, REINSTATE SURFACES TO EXISTING CONDITION OR BETTER. ASPHALT RESTORATION SHALL BE IN ACCORDANCE WITH CITY OF OTTAWA STANDARD DRAWING No. R10. -THICKNESS OF GRANULARS AND ASPHALT LAYERS SHALL MATCH EXISTING. REFER TO ARCHITECTURAL DRAWINGS FOR SITE LAYOUT.
13. BENCHMARK: TOP OF SPINDLE OF FIRE HYDRANT LOCATED ON EAST SIDE OF PARKDALE AVENUE WITH ELEVATION = 61.07m. AS PROVIDED BY ANNIS, OUSILVIAN, VOLLEBEKK LTD. (AOV). BENCHMARK IS VALID UNTIL HYDRANT IS RELOCATED. BENCHMARK IS TO BE TRANSFERRED BY AOV PRIOR TO RELOCATING THE HYDRANT.
15. INSULATE FULL LENGTH OF 2000 STORM SERVICE AS PER CITY OF OTTAWA W22.



NORTH WATERMAIN TABLE- Sta. 1+000 to 1+010.5			
PVC DR-18 CL-150			
STATION ALONG WM	DETAIL	FINISHED GRADE	TOP OF WM
1+000	TAPPING VALVE & SLEEVE	59.80	57.40
1+007.3	VALVE & VB	60.09	57.69
1+007.8	FACE OF UNDERGROUND PARKING STRUCTURE	60.09	57.69

SOUTH WATERMAIN TABLE- Sta. 2+000 to 2+010.5			
PVC DR-18 CL-150			
STATION ALONG WM	DETAIL	FINISHED GRADE	TOP OF WM
2+000	TAPPING VALVE & SLEEVE	60.10	57.70
2+007.3	VALVE & VB	60.30	57.90
2+007.8	FACE OF UNDERGROUND PARKING STRUCTURE	60.30	58.00

ASPHALT PAVEMENT STRUCTURE FOR REAR LANE	
150mm (MIN) GRAN 'B' TYPE II	
150mm GRAN 'A'	
50mm SP19.0	
40mm SP12.5	

REFER TO GEOTECHNICAL REPORT

\* GRANULAR 'B' THICKNESS TO BE CONFIRMED BY GEOTECHNICAL ENGINEER AT TIME OF CONSTRUCTION AND/OR SUBGRADE PREPARATION.



**LEGEND**

- EXISTING CATCH BASIN
- PROPOSED WATERMAIN & VALVE
- EXISTING WATERMAIN, VALVE & HYDRANT
- EXISTING SANITARY SEWER & MANHOLE
- PROPOSED SANITARY SEWER
- PROPOSED STORM SEWER & MANHOLE
- RETAINING WALL
- FF+104.48 FINISHED FLOOR ELEVATION
- WATER METER
- REMOTE WATER METER
- SIAMISE CONNECTION
- PROPOSED BUILDING ENTRANCE
- OVERFLOW ROOF SCUPPER
- PROPERTY LINE
- OUTLINE OF UNDERGROUND PARKING LEVELS

No.	ISSUE / REVISION	DD/MM/YY
05	REVISED LATERAL SIZES ISSUED FOR CITY STAMP	24/06/2020
04	RE-ISSUED PER REVISED SITE PLAN - FIFTH SUBMISSION	06/05/2020
03	ISSUED TO CITY FOR REVIEW - THIRD SUBMISSION	13/03/2020
02	ISSUED TO CITY FOR REVIEW - SECOND SUBMISSION	07/02/2020
01	ISSUED TO CITY FOR REVIEW - FIRST SUBMISSION	22/10/2019

This drawing is copyright protected and may not be reproduced or used for purposes other than execution of the described work without the express written consent of J.L. Richards & Associates Limited.

VERIFY SHEET SIZE AND SCALES. BAR TO THE RIGHT IS 25mm IF THIS IS A FULL SIZE DRAWING.

SCALE: 1:100

CLIENT:

# BRIGIL

CONSULTANT: [www.jlrichards.ca](http://www.jlrichards.ca)

CONSULTANT:

**J.L. Richards**  
ENGINEERS - ARCHITECTS - PLANNERS

PROFESSIONAL STAMP

PROJECT NORTH

PROJECT:

**99 PARKDALE AVENUE**

OTTAWA ONTARIO

DRAWING:

**SITE SERVICING PLAN**

DESIGN: SP

DRAWN: SP

CHECKED: LD

JLR #: 25205-100

DRAWING #: **S1**

File Location: P:\25205\25205-100 - Brigil - 99 Parkdale Avenue-Production\1-Child\25205-100 & S1.dwg

City File No: D07-12-19-0176 Plan No: 18067

---

# Appendix C

Headloss Calculations

### 99 Parkdale Avenue Condominium Tower

Brigil (11034936 Canada Inc.)  
25205-100

#### Headloss Calculations (Hazen Williams Equation)

Calculate headloss in a given pipe length based on flows and C value

$$HL = 10.675 * L * Q^{1.852} / (C^{1.856} * D^{4.8704})$$

Where,

HL = Headloss (m)

L - Length (m)

Q - Flow (m<sup>3</sup>/s)

C - Hazen Williams "C"

D - Main Diameter (m)

Water Demand Condition	Flow - Q (L/s)	Flow - Q (m <sup>3</sup> /s)	Length (m)	C	D (m)	HeadLoss (m)	HGL (m) @ 200mm WM	HGL @ Tower (m)	Tower Elevation (m)	Pressure @ Tower		Requirement	Criteria Acheived?
										(m)	(kPa)		
Average Day	1.34	0.00134	10	100	0.2								
Maximum Day	4.21	0.00421	10	100	0.2								
Peak Hour	6.32	0.00632	10	100	0.2	0.0045	107.5	107.496	60	47.496	466	275	Yes
Maximum HGL	0.37	0.00037	10	100	0.2	0.000023	115.0	115.000	60	55.000	540	552	Yes
Maximum Day Plus Fire (Q = 4.21 L/s + 69.2 L/s)	73.41	0.07341	10	100	0.2	0.4188	106.0	105.581	60	45.581	447	140	Yes

**Domestic Booster Pump & Fire Pump to be designed by the Owner's Mechanical Engineer**