

No.	Y / M / D	REVISION
6.	2020-04-21	SITE PLAN COMMENTS
5.	2020-03-17	ISSUED FOR BUILDING PERMIT
4.	2020-02-25	FOR CONSULTANT COORDINATION
3.	2020-02-24	ISSUED FOR RE-SUBMISSION
2.	2020-02-03	COORD. FOR RE-SUBMISSION
1.	2019-11-08	ISSUED FOR SITE PLAN CONTROL

Civil Engineer:
LRL Associates Ltd.
Johnston, Virginia
johnson@lrl.ca
613-842-3434 (x 223)

Structural Engineer:
LRL Associates Ltd.
esmith@lrl.ca
613-842-3434 (ext. 213)

Surveyor:
Annis O'Sullivan
Vollbeck Ltd.
Ed Herweyer
EstH@vovltd.com
613-727-0934

Landscape Architect:
James B. Lennox &
Associates Inc.
Lennox, James
j@jbla.ca
613-722-5168

Mech/Elec. Engineer:
LRL Associates Ltd.
Tessier, Martin
mtessier@lrl.ca
613-842-3434 (x 240)

Noise Consultant:
State of the Art Acoustik Inc.
Alexandre Fortier
afortier@sota.ca
613-745-2003 ext. 5

Environmental Study:
Pinchin Ltd.
Wilson, Christine
cwilson@pinchin.com
613-592-5387 (x 1827)

Geotechnical Engineer:
Paterson Group
David Gilbert
dgilbert@patersongroup.ca
613-226-7381 ext. 205

ANNOTATION LEGEND

- XX ASSEMBLY NUMBER
- XX FIRE RESISTANCE RATING IN HOURS
- XX DOOR NUMBER
- XX WINDOW NUMBER
- X X DETAIL OR SECTION NUMBER
- XX REFERENCE SHEET

GENERAL NOTES BELOW GRADE

1. ALL UN-INSULATED CAST IN PLACE FOUNDATION WALL THICKNESSES AS PER STRUCTURAL DRAWINGS
WALL TYPE: (WIA) (7.5)
2. ALL INSULATED CAST IN PLACE FOUNDATION WALL THICKNESSES AS PER STRUCTURAL DRAWINGS
WALL TYPE: (WIB) (7.5)
3. ALL PARTY WALLS TO HAVE AN OVERALL THICKNESS OF 9" UNLESS NOTED.
WALL TYPE: (WPA) (7.5)
4. EXIT STAIRS/SUITE DEMISING WALLS TO HAVE AN OVERALL THICKNESS OF 8" UNLESS NOTED.
WALL TYPE: (WIC) (7.5)
5. ALL CORRIDOR WALLS TO HAVE AN OVERALL THICKNESS OF 7 1/2" UNLESS NOTED.
WALL TYPE: (WIC) (7.5)
6. NON-LOADBEARING INTERIOR SUITE WALLS TO HAVE AN OVERALL THICKNESS OF 4" UNLESS NOTED.
WALL TYPE: (WIA) (7.5)
7. LOADBEARING INTERIOR SUITE WALLS TO HAVE AN OVERALL THICKNESS OF 4" UNLESS NOTED.
WALL TYPE: (WIC) (7.5)
8. ALL INTERIOR SUITE PLUMBING WALLS TO HAVE AN OVERALL THICKNESS AS NOTED.
WALL TYPE: (WIB) (7.5)
9. ALL INTERIOR SUITE PLUMBING FURRING WALLS TO HAVE AN OVERALL THICKNESS OF 6" UNLESS NOTED.
WALL TYPE: (WIB) (7.5)

It is the responsibility of the appropriate contractor to check & verify all dimensions on site and report all errors &/or omissions to the architect. All contractors must comply with all pertinent codes & by-laws, & use proprietary products as directed by the manufacturer. Do not scale drawings. This drawing may not be used for construction until issued as such. Copyright reserved.

COLUMBUS APARTMENTS
261-265 Columbus Ave., Ottawa, Ontario

BASEMENT PLAN

Drawn By:	Date:	A1.2
MP	July 2019	
Project No:	Scale:	
1902	1/4" = 1'-0"	

D07-12-19-0192

