

January 24, 2020

File No: 19214

By Email: vladimirp@n45.ca

N45 Architecture Inc.
The Sovereign Building
71 Bank Street, 7th Floor
Ottawa, Ontario
Canada K1P 5N2

Attention: Vladimir Popovic

Partners

A. Lawton, P.Eng.
B. Thornhill, P.Eng.

Associate Partners

S. Chénier, P.Eng., ing.
G. Mauzeroll, P.Eng., ing.

**Reference: 480 Cope Drive - Fernbank Elementary School - OCDSB
Site Lighting**

Dear Vlad,

We write this letter to confirm that the new site lighting design from the site plan application for the above project will not exceed 0.5 fc (5.38 lux) maintained on the adjacent properties at grade level. Please refer to the lighting calculations shown on plans ES-1 and ES-2 included as part of the electrical drawing package.

Furthermore, all new light fixtures proposed on the aforementioned site plan will meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES).

Please call if you require any additional information.

Yours truly,

McKee ENGINEERING LTD.



Guy-Olivier Mauzeroll, P.Eng., ing., LEED®AP
Associate Partner – Electrical

