

2	120111110 21 1VI SEVICE INV 01.28	0.78
	300mmØ WATERMAIN OBV 60.80	
3	150mmØ STM SERVICE INV 61.54	1.08
	250mmØ SAN SEWER OBV 60.46	
4	150mmØ STM SERVICE INV 61.58	0.76
	300mmØ WATERMAIN OBV 60.82	
5	100mmØ SAN SEWER INV 61.16	0.31
	300mmØ WATERMAIN TOP 60.85	
*NOTE: CONTRACTOR TO ENSURE A MINIMUM OF 0.30m OF VERTICAL SEPARATION		
BETWEEN EXISTING UTILITIES, SEWERS, AND PROPOSED SERVICES		