

December 16, 2020

File No: 20029

By Email: emily.mcgirr@taggart.ca

Taggart Realty Management
225 Metcalfe Street, Suite 708
Ottawa, Ontario
K2P 1P9

Partners

A. Lawton, P.Eng.
B. Thornhill, P.Eng.

Associate Partners

S. Chénier, P.Eng., ing.
G. Mauzeroll, P.Eng., ing.

Attention: Emily McGirr

**Reference: Purolator Distribution Kanata
1400 Upper Canada Street, Kanata, Ontario
Site Lighting**

Dear Emily,

We write this letter to confirm that the new site lighting design from the site plan application for the above project will not exceed 0.5 fc (5.38 lux) maintained on the adjacent properties at grade level. Please refer to the lighting calculations shown on plans SP-E01 and SP-E02 prepared by our office.

Furthermore, all new light fixtures proposed on the aforementioned site plan will meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES).

Please call if you require any additional information.

Yours truly,

McKee ENGINEERING LTD.



Guy-Olivier Mauzeroll, P.Eng.
Associate Partner - Electrical

