



City of Ottawa
Development Review (Suburban Services, East)
Planning, Infrastructure and Economic Development Department
110 Laurier Avenue West, 4th Floor
Ottawa, Ontario
K1P 1J1

Attn: **Shoma Murshid, MCIP, RPP**
File Lead, Planner II

Re: **File D07-12-20-0094**
6137 Renaud Road, Ottawa
Site Lighting Certificate

Dear Madam:

Please be advised of the following:

- The specified fixtures meet the criteria for Full Cut-Off Classification as recognized by the Illuminating Engineering Society of North America.
- The light generated by the street lighting does not spill over onto adjacent properties more than 0.5fc as per the City of Ottawa requirements. As indicated in the Photometric Plan, the maximum light level on the property line is 0.2fc.

Should you have any questions and/or concerns, please contact the undersigned at your earliest convenience.

Sincerely,



UTILITY BOX DESIGNS
Residential + Commercial Development

Danielle Poirier, P.Eng., LEED®AP
(416) 666-7500
dpoirier@utilitybox.ca

