

April 09, 2021

Metro Ontario Inc.  
5150 Spectrum Way, Suite 401  
Mississauga, ON L4W 5G2

Attention: Mr. Antony Cannell

**Re: Plaza at Greenbank Road & Cambrian Road – Site Plan Approval  
Ottawa, Ontario  
Our Reference #20-044-024**

Dear Sir;

With respect to the required certificate, required by the City of Ottawa, regarding the Site Lighting, we can confirm that the site lighting has been designed using only fixtures that meet the Full Cut-Off Criteria, as recognized by the Illuminating Engineering Society of North America. Luminaires at the property line will be equipped with house side shield to minimize light trespass. We can also confirm that light spillage on the property line meets the City of Ottawa recommended maximum allowable light spillage of 0.5 fc as per submitted photometric calculations.

Yours very truly,

HAMMERSCHLAG & JOFFE INC.



Mike Bekhit, P.Eng.  
/ah

