



Ottawa, November 25, 2020  
No.: 6301-Campeau-YME-L2

Sameer Gulamani  
Bayview Hospitality Holdings Ltd.

**Reference:** Proposed development at 6301 Campeau Drive: “Overall Grading Plan by WSP Group for their project numbered 201-03048-00 dated November 20, 2020 ”.

**Subject:** Review from the geotechnical stand point based on the findings reported in Subsurface Investigation Report 46-BHH-R1.

YME has no objections to the referenced grading plan from the geotechnical stand point.

Rock cuts along the perimeter of the buildings shown in the referenced plan or required for grading can be vertical.

Rock faces and slopes are expected to be stable where they meet the proposed grades.

Do not hesitate to contact us if you have any questions.



Yuri Mendez, M. Eng, P. Eng