

March 29, 2022

City of Ottawa
c/o Lisa Stern - Development Review Planner
110 Laurier Avenue West, 4th Floor
Ottawa, ON
K1P 1J1

RE: 6301 Campeau Drive Site Lighting Memo
DWE Project #: 2020349

Dear Lisa,

We have designed the site lighting for the new development located at 6301 Campeau Dr. Kanata, ON in accordance with the following guidelines as requested by the City of Ottawa.

1. It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;
2. It must result in minimal light spillage onto adjacent properties. As a guideline, 0.5-foot candles is normally the maximum allowable spillage.

Should you have any questions or concerns please feel free to contact me.

Sincerely,



Haydar Al Dahhan, P.Eng., IntPE, APEC
President & CEO | Mechanical/Electrical Engineer

#1250 10130 103 St. NW,
Edmonton, AB T5J 3N9

900 W Hastings St.,
Vancouver, BC V6C 1E5

#116 8805 Resources Road,
Grande Prairie, AB T8V 3A6

Suite 510 999 8 St.,
Calgary, AB, T2R 1J5

2345 1 Adelaide Street East,
Toronto, ON M5C 2V9

Suite 700 1 Rideau Street
Ottawa, ON, K1N 8S7