

City of Ottawa – Technical Circulatoin Comments – 2nd Review**Site Plan Control and Condominium Applications****Dymon Storage – 3455 Hawthorne Rd., Ottawa, ON****July 28 2022**

1. *Prior to Site Plan Approval, the City will require certification from a Professional Engineer stating that the site lighting has been designed with sharp cut-off fixtures such that minimal light spillage will occur on adjoining properties (**maximum 0.5 fc**). The location of the fixtures, as well as height, fixture type, make, model and part number must be shown on the site plan or servicing plan.*

The site lighting as per drawing E0.2 the site lighting has been designed to minimize any excess spillage of light past the property line. With the use of field installed **Sharp Cut-Off Shields** and field testing with an Approved light meter, the forward thrown light will be minimized to keep all spill light levels significantly under 0.5 fc.

End of Response.