DESCRIPTION	EXISTING	PROPOSED	DESCRIPTION	EXISTING	PROPOSED
SITE FEATURES			SERVICES AND STRUCTURES		
PROPERTY LINE	<b>———</b>		SANITARY SEWER	SA <i>EX.250mmø SAN</i> SA	250mmø SAN
TOP OF SLOPE			COMBINATION SEWER	EX.300mmø COMB	300mmø COMB
TERRACING (3:1 TYPICAL)			STORM SEWER	st	375mmø STM
© DITCH/SWALE AND DIRECTION OF FLOW	_··-·		STORM SUBDRAIN	EX.150mmø_SUBDRAIN	150mmø SUBDRAIN
EDGE OF SHOULDER			STORM CULVERT		600mmø CUL <u>VERT</u>
EDGE OF PAVEMENT			SANITARY MANHOLE	○ EX.SAN	SANMH 100
ROAD/ALIGNMENT			COMBINATION MANHOLE	○ EX.COMB	○ COMBMH 100
CHAINLINK FENCE	XX	xx	STORM MANHOLE	○ EX.STM	O STMMH 200
POST AND RAIL FENCE		<b></b>	CATCHBASIN MANHOLE	○ EX.CBMH	■ CBMH 100
SIDEWALK (TYPE AS NOTED ON DRAWINGS)			CATCHBASIN	□ EX.CB	■ CB1
BARRIER CURB (SC1.1)			DOUBLE CATCHBASIN	□□ EX.DCB	■■ DCB1
MOUNTABLE CURB (SC1.3)			AREA DRAINS		<b>O</b> AD
DEPRESSED CURB		DC DC	ROOF DRAINS		<b>O</b> RD
FACTILE WALKING SURFACE INDICATOR "TWSI" (SC7.3)			CURB INLET CATCHBASIN	□ EX.CICB	■ CICB 1
GUARDRAIL		11 11	DITCH INLET CATCHBASIN	Ⅲ EX.DICB	■ DICB 1
JERSEY BARRIERS	# #		WATERMAIN	200mmø WATERMAIN	200mmø WATERMAIN
BUILDING ENTRY/EXIT WITH RISERS	<b>▼</b> xR	<b>▼</b> xR	IRRIGATION	IR	IR IR
UILDING ENTRY/EXIT BARRIER FREE	₩BF	<b>▼</b> BF	VALVE AND VALVE BOX	⊗ V&VB	⊗ V&VB
BUILDING ENTRY/EXIT OVERHEAD DOOR	$\nabla$	$\nabla$	VALVE AND VALVE CHAMBER	⊗V&VC	<b>⊗</b> V&VC
OST	⊚ POST	⊚ POST	FIRE HYDRANT	-Ó-FH	- <b>Ó</b> -FH
SIGN	⊳ SIGN	Þ SIGN	SIAMESE CONNECTION	Ŷsc	Ƴsc
BOLLARD	© BOLL	© BOLL	WATER METER	(M)	M
/EGETATION		~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	REMOTE WATER METER	RM	RM
			45° BEND	<b>√</b> ₁ 45°	⁴ 45*
			22.5* BEND	← 22*	~ 22°
			11.25° BEND	ы 11°	ы11°
JTILITY AND STRUCTURES			TEE	́ 200Х150 TEE	₼ 200X150 TEE
HYDRO (OVERHEAD)	OH	ОН	REDUCER	>200X100 RED	>200X100 RED
HYDRO		н	CROSS	⊕300X200 CROSS	⊕300X200 CROSS
POWER	D D	B B	CURB STOP	⊗ CS	● CS
	— r — r —		WATER WELL	<b>(</b> (0)	<b>®</b>
CLECTRICAL  OFFICE (OVERLIEAD)					
BELL (OVERHEAD)	OB				
BELL	В	В	004000		
CABLE (OVERHEAD)	OC	oc	GRADING		
CABLE TV	C	с	GROUND ELEVATION	X 100.00	X 100.00
FIBRE OPTIC	F0	F0	SWALE ELEVATION	X 100.00(S)	X 100.00(S)
STREETLIGHT	SL	SL	TOP OF GRATE ELEVATION	T/G=100.00	T/G=100.00
GASMAIN .	G		TOP OF WALL ELEVATION	X 100.00 T/W	X 100.00 T/W
JOINT USE TRENCH — BELL/CABLE TV	BC	BC	BOTTOM OF WALL ELEVATION	X 100.00 B/W	X 100.00 B/W
JOINT USE TRENCH - HYDRO/BELL/CABLE TV	HBC	HBC	FINISHED FLOOR ELEVATION	FF=100.00	FF=100.00
JOINT USE TRENCH - HYDRO/BELL/CABLE TV/GAS		HBCG	TOP OF FOUNDATION ELEVATION	TF=100.00	TF=100.00
JOINT USE TRENCH - BELL/CABLE TV/GAS	BCG	BCG	BASEMENT FLOOR ELEVATION	BF=100.00	BF=100.00
OUCT CROSSING WITH NUMBER AND TYPE OF DUCTS	2H,2C,2B	2H,2C,2B	PARKING LEVEL ELEVATION	P1=100.00	P1=100.00
STREETLIGHT	∺—⊗ ols	ಬ⇔⇔⊷∺	UNDERSIDE OF FOOTING ELEVATION	USF=100.00	USF=100.00
STREETLIGHT DISCONNECT	SD	SD.	ORIGINAL GROUND ELEVATION	<i>OG=100.00</i>	OG=100.00
YDRO TRANSFORMER			TOP OF ROCK ELEVATION	T/ROCK=100.00	T/ROCK=100.00
HYDRO SWITCHING KIOSK			CONTOUR LINES	100.00	100.00
YDRO MANHOLE	$\Theta$	<b>(P)</b>	SLOPE AND DIRECTION OF FLOW	2.0%	2.0%
YDRO METER	$\Leftrightarrow$	•	OVERLAND FLOW ROUTE ONSITE		
JTILITY POLE AND GUY WIRE	(—O UP	(—OUP	OVERLAND FLOW ROUTE EXTERNAL		$\langle \Box $
CABLE PEDESTAL	C	C		<b>\</b>	<b>V</b>
BELL PEDESTAL	B	B			
BELL MANHOLE	B	$^{lack}$			
BELL GROUND LEVEL BOX	GLB	GLB	STORMWATER MANAGEMENT		
ENDWALL			STORM DRAINAGE AREA BOUNDARY		
COMMUNITY MAILBOX	CMB	<u>CMB</u>	STORM DRAINAGE AREA NUMBER STORM DRAINAGE AREA IN HECTARES	1 0.06	1 0.06
GAS VALVE	⊗ GV	⊗ GV	RUN-OFF COEFFICENT	0.06	0.06
SAS METER	<b>\&amp;</b>	<b>\$</b>	5 YEAR PONDING AREA	5 YR	5 YR
RAFFIC MANHOLE	○ TMH	<b>○</b> TMH	100 YEAR PONDING AREA	100 YR	100 YR
RAFFIC HAND HOLE	□ HH	□ HH			
RAFFIC JOINT USE POLE	⊚ JUP	⊚ JUP			
RAFFIC MAST ARM	=⊖= MAF	=O= MAF	05075010000		
TRAFFIC CONDUIT	тт	— т — т —	GEOTECHNICAL		
			BOREHOLE	⊕- ВН	<b>-</b> ф-ВН
			TEST PIT	TP	- <del>D</del> -TP
			COREHOLE	<del>ф</del> сн	<del>-ф</del> сн
			PIEZOMETER	→ PIZ	<del>-</del> PIZ
			MONITORING WELL	₩w	<b>⊕</b> мw
				•	•

**DESCRIPTION** 

# MISCELLANEOUS

REMOVED RELOCATED ADJUSTED

STANDARD R10

LIGHT DUTY PAVEMENT REFER TO NOTES FOR COMPOSITION HEAVY DUTY PAVEMENT REFER TO NOTES FOR COMPOSITION ROAD REINSTATEMENT AS PER CITY

RIP-RAP AS PER OPSD 810.010

LANDSCAPE REINSTATEMENT

MONOLITHIC CURB INSTALLATION

X X X) REM **GENERAL NOTES** 

ALL WORKS AND MATERIALS SHALL CONFORM TO THE LATEST REVISIONS OF THE STANDARDS AND SPECIFICATIONS OF THE CITY OF OTTAWA, ONTARIO PROVINCIAL STANDARD DRAWINGS (OPSD) AND SPECIFICATIONS (OPSS), WHERE APPLICABLE.

- 2. THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR IS RESPONSIBLE TO PROVIDE THE LOCATION AND STATUS OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION OF PLANT AND EQUIPMENT FROM DAMAGE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIR OR REPLACEMENT OF ANY SERVICES OR UTILITIES DISTURBED DURING CONSTRUCTION, TO THE SATISFACTION OF THE AUTHORITY HAVING JURISDICTION.
- 3. THE CONTRACTOR SHALL VERIFY THE LOCATION AND ELEVATION OF EXISTING SERVICES PRIOR TO ANY CONSTRUCTION. THE CONTRACTOR SHALL CONFIRM LOCATIONS AND ELEVATIONS OF EXISTING SERVICES AND STRUCTURES TO BE CONNECTED TO AND EXISTING SERVICES THAT MAY BE DAMAGED OR CAUSE CONFLICTS PRIOR TO CONSTRUCTION OF ANY NEW SEWER, WATER AND/OR STORM WATER WORKS. ALL DIMENSIONS SHALL BE CHECKED AND VERIFIED IN THE FIELD BY THE CONTRACTOR PRIOR TO THE START OF CONSTRUCTION. ANY DISCREPANCIES, INTERPRETATIONS, CHANGES AND ADDITIONS TO THESE DRAWINGS MUST BE BROUGHT TO THE ATTENTION OF THE ENGINEER. WHEN NOTED AND BEFORE PROCEEDING WITH CONSTRUCTION WORKS. DO NOT CONTINUE CONSTRUCTION IN AREAS WHERE DISCREPANCIES APPEAR UNTIL SUCH DISCREPANCIES HAVE BEEN RESOLVED.
- 4. ALL ELEVATIONS ARE GEODETIC AND UTILIZE METRIC UNITS. ALL DIMENSIONS ARE IN METRES UNLESS OTHERWISE SPECIFIED. ALL DRAWINGS SHOULD NOT BE SCALED BY THE CONTRACTOR. ANY MISSING OR QUESTIONABLE DIMENSIONS ARE TO BE CONFIRMED WITH THE ENGINEER IN WRITING.
- 5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL PERMITS REQUIRED AND BEAR COST OF THE SAME.
- 6. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE "OCCUPATIONAL HEALTH AND SAFETY ACT AND REGULATIONS FOR CONSTRUCTION PROJECTS", THE GENERAL CONTRACTOR SHALL BE DEEMED TO BE THE CONSTRUCTOR AS DEFINED IN THE ACT.
- 7. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EXCAVATION, BACKFILL AND REINSTATEMENT OF ALL AREAS DISTURBED DURING CONSTRUCTION TO THE SATISFACTION OF THE ENGINEER, THE CITY OF OTTAWA AND THE AUTHORITY HAVING JURSIDICTION.
- 8. ANY AREAS BEYOND THE LIMIT OF THE SITE DISTURBED DURING CONSTRUCTION SHALL BE RESTORED TO ORIGINAL CONDITION OR BETTER TO THE SATISFACTION OF THE AUTHORITY HAVING JURISDICTION AT THE CONTRACTOR'S EXPENSE.
- 9. THE CONTRACTOR SHALL COMPLY WITH THE CITY OF OTTAWA REQUIREMENTS FOR TRAFFIC CONTROL WHEN WORKING ON CITY STREETS. ALL CONSTRUCTION SIGNAGE MUST CONFORM TO THE M.T.O. MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES (LATEST AMENDMENT).
- 10. THE SUPPORT OF ALL UTILITIES SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
- 11. THERE WILL BE NO SUBSTITUTION OF MATERIALS UNLESS WRITTEN APPROVAL BY THE ENGINEER HAS BEEN OBTAINED.
- 12. EXCESS EXCAVATED MATERIAL SHALL BE REMOVED FROM THE SITE.
- 13. THE SITE LAYOUT IS THE RESPONSIBILITY OF THE CONTRACTOR. AS-BUILT SITE SERVICING & GRADING DRAWINGS SHALL BE MAINTAINED ON SITE BY THE CONTRACTOR.
- 14. ALL EDGES OF DISTURBED PAVEMENT SHALL BE SAW CUT TO FORM A NEAT AND STRAIGHT LINE PRIOR TO PLACING NEW PAVEMENT.
- 15. FOR GEOTECHNICAL INFORMATION REFER TO GEOTECHNICAL INVESTIGATION REPORT PREPARED BY EXP SERVICES INC DATED MARCH, 2022, PROJECT NO. OTT-00238207-C0
- 16. THE CONTRACTOR SHALL APPRAISE HIS/HER SELF OF ALL SURFACE AND SUBSURFACE CONDITIONS TO BE ENCOUNTERED AND SHALL CARRY OUT THEIR OWN TEST PITS AS REQUIRED TO MAKE THEIR OWN INDEPENDENT ASSESSMENT OF GROUND CONDITIONS. THE CONTRACTOR SHALL NOT MAKE ANY CLAIM FOR ANY EXTRA COST DUE TO ANY SUCH GROUND CONDITIONS VARYING FROM THOSE ANTICIPATED BY THE CONTRACTOR.
- 17. DO NOT CONSTRUCT USING DRAWINGS THAT ARE NOT MARKED "ISSUED FOR CONSTRUCTION".
- 18. FOR TOPOGRAPHICAL INFORMATION REFER TO PLAN PREPARED BY ANIS, O'SULLIVAN, VOLLEBEKK SURVEYING LTD. DATED JUNE 16, 2017.
- 19. CIVIL DRAWINGS TO BE READ IN CONJUNCTION WITH ARCHITECTURAL, MECHANICAL, ELECTRICAL, STRUCTURAL, LANDSCAPE AND LEGAL
- 20. A SCHEMATIC DIAGRAM INCLUDING PROPOSED ELEVATIONS, DETAILS OF PROPOSED FOUNDATION DRAINS, STORM LATERAL, AND INTERNAL MECHANICAL PIPING WILL BE PREPARED BY THE MECHANICAL CONSULTANT PRIOR TO REGISTRATION.
- 21. THE SIDES OF THE EXCAVATION FOR UTILITY TRENCHES AND SUBSURFACE BASEMENT WALLS THAT EXTEND INTO THE SHALE BEDROCK BELOW THE GROUND WATER SHOULD BE SPRAYED WITH GUNNITE TO PREVENT DETERIORATION AND HEAVE OF THE SHALE BEDROCK. FOR UNDERGROUND SERVICE, AN ALTERNATIVE TO GUNNITE IS TO BACKFILL THE PORTION OF THE TRENCHES IN BEDROCK BELOW THE GROUNDWATER LEVEL USING CLAY OR CONCRETE.

# **SANITARY SEWER NOTES:**

- 1. ALL SANITARY SEWER MATERIALS AND INSTALLATION SHALL CONFORM TO THE LATEST REVISIONS OF THE STANDARDS AND SPECIFICATIONS OF THE CITY OF OTTAWA, ONTARIO PROVINCIAL STANDARD DRAWINGS (OPSD) AND SPECIFICATIONS (OPSS).
- 2. ALL SANITARY SEWERS SHALL BE PVC DR 35, IPEX "RING-TITE" (OR EQUIVALENT), AS PER CSA STANDARD B182.2 OR LATEST AMENDMENT, UNLESS OTHERWISE NOTED.
- 3. SANITARY SEWER TRENCH AND BEDDING SHALL BE AS PER CITY OF OTTAWA STD. S6 AND S7, CLASS 'B BEDDING UNLESS OTHERWISE NOTED. BEDDING DEPTH AS PER GEOTECHNICAL STUDY.
- 4. THE CONTRACTOR SHALL CONDUCT CCTV INSPECTION OF ALL NEWLY INSTALLED SANITARY SEWERS AND EXISTING SEWERS CONNECTED TO. THE TEST SHALL BE PERFORMED IMMEDIATELY AFTER SEWERS

- 5. THE CONTRACTOR SHALL CONSTRUCT FLEXIBLE SANITARY SEWERS IN ACCORDANCE WITH OPSD 802.010 AND 802.013. DURING CONSTRUCTION, THE CONTRACTOR SHALL PROTECT THE PIPES FROM HEAVY CONSTRUCTION EQUIPMENT. BEDDING AND BACKFILL SHALL BE COMPACTED TO A MINIMUM OF 95% SPMDD.
- 6. ALL ABANDONED EXISTING SEWERS TO BE CAPPED AT THE PROPERTY LINE TO THE SATISFACTION OF THE CITY OF OTTAWA'S SEWER OPERATIONS.
- 7. WITHIN THE FROST ZONE, THE BACKFILL IN THE SERVICE TRENCHES SHOULD MATCH THE SOIL ON SIDES TO MINIMIZE DIFFERENTIAL FROST

## **STORM SEWER NOTES:**

- 1. ALL STORM SEWER MATERIALS AND INSTALLATION SHALL CONFORM TO THE LATEST REVISIONS OF THE STANDARDS AND SPECIFICATIONS OF THE CITY OF OTTAWA, ONTARIO PROVINCIAL STANDARD DRAWINGS (OPSD) AND SPECIFICATIONS (OPSS).
- 2. ALL PVC STORM SEWERS ARE TO BE SDR 35 APPROVED PER C.S.A. B182.2 OR LATEST AMENDMENT, UNLESS OTHERWISE SPECIFIED.
- 3. THE CONTRACTOR SHALL CONSTRUCT FLEXIBLE STORM SEWERS IN ACCORDANCE WITH OPSD 802.010 AND 802.013. DURING CONSTRUCTION THE CONTRACTOR SHALL PROTECT THE PIPES FROM HEAVY CONSTRUCTION EQUIPMENT. BEDDING AND BACKFILL SHALL BE COMPACTED TO A MINIMUM OF 95% SPMDD.
- 4. SEWER BEDDING DEPTH AS PER GEOTECHINCAL STUDY.
- 5. ALL ABANDONED EXISTING SEWERS TO BE CAPPED AT THE PROPERTY LINE TO THE SATISFACTION OF THE CITY OF OTTAWA'S SEWER
- 6. WITHIN THE FROST ZONE, THE BACKFILL IN THE SERVICE TRENCHES SHOULD MATCH THE SOIL ON SIDES TO MINIMIZE DIFFERENTIAL FROST HEAVING IN THE SUBGRADE.
- 7. ALL STORM SERVICES TO BE EQUIPPED WITH APPROVED BACKWATER VALVES. REFER TO MECHANICAL DRAWINGS.
- 8. THE CONTRACTOR SHALL CONDUCT CCTV INSPECTION OF ALL NEWLY INSTALLED STORM SEWERS AND EXISTING SEWERS CONNECTED TO. THE TEST SHALL BE PERFORMED IMMEDIATELY AFTER SEWERS INSTALLED.
- 9. CONTRACTOR TO PROVIDE SHOP DRAWINGS FOR ALL STORMTECH

1. ALL WATERMAIN MATERIALS AND INSTALLATION SHALL CONFORM TO THE LATEST REVISIONS OF THE STANDARDS AND SPECIFICATIONS OF THE CITY OF OTTAWA, ONTARIO PROVICIAL STANDARD DRAWINGS (OPSD) AND SPECIFICATIONS (OPSS).

- 2. NO WORK SHALL COMMENCE UNLESS A CITY WATER WORKS INSPECTOR IS ON SITE. WATERMAIN CONNECTIONS BY CITY OF OTTAWA FORCES WITH ALL EXCAVATION BACKFILL AND ROAD REINSTATEMENT BY
- 3. WATERMAINS TRENCH AND BEDDING SHALL BE IN ACCORDANCE WITH CITY OF OTTAWA STANDARD W17, UNLESS OTHERWISE SPECIFIED. BEDDING AND COVER MATERIAL SHALL BE SPECIFIED BY PROJECT GEOTECHNICAL ENGINEER.
- 4. CATHODIC PROTECTION IS REQUIRED ON ALL METALLIC FITTINGS AS PER CITY OF OTTAWA STD. W40. ALL ANODES SHALL BE A Z-24-48 AS PER CITY OF OTTAWA STD. W44.
- 5. ALL WATERMAINS TO BE INSTALLED AT MINIMUM COVER OF 2.4m.
- 6. IF WATERMAIN MUST BE DEFLECTED TO MEET ALIGNMENT, ENSURE THAT THE AMOUNT OF DEFLECTION USED IS LESS THAN HALF THAT RECOMMENDED BY THE MANUFACTURER.
- DISINFECTION AND TESTING OF WATERMAIN TO BE IN ACCORDANCE WITH CITY OF OTTAWA STANDARDS.
- 8. WATER METER TO BE INSTALL TO BE COORDINATED WITH MECHANICAL.
- 9. INSULATION FOR WATERMAIN CROSSING OVER AND BELOW SEWER SHALL BE IN ACCORDANCE WITH CITY OF OTTAWA STD. W25.2 AND W25, RESPECTIVELY, WHERE WATERMAN COVER IS LESS THAN 2.4m.
- 10. PRESSURE REDUCING MEASURES REQUIRED FOR INTERNAL WATER

# **ROAD NOTES:**

- 1. PAVEMENT REINSTATEMENT FOR SERVICE AND UTILITY CUTS SHALL BE IN ACCORDANCE WITH CITY OF OTTAWA STD. R10 AND OPSD 509.010,
- 2. GRANULAR "A" SHALL BE PLACED TO A MINIMUM THICKNESS OF 300mm AROUND ALL STRUCTURES WITHIN PAVEMENT AREA.
- 3. ALL GRANULAR FOR ROADS SHALL BE COMPACTED TO A MINIMUM OF 95% STANDARD PROCTOR MAXIMUM DRY DENSITY.

### 4. PAVEMENT STRUCTURE: SITE ACCESS DRIVEWAYS:

- 40mm SUPERPAVE 12.5 ASPHALTIC CONCRETE - 50mm SUPERPAVE 19.0 ASPHALTIC CONCRETE
- 150mm GRANULAR "A" CRUSHED LIMESTONE (OPSS 1010) - 400mm GRANULAR "B" TYPE II (OPSS 1010)
- BEECHWOOD AVENUE:
- 40mm SUPERPAVE 12.5 ASPHALTIC CONCRETE
- 50mm SUPERPAVE 19.0 ASPHALTIC CONCRETE
- 150mm GRANULAR "A" CRUSHED LIMESTONE (OPSS 1010) - 400mm GRANULAR "B" TYPE II (OPSS 1010)

BMT

E POSITION OF ALL POLE LINES, CONDUITS, WATERMAINS, SEWERS AND OTHER UNDERGROUND AND OVERGROUND UTILITIES AND STRUCTURES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND TRUCTURES IS NOT GUARANTEED. BEFORE STARTING WORK, DETERMINE THE EXACT OCATION OF ALL SUCH UTILITIES AND STRUCTURES AND ASSUME ALL LIABILITY FOR AMAGE TO THEM.

ISSUED FOR APPROVAL |28/07/23| SAB | BM ISSUED FOR CITY REVIEW |22/03/22| AC |BM<sup>-</sup> ISSUED FOR SITE PLAN CONTROL |15/12/20 | SK | BM REVISION DESCRIPTION DATE BY APF REV REVISION DESCRIPTION DATE BY APP



229 BEECHWOOD HOLDINGS INC. AND 241 BEECHWOOD HOLDINGS INC. C/O BINTEE DEV INC.BINTEE DEV INC 226 ARGYLE Ave., OTTAWA, ON, K2P 1B9

+1.613.688.1899 | f: +1.613.225.7330 2050 Queensview Drive, Unit 100 Ottawa, ON K2B 8H6 Canada

• BUILDINGS • EARTH & ENVIRONMENT • ENERGY •

• INDUSTRIAL • INFRASTRUCTURE • SUSTAINABILITY •

229-247 BEECHWOOD JLF/ARO OTTAWA, ON BMT

NOTES AND LEGEND SHEET

OTT-238207-C0

AOV

DEC 2020

C001