



Kollaard Associates
Engineers

210 Prescott Street, Unit 1
P.O. Box 189
Kemptville, Ontario K0G 1J0

Civil • Geotechnical •
Structural • Environmental •
Hydrogeology • Materials Testing •

(613) 860-0923

info@kollaard.ca

FIELD REPORT

Our File #: 190361

Date: 08/19/24 08:00

CLIENT: Monte Pickard

PROJ. LOCATION: 1994 St. Joseph Boulevard
Ottawa

INSPECTION TYPE: Test Pits

OBSERVATIONS:

At the time of the site visit 2 test pits were completed at opposite ends of the existing retaining wall down to the footing level

The soil at the bottom of the existing wall consisted of a grey brown silty clay.

An allowable bearing pressure of 100 kPa SLS 150 kPa ULS may be used for design purposes.

Observations in test pits:

2' of backfill cover

16" of extending footing

4" footing height

2" of rigid insulation was underneath footing and extended approximately 0.9m

Signature: *Nick Reestie*



Professional Engineers
Ontario

Authorized by the Association of Professional Engineers
of Ontario to offer professional engineering services



Kollaard Associates
Engineers



210 Prescott Street, Unit 1
P.O. Box 189
Kemptville, Ontario K0G 1J0

Civil • Geotechnical •
Structural • Environmental •
Hydrogeology • Materials Testing •

(613) 860-0923

FAX: (613) 258-0475

SITE PHOTOS



ADDITIONAL NOTES