



**Goodkey, Weedmark
& Associates Limited**

Consulting Engineers

1688 Woodward Dr.
Ottawa, ON
Canada
K2C 3R8

Tel. 613-727-5111
info@gwal.com
www.gwal.com

Principal, Partners & Associates
F.W.A. Bann, P.Eng.
R. Lefebvre, P.Eng., LEED® AP
D.R. Vyas, P.Eng., MIEEE
S. Hamilton, P.Eng.
J. Moffat, P.Eng.
E. Pérusse, P.Eng., ing.
R. Boivin, P.Eng., ing.
R. Leonard, P.Eng.
M. Sarasin, P.Eng.

Executive Consultants
A. Bogdanowicz, P.Eng.
M.G. Carriere, C.E.T.
R.J. McIntyre, P.Eng.

April 28, 2021

VIA E-MAIL

Hobin Architecture Incorporated
63 Pamilla Street
Ottawa, Ontario
K1S 3K7

ATTENTION: MR. PATRICK BISSON, ARCHITECT, ASSOCIATE

**SUBJECT: 100 BAYSHORE DR., APARTMENT BUILDING
OUR PROJECT NO. 2020-502**

Dear Sir:

We have designed the site lighting for the new apartment building, located at 100 Bayshore Drive, in accordance with the following guidelines as requested by the City of Ottawa:

1. It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;
2. It must result in minimal light spillage onto adjacent properties. As a guideline, 0.5 fc is normally the maximum allowable spillage.

Yours very truly,

GOODKEY, WEEDMARK & ASSOCIATES LIMITED



James Moffat, P.Eng.
Partner
Senior Electrical Engineer

JM/cb

e.c.: Cory Behan (GWA – Electrical)

