



July 24, 2021

Reference No. 11227097-A1

Mr. Russell Beach
Senior Development Manager
Medusa LP
Kirkland, Quebec H9H 4M7

By Email
russell.beach@broccolini.com

**Re: Geotechnical Review – Proposed Pavement Grading
Proposed Sortation Facility
Intersection of Leikin Drive and Merivale Road, Nepean, Ontario**

Dear Sir,

GHD completed a geotechnical review of the proposed pavement grading for the proposed sortation facility located at the Leikin Drive and Merivale Road intersection in Nepean, Ontario.

Specifically, the proposed site pavement grading presented in grading Plans GR1 through GR3, rev3 and prepared by Novatech, globally satisfy GHD's exterior site grade raise limit of 1.2 m.

Sincerely,

GHD



Alex Fiorilli, P.Eng.

AF