


---

110 Didsbury Rd – Unit M090, Kanata, ON, K2T 0C2  
Tel: 613-627-2462 Email: Admin@jrpeng.com

An exact copy of all working documents including, without limitations, the original of the present document or plan is kept on file by J.R.P. Engineering Any modification carried out to this document or plan or to accompanying documents without written authorization by the engineer is prohibited.

Authorized modifications must be signed and sealed by an engineer and this engineer will be completely responsible for these modifications. J.R.P. Engineering is not and will not be responsible for the consequences of these modifications or for modifications carried out without it's consent.



1 SITE LIGHTING PLAN  
SP-E1 3/32" = 1' 0"

LIGHTING FIXTURE SCHEDULE						
Type	Make/Model	Voltage	Mount	Wattage	Temperature	Notes
P1	LITHONIA LIGHTING RSX1 LED P1 30K R4	120V	POLE	52	3000K	ALL LIGHTING TO BE TIED INTO COMMON PHOTOCELL
P2	LITHONIA LIGHTING RSX1 LED P3 30K R4	120V	POLE	110	3000K	
W1	LITHONIA LIGHTING WDGE1 LED P1 30K 80CRI VW	120V	WALL PACK	10	3000K	
W2	LITHONIA LIGHTING WDGE2 LED P2 30K 70CRI T1C	120V	WALL PACK	7	3000K	

**APPROVED**

**KERSTEN NITSCHE, MCIP RPP  
MANAGER (A), DEVELOPMENT REVIEW WEST  
PLANNING, DEVELOPMENT AND BUILDING SERVICES  
DEPARTMENT, CITY OF OTTAWA**

project:  
**TWO STORY OFFICE  
BUILDING**

1037 CARP ROAD  
OTTAWA, ONTARIO

drawing = title;

# ELECTRICAL SITE LIGHTING PLAN

scale:	AS NOTED	drawn by:	C.M.
designed by:	C.M.	reviewed by:	M.G.
approved by:	M.G.	date:	DEC 2022

project no.:	drawing no.:
100-2302	SP-E1 of 1