



## Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3  
613 230 1186 f 613 230 2598 [smithandandersen.com](http://smithandandersen.com)

2020-04-29

### City of Ottawa

Infrastructure Services and Community Sustainability  
110 Laurier Avenue West  
Ottawa, ON  
K1P 1J1

**Attention: City Building Official**

**RE: 2 ROBINSON / 320 LEES AVENUE  
S+A PROJECT # 211133.000  
SITE LIGHTING**

Dear City Building Official:

This letter is to confirm that the exterior light fixtures used for this project will be designed to meet the criteria for the City of Ottawa Site Lighting requirements as follows;

- I. The fixtures will be full cut-off classification as recognized by the Illuminating Engineering Society of North America (IESNA)
- II. The resulting light spillage onto adjacent properties is below the maximum allowable spillage (0.5 fc) by City of Ottawa Standards.

Yours truly,

SMITH + ANDERSEN

Andre Drouin, P. Eng.  
Principal

20041.001.E.200.1001-CityLtg

