

2021-08-26

VIA Email

City of Ottawa
Development Review Rural Services
Planning, Infrastructure and Economic Development Department


Re: Local 47
765 Green Creek Dr, Ottawa

1. The site lighting has been designed with sharp cut-off fixtures such that a maximum light spillage of 0.5fc will occur on adjoining properties.

If you have any further questions or require any further clarification, please contact me at your earliest convenience.

Yours Truly,

JRP Engineering



Michael Gerrard, P.Eng

