



Water Supply Calculations

LRL File No. 210216-02
 Date June 9, 2023
 Prepared by K. Herold
 Project Location 6001/6005 Renaud

Residential Demand based on the City of Ottawa Design Guidelines-Water Distribution, 2010

Unit Type	Persons Per Unit	Number of Units	Population
Townhouse	2.7	20	54.0
Total		20	54.0

Average Water Consumption Rate	280 L/c/d	
Average Day Demand	15,120 L/d	0.18 L/s
Maximum Day Factor	7.5	(MOE Table 3-3)
Maximum Daily Demand	112,697 L/d	1.30 L/s
Peak Hour Factor	11.2	(MOE Table 3-3)
Maximum Hour Demand	1,263,509 L/d	14.62 L/s

Water Service Pipe Sizing

$$Q = VA$$

Where: V = velocity

A = area of pipe

Q = flow rate

Assuming a maximum velocity of 1.8m/s, the diameter of pipe is calculated as:

$$\begin{aligned} \text{Minimum pipe diameter (d)} &= (4Q/\pi V)^{1/2} \\ &= 0.102 \text{ m} \\ &= 102 \text{ mm} \end{aligned}$$

$$\begin{aligned} \text{Proposed pipe diameter (d)} &= 150 \text{ mm} \\ &= 6 \text{ Inches} \end{aligned}$$



LRJ

**Fire Flow Calculations
6001 / 6005 Renaud - Block A**

LRL File No. 210216-02
 Date June 9, 2023
 Method Fire Underwriters Survey (FUS)
 Prepared by K. Herold

Step	Task	Term	Options	Multiplier	Choose:	Value	Unit	Fire Flow
Structural Framing Material								
1	Choose frame used for building	Coefficient C related to the type of construction	Wood Frame	1.5	Wood Frame	1.5		
			Ordinary Construction	1.0				
			Non-combustible construction	0.8				
			Fire resistive construction <2 hrs	0.7				
			Fire resistive construction >2 hrs	0.6				
Floor Space Area (A)								
2			Total area (building area of 360m ² , 4 stories)			1,440	m ²	
3	Obtain fire flow before reductions	Required fire flow	Fire Flow = 220 x C x A ^{0.5}				L/min	12,523
Reductions or surcharge due to factors affecting burning								
4	Choose combustibility of contents	Occupancy hazard reduction or surcharge	Non-combustible	-25%	Limited combustible	-15%	L/min	10,644
			Limited combustible	-15%				
			Combustible	0%				
			Free burning	15%				
			Rapid burning	25%				
5	Choose reduction for sprinklers	Sprinkler reduction	Full automatic sprinklers	-30%	False	0%	L/min	10,644
			Water supply is standard for both the system and fire department hose lines	-10%	False	0%		
			Fully supervised system	-10%	False	0%		
6	Choose separation	Exposure distance between units	North side	20.1 to 30m	10%	L/min	15,966	
			East side	3.1 to 10m	20%			
			South side	>45m	0%			
			West side	3.1 to 10m	20%			50%
Net required fire flow								
7	Obtain fire flow, duration, and volume					Minimum required fire flow rate (rounded to nearest 1000)	L/min	16,000
						Minimum required fire flow rate	L/s	266.7
						Required duration of fire flow	hr	4.25



LRJ

**Fire Flow Calculations
6001 / 6005 Renaud - Block B**

LRL File No. 210216-02
 Date June 9, 2023
 Method Fire Underwriters Survey (FUS)
 Prepared by K. Herold

Step	Task	Term	Options	Multiplier	Choose:	Value	Unit	Fire Flow
Structural Framing Material								
1	Choose frame used for building	Coefficient C related to the type of construction	Wood Frame	1.5	Wood Frame	1.5		
			Ordinary Construction	1.0				
			Non-combustible construction	0.8				
			Fire resistive construction <2 hrs	0.7				
			Fire resistive construction >2 hrs	0.6				
Floor Space Area (A)								
2			Total area (building area of 360m ² , 4 stories)			1,440	m ²	
3	Obtain fire flow before reductions	Required fire flow	Fire Flow = 220 x C x A ^{0.5}				L/min	12,523
Reductions or surcharge due to factors affecting burning								
4	Choose combustibility of contents	Occupancy hazard reduction or surcharge	Non-combustible	-25%	Limited combustible	-15%	L/min	10,644
			Limited combustible	-15%				
			Combustible	0%				
			Free burning	15%				
			Rapid burning	25%				
5	Choose reduction for sprinklers	Sprinkler reduction	Full automatic sprinklers	-30%	False	0%	L/min	10,644
			Water supply is standard for both the system and fire department hose lines	-10%	False	0%		
			Fully supervised system	-10%	False	0%		
6	Choose separation	Exposure distance between units	North side	20.1 to 30m	10%	L/min	15,966	
			East side	3.1 to 10m	20%			
			South side	>45m	0%			
			West side	3.1 to 10m	20%			50%
Net required fire flow								
7	Obtain fire flow, duration, and volume		Minimum required fire flow rate (rounded to nearest 1000)			L/min	16,000	
			Minimum required fire flow rate			L/s	266.7	
			Required duration of fire flow			hr	4.25	



Pipe Pressure Losses Calculations

LRL File No. 210216-02

Project Navan Stacked Townhomes

Location: 6001/6005 Renaud Road

Date June 9, 2023

Designed: K. Herold

Piezometric Head Equation (Derived from Bernoulli's Equation)

$$h = \frac{p}{\gamma} + z$$

Where:

h = HGL (m)

p = Pressure (Pa)

γ = Specific weight (N/m³) =

9810

z = Elevation of centreline of pipe (m) =

73.6

Water Pressure on Huron Street			
HGL (m)		Pressure	
		kPa	psi
Minimum =	126.7	520.91	75.55
Maximum =	130.7	560.15	81.24
Max. Day + Fire =	115.5	411.04	59.62

Hazen Williams Equation

$$h_f = \frac{10.67 \times Q^{1.85} \times L}{C^{1.85} \times d^{4.87}}$$

Where:

h_f = Head loss over the length of pipe (m)

Q = Volumetric flow rate (m³/s)

L = Length of pipe (m)

C = Pipe roughness coefficient

d = Pipe diameter (m)

Scenario 1: maximum daily demand

Q (L/s)	1.30
C	150
L (m.)	121.5

I.D. (mm)	150	
V (m/s)	0.07	
h_f (m)	0.01	
Head Loss (psi)	0.01	
Min. Pressure (psi)	75.54	
Max. Pressure (psi)	81.23	
Service Obs. @ Street Connection (m)	70.86	
Service Obs. @ Building Connection (m)	72.50	
Pressure Adjustment (psi)	-2.33	(due to service elevation difference from street to building)
Adjusted Min. Pressure (psi)	73.21	(must not be less than 50psi)
Adjusted Max. Pressure (psi)	78.90	(must not be more than 80psi)

Scenario 2: maximum hourly demand

Q (L/s)	14.62	
C	150	
L (m.)	121.5	
I.D. (mm)	150	
V (m/s)	0.83	
h_f (m)	0.51	
Head Loss (psi)	0.72	
Min. Pressure (psi)	74.83	
Max. Pressure (psi)	80.52	
Service Obs. @ Street Connection (m)	70.86	
Service Obs. @ Building Connection (m)	72.50	
Pressure Adjustment (psi)	-2.33	(due to service elevation difference from street to building)
Adjusted Min. Pressure (psi)	72.50	(must not be less than 40psi)
Adjusted Max. Pressure (psi)	78.19	(must not be more than 80psi)

City of Ottawa Boundary Conditions (Multi-Hydrant Analysis)


	Quantity	Max Capacity (L/min)*	Available Fire Flow** (L/min)
Fire Hydrant(s) Within 76m	2	5678	11356
Fire Hydrant(s) Within 76m to 152m	6	3785	22710
Fire Hydrant(s) Within 152m to 305m		2839	0
Available Combined Fire Flow (L/min)			34066
Max Day + Fire Flow Demand (L/min)			16000

*as per Table 18.5.4.3. of ISTB-2018-02

**assumed class AA hydrants

***flow provided from all hydrants within 76m is more than adequate to accommodate fire flow requirements, balance of hydrants within 152m and 305m not considered in design

City of Ottawa - Water Distribution System Facilities & Feeder mains



Legend

Water System Structure

- Pump Station
- Backup Pump Station
- Water Treatment Plant
- Well
- Elevated Tank
- Reservoir

WATERMAINS

- Priority, Internal Diameter
- Backbone 1524mm - 1067mm
 - Backbone 1067mm - 1372mm
 - Backbone 610mm - 914mm
 - Backbone 406mm - 305mm
 - Backbone 152mm - 305mm
 - Distribution 1679mm - 1561mm
 - Distribution 1067mm - 1372mm
 - Distribution 610mm - 914mm
 - Distribution 406mm - 305mm
 - Distribution 305mm - 301mm

PRESSURE ZONES

- 1E
- 1W
- 2C
- 2E
- 2W
- 3C
- 3W
- 4C
- 4W
- 5C
- 5W
- 6C
- 6W
- 7C
- 7W
- 8C
- 8W
- 9C
- 9W
- 10C
- 10W
- SHAD

Boundary Conditions 6001-6005 Renaud Road

Provided Information

Scenario	Demand	
	L/min	L/s
Average Daily Demand	11	0.18
Maximum Daily Demand	78	1.30
Peak Hour	877	14.62
Fire Flow Demand #1	16,002	266.70

Location



Results

Connection 1 – Ziegler St.

Demand Scenario	Head (m)	Pressure ¹ (psi)
Maximum HGL	130.7	81.2
Peak Hour	126.7	75.5
Max Day plus Fire Flow	115.5	59.5

¹ Ground Elevation = 73.6 m

Notes

- As per the Ontario Building Code in areas that may be occupied, the static pressure at any fixture shall not exceed 552 kPa (80 psi.) Pressure control measures to be considered are as follows, in order of preference:

- a. If possible, systems to be designed to residual pressures of 345 to 552 kPa (50 to 80 psi) in all occupied areas outside of the public right-of-way without special pressure control equipment.
- b. Pressure reducing valves to be installed immediately downstream of the isolation valve in the home/ building, located downstream of the meter so it is owner maintained.

Disclaimer

The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation. Fire Flow analysis is a reflection of available flow in the watermain; there may be additional restrictions that occur between the watermain and the hydrant that the model cannot take into account.

**FIRE HYDRANT
LOCATIONS
FIGURE**

LEGEND

SUBJECT SITE

HYDRANTS WITHIN 75 M ●

HYDRANTS WITHIN 150 M ●



Table 18.5.4.3 Maximum Fire Hydrant Fire Flow Capacity

Distance to Building ^a		Maximum Capacity ^b	
(ft)	(m)	(gpm)	(L/min)
≤ 250	≤ 76	1500	5678
> 250 and ≤ 500	> 76 and ≤ 152	1000	3785
> 500 and ≤ 1000	> 152 and ≤ 305	750	2839

^aMeasured in accordance with 18.5.1.4 and 18.5.1.5.
^bMinimum 20 psi (139.9 kPa) residual pressure.