

## **Appendix A**      **WATER SUPPLY SERVICING**

### **A.1**    **DOMESTIC WATER DEMAND ESTIMATE**

**Holland Cross Phase 3 Residential**

Project #160410274  
3-Jun-22

|           | Number of Units | Density | Population |
|-----------|-----------------|---------|------------|
| Studio    | 18              | 1.4     | 25.2       |
| 1 BR      | 110             | 1.4     | 154.0      |
| 1BR + Den | 51              | 2.1     | 107.1      |
| 2 BR      | 101             | 2.1     | 212.1      |
| 2BR + Den | 0               | 3.1     | 0.0        |
| Guest     | 1               | 1.4     | 1.4        |

| Building ID                         | Area (m <sup>2</sup> ) | Population | Daily Rate of Demand <sup>1,2</sup> (L/m <sup>2</sup> /day) | Avg Day Demand |             | Max Day Demand <sup>3,4</sup> |             | Peak Hour Demand <sup>3,4</sup> |              |
|-------------------------------------|------------------------|------------|---|----------------|-------------|-------------------------------|-------------|---------------------------------|--------------|
|                                     |                        |            |   | (L/min)        | (L/s)       | (L/min)                       | (L/s)       | (L/min)                         | (L/s)        |
| Residential                         |                        | 500        | 350   | 121.5          | 2.02        | 303.7                         | 5.06        | 668.1                           | 11.14        |
| Commercial, Lobby and Amenity Space | 1,282                  |            | 28000   | 2.5            | 0.04        | 3.7                           | 0.06        | 6.7                             | 0.11         |
| <b>Total Site :</b>                 |                        |            |   | <b>124.0</b>   | <b>2.07</b> | <b>307.4</b>                  | <b>5.12</b> | <b>674.9</b>                    | <b>11.25</b> |

<sup>1</sup> Average day water demand for residential areas are equal to 350 L/cap/d

<sup>2</sup> 28,000 L/gross ha/day is used to calculate water demand for commercial facilities.

<sup>3</sup> Water demand criteria used to estimate peak demand rates for residential areas are as follows:

maximum day demand rate = 2.5 x average day demand rate

peak hour demand rate = 2.2 x maximum day demand rate


<sup>4</sup> Water demand criteria used to estimate peak demand rates for commercial and institutional areas are as follows:

maximum day demand rate = 1.5 x average day demand rate

peak hour demand rate = 1.8 x maximum day demand rate

Appendix A Water Supply Servicing  
April 20, 2023

## **A.2 HYDRAULIC ANALYSIS SHEET**

|   |                                     |                      |
|---|-------------------------------------|----------------------|
|  | Project: <b>Holland Cross</b>       | No. <b>160410274</b> |
|   | <b>SITE PLAN HYDRAULIC ANALYSIS</b> |                      |
|   | Revision: 00                        | Prepared By: AM      |
| Revision Date: 24-Nov-2022  | Checked By: NC                      |                      |

| BOUNDARY CONDITIONS (BC)       |             |
|--------------------------------|-------------|
| Connection at Hamilton Avenue  |             |
| Site Plan Revision Date        | 14-Oct-2022 |
| Min. HGL (m)                   | 107.9       |
| Max. HGL (m)                   | 114.6       |
| Max. Day + Fire Flow (150 L/s) | 104.4       |

|   |       |
|---|-------|
| Ground Floor Elevation (GFE) (Level 01) (m) | 62.95 |
|---|-------|

| GROUND FLOOR (GF) PRESSURE RANGE |                        |                              |                                       |   |
|----------------------------------|------------------------|------------------------------|---------------------------------------|---|
|                                  | GF HGL (m)             | GF Pressure (kPa)            | GF Pressure (psi)                     | Outcome   |
|                                  | = BC HGL (m) - FFE (m) | = GF HGL (m) x 9.804 (kPa/m) | = GF Pressure (kPa) x 0.145 (psi/kPa) | If min <50 psi: booster pump<br>If max >100 psi: pressure reducer |
| Minimum Normal                   | 44.95                  | 440.7                        | 63.9                                  | No Booster Pump Required  |
| Maximum Normal                   | 51.65                  | 506.4                        | 73.4                                  | No Pressure Reducer Required                                      |

|                                      |      |
|--------------------------------------|------|
| Number of Floors Not Below Ground    | 25   |
| Approximate Height of One Storey (m) | 3.21 |
| Pressure Drop Per Floor (kPa)        | 31.5 |
| Pressure Drop Per Floor (psi)        | 4.6  |

| RESIDUAL PRESSURE RANGE IN MULTI-LEVEL BUILDINGS          |                         |                         |                       |
|---|-------------------------|-------------------------|-----------------------|
|   | Residual Pressure (kPa) | Residual Pressure (psi) | Outcome               |
| Top Floor Min   | -314.6                  | -45.6                   | Booster Pump Required |
| Top Floor Max   | -248.9                  | -36.1                   |                       |
| Maximum Number of Floors Above Ground at Minimum Pressure | 5                       |                         |                       |

| RESIDUAL PRESSURE FROM FIRE FLOW |                  |                         |                         |                    |
|----------------------------------|------------------|-------------------------|-------------------------|--------------------|
|                                  | Residual HGL (m) | Residual Pressure (kPa) | Residual Pressure (psi) | Outcome            |
| Ground Floor                     | 41.45            | 406.4                   | 58.9                    | Fire Pump Required |
| Top Floor                        | -35.59           | -348.9                  | -50.6                   |                    |

| Pressure Check               |                |                |
|------------------------------|----------------|----------------|
|                              | Pressure (kPa) | Pressure (psi) |
| Pressure Below Minimum       | <138           | <20            |
| Pressure Below Normal        | 138-345        | 20-50          |
| Pressure Within Normal Range | 345-552        | 50-80          |
| Pressure Above Normal Range  | 552-690        | 80-100         |
| Pressure Above Maximum       | >690           | >100           |

Appendix A Water Supply Servicing  
April 20, 2023

### **A.3 FIRE FLOW REQUIREMENTS PER FUS**



FUS Fire Flow Calculation Sheet - 2020 FUS Guidelines

Stantec Project #: 160410274

Project Name: Holland Cross

Date: 2/24/2023

Fire Flow Calculation #: 1

Description: 25 Floor Apartment Building with Fire Separations between floors

Notes: 1356m<sup>2</sup> Floorplate

| Step | Task  | Notes  |                       |                    |                          |                                    |                                    |                          | Value Used | Req'd Fire Flow (L/min) |
|------|---|--|-----------------------|--------------------|--------------------------|------------------------------------|------------------------------------|--------------------------|------------|-------------------------|
| 1    | Determine type of Construction              | Type II - Noncombustible Construction / Type IV-A - Mass Timber Construction |                       |                    |                          |                                    |                                    |                          | 0.8        | -                       |
| 2    | Determine Effective Floor Area              | Sum of Two Largest Floors + 50% of Eight Additional Floors                   |                       |                    |                          | Vertical Openings Protected?       |                                    |                          | NO         | -                       |
|      |   | 1356   |                       |                    |                          |                                    |                                    |                          | 1356       | -                       |
| 3    | Determine Required Fire Flow                | (F = 220 x C x A <sup>1/2</sup> ). Round to nearest 1000 L/min               |                       |                    |                          |                                    |                                    |                          | -          | 6000                    |
| 4    | Determine Occupancy Charge                  | Limited Combustible  |                       |                    |                          |                                    |                                    |                          | -15%       | 5100                    |
| 5    | Determine Sprinkler Reduction               | Conforms to NFPA 13  |                       |                    |                          |                                    |                                    |                          | -30%       | -2040                   |
|      |   | Standard Water Supply  |                       |                    |                          |                                    |                                    |                          | -10%       |                         |
|      |   | Not Fully Supervised or N/A  |                       |                    |                          |                                    |                                    |                          | 0%         |                         |
|      |   | % Coverage of Sprinkler System   |                       |                    |                          |                                    |                                    |                          | 100%       |                         |
| 6    | Determine Increase for Exposures (Max. 75%) | Direction  | Exposure Distance (m) | Exposed Length (m) | Exposed Height (Stories) | Length-Height Factor (m x stories) | Construction of Adjacent Wall      | Firewall / Sprinklered ? | -          | -                       |
|      |   | North  | 0 to 3                | 49.3               | 1                        | 41-60                              | Type III-IV - Unprotected Openings | YES                      | 0%         | 1020                    |
|      |   | East   | 20.1 to 30            | 26.5               | 5                        | > 100                              | Type III-IV - Unprotected Openings | NO                       | 5%         |                         |
|      |   | South  | 10.1 to 20            | 49.8               | 3                        | > 100                              | Type V                             | NO                       | 15%        |                         |
|      |   | West   | 0 to 3                | 23.1               | 1                        | 21-49                              | Type III-IV - Unprotected Openings | YES                      | 0%         |                         |
| 7    | Determine Final Required Fire Flow          | Total Required Fire Flow in L/min, Rounded to Nearest 1000L/min              |                       |                    |                          |                                    |                                    |                          |            | 4000                    |
|      |   | Total Required Fire Flow in L/s  |                       |                    |                          |                                    |                                    |                          |            | 66.7                    |
|      |   | Required Duration of Fire Flow (hrs)   |                       |                    |                          |                                    |                                    |                          |            | 1.50                    |
|      |   | Required Volume of Fire Flow (m <sup>3</sup> )                               |                       |                    |                          |                                    |                                    |                          |            | 360                     |

## **A.4 FIRE FLOW REQUIREMENTS PER OBC**

## Fire Flow Calculations as per Ontario Building Code (Appendix A)

Job# 1604-10274  
Date 24-Feb-23

Designed by: WJ  
Checked by: NC  
Description: 25 Floor Apt

$$Q = KVS_{tot}$$

Q = Volume of water required (L)

V = Total building volume (m<sup>3</sup>)

K = Water supply coefficient from Table 1

S<sub>tot</sub> = Total of spatial coefficient values from property line exposures on all sides as obtained from the formula

$$S_{tot} = 1.0 + [S_{side1} + S_{side2} + S_{side3} + S_{side4}]$$

|   |  |                          |                       |   |
|---|--|--------------------------|-----------------------|---|
| 1 | Type of construction                         | Building Classification  |                       | Water Supply Coefficient                |
|   | Non-Combustible with Fire-Resistance Ratings | A-2, B-1, B-2, B-3, C, D |                       | 10                                      |
| 2 | Area of one floor (m <sup>2</sup> )          | number of floors         | height of ceiling (m) | Total Building Volume (m <sup>3</sup> ) |
|   | 1356   | 25                       | 3.0                   | 102,284                                 |
| 3 | Side   | Exposure Distance (m)    | Spatial Coefficient   | Total Spatial Coefficient               |
|   | North  | 0                        | 0.5                   | 2                                       |
|   | East   | 26                       | 0                     |   |
|   | South  | 19.1                     | 0                     |   |
|   | West   | 0                        | 0.5                   |   |
| 4 | Established Fire Safety Plan?                | Reduction in Volume (%)  |                       | Total Volume Reduction                  |
|   | no   | 0%                       |                       | 0%                                      |
| 5 | Total Volume 'Q' (L)                         |                          |                       |   |
|   |  |                          |                       | 2,045,680                               |
|   | Minimum Required Fire Flow (L/min)           |                          |                       |   |
|   |  |                          | 9,000                 |   |



Appendix A Water Supply Servicing  
April 20, 2023

## **A.5 BOUNDARY CONDITIONS**

# Boundary Conditons for Hamilton Avenue - 29 Storey Condo



## Legend

- PRIVATE
- PUBLIC

**From:** [Wu, John](#)  
**To:** [Rathnasooriya, Thakshika](#)  
**Subject:** RE: Boundary Conditions  
**Date:** Thursday, July 30, 2020 4:07:21 PM  
**Attachments:** [Hamilton Avenue July 2020.pdf](#)

---

**Here is the result:**

The following are boundary conditions, HGL, for hydraulic analysis on Hamilton Avenue (zone 1E) assumed to be connected to the 203mm on Hamilton Avenue (see attached PDF for location).

Minimum HGL = 107.9m

Maximum HGL = 114.6m

Max Day + FF = 104.4m

These are for current conditions and are based on computer model simulation.

*Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermain deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.*

John

---

**From:** Rathnasooriya, Thakshika <Thakshika.Rathnasooriya@stantec.com>  
**Sent:** July 29, 2020 2:46 PM  
**To:** Wu, John <John.Wu@ottawa.ca>  
**Cc:** Kilborn, Kris <kris.kilborn@stantec.com>  
**Subject:** Boundary Conditions

**CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.**

**ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.**


Hi John,

I am looking for watermain hydraulic boundary conditions for Holland Cross Phase 3 residential. The proposed residential building consists of 29 storeys. We anticipate connecting to the existing 150mm watermain service in addition to constructing a secondary connection( basic day demand is greater than 50 m3/day). The service is connected to the exiting 200mm diameter watermain on Hamilton Avenue North and Bullman Street. (please see attached figure).

Please see the estimated domestic demands and fire flow requirements for the site as mentioned below:

|                    |             |
|--------------------|-------------|
| Average Day Demand | - 2.63 L/s  |
| Max Day Demand     | - 6.55 L/s  |
| Peak Hour Demand   | - 14.41 L/s |

Fire Flow Requirement per OBC were used for the apartment building - 150 L/s (9,000 L/min)



Thank you.

**Shika Rathnasooriya**, P.Eng.

Direct: 613 724-4081  
[Thakshika.Rathnasooriya@stantec.com](mailto:Thakshika.Rathnasooriya@stantec.com)

Stantec  
400 - 1331 Clyde Avenue  
Ottawa ON K2C 3G4



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

## **A.6 ARCHITECT CONFIRMATIONS**

## Johnson, Warren

---

**From:** Robert Matthews <robertm@n45.ca>  
**Sent:** Friday, February 17, 2023 2:20 PM  
**To:** Shahzadeh, Serene; Yin, David; Holmes, Keith; Johnson, Warren; Cody, Neal  
**Cc:** Barbieri, Sam; Ghajar, Sonia; Meloshe, Nancy  
**Subject:** RE: 1560 Scott - Resubmission Comments

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Serene,

In respect to your letter and item nos. 9 & 10, we respond as follows:-

### Item 9

On the Ground Floor attached, the RED line is the fire separation.

### Item 10

- The building construction will be non-combustible – concrete.
- Unsupervised sprinklers conforming to NFPA 13 will be provided, the design will be designed by a professional mechanical engineer.
- The floors will be designed as 2hr fire separations as per FUS guidelines.
- The building envelope will be designed at a minimum as a 1hr fire separation. This includes walls, decorative elements, structure, and floors, all as per FUS guidelines.
- The fire hazard of the building contents will conform to FUS guidelines.
- The gross floor area of the largest floor is +/- 970m<sup>2</sup>.

Robert Matthews  
Partner  
N45 ARCHITECTURE Inc.

**I will be out of the office from Tuesday, 21 February, returning on Monday, 13 March.**

**N45 ARCHITECTURE Inc.**

The Sovereign Building  
71 Bank St., 7<sup>th</sup> Floor  
Ottawa, ON.  
K1P 5N2  
O 613-224-0095 x 234  
C 613-858-2789

---

**From:** Shahzadeh, Serene <Serene.Shahzadeh@stantec.com>  
**Sent:** Monday, January 30, 2023 2:35 PM  
**To:** Robert Matthews <robertm@n45.ca>; Yin, David <david.yin@stantec.com>; Holmes, Keith <Keith\_Holmes@golder.com>; Johnson, Warren <Warren.Johnson@stantec.com>; Cody, Neal <Neal.Cody@stantec.com>  
**Cc:** Barbieri, Sam <Sam.Barbieri@lasalle.com>; Ghajar, Sonia <Sonia.Ghajar@lasalle.com>; Meloshe, Nancy <Nancy.Meloshe@stantec.com>  
**Subject:** 1560 Scott - Resubmission Comments

Good afternoon all,

We have received the resubmission comments for the Site Plan Control application on 1560 Scott Street. I have attached the draft response letter for your reference, flagging which comments are to be addressed by whom.

Please have the updates and comments addressed by February 17. Let me know if you have any questions, or if there is anything you need to address the comments.

Thanks,

**Serene Shahzadeh**

Planner

[Serene.Shahzadeh@stantec.com](mailto:Serene.Shahzadeh@stantec.com)

Stantec  
300 - 1331 Clyde Avenue  
Ottawa ON K2C 3G4




**5th most sustainable corporation in the world, 1st in North America: Proud to be named a Corporate Knights world sustainability leader.**

The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

**Caution:** This email originated from outside of Stantec. Please take extra precaution.

**Attention:** Ce courriel provient de l'extérieur de Stantec. Veuillez prendre des précautions supplémentaires.

**Atención:** Este correo electrónico proviene de fuera de Stantec. Por favor, tome precauciones adicionales.



**1** GROUND FLOOR PLAN  
SCALE 1:150

| no. | revision                         | date          |
|-----|----------------------------------|---------------|
| 4   | RE-ISSUE FOR SITE PLAN APP.      | 11 Oct. 2022  |
| 3   | ISSUED FOR SITE PLAN APPLICATION | 14 Jan. 2022  |
| 2   | REISSUED FOR ZONING AMENDMENT    | 17 Sept. 2021 |
| 1   | ISSUED FOR ZONING AMENDMENT      | 30 July 2020  |

**N45 ARCHITECTURE INC.**  
71 Bank Street, 7th Floor - Ottawa, Ontario, K1P 5N2  
tel. 613.224.0095 fax 613.224.9811

project  
**HOLLAND CROSS  
PHASE 3 RESIDENTIAL**

HOLLAND AVE, OTTAWA, ON.

|                    |      |
|--------------------|------|
| construction north | seal |
|                    |      |

|   |                                |
|---|--------------------------------|
| drawing title<br><b>GROUND FLOOR PLAN</b>   |                                |
| scale<br>AS SHOWN   | drawn by<br>J. J.              |
| date<br>MAY 2020  | checked by<br>R.M.             |
| project number<br><b>20-540</b>   | drawing number<br><b>A-101</b> |
| CONTRACTOR TO VERIFY ALL DIMENSIONS AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES BEFORE WORK COMMENCES. DO NOT SCALE DRAWINGS. |                                |
| revision  |                                |



Appendix B Wastewater Servicing  
April 20, 2023

## **Appendix B WASTEWATER SERVICING**

### **B.1 SANITARY SEWER DESIGN SHEET**



SUBDIVISION:  
**HOLLAND CROSS**

DATE: 2023-02-24  
REVISION: 3  
DESIGNED BY: WAJ  
CHECKED BY:

**SANITARY SEWER  
DESIGN SHEET**  
(City of Ottawa)

FILE NUMBER: 160410274


| DESIGN PARAMETERS            |          |                           |                 |
|------------------------------|----------|---------------------------|-----------------|
| MAX PEAK FACTOR (RES.)=      | 4.0      | AVG. DAILY FLOW / PERSON  | 280 L/p/day     |
| MIN PEAK FACTOR (RES.)=      | 2.0      | COMMERCIAL                | 28,000 L/ha/day |
| PEAKING FACTOR (INDUSTRIAL): | 2.4      | INDUSTRIAL (HEAVY)        | 55,000 L/ha/day |
| PEAKING FACTOR (ICI >20%):   | 1.5      | INDUSTRIAL (LIGHT)        | 35,000 L/ha/day |
| PERSONS / STUDIO             | 1.4      | INSTITUTIONAL             | 28,000 L/ha/day |
| PERSONS / 1 BEDROOM          | 1.4      | INFILTRATION              | 0.33 L/s/ha     |
| PERSONS / 1 BEDROOM + DEN    | 2.1      | PERSONS / 2 BEDROOM + DEN | 3.1             |
| PERSONS / 2 BEDROOM          | 2.1      | PERSONS / GUEST           | 1.4             |
| MINIMUM VELOCITY             | 0.60 m/s |                           |                 |
| MAXIMUM VELOCITY             | 3.00 m/s |                           |                 |
| MANNINGS n                   | 0.013    |                           |                 |
| BEDDING CLASS                | B        |                           |                 |
| MINIMUM COVER                | 2.50 m   |                           |                 |
| HARMON CORRECTION FACTOR     | 0.8      |                           |                 |

| LOCATION       |           |         | RESIDENTIAL AREA AND POPULATION |        |           |                 |           |                 |       |      |                      |                 | COMMERCIAL |                 | INDUSTRIAL (L) |                 | INDUSTRIAL (H) |                 | INSTITUTIONAL |                 | GREEN / UNUSED |                 | C+i+l           | INFILTRATION    |                 |                    | TOTAL            | PIPE       |          |          |       |           |                   |      |
|----------------|-----------|---------|---------------------------------|--------|-----------|-----------------|-----------|-----------------|-------|------|----------------------|-----------------|------------|-----------------|----------------|-----------------|----------------|-----------------|---------------|-----------------|----------------|-----------------|-----------------|-----------------|-----------------|--------------------|------------------|------------|----------|----------|-------|-----------|-------------------|------|
| AREA ID NUMBER | FROM M.H. | TO M.H. | AREA (ha)                       | STUDIO | 1 BEDROOM | 1 BEDROOM + DEN | 2 BEDROOM | 2 BEDROOM + DEN | GUEST | POP. | CUMULATIVE AREA (ha) | CUMULATIVE POP. | PEAK FACT. | PEAK FLOW (L/s) | AREA (ha)      | ACCU. AREA (ha) | AREA (ha)      | ACCU. AREA (ha) | AREA (ha)     | ACCU. AREA (ha) | AREA (ha)      | ACCU. AREA (ha) | PEAK FLOW (L/s) | TOTAL AREA (ha) | ACCU. AREA (ha) | INFILT. FLOW (L/s) | TOTAL FLOW (L/s) | LENGTH (m) | DIA (mm) | MATERIAL | CLASS | SLOPE (%) | CAP. (FULL) (l/s) |      |
| SITE           | BLDG      | SAN 2   | 0.360                           | 18     | 110       | 51              | 101       | 0               | 1     | 500  | 0.360                | 500             | 3.97       | 6.44            | 0.0054         | 0.005           | 0.000          | 0.000           | 0.000         | 0.000           | 0.000          | 0.000           | 0.000           | 0.000           | 0.365           | 0.365              | 0.12             | 6.56       | 4.7      | 250      | PVC   | SDR 35    | 1.00              | 60.6 |
|                | SAN 2     | SAN 1   | 0.000                           | 0      | 0         | 0               | 0         | 0               | 0     | 0    | 0.360                | 500             | 3.97       | 6.44            | 0.0000         | 0.005           | 0.000          | 0.000           | 0.000         | 0.000           | 0.000          | 0.000           | 0.000           | 0.000           | 0.000           | 0.365              | 0.12             | 6.56       | 11.1     | 250      | PVC   | SDR 35    | 1.00              | 60.6 |
|                |           |         |                                 |        |           |                 |           |                 |       |      |                      |                 |            |                 |                |                 |                |                 |               |                 |                |                 |                 |                 |                 |                    | 250              |            |          |          |       |           |                   |      |

| CAP. V<br>PEAK FLOW<br>(%) | VEL.<br>(FULL)<br>(m/s) | VEL.<br>(ACT.)<br>(m/s) |
|----------------------------|-------------------------|-------------------------|
| 10.82%                     | 1.22                    | 0.67                    |
| 10.82%                     | 1.22                    | 0.67                    |

## **Appendix C** **STORMWATER MANAGEMENT**

### **C.1 STORM SEWER DESIGN SHEET**

|   |                      |            |   |                          |                           |                            |                        |                      |                      |                       |                        |                           |  |                           |                        |                            |                         |                             |                          |                       |                                |                                |                                 |                                  |                               |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |
|---|----------------------|------------|---|--------------------------|---------------------------|----------------------------|------------------------|----------------------|----------------------|-----------------------|------------------------|---------------------------|--|---------------------------|------------------------|----------------------------|-------------------------|-----------------------------|--------------------------|-----------------------|--------------------------------|--------------------------------|---------------------------------|----------------------------------|-------------------------------|-----------------|---------------------------|---------------|--------------------|------------------------|----------------------|-----------------|--------------|--------------|---------------------------|---------------|-------------------------|------------------------|--------------------------|--|--|--|--|--|--|--|--|
|  | <b>HOLLAND CROSS</b> |            | <b>STORM SEWER DESIGN SHEET</b><br>(City of Ottawa) |                          |                           |                            |                        |                      |                      |                       |                        |                           | <b>DESIGN PARAMETERS</b><br>$I = a / (t+b)^c$ (As per City of Ottawa Guidelines, 2012) |                           |                        |                            |                         |                             |                          |                       |                                |                                |                                 |                                  |                               |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |
|   | DATE: 2022-01-19     |            | <b>FILE NUMBER: 160410274</b>                       |                          |                           |                            |                        |                      |                      |                       |                        |                           | a = 732.951  | 998.071                   | 1174.184               | 1735.688                   | MANNING'S n = 0.013     | BEDDING CLASS B             |                          |                       |                                |                                |                                 |                                  |                               |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |
|   | REVISION: 2          |            |   |                          |                           |                            |                        |                      |                      |                       |                        |                           | b = 6.199  | 6.053                     | 6.014                  | 6.014                      | MINIMUM COVER: 2.00 m   |                             |                          |                       |                                |                                |                                 |                                  |                               |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |
|   | DESIGNED BY: WAJ     |            |   |                          |                           |                            |                        |                      |                      |                       |                        |                           | c = 0.810  | 0.814                     | 0.816                  | 0.820                      | TIME OF ENTRY 10 min    |                             |                          |                       |                                |                                |                                 |                                  |                               |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |
| <b>LOCATION</b>   |                      |            | <b>DRAINAGE AREA</b>                                |                          |                           |                            |                        |                      |                      |                       |                        |                           |  |                           |                        |                            |                         |                             |                          | <b>PIPE SELECTION</b> |                                |                                |                                 |                                  |                               |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |
| AREA ID<br>NUMBER   | FROM<br>M.H.         | TO<br>M.H. | AREA<br>(2-YEAR)<br>(ha)                            | AREA<br>(5-YEAR)<br>(ha) | AREA<br>(10-YEAR)<br>(ha) | AREA<br>(100-YEAR)<br>(ha) | AREA<br>(ROOF)<br>(ha) | C<br>(2-YEAR)<br>(-) | C<br>(5-YEAR)<br>(-) | C<br>(10-YEAR)<br>(-) | C<br>(100-YEAR)<br>(-) | A x C<br>(2-YEAR)<br>(ha) | ACCUM<br>(2YR)<br>(ha)   | A x C<br>(5-YEAR)<br>(ha) | ACCUM<br>(5YR)<br>(ha) | A x C<br>(10-YEAR)<br>(ha) | ACCUM<br>(10YR)<br>(ha) | A x C<br>(100-YEAR)<br>(ha) | ACCUM<br>(100YR)<br>(ha) | T of C<br>(min)       | I <sub>2</sub> -YEAR<br>(mm/h) | I <sub>5</sub> -YEAR<br>(mm/h) | I <sub>10</sub> -YEAR<br>(mm/h) | I <sub>100</sub> -YEAR<br>(mm/h) | Q <sub>CONTROL</sub><br>(L/s) | ACCUM.<br>(L/s) | Q <sub>ACT</sub><br>(L/s) | LENGTH<br>(m) | PIPE WIDTH<br>(mm) | PIPE<br>HEIGHT<br>(mm) | PIPE<br>SHAPE<br>(-) | MATERIAL<br>(-) | CLASS<br>(-) | SLOPE<br>(%) | Q <sub>CAP</sub><br>(L/s) | % FULL<br>(-) | VEL.<br>(FULL)<br>(m/s) | VEL.<br>(ACT)<br>(m/s) | TIME OF<br>FLOW<br>(min) |  |  |  |  |  |  |  |  |
| BLDG, L101A   | BLDG                 | MAIN       | 0.100   | 0.00                     | 0.00                      | 0.00                       | 0.13                   | 0.90                 | 0.00                 | 0.00                  | 0.00                   | 0.090                     | 0.090  | 0.000                     | 0.000                  | 0.000                      | 0.000                   | 0.000                       | 0.000                    | 10.00                 | 76.81                          | 104.19                         | 122.14                          | 178.56                           | 9.5                           | 9.5             | 28.7                      | 14.0          | 200                | 200                    | CIRCULAR             | PVC             | SDR 28       | 1.00         | 33.3                      | 86.0%         | 1.05                    | 1.05                   | 0.22                     |  |  |  |  |  |  |  |  |
|   |                      |            |   |                          |                           |                            |                        |                      |                      |                       |                        |                           |  |                           |                        |                            |                         |                             |                          |                       | 10.22                          |                                | 200                             |                                  | 200                           |                 |                           |               |                    |                        |                      |                 |              |              |                           |               |                         |                        |                          |  |  |  |  |  |  |  |  |

## **C.2 RATIONAL METHOD CALCULATIONS**

## Stormwater Management Calculations

File No: 160410274  
 Project: Holland Cross  
 Date: 19-Jan-22

SWM Approach:  
 Post-development to Pre-development flows

**Post-Development Site Conditions:**

**Overall Runoff Coefficient for Site and Sub-Catchment Areas**

| Runoff Coefficient Table              |                    |      |  |               |                        |       |         |              |                            |
|---------------------------------------|--------------------|------|--|---------------|------------------------|-------|---------|--------------|----------------------------|
| Catchment Type                        | Sub-catchment Area |      |  | Area (ha) "A" | Runoff Coefficient "C" |       | "A x C" |              | Overall Runoff Coefficient |
|                                       | ID / Description   |      |  |               |                        |       |         |              |                            |
| Controlled - Tributary                | L101A              | Hard |  | 0.100         | 0.9                    | 0.090 |         |              |                            |
|                                       |                    | Soft |  | 0.000         | 0.2                    | 0.000 |         |              |                            |
|                                       | Subtotal           |      |  |               | 0.1                    |       | 0.09    |              | 0.900                      |
| Uncontrolled - Non-Tributary          | UNC-1              | Hard |  | 0.039         | 0.9                    | 0.035 |         |              |                            |
|                                       |                    | Soft |  | 0.011         | 0.2                    | 0.002 |         |              |                            |
|                                       | Subtotal           |      |  |               | 0.05                   |       | 0.0375  |              | 0.750                      |
| Roof                                  | BLDG               | Hard |  | 0.130         | 0.9                    | 0.117 |         |              |                            |
|                                       |                    | Soft |  | 0.000         | 0.2                    | 0.000 |         |              |                            |
|                                       | Subtotal           |      |  |               | 0.13                   |       | 0.117   |              | 0.900                      |
| <b>Total</b>                          |                    |      |  |               |                        |       |         | <b>0.280</b> | <b>0.245</b>               |
| <b>Overall Runoff Coefficient= C:</b> |                    |      |  |               |                        |       |         |              | <b>0.87</b>                |

|   |              |
|---|--------------|
| Total Roof Areas  | 0.130 ha     |
| Total Tributary Surface Areas (Controlled and Uncontrolled) | 0.100 ha     |
| Total Tributary Area to Outlet                              | 0.230 ha     |
| <br>Total Uncontrolled Areas (Non-Tributary)                | <br>0.050 ha |
| <br>Total Site  | <br>0.280 ha |

**Roof Drain Design Calculation Sheet**

**Project #160410274, Holland Cross  
Roof Drain Design Sheet, Area BLDG  
Standard Watts Model R1100 Accutrol Roof Drain**

| Rating Curve  |                         |                           |                 | Volume Estimation |              |                |             | Water Depth (m) |
|---------------|-------------------------|---------------------------|-----------------|-------------------|--------------|----------------|-------------|-----------------|
| Elevation (m) | Discharge Rate (cu.m/s) | Outlet Discharge (cu.m/s) | Storage (cu. m) | Elevation (m)     | Area (sq. m) | Volume (cu. m) |             |                 |
|               |                         |                           |                 |                   |              | Increment      | Accumulated |                 |
| 0.000         | 0.0000                  | 0.0000                    | 0               | 0.000             | 0            | 0              | 0           | 0.000           |
| 0.025         | 0.0003                  | 0.0047                    | 0               | 0.025             | 29           | 0              | 0           | 0.025           |
| 0.050         | 0.0006                  | 0.0095                    | 2               | 0.050             | 116          | 2              | 2           | 0.050           |
| 0.075         | 0.0006                  | 0.0095                    | 7               | 0.075             | 260          | 5              | 7           | 0.075           |
| 0.100         | 0.0006                  | 0.0095                    | 15              | 0.100             | 462          | 9              | 15          | 0.100           |
| 0.125         | 0.0006                  | 0.0095                    | 30              | 0.125             | 722          | 15             | 30          | 0.125           |
| 0.150         | 0.0006                  | 0.0095                    | 52              | 0.150             | 1040         | 22             | 52          | 0.150           |

| Drawdown Estimate   |                  |            |                     |
|---------------------|------------------|------------|---------------------|
| Total Volume (cu.m) | Total Time (sec) | Vol (cu.m) | Detention Time (hr) |
| 0.0                 | 0.0              | 0.0        | 0                   |
| 1.7                 | 178.1            | 1.7        | 0.04946             |
| 6.3                 | 483.3            | 4.6        | 0.18372             |
| 15.2                | 941.2            | 8.9        | 0.44518             |
| 29.9                | 1551.8           | 14.7       | 0.87622             |
| 51.8                | 2314.9           | 21.9       | 1.51926             |

**Roof Storage Summary**

|  |      |   |
|--|------|---|
| Total Building Area (sq.m)               | 1300 |   |
| Assume Available Roof Area (sq. m)       | 80%  | 1040  |
| Roof Imperviousness                      |      | 0.99  |
| Roof Drain Requirement (sq.m/Notch)      |      | 232   |
| *** Number of Roof Notches*              |      | 15  |
| Max. Allowable Depth of Roof Ponding (m) | 0.15 | * As per Ontario Building Code section OBC 7.4.10.4.(2)(c). |
| Max. Allowable Storage (cu.m)            |      | 52  |
| Estimated 100 Year Drawdown Time (h)     |      | 1.3   |

**From Watts Drain Catalogue**

|          |        |        |        |                      |
|----------|--------|--------|--------|----------------------|
| Head (m) | L/s    |        |        |                      |
| Open     | 0.75   | 0.5    | 0.25   | <b>Closed</b>        |
| 0.025    | 0.3155 | 0.3155 | 0.3155 | 0.3155 <b>0.3155</b> |
| 0.05     | 0.6309 | 0.6309 | 0.6309 | 0.6309 <b>0.6309</b> |
| 0.075    | 0.9464 | 0.8675 | 0.7886 | 0.7098 <b>0.6309</b> |
| 0.1      | 1.2618 | 1.1041 | 0.9464 | 0.7886 <b>0.6309</b> |
| 0.125    | 1.5773 | 1.3407 | 1.1041 | 0.8675 <b>0.6309</b> |
| 0.15     | 1.8927 | 1.5773 | 1.2618 | 0.9464 <b>0.6309</b> |

\* Note: Number of drains can be reduced if multiple-notch drain used.

**Calculation Results**

|                  | 2yr   | 100yr | Available |
|------------------|-------|-------|-----------|
| Qresult (cu.m/s) | 0.009 | 0.009 | -         |
| Depth (m)        | 0.083 | 0.139 | 0.150     |
| Volume (cu.m)    | 9.3   | 42.7  | 52.0      |
| Drain time (hrs) | 0.3   | 1.3   |           |



# Stormwater Management Calculations

## Project #160410274, Holland Cross Modified Rational Method Calculators for Storage

|                                  |                 |             |         |           |
|----------------------------------|-----------------|-------------|---------|-----------|
| 2 yr Intensity<br>City of Ottawa | $I = a/(t + b)$ | a = 732.951 | t (min) | I (mm/hr) |
|                                  |                 | b = 6.199   | 10      | 76.81     |
|                                  |                 | c = 0.81    | 20      | 52.03     |
|                                  |                 |             | 30      | 40.04     |
|                                  |                 |             | 40      | 32.86     |
|                                  |                 |             | 50      | 28.04     |
|                                  |                 |             | 60      | 24.56     |
|                                  |                 |             | 70      | 21.91     |
|                                  |                 |             | 80      | 19.83     |
|                                  |                 |             | 90      | 18.14     |
|                                  |                 |             | 100     | 16.75     |
|                                  |                 |             | 110     | 15.57     |
|                                  |                 |             | 120     | 14.56     |

### 2 YEAR Predevelopment Target Release from Portion of Site

Subdrainage Area: Predevelopment Tributary Area to Outlet  
 Area (ha): 0.2800  
 C: 0.86

Typical Time of Concentration

| tc (min) | I (2 yr) (mm/hr) | Qtarget (L/s) |
|----------|------------------|---------------|
| 10       | 76.81            | 51.46         |

### 2 YEAR Modified Rational Method for Entire Site

Subdrainage Area: L101A Controlled - Tributary  
 Area (ha): 0.10  
 C: 0.90

| tc (min) | I (2 yr) (mm/hr) | Qactual (L/s) | Qrelease (L/s) | Qstored (L/s) | Vstored (m³) |
|----------|------------------|---------------|----------------|---------------|--------------|
| 10       | 76.81            | 19.22         | 18.77          | 0.45          | 0.27         |
| 20       | 52.03            | 13.02         | 18.77          | 0.00          | 0.00         |
| 30       | 40.04            | 10.02         | 18.77          | 0.00          | 0.00         |
| 40       | 32.86            | 8.22          | 18.77          | 0.00          | 0.00         |
| 50       | 28.04            | 7.02          | 18.77          | 0.00          | 0.00         |
| 60       | 24.56            | 6.14          | 18.77          | 0.00          | 0.00         |
| 70       | 21.91            | 5.48          | 18.77          | 0.00          | 0.00         |
| 80       | 19.83            | 4.96          | 18.77          | 0.00          | 0.00         |
| 90       | 18.14            | 4.54          | 18.77          | 0.00          | 0.00         |
| 100      | 16.75            | 4.19          | 18.77          | 0.00          | 0.00         |
| 110      | 15.57            | 3.90          | 18.77          | 0.00          | 0.00         |
| 120      | 14.56            | 3.64          | 18.77          | 0.00          | 0.00         |

Storage: Above CB

Orifice Equation:  $Q = CdA(2gh)^{0.5}$  Where C = 0.61  
 Orifice Diameter: 133.00 mm  
 Invert Elevation: 62.53 m  
 T/G Elevation: 62.71 m  
 Max Ponding Depth: 0.07 m  
 Downstream W/L: 58.20 m

| Stage              | Head (m) | Discharge (L/s) | Vreq (cu. m) | Vavail (cu. m) | Volume Check |
|--------------------|----------|-----------------|--------------|----------------|--------------|
| 2-year Water Level | 62.78    | 0.25            | 18.77        | 0.27           | 19.00 OK     |

Subdrainage Area: UNC-1 Uncontrolled - Non-Tributary  
 Area (ha): 0.05  
 C: 0.75

| tc (min) | I (2 yr) (mm/hr) | Qactual (L/s) | Qrelease (L/s) | Qstored (L/s) | Vstored (m³) |
|----------|------------------|---------------|----------------|---------------|--------------|
| 10       | 76.81            | 8.01          | 8.01           |               |              |
| 20       | 52.03            | 5.42          | 5.42           |               |              |
| 30       | 40.04            | 4.17          | 4.17           |               |              |
| 40       | 32.86            | 3.43          | 3.43           |               |              |
| 50       | 28.04            | 2.92          | 2.92           |               |              |
| 60       | 24.56            | 2.56          | 2.56           |               |              |
| 70       | 21.91            | 2.28          | 2.28           |               |              |
| 80       | 19.83            | 2.07          | 2.07           |               |              |
| 90       | 18.14            | 1.89          | 1.89           |               |              |
| 100      | 16.75            | 1.75          | 1.75           |               |              |
| 110      | 15.57            | 1.62          | 1.62           |               |              |
| 120      | 14.56            | 1.52          | 1.52           |               |              |

Subdrainage Area: BLDG Roof Maximum Storage Depth: 150 mm  
 Area (ha): 0.13  
 C: 0.90

| tc (min) | I (2 yr) (mm/hr) | Qactual (L/s) | Qrelease (L/s) | Qstored (L/s) | Vstored (m³) | Depth (mm) |
|----------|------------------|---------------|----------------|---------------|--------------|------------|
| 10       | 76.81            | 24.98         | 9.46           | 15.52         | 9.31         | 82.9       |
| 20       | 52.03            | 16.92         | 9.46           | 7.46          | 8.95         | 81.9       |
| 30       | 40.04            | 13.02         | 9.46           | 3.56          | 6.41         | 74.5       |
| 40       | 32.86            | 10.69         | 9.46           | 1.23          | 2.94         | 55.6       |
| 50       | 28.04            | 9.12          | 8.58           | 0.54          | 1.61         | 45.3       |
| 60       | 24.56            | 7.99          | 7.63           | 0.35          | 1.27         | 40.3       |
| 70       | 21.91            | 7.13          | 6.89           | 0.24          | 1.01         | 36.4       |
| 80       | 19.83            | 6.45          | 6.28           | 0.17          | 0.79         | 33.2       |
| 90       | 18.14            | 5.90          | 5.79           | 0.11          | 0.62         | 30.6       |
| 100      | 16.75            | 5.45          | 5.37           | 0.08          | 0.47         | 28.4       |
| 110      | 15.57            | 5.06          | 5.01           | 0.05          | 0.34         | 26.5       |
| 120      | 14.56            | 4.74          | 4.70           | 0.03          | 0.24         | 24.8       |

Storage: Roof Storage

| Depth (mm)         | Head (m) | Discharge (L/s) | Vreq (cu. m) | Vavail (cu. m) | Discharge Check |
|--------------------|----------|-----------------|--------------|----------------|-----------------|
| 2-year Water Level | 82.89    | 0.08            | 9.46         | 9.31           | 52.00 0.00      |

## Project #160410274, Holland Cross Modified Rational Method Calculators for Storage

|                                    |                 |              |         |           |
|------------------------------------|-----------------|--------------|---------|-----------|
| 100 yr Intensity<br>City of Ottawa | $I = a/(t + b)$ | a = 1735.688 | t (min) | I (mm/hr) |
|                                    |                 | b = 6.014    | 10      | 178.56    |
|                                    |                 | c = 0.820    | 20      | 119.95    |
|                                    |                 |              | 30      | 91.87     |
|                                    |                 |              | 40      | 75.15     |
|                                    |                 |              | 50      | 63.95     |
|                                    |                 |              | 60      | 55.89     |
|                                    |                 |              | 70      | 49.79     |
|                                    |                 |              | 80      | 44.99     |
|                                    |                 |              | 90      | 41.11     |
|                                    |                 |              | 100     | 37.90     |
|                                    |                 |              | 110     | 35.20     |
|                                    |                 |              | 120     | 32.89     |

### 100 YEAR Predevelopment Target Release from Portion of Site

Subdrainage Area: Predevelopment Tributary Area to Outlet  
 Area (ha): 0.2800  
 C: 0.86

### 100 YEAR Modified Rational Method for Entire Site

Subdrainage Area: L101A Controlled - Tributary  
 Area (ha): 0.10  
 C: 1.00

| tc (min) | I (100 yr) (mm/hr) | Qactual (L/s) | Qrelease (L/s) | Qstored (L/s) | Vstored (m³) |
|----------|--------------------|---------------|----------------|---------------|--------------|
| 10       | 178.56             | 49.64         | 18.77          | 30.87         | 18.52        |
| 20       | 119.95             | 33.35         | 18.77          | 14.58         | 17.49        |
| 30       | 91.87              | 25.54         | 18.77          | 6.77          | 12.19        |
| 40       | 75.15              | 20.89         | 18.77          | 2.12          | 5.09         |
| 50       | 63.95              | 17.78         | 18.77          | 0.00          | 0.00         |
| 60       | 55.89              | 15.54         | 18.77          | 0.00          | 0.00         |
| 70       | 49.79              | 13.84         | 18.77          | 0.00          | 0.00         |
| 80       | 44.99              | 12.51         | 18.77          | 0.00          | 0.00         |
| 90       | 41.11              | 11.43         | 18.77          | 0.00          | 0.00         |
| 100      | 37.90              | 10.54         | 18.77          | 0.00          | 0.00         |
| 110      | 35.20              | 9.79          | 18.77          | 0.00          | 0.00         |
| 120      | 32.89              | 9.14          | 18.77          | 0.00          | 0.00         |

Storage: Surface Storage Above CB

Orifice Equation:  $Q = CdA(2gh)^{0.5}$  Where C = 0.61  
 Orifice Diameter: 133.00 mm  
 Invert Elevation: 62.53 m  
 T/G Elevation: 62.71 m  
 Max Ponding Depth: 0.07 m  
 Downstream W/L: 58.20 m

| Stage                | Head (m) | Discharge (L/s) | Vreq (cu. m) | Vavail (cu. m) | Volume Check |
|----------------------|----------|-----------------|--------------|----------------|--------------|
| 100-year Water Level | 62.78    | 0.25            | 18.77        | 18.52          | 19.00 OK     |

Subdrainage Area: UNC-1 Uncontrolled - Non-Tributary  
 Area (ha): 0.05  
 C: 0.94

| tc (min) | I (100 yr) (mm/hr) | Qactual (L/s) | Qrelease (L/s) | Qstored (L/s) | Vstored (m³) |
|----------|--------------------|---------------|----------------|---------------|--------------|
| 10       | 178.56             | 23.27         | 23.27          |               |              |
| 20       | 119.95             | 15.63         | 15.63          |               |              |
| 30       | 91.87              | 11.97         | 11.97          |               |              |
| 40       | 75.15              | 9.79          | 9.79           |               |              |
| 50       | 63.95              | 8.33          | 8.33           |               |              |
| 60       | 55.89              | 7.28          | 7.28           |               |              |
| 70       | 49.79              | 6.49          | 6.49           |               |              |
| 80       | 44.99              | 5.86          | 5.86           |               |              |
| 90       | 41.11              | 5.36          | 5.36           |               |              |
| 100      | 37.90              | 4.94          | 4.94           |               |              |
| 110      | 35.20              | 4.59          | 4.59           |               |              |
| 120      | 32.89              | 4.29          | 4.29           |               |              |

Subdrainage Area: BLDG Roof Maximum Storage Depth: 150 mm  
 Area (ha): 0.13  
 C: 1.00

| tc (min) | I (100 yr) (mm/hr) | Qactual (L/s) | Qrelease (L/s) | Qstored (L/s) | Vstored (m³) | Depth (mm) |
|----------|--------------------|---------------|----------------|---------------|--------------|------------|
| 10       | 178.56             | 64.53         | 9.46           | 55.07         | 33.04        | 128.4      |
| 20       | 119.95             | 43.35         | 9.46           | 33.89         | 40.66        | 137.1      |
| 30       | 91.87              | 33.20         | 9.46           | 23.74         | 42.73        | 139.4      |
| 40       | 75.15              | 27.16         | 9.46           | 17.69         | 42.47        | 139.1      |
| 50       | 63.95              | 23.11         | 9.46           | 13.65         | 40.95        | 137.4      |
| 60       | 55.89              | 20.20         | 9.46           | 10.74         | 38.65        | 134.8      |
| 70       | 49.79              | 17.99         | 9.46           | 8.53          | 35.83        | 131.5      |
| 80       | 44.99              | 16.26         | 9.46           | 6.80          | 32.62        | 127.9      |
| 90       | 41.11              | 14.86         | 9.46           | 5.39          | 29.13        | 123.4      |
| 100      | 37.90              | 13.70         | 9.46           | 4.23          | 25.41        | 117.0      |
| 110      | 35.20              | 12.72         | 9.46           | 3.26          | 21.51        | 110.4      |
| 120      | 32.89              | 11.89         | 9.46           | 2.42          | 17.46        | 103.5      |

Storage: Roof Storage

| Depth (mm)           | Head (m) | Discharge (L/s) | Vreq (cu. m) | Vavail (cu. m) | Discharge Check |
|----------------------|----------|-----------------|--------------|----------------|-----------------|
| 100-year Water Level | 139.42   | 0.14            | 9.46         | 42.73          | 52.00 0.00      |

## Stormwater Management Calculations

**Project #160410274, Holland Cross**  
**Modified Rational Method Calculatons for Storage**

| SUMMARY TO OUTLET           |          |           |                   |    |
|-----------------------------|----------|-----------|-------------------|----|
|                             |          | Vrequired | Vavailable*       |    |
| Tributary Area              | 0.230 ha |           |                   |    |
| Total 2yr Flow to Sewer     | 28.2 L/s | 10        | 71 m <sup>3</sup> | Ok |
| Non-Tributary Area          | 0.050 ha |           |                   |    |
| Total 2yr Flow Uncontrolled | 8.0 L/s  |           |                   |    |
| Total Area                  | 0.280 ha |           |                   |    |
| Total 2yr Flow              | 36.2 L/s |           |                   |    |
| Target                      | 51.5 L/s |           |                   |    |

**Project #160410274, Holland Cross**  
**Modified Rational Method Calculatons for Storage**

| SUMMARY TO OUTLET             |          |           |                   |    |
|-------------------------------|----------|-----------|-------------------|----|
|                               |          | Vrequired | Vavailable*       |    |
| Tributary Area                | 0.230 ha |           |                   |    |
| Total 100yr Flow to Sewer     | 28.2 L/s | 61        | 71 m <sup>3</sup> | Ok |
| Non-Tributary Area            | 0.050 ha |           |                   |    |
| Total 100yr Flow Uncontrolled | 23.3 L/s |           |                   |    |
| Total Area                    | 0.280 ha |           |                   |    |
| Total 100yr Flow              | 51.5 L/s |           |                   |    |
| Target                        | 51.5 L/s |           |                   |    |

## **Appendix D**      **DESIGN CRITERIA AND REPORT EXCERPTS**

### **D.1**      **2013 HOLLAND CROSS EXPANSION SWM REPORT EXCERPTS**

## Engineering

Land / Site  
Development  
Municipal  
Infrastructure  
Environmental /  
Water Resources  
Traffic/  
Transportation  
Structural  
Recreational

## Planning

Land/Site  
Development  
Planning  
Application  
Management  
Municipal  
Planning  
Documents &  
Studies  
Expert Witness  
(OMB)  
Wireless Industry

## Landscape Architecture

Urban Design &  
Streetscapes  
Recreation & Parks  
Planning  
Environmental  
Restoration  
Sustainable Design



## HOLLAND CROSS EXPANSION CITY OF OTTAWA

## SERVICING & STORMWATER MANAGEMENT REPORT

**HOLLAND CROSS EXPANSION  
CITY OF OTTAWA**

**SERVICING & STORMWATER MANAGEMENT REPORT**

Prepared For:

**Colonnade Development Ltd.**  
16 Concourse Gate, Suite 200  
Ottawa, Ontario  
K2E 7S8

Prepared By:

**NOVATECH**  
Suite 200, 240 Michael Cowpland Drive  
Ottawa, Ontario  
K2M 1P6

December 2013  
Revised August 2014

Novatech File: 113150  
Ref: R-2013-108

August 25, 2014

City of Ottawa  
Planning and Growth Management Department  
Development Review (Urban) Services Branch  
Infrastructure Approvals Division  
110 Laurier Avenue West  
Ottawa, ON K1P 1J1

**Attention: Kristin Bazinet**

Dear Madam:

**Re: 1560 Scott Street – Holland Cross Expansion  
Servicing Design Brief  
Our File No.: 113150**

---

Please find enclosed six (6) copies of the Holland Cross Expansion – Servicing and Stormwater Management Report, dated August 2014. This report has been revised per City comments and is hereby submitted for approval.

If you have any questions, please contact the undersigned.

Yours truly,

**NOVATECH**



Cara Ruddle, P.Eng.  
Project Manager

cc: Kelly Rhodenizer, Colonnade Development Ltd.

**TABLE OF CONTENTS**

**1.0 INTRODUCTION ..... 1**

**2.0 EXISTING AND PROPOSED DEVELOPMENT..... 1**

**3.0 WATERMAIN SERVICING ..... 1**

    3.1 Domestic Water Demand ..... 1

    3.2 Fire Demand ..... 2

**4.0 SANITARY SERVICING ..... 2**

**5.0 STORM SERVICING ..... 2**

    5.1 Existing Drainage and Servicing..... 2

    5.2 Proposed Site Drainage ..... 3

    5.3 Stormwater Management ..... 3

**6.0 EROSION AND SEDIMENT CONTROL MEASURES ..... 3**

    6.1 Temporary Measures ..... 3

**7.0 CONCLUSIONS AND RECOMMENDATIONS ..... 4**

**List of Figures**

- Figure 1 Key Plan
- Figure 2 Existing Site Conditions
- Figure 3 Proposed Site Plan
- Figure 4 Existing Servicing
- Figure 5 Downstream Sanitary Drainage Areas
- Figure 6 General Plan of Grading and Servicing
- Figure 7 Erosion and Sediment Control Plan

**List of Appendices**

- Appendix A Watermain Information
- Appendix B Sanitary Sewer Information
- Appendix C Engineering Figures
- Appendix D City of Ottawa Checklist

## 1.0 INTRODUCTION

Novatech Engineering Consultants Ltd. has been retained by Colonnade Development Ltd. to prepare a Servicing and Stormwater Management Report in support of the rezoning and site plan applications. The site is located at 1560 Scott Street on the southeast corner of the intersection of Scott Street and Holland Street in the City of Ottawa. Figure 1 is a Key Plan showing the site location.

## 2.0 EXISTING AND PROPOSED DEVELOPMENT

The property is approximately 3.2 hectares in size and is currently occupied by an existing seven storey tall complex consisting of two six storey office towers on top of a 1 storey retail podium. The site is bounded by office buildings to the north (Holland Cross), residential housing to the east and west, and residential condominiums to the south. Figure 2 shows the existing conditions of the site.

It is proposed to demolish part of the existing 1 storey retail building, and to construct a 12 storey office building (approximately 18,000ft<sup>2</sup> per floor) over the existing parking garage. Therefore, the building footprint will remain the same. Underground parking is already provided as part of the previous development. Refer to Figure 3 – Proposed Site Plan for details.

## 3.0 WATERMAIN SERVICING

The existing building complex is serviced by two 150mm diameter water services from Holland Ave and Bullman St, and one 50mm diameter water service from Scott Street. These existing water services connect to the municipal water system surrounding the existing development. The internal building water system will be extended to service the proposed development. Refer to Figure 4 – Existing Services for details on the existing water system.

Hydraulic boundary conditions were provided by the City of Ottawa and are as follows:

Minimum HGL = 107.4m  
Maximum HGL = 115.8m  
Max Day + FF = 77.5m


### 3.1 Domestic Water Demand

The following domestic water demands are based on the City of Ottawa Water Distribution Guidelines (Gross Site Area), and the Ontario Building Code, OBC, (Gross Floor Area). The Gross Floor Area method results in a more conservative value, which is used for this report. Refer to Appendix A for detailed calculations.

Estimated water demands for the entire complex including the proposed expansion are as follows:

$$\begin{aligned} Q_{\text{avg day}} &= (47,409\text{m}^2 / 9.3 \text{ m}^2/\text{pers}) \times 75\text{L}/\text{pers}/\text{day} \\ Q_{\text{avg day}} &= 382,331\text{L}/\text{day} = 4.43 \text{ L/s} \end{aligned}$$






M:\2013\113150\CAD\Design\Figures\Figure 1.dwg, Sheet Bx11 portrait, Dec 09, 2013 - 3:22pm, bthurber

**NOVATECH**  
**ENGINEERING**  
**CONSULTANTS LTD.**  
 ENGINEERS & PLANNERS  
 Suite 200, 240 Michael Cowpland Drive  
 Ottawa, Ontario, Canada  
 K2M 1P6  
 Telephone (613) 254-9643  
 Facsimile (613) 254-5867  
 Email: novainto@novatech-eng.com

1560 SCOTT STREET -  
 HOLLAND CROSS PHASE 3

KEY PLAN

DEC 2013 113150 FIGURE 1



SITE

M:\2013\113150\CAD\Design\Figures\Figure2.dwg, figure2, Dec 09, 2013 - 3:21pm, bthurber

**NOVATECH**  
**ENGINEERING**  
**CONSULTANTS LTD.**  
 ENGINEERS & PLANNERS  
 Suite 200, 240 Michael Cowpland Drive  
 Ottawa, Ontario, Canada  
 K2M 1P6  
 Telephone: (613) 254-9643  
 Facsimile: (613) 254-5867  
 Email: novainfo@novatech-eng.com

SCALE  
 1:1250  
 1:1250  
 0 10 20 30 40 50

1560 SCOTT STREET -  
 HOLLAND CROSS PHASE 3  
 EXISTING SITE  
 CONDITIONS  
 DEC 2013 113150 FIGURE 2




M:\2013\113150\CAD\Design\Figures\Figure3.dwg, Dec 09, 2013 - 3:21pm, bthurber

**NOVATECH**  
**ENGINEERING CONSULTANTS LTD.**  
 ENGINEERS & PLANNERS  
 Suite 200, 240 Michael Cowpland Drive  
 Ottawa, Ontario, Canada  
 K2M 1P6  
 Telephone (613) 254-9643  
 Facsimile (613) 254-5867  
 Email: novainfo@novatech-eng.com

SCALE  
 1:1250  
 1:1250  
 0 10 20 30 40 50


1560 SCOTT STREET -  
 HOLLAND CROSS PHASE 3  
**PROPOSED SITE PLAN**  
 DEC 2013 113150 FIGURE 3



M:\2013\113150\CAD\Design\Figures\Figure4.dwg, figure4 1 1500, Dec 09, 2013 - 3:21pm, bhuber

- LEGENDS:**
- SANITARY
  - STORMWATER
  - WATERMAIN

**NOVATECH**  
**ENGINEERING**  
**CONSULTANTS LTD.**  
 ENGINEERS & PLANNERS  
 Suite 200, 240 Michael Cowpland Drive  
 Ottawa, Ontario, Canada  
 K2M 1P6  
 Telephone (613) 254-9643  
 Facsimile (613) 254-5867  
 Email: novainfo@novatech-eng.com



**1560 SCOTT STREET -  
 HOLLAND CROSS PHASE 3**

**EXISTING SERVICING**

DEC 2013    113150    **FIGURE 4**

### **3.2 Fire Demand**

For this type of building, the existing underground parking garage is classified as "Ordinary Hazard" (Group 1), and the new office building is classified as "Light Hazard." The calculations for required fire flow are based on the existing garage; therefore there is only a marginal increase in the required fire flow for the new addition.

The required fire demand is calculated using the Fire Underwriters Survey (FUS) Guidelines. The required fire demand is calculated to be 100L/s using the FUS method. Using the National Fire Protection Association (NFPA) Standard for Sprinkler Systems the supply requirement is 41.0L/s for the sprinklers and hoses. Refer to Appendix A for detailed calculations.

According to the hydraulic boundary conditions provided by the City, the existing 200mm dia. watermain on Hamilton Street and Bullman Avenue has a hydraulic grade line of 77.5m at the maximum day demand plus a fire demand of 92.7L/s. This results in 92.7L/s of fire flow available at 22.4psi. Therefore the existing municipal watermain can provide the fire demand at a pressure greater than 20 psi.

### **4.0 SANITARY SERVICING**

The existing building is serviced by a 150mm diameter sanitary which connects to an existing 250mm diameter sanitary sewer within the Hamilton Street right-of-way. It is proposed to extend the internal plumbing to service the proposed development.

A review of the existing downstream sewer system is required to ensure there are no capacity issues. The sanitary flows from the proposed development are calculated to be 2.8L/s. Drainage areas and flows have been calculated for the downstream area and input into a sanitary sewer design sheet. There appears to be no issue with capacity in the existing sanitary sewer system due to the proposed development. Refer to Appendix B for flow calculations, the drainage area plan and sanitary sewer design sheet.

### **5.0 STORM SERVICING**

#### **5.1 Existing Drainage and Servicing**

As indicated previously, the site is currently developed with single storey building as part of an existing office and retail development. The existing building is serviced by an existing 200mm storm service that connects to a 450mm diameter storm sewer at the Hamilton Avenue / Bullman Street intersection.

Stormwater from the building areas flow into roof drains and outlets to storm services which connect to the City storm sewer system along Scott Street, Holland Avenue and Hamilton Avenue. The remaining parking area sheet drains to catchbasins which outlet to the City storm sewer system on Scott Street.

## **5.2 Proposed Site Drainage**

Stormwater from the proposed development will drain to roof drains and outlet to the existing storm service per existing conditions and continue to outlet to the existing storm sewer on Hamilton Avenue.

## **5.3 Stormwater Management**

The building footprint will not change from existing conditions. Therefore, there is no increase in storm flows from the proposed development and stormwater management is not required.

## **6.0 EROSION AND SEDIMENT CONTROL MEASURES**

### **6.1 Temporary Measures**

Temporary erosion and sediment control measures will be implemented during construction. Silt fence and filter cloth catches will be used as erosion and sediment control measures. Details are provided on Figure 7.

Filter cloth catches should be inspected daily, and after every rain event to determine maintenance, repair or replacement requirements. Sediments or granulars that enter site sewers shall be removed immediately by the contractor. These measures will be implemented prior to the commencement of construction and maintained in good order until vegetation has been established.

## 7.0 CONCLUSIONS AND RECOMMENDATIONS

The conclusions of this report are as follows:

- Water servicing, including both domestic and fire protection, can be provided by connection to the existing watermain infrastructure along Bullman Street.
- Sanitary flows for the proposed development have been calculated and there is sufficient capacity within the existing City sanitary sewer system along Bullman Street to service the development.
- Quantity and quality control of stormwater is not required, as there will be no change to the existing stormwater drainage.
- The existing overland flow route will be maintained.
- Erosion and sediment control measures will be implemented during construction.

### NOVATECH

Prepared by:



Cara Ruddle, P.Eng.  
Project Manager

Reviewed by:

A handwritten signature in blue ink, appearing to read "J. Lee Sheets".

J. Lee Sheets, CET  
Sr. Project Manager

**APPENDIX A**  
*Watermain Information*



The following are boundary conditions (provided by the City of Ottawa), HGL, for hydraulic analysis at 150 Holland Avenue assumed to be connected to the 200mm on Hamilton Street and Bullman Avenue.

Minimum HGL = 107.4m

Maximum HGL = 115.8m

Max Day + FF (92.7 L/s) = 77.5m

These are for current conditions and are based on computer model simulation.

#### Pressure Check:

Centreline of road at the intersection of Hamilton Street and Bullman Avenue = 61.7m  
(refer to the City as-built drawings)

2.31ft = 1 psi

Maximum HGL = (115.8m - 61.7m) x 3.281ft/m ÷ 2.31ft/1psi = 76.8psi

Minimum HGL = (107.4m - 61.7m) x 3.281ft/m ÷ 2.31ft/1psi = 64.9psi

- The system has adequate pressure under peak hour demand condition.

#### Fire Flow Check

Max Day + FF (92.7L/s) = (77.5m - 61.7m) x 3.281ft/m ÷ 2.31ft/1psi = 22.4psi

- The system has adequate pressure for fire flow conditions.

| <b>12 Storey New Expansion<br/>Water Demand</b> |              |                     |                   |                  |
|---|--------------|---------------------|-------------------|------------------|
| <b>Node</b>                                     | <b>Area</b>  | <b>Demand (L/s)</b> |                   |                  |
|   |              | <b>Average Day</b>  | <b>Max. Daily</b> | <b>Peak Hour</b> |
| <b>Gross Floor Area (m<sup>2</sup>)</b>         |              |                     |                   |                  |
| New   | 19564        | 1.83                | 2.74              | 3.29             |
| Existing  | 27845        | 2.60                | 3.90              | 7.02             |
| <b>Total</b>                                    | <b>47409</b> | <b>4.43</b>         | <b>6.64</b>       | <b>10.30</b>     |
| <b>Gross Site Area (ha)</b>                     |              |                     |                   |                  |
| New   | 0.0          | 0.00                | 0.00              | 0.00             |
| Existing  | 1.7          | 0.53                | 0.80              | 1.44             |
| <b>Total</b>                                    | <b>1.7</b>   | <b>0.53</b>         | <b>0.80</b>       | <b>1.44</b>      |

**Notes:**

1. All water demand calculations based on the City of Ottawa Design Guidelines for Water Distribution Table 4.2.
2. Water Demand is based assuming all lands to be Other Commercial with a demand of 28,000L/gross ha/d.
3. Peaking Factors: Maximum Daily Demand = 1.5 average daily demand ; Peak Hour = 1.8 max daily demand.
4. Gross Floor Area demand calculations based on Ontario Building Code; 9.3 m<sup>2</sup>/pers and 75 L/pers/day

# 12 Storey Office Building

## Fire Flow Calculations - Holland Cross Expansion

As per Fire Underwriter's Survey Guidelines

PROJECT: Holland Cross Expansion  
JOB#: 113150

DATE: December 12, 2013

|          |   |                 |  |
|----------|---|-----------------|--|
| <b>C</b> | <b>Coefficient related to type of construction</b>  | <u>[yes/no]</u> |  |
|          | ♦ Wood frame  |                 | 1.5  |
|          | ♦ Ordinary construction   |                 | 1  |
|          | ♦ Non-combustible construction  |                 | 0.8  |
|          | ♦ Fire resistive construction (> 3 hrs)   | yes             | 0.6  |
|          | ♦ Interpolation (Using FUS Tables)  |                 |  |
|          | Foot Print of New Tower   |                 | 18,610 ft <sup>2</sup>   |
|          | Gross Floor area of Expanded Common Podium  |                 | 99,060 ft <sup>2</sup>   |
|          | Gross Floor area of Existing Garage   |                 | 129,920 ft <sup>2</sup>  |
| <b>A</b> | <b>Area of structure considered (m<sup>2</sup>)</b>   | 5,320           | <==> <span style="border: 1px solid black; padding: 2px;">57,269 ft<sup>2</sup></span> |
|          | <i>(All floors excluding Basement, under 2-Storeys)</i>   |                 |  |
|          | *Note: This assumes protected openings, and considers 40% of the common 1 storey podium, plus 25% of the GFA of each of the two adjacent floors (New Tower + 40% of Garage) |                 |  |
| <b>F</b> | <b>Required fire flow (L/min)</b>   |                 | <u>10,000 L/min</u>  |
|          | $F = 220 C (A)^{0.5}$   |                 |  |
|          | <b>Occupancy hazard reduction of surcharge</b>  | <u>[yes/no]</u> |  |
|          | ♦ Non-combustible   |                 | -25%   |
|          | ♦ Limited combustible   | yes             | -15% * Due to Parking Garage   |
|          | ♦ Combustible   |                 | 0%   |
|          | ♦ Free burning  |                 | 15%  |
|          | ♦ Rapid burning   |                 | 25%  |
|          |   |                 | <u>8,500 L/min (1)</u>   |
|          | <b>Sprinkler Reduction</b>  |                 |  |
|          | ♦ Non-combustible - Fire Resistive (3)  | yes             | 50% <u>4,250 L/min (2)</u>   |
|          | <b>Exposure surcharge (cumulative (%))</b>  | <u>[yes/no]</u> |  |
|          | 0 - 3 m   |                 | 25%  |
|          | 3.1 - 10 m  |                 | 20%  |
|          | 10.1 - 20 m   | yes             | 15% 1 side 15%   |
|          | 20.1 - 30 m   | yes             | 10% 1 side 10%   |
|          | 30.1- 45 m  | no              | 5% 1 side  |
|          |   |                 | <b>Cumulative Total 25%</b>  |
|          |   |                 | 2,125 L/min  |
|          | <b>Fire Wall Separation</b>   |                 |  |
|          | ♦ Number of Party Walls * 1000 L/min  |                 |  |
|          | <i>(As per City of Ottawa Standard)</i>   |                 | <u>2,125 L/min (3)</u>   |
|          | <b>REQUIRED FIRE FLOW [(1) - (2) + (3)]</b>   |                 | <b>6,000 L/min</b>   |
|          | (2,000 L/min < Fire Flow < 45,000 L/min)  | <b>or</b>       | <b>100 L/s</b>   |
|          | Rounded to nearest 1000L/min  | <b>or</b>       | <b>1,321 IGPM</b>  |
|          | BY: Alex McAuley  |                 |  |

**6-4.5.9\*** For individual fasteners, the loads determined in 6-4.5.6 shall not exceed the allowable loads provided in Figure 6-4.5.9.

The type of fasteners used to secure the bracing assembly to the structure shall be limited to those shown in Figure 6-4.5.9. For connections to wood, through bolts with washers on each end shall be used. Holes for through bolts shall be  $1/16$  in. (1.6 mm) greater than the diameter of the bolt.

*Exception No. 1: Where it is not practical to install through bolts due to the thickness of the member or inaccessibility, lag screws shall be permitted. Holes shall be pre-drilled  $1/8$  in. (3.2 mm) smaller than the maximum root diameter of the lag screw.*

*Exception No. 2: Other fastening methods are acceptable for use if certified by a registered professional engineer to support the loads determined in accordance with the criteria in 6-4.5.9. Calculations shall be permitted where required by the authority having jurisdiction.*

**6-4.5.10** Sway bracing assemblies shall be listed for a maximum load rating. The loads shall be reduced as shown in Table 6-4.5.10 for loads that are less than 90 degrees from vertical.

*Exception: Where sway bracing utilizing pipe, angles, flats, or rods as shown in Table 6-4.5.8 is used, the components do not require listing. Bracing fittings and connections used with those specific materials shall be listed.*

**Table 6-4.5.10 Allowable Horizontal Load on Brace Assemblies Based on the Weakest Component of the Brace Assembly**

| Brace Angle                 | Allowable Horizontal Load           |
|-----------------------------|-------------------------------------|
| 30-40 degrees from vertical | Listed load rating divided by 2.000 |
| 45-59 degrees from vertical | Listed load rating divided by 1.414 |
| 60-89 degrees from vertical | Listed load rating divided by 1.155 |
| 90 degrees from vertical    | Listed load rating                  |

**6-4.5.11** Bracing shall be attached directly to feed and cross mains. Each run of pipe between changes in direction shall be provided with both lateral and longitudinal bracing.

*Exception: Pipe runs less than 12 ft (3.6 m) in length shall be permitted to be supported by the braces on adjacent runs of pipe.*

**6-4.5.12** A length of pipe shall not be braced to sections of the building that will move differentially.

#### 6-4.6 Restraint of Branch Lines.

**6-4.6.1\*** Restraint is considered a lesser degree of resisting loads than bracing and shall be provided by use of one of the following:

- (1) A listed sway brace assembly
- (2) A wraparound U-hook satisfying the requirements of 6-4.5.3, Exception No. 3
- (3) No. 12, 440-lb (200-kg) wire installed at least 45 degrees from the vertical plane and anchored on both sides of the pipe
- (4) Other approved means

Wire used for restraint shall be located within 2 ft (610 mm) of a hanger. The hanger closest to a wire restraint shall be of a type that resists upward movement of a branch line.

**6-4.6.2** The end sprinkler on a line shall be restrained against excessive vertical and lateral movement.

**6-4.6.3\*** Where upward or lateral movement would result in an impact against the building structure, equipment, or finish materials, branch lines shall be restrained at intervals not exceeding 30 ft (9 m).

**6-4.6.4\*** Sprig-ups 4 ft (1.2 m) or longer shall be restrained against lateral movement.

#### 6-4.7 Hangers and Fasteners Subject to Earthquakes.

**6-4.7.1** C-type clamps (including beam and large flange clamps) used to attach hangers to the building structure in areas subject to earthquakes shall be equipped with a restraining strap. The restraining strap shall be listed for use with a C-type clamp or shall be a steel strap of not less than 16 gauge thickness and not less than 1 in. (25.4 mm) wide for pipe diameters 8 in. (203 mm) or less and 14 gauge thickness and not less than  $1\frac{1}{4}$  in. (31.7 mm) wide for pipe diameters greater than 8 in. (203 mm). The restraining strap shall wrap around the beam flange not less than 1 in. (25.4 mm). A lock nut on a C-type clamp shall not be used as a method of restraint. A lip on a "C" or "Z" purlin shall not be used as a method of restraint.

Where purlins or beams do not provide an adequate lip to be secured by a restraining strap, the strap shall be through-bolted or secured by a self-tapping screw.

**6-4.7.2** C-type clamps (including beam and large flange clamps), with or without restraining straps, shall not be used to attach braces to the building structure.

**6-4.7.3** Powder-driven fasteners shall not be used to attach braces to the building structure.

*Exception: Powder-driven fasteners shall be permitted where they are specifically listed for service in resisting lateral loads in areas subject to earthquakes.*

**6-4.7.4** Powder-driven fasteners shall not be used to attach hangers to the building structure where the systems are required to be protected against earthquakes using a horizontal force factor exceeding  $0.50 W_p$ , where  $W_p$  is the weight of the water-filled pipe.

*Exception: Powder-driven fasteners shall be permitted where they are specifically listed for horizontal force factors in excess of  $0.50 W_p$ .*

## Chapter 7 Design Approaches

### 7-1 General.

**7-1.1** Water demand requirements shall be determined from the occupancy hazard fire control approach of Section 7-2.

*Exception: Special design approaches as permitted in Section 7-9.*

**7-1.2** For buildings with two or more adjacent occupancies that are not physically separated by a barrier or partition capable of delaying heat from a fire in one area from fusing sprinklers in the adjacent area, the required sprinkler protection for the more demanding occupancy shall extend 15 ft (4.6 m) beyond its perimeter.

## 7-2 Occupancy Hazard Fire Control Approach.

### 7-2.1 Occupancy Classifications.

**7-2.1.1** Occupancy classifications for this standard relate to sprinkler installations and their water supplies only. They shall not be used as a general classification of occupancy hazards.

**7-2.1.2** Occupancies or portions of occupancies shall be classified according to the quantity and combustibility of contents, the expected rates of heat release, the total potential for energy release, the heights of stockpiles, and the presence of flammable and combustible liquids, using the definitions contained in Section 1-4. Classifications are as follows:

- Light hazard
- Ordinary hazard (Groups 1 and 2)
- Extra hazard (Groups 1 and 2)
- Special occupancy hazard (*see Section 7-10*)

### 7-2.2 Water Demand Requirements — Pipe Schedule Method.

**7-2.2.1** Table 7-2.2.1 shall be used in determining the minimum water supply requirements for light and ordinary hazard occupancies protected by systems with pipe sized according to the pipe schedules of Section 8-5. Pressure and flow requirements for extra hazard occupancies shall be based on the hydraulic calculation methods of 7-2.3. The pipe schedule method shall be permitted only for new installations of 5000 ft<sup>2</sup> (465 m<sup>2</sup>) or less or for additions or modifications to existing pipe schedule systems sized according to the pipe schedules of Section 8-5. Table 7-2.2.1 shall be used in determining the minimum water supply requirements.

*Exception No. 1: The pipe schedule method shall be permitted for use in systems exceeding 5000 ft<sup>2</sup> (465 m<sup>2</sup>) where the flows required in Table 7-2.2.1 are available at a minimum residual pressure of 50 psi (3.4 bar) at the highest elevation of sprinkler.*

*Exception No. 2: The pipe schedule method shall be permitted for additions or modifications to existing extra hazard pipe schedule systems.*

**7-2.2.2** The lower duration value of Table 7-2.2.1 shall be acceptable only where remote station or central station water-flow alarm service is provided.

**7-2.2.3\*** The residual pressure requirement of Table 7-2.2.1 shall be met at the elevation of the highest sprinkler. (*See the Exceptions to 7-2.2.1*).

**7-2.2.4** The lower flow figure of Table 7-2.2.1 shall be permitted only where the building is of noncombustible construction or the potential areas of fire are limited by building size or compartmentation such that no open areas exceed 3000 ft<sup>2</sup> (279 m<sup>2</sup>) for light hazard or 4000 ft<sup>2</sup> (372 m<sup>2</sup>) for ordinary hazard.

**Table 7-2.2.1 Water Supply Requirements for Pipe Schedule Sprinkler Systems**

| Occupancy Classification | Minimum Residual Pressure Required (psi) | Acceptable Flow at Base of Riser (Including Hose Stream Allowance) (gpm) | Duration (minutes) |
|--------------------------|--|--|--------------------|
| Light hazard             | 15                                       | 500–750  | 30–60              |
| Ordinary hazard          | 20                                       | 850–1500   | 60–90              |

For SI units, 1 gpm = 3.785 L/min; 1 psi = 0.0689 bar.

### 7-2.3 Water Demand Requirements — Hydraulic Calculation Methods.

#### 7-2.3.1 General.


**7-2.3.1.1\*** The minimum water supply requirements for a hydraulically designed occupancy hazard fire control sprinkler system shall be determined by adding the hose stream demand from Table 7-2.3.1.1 to the water supply for sprinklers determined in 7-2.3.1.2. This supply shall be available for the minimum duration specified in Table 7-2.3.1.1.

*Exception No. 1: An allowance for inside and outside hose shall not be required where tanks supply sprinklers only.*

*Exception No. 2: Where pumps taking suction from a private fire service main supply sprinklers only, the pump need not be sized to accommodate inside and outside hose. Such hose allowance shall be considered in evaluating the available water supplies.*

**7-2.3.1.2** The water supply for sprinklers only shall be determined either from the area/density curves of Figure 7-2.3.1.2 in accordance with the method of 7-2.3.2 or be based upon the room design method in accordance with 7-2.3.3, at the discretion of the designer. For special areas under consideration, as described in 7-2.3.4, separate hydraulic calculations shall be required in addition to those required by 7-2.3.2 or 7-2.3.3.

Figure 7-2.3.1.2 Area/density curves.



TO BE CONSERVATIVE  
 - CURVE 2  
 $4000 \text{ ft}^2 \times 0.10 \text{ gpm/ft}^2 = 400 \text{ gpm}$   
 SPRINKLERS  
 $\frac{400 \text{ gpm}}{400 \text{ gpm}} \Rightarrow 25.2 \text{ L/s}$   
 HOSE DEMAND  
 $250 \text{ gpm} \Rightarrow 15.8 \text{ L/s}$   
 TOTAL SUPPLY REQUIREMENT  
 $650 \text{ gpm} \Rightarrow 41.0 \text{ L/s}$

7-2.3.1.3 Regardless of which of the two methods is used, the following restrictions shall apply:

(a) For areas of sprinkler operation less than 1500 ft<sup>2</sup> (139 m<sup>2</sup>) used for light and ordinary hazard occupancies, the density for 1500 ft<sup>2</sup> (139 m<sup>2</sup>) shall be used. For areas of sprinkler operation less than 2500 ft<sup>2</sup> (232 m<sup>2</sup>) for extra hazard occupancies, the density for 2500 ft<sup>2</sup> (232 m<sup>2</sup>) shall be used.

(b) \*For buildings having unsprinklered combustible concealed spaces (as described in 5-13.1.1 and 5-13.7), the minimum area of sprinkler operation shall be 3000 ft<sup>2</sup> (279 m<sup>2</sup>).

*Exception No. 1: Combustible concealed spaces filled entirely with noncombustible insulation.*

*Exception No. 2: \*Light or ordinary hazard occupancies where noncombustible or limited combustible ceilings are directly attached to the bottom of solid wood joists so as to create enclosed joist spaces 160 ft<sup>3</sup> (4.8 m<sup>3</sup>) or less in volume.*

*Exception No. 3: \*Concealed spaces where the exposed surfaces have a flame spread rating of 25 or less and the materials have been demonstrated to not propagate fire in the form in which they are installed in the space.*

(c) Water demand of sprinklers installed in racks or water curtains shall be added to the ceiling sprinkler water demand at the point of connection. Demands shall be balanced to the higher pressure. (See Chapter 8.)

(d) Water demand of sprinklers installed in concealed spaces or under obstructions such as ducts and cutting tables need not be added to ceiling demand.

(e) Where inside hose stations are planned or are required, a total water allowance of 50 gpm (189 L/min) for a single hose station installation or 100 gpm (378 L/min) for a multiple hose station installation shall be added to the sprinkler requirements. The water allowance shall be added in 50-gpm (189-L/min) increments beginning at the most remote hose station, with each increment added at the pressure required by the sprinkler system design at that point.

(f) When hose valves for fire department use are attached to wet pipe sprinkler system risers in accordance with 5-15.5.2, the water supply shall not be required to be added to standpipe demand as determined from NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*.

*Exception No. 1: Where the combined sprinkler system demand and hose stream allowance of Table 7-2.3.1.1 exceeds the requirements of NFPA 14, Standard for the Installation of Standpipe and Hose Systems, this higher demand shall be used.*

*Exception No. 2: For partially sprinklered buildings, the sprinkler demand, not including hose stream allowance, as indicated in Table 7-2.3.1.1 shall be added to the requirements given in NFPA 14, Standard for the Installation of Standpipe and Hose Systems.*

(g) Water allowance for outside hose shall be added to the sprinkler and inside hose requirement at the connection to the city water main or a yard hydrant, whichever is closer to the system riser.

(h) The lower duration values in Table 7-2.3.1.1 shall be permitted where remote station or central station waterflow alarm service is provided.

(i) Where pumps, gravity tanks, or pressure tanks supply sprinklers only, requirements for inside and outside hose need not be considered in determining the size of such pumps or tanks.

7-2.3.1.4 Total system water supply requirements shall be determined in accordance with the hydraulic calculation procedures of Section 8-4.

7-2.3.2 Area/Density Method.

7-2.3.2.1 The water supply requirement for sprinklers only shall be calculated from the area/density curves in Figure 7-2.3.1.2 or from Section 7-10 where area/density criteria is specified for special occupancy hazards. When using Figure 7-2.3.1.2, the calculations shall satisfy any single point on the appropriate area/density curve as follows:

- (1) Light hazard area/density curve 1
- (2) Ordinary hazard (Group 1) area/density curve 2
- (3) Ordinary hazard (Group 2) area/density curve 3
- (4) Extra hazard (Group 1) area/density curve 4
- (5) Extra hazard (Group 2) area/density curve 5

It shall not be necessary to meet all points on the selected curve.

*Exception: Sprinkler demand for storage occupancies as determined in Sections 7-3 through 7-8.*

7-2.3.2.2 For protection of miscellaneous storage, miscellaneous tire storage, and storage up to 12 ft (3.7 m) in height, the discharge criteria in Table 7-2.3.2.2 shall apply.

**Table 7-2.3.1.1† Hose Stream Demand and Water Supply Duration Requirements for Hydraulically Calculated Systems**

| Occupancy or Commodity Classification  | Inside Hose (gpm) | Total Combined Inside and Outside Hose (gpm) | Duration (minutes) |
|--|-------------------|--|--------------------|
| Light hazard   | 0, 50, or 100     | 100  | 30                 |
| Ordinary hazard  | 0, 50, or 100     | 250  | 60-90              |
| Extra hazard   | 0, 50, or 100     | 500  | 90-120             |
| Rack storage, Class I, II, and III commodities up to 12 ft (3.7 m) in height             | 0, 50, or 100     | 250  | 90                 |
| Rack storage, Class IV commodities up to 10 ft (3.1 m) in height                         | 0, 50, or 100     | 250  | 90                 |
| Rack storage, Class IV commodities up to 12 ft (3.7 m) in height                         | 0, 50, or 100     | 500  | 90                 |
| Rack storage, Class I, II, and III commodities over 12 ft (3.7 m) in height              | 0, 50, or 100     | 500  | 90                 |
| Rack storage, Class IV commodities over 12 ft (3.7 m) in height and plastic commodities  | 0, 50, or 100     | 500  | 120                |
| General storage, Class I, II, and III commodities over 12 ft (3.7 m) up to 20 ft (6.1 m) | 0, 50, or 100     | 500  | 90                 |
| General storage, Class IV commodities over 12 ft (3.7 m) up to 20 ft (6.1 m)             | 0, 50, or 100     | 500  | 120                |
| General storage, Class I, II, and III commodities over 20 ft (6.1 m) up to 30 ft (9.1 m) | 0, 50, or 100     | 500  | 120                |
| General storage, Class IV commodities over 20 ft (6.1 m) up to 30 ft (9.1 m)             | 0, 50, or 100     | 500  | 150                |
| General storage, Group A plastics ≤ 5 ft (1.5 m)   | 0, 50, or 100     | 250  | 90                 |
| General storage, Group A plastics over 5 ft (1.5 m) up to 20 ft (6.1 m)                  | 0, 50, or 100     | 500  | 120                |
| General storage, Group A plastics over 20 ft (6.1 m) up to 25 ft (7.6 m)                 | 0, 50, or 100     | 500  | 150                |

For SI units, 1 gpm = 3.785 L/min.

## Alex McAuley

---

**From:** White, Joshua <Joshua.White@ottawa.ca>  
**Sent:** October-29-13 3:49 PM  
**To:** Alex McAuley  
**Cc:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Good eye Alex. There was a mistake in the model. We are looking into it please find the revision below to the HGL.

The Max Day + FF HGL is actually 77.5m, not 112.2m.

Cheers

Josh

---

**From:** Alex McAuley [mailto:a.mcauley@novatech-eng.com]  
**Sent:** October 11, 2013 11:28 AM  
**To:** White, Joshua  
**Cc:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Josh,

Can you please double check the HGL below? The Max Day + Fire Flow is 4.8m above the Min HGL, which is unusual.

Thank you,

Alex McAuley, P.Eng  
Project Engineer

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643

Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

---

**From:** Alex McAuley  
**Sent:** October-11-13 11:22 AM  
**To:** 'White, Joshua'  
**Cc:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Thank you Josh,

Regards,



Alex McAuley, P.Eng  
Project Engineer

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643  
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

---

**From:** White, Joshua [<mailto:Joshua.White@ottawa.ca>]  
**Sent:** October-11-13 9:44 AM  
**To:** Alex McAuley  
**Cc:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Hi Alex,

I have received the revised boundary conditions.

Cheers

Josh

Please find attached the revised boundary conditions for the above noted

**\*\*\*\*The following information may be passed on to the consultant, but do NOT forward this e-mail directly.\*\*\*\***

The following are boundary conditions, HGL, for hydraulic analysis at 1560 Scott Street (zone 1W) assumed to be connected to the existing 152mm on Bullman (see attached PDF for location).

Minimum HGL = 107.4 m

Maximum HGL = 115.8 m

Max Day + FF (92.7 L/s) = 112.2 m

These are for current conditions and are based on computer model simulation.

*Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.*

---

**From:** Alex McAuley [<mailto:a.mcauley@novatech-eng.com>]  
**Sent:** October 08, 2013 10:04 AM  
**To:** White, Joshua  
**Cc:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Hi Josh,

Thank you for the information.

We will be reusing the existing 150mm diameter water service that is fed from the corner of Bullman Street and Hamilton Ave N. The information provided below is for the Holland Street service, and gives us approximately 22.8psi during fire flow conditions which is sufficient. We are close to the Scott Street trunk watermain, so I wouldn't anticipate a major drop, but will there be any change to the HGL at that location?

I attached a sketch with the location of the service we are proposing to use.

Regards,

Alex McAuley, P.Eng  
Project Engineer

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643  
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

---

**From:** White, Joshua [<mailto:Joshua.White@ottawa.ca>]  
**Sent:** October-07-13 11:10 AM  
**To:** Alex McAuley  
**Subject:** RE: Holland Cross - 1560 Scott Street

Hi Alex,

Here is the results of the water boundary condition modeling.

Cheers

Josh

The following are boundary conditions, HGL, for hydraulic analysis at 1560 Scott Street (zone 1W) assumed to be connected to the existing 152mm on Holland Avenue (see attached PDF for location).

Minimum HGL = 108.8 m

Maximum HGL = 115.3 m

Max Day + FF (92.7 L/s) = 77.0 m

These are for current conditions and are based on computer model simulation.

*Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.*

---

**From:** Alex McAuley [<mailto:a.mcauley@novatech-eng.com>]  
**Sent:** September 27, 2013 10:36 AM  
**To:** White, Joshua  
**Subject:** RE: Holland Cross - 1560 Scott Street

Hi Josh,

We will be reusing the existing water connection.

Alex McAuley, P.Eng  
Engineer

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643

Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

---

**From:** White, Joshua [<mailto:Joshua.White@ottawa.ca>]  
**Sent:** September-26-13 1:19 PM  
**To:** Alex McAuley  
**Subject:** RE: Holland Cross - 1560 Scott Street

Hi Alex,

Just to confirm the water connection will be from the internal private water main, or are you planning on installing a connection to the water main in the street.

Cheers

Josh

---

**From:** Alex McAuley [<mailto:a.mcauley@novatech-eng.com>]  
**Sent:** September 26, 2013 11:44 AM  
**To:** White, Joshua  
**Cc:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Josh,

Per our phone conversation yesterday, I have revised our fire flow calculations for the new addition based on FUS for a sprinklered office building with fire resistive construction.

I have calculated the fire flows and demands based on the new expansion only, as the existing two towers have independent services.

Fire Flow (FUS) = 92.7 L/s  
Average Daily Flow = 1.88 L/s  
Max Day Flow = 2.81 L/s  
Max hourly Flow = 3.38 L/s

Please let me know if you require additional information.

Regards,

Alex McAuley, P.Eng  
Engineer

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643  
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

---

**From:** Cara Ruddle  
**Sent:** September-19-13 11:02 AM  
**To:** Alex McAuley  
**Subject:** FW: Holland Cross - 1560 Scott Street

Cara Ruddle, P.Eng.  
Project Manager

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643 x 220  
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

---

**From:** White, Joshua [<mailto:Joshua.White@ottawa.ca>]  
**Sent:** September-19-13 11:05 AM  
**To:** Cara Ruddle  
**Subject:** RE: Holland Cross - 1560 Scott Street

Hi Cara,

The fire flow should be based off of the Fire Under Writers Survey. Also the may I please have the following information;

Average Daily Flow: l/s  
Max Day Flow: l/s  
Max hourly Flow: l/s

I have put in a request to our ISD regarding possible servicing constraints in the area and I will relay them to you once I have received them.

Cheers

Josh

---

**From:** Cara Ruddle [<mailto:c.ruddle@novatech-eng.com>]  
**Sent:** September 19, 2013 10:43 AM  
**To:** White, Joshua  
**Subject:** Holland Cross - 1560 Scott Street

Josh:  
Using the NFPA 13 Sprinkler/Hose demands and a max day office demand we have calculated a fire flow requirement of 650gpm (43.82L/s) for the new 12 storey building. We would use the existing 150mm water service at the corner of Bullman and Hamilton.

Sanitary flows are calculated to be just less than 3.0 L/s. The sanitary connection for the building is also by the intersection of Bullman and Hamilton.

As discussed, please provide boundary conditions for the water system and any servicing constraints that you are aware of for this development.

Please call or email if you have any questions. Thanks.

Cara Ruddle, P.Eng.  
Project Manager

\*\*\*\*\*

Novatech Engineering Consultants Ltd  
200-240 Michael Cowpland Drive  
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643 x 220  
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

**APPENDIX B**  
*Sanitary Sewer Information*



# SANITARY SEWER DESIGN SHEET

PROJECT : 113150  
 DESIGNED BY: ARM  
 CHECKED BY: CJR  
 DATE: 09-Dec-13  
 DATE REVISED:



| LOCATION         |            |            |           | JOBS & POPULATION |                     |            |      |           |                 |                 |                 | PROPOSED SEWER PIPE  |                              |                             |           |              |              | CHECK     |                |                          |            |
|------------------|------------|------------|-----------|-------------------|---------------------|------------|------|-----------|-----------------|-----------------|-----------------|----------------------|------------------------------|-----------------------------|-----------|--------------|--------------|-----------|----------------|--------------------------|------------|
| STREET           | FROM       | TO         | AREA (ha) | Jobs (per ha)     | Population (per ha) | CUMULATIVE |      |           | Jobs/Commercial |                 | Population      |                      | PEAK EXTRAN. FLOW Q(i) (L/s) | PEAK DESIGN FLOW Q(d) (L/s) | DIA. (mm) | PIPE ID (mm) | TYPE OF PIPE | SLOPE (%) | CAPACITY (L/s) | FULL FLOW VELOCITY (m/s) | Qpeak/Qcap |
|                  |            |            |           |                   |                     | Jobs       | POP. | AREA (ha) | PEAK FACTOR (M) | FLOW Q(p) (L/s) | PEAK FACTOR (M) | POP. FLOW Q(p) (L/s) |                              |                             |           |              |              |           |                |                          |            |
|                  |            |            |           | 207               | 48                  |            |      |           |                 |                 |                 | 0.28                 |                              |                             |           |              |              |           |                |                          |            |
| Hamilton Av N    | Oxford     | Bullman    | 1.05      | 217               | 50                  | 217        | 50   | 1.05      | 1.50            | 0.28            | 4.00            | 0.81                 | 0.29                         | 1.39                        | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 4.7%       |
| 12 Storey Office | Bullman    |            |           | 2161              | 0                   | 2161       | 0    | 1.05      | 1.50            | 2.81            | 4.00            | 0.00                 | 0.29                         | 3.11                        | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 10.5%      |
| Bullman          | Hamilton   | Parkdale   | 0.36      | 75                | 17                  | 2453       | 67   | 2.46      | 1.50            | 3.19            | 4.00            | 1.09                 | 0.69                         | 4.97                        | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 16.8%      |
| Parkdale         | Oxford     | Bullman    | 1.30      | 269               | 62                  | 2722       | 129  | 3.76      | 1.50            | 3.54            | 4.00            | 2.09                 | 1.05                         | 6.69                        | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 22.6%      |
| Parkdale         | Bullman    | Scott      | 0.75      | 155               | 36                  | 2877       | 165  | 4.51      | 1.50            | 3.75            | 4.00            | 2.67                 | 1.26                         | 7.68                        | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 26.0%      |
| Scott            |            | Parkdale   | 1.62      | 335               | 78                  | 335        | 78   | 1.62      | 1.50            | 0.44            | 4.00            | 1.26                 | 0.45                         | 2.15                        | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 7.3%       |
| Scott            | Parkdale   | Pinehurst  | 0.17      | 35                | 8                   | 3247       | 251  | 6.30      | 1.50            | 4.23            | 4.00            | 4.07                 | 1.76                         | 10.06                       | 250       | 251.5        | DR 35        | 0.24      | 29.6           | 0.60                     | 34.0%      |
| Scott            | Pinehurst  |            | 2.25      | 466               | 108                 | 3713       | 359  | 8.55      | 1.50            | 4.83            | 4.00            | 5.82                 | 2.39                         | 13.05                       | 300       | 299.4        | DR 35        | 0.19      | 41.9           | 0.60                     | 31.1%      |
| Scott            |            | Carruthers | 1.50      | 311               | 72                  | 4024       | 431  | 10.05     | 1.50            | 5.24            | 4.00            | 6.98                 | 2.81                         | 15.04                       | 300       | 299.4        | DR 35        | 0.19      | 41.9           | 0.60                     | 35.9%      |
| Scott            | Carruthers | Stirling   | 1.40      | 290               | 67                  | 4314       | 498  | 11.45     | 1.50            | 5.62            | 3.98            | 8.02                 | 3.21                         | 16.84                       | 300       | 299.4        | DR 35        | 0.19      | 41.9           | 0.60                     | 40.2%      |
| Scott            | Stirling   | Pinhey     | 1.47      | 304               | 71                  | 4618       | 569  | 12.92     | 1.50            | 6.01            | 3.94            | 9.09                 | 3.62                         | 18.72                       | 300       | 299.4        | DR 35        | 0.19      | 41.9           | 0.60                     | 44.7%      |
| Scott            | Pinhey     | Merton     | 1.72      | 356               | 83                  | 4974       | 652  | 14.64     | 1.50            | 6.48            | 3.91            | 10.33                | 4.10                         | 20.91                       | 300       | 299.4        | DR 35        | 0.19      | 41.9           | 0.60                     | 49.9%      |

\* Note: Assumed minimum slope

**Notes:**

1.  $Q(d) = Q(p) + Q(i)$ , where

Q(d) = Design Flow (L/sec)  
 Q(p) = Population Flow (L/sec)  
 Q(i) = Extraneous Flow (L/sec)

2.  $Q(i) = 0.28$  L/sec/ha


3.  $Q(p) = (P \times q \times M / 86.4)$ , where

P = Persons (Population = 48/ha, Jobs=207/ha)  
 q = Average per capita flow = 350 L/cap/day  
 M = Harmon Formula (maximum of 4.0)

4. Depth of flow/Diameter from Hydraulic properties of circular pipes flowing partially full

5. Population/Jobs Target Density 2031 = 250/ha (17915 jobs, 4204 pop = 255/ha density at 2031) per Figure 30 for Tunney's-Quad area (Residential Land Strategy for Ottawa 2006-2031, City of Ottawa Feb 2009)

| Breakdown   | Jobs  | Population |
|-------------|-------|------------|
| Projected   | 17915 | 4204       |
| Percentage  | 81.0% | 19.0%      |
| At 255/ha = | 207   | 48         |




M:\2013\113150\CAD\Design\Figures\Figure5.dwg, figure 5 1:3000, Dec 09, 2013 - 3:20pm, bhurber

**NOVATECH**  
**ENGINEERING**  
**CONSULTANTS LTD.**  
 ENGINEERS & PLANNERS  
 Suite 200, 240 Michael Cowpland Drive  
 Ottawa, Ontario, Canada  
 K2M 1P6  
 Telephone (613) 254-9643  
 Facsimile (613) 254-5867  
 Email: novainfo@novatech-eng.com

SCALE  
 1:3000  
 1:3000  
 0 30 60 90 120


1560 SCOTT STREET -  
 HOLLAND CROSS PHASE 3  
 DOWNSTREAM SANITARY  
 DRAINAGE AREAS  
 DEC 2013 113150 FIGURE 5

**APPENDIX C**  
*Engineering Figures*



M:\2013\113150\CAD\Design\Figures\Figure6.dwg, Figure 6, Dec 12, 2013 - 3:31pm, iandric


**NOVATECH**  
 ENGINEERING  
 CONSULTANTS LTD.  
 ENGINEERS & PLANNERS  
 Suite 200, 240 Michael Cowpland Drive  
 Ottawa, Ontario, Canada  
 K2M 1P6  
 Telephone (613) 254-9643  
 Facsimile (613) 254-5867  
 Email: novainfo@novatech-eng.com



1560 SCOTT STREET-  
 HOLLAND CROSS PHASE 3  
 GRADING AND SERVICING

DEC 2013     113150     FIGURE 6







**NOTE:**  
 ALL UNDERGROUND INFORMATION WITHIN PROPERTY LIMITS OBTAINED FROM RYBKA, SMITH AND GINSLER LIMITED CONSULTING ENGINEERS PLAN TITLED "SITE PLAN-MECHANICAL" DATED AUGUST 26, 1987. ALL UNDERGROUND INFORMATION WITHIN CITY OF OTTAWA RIGHT OF WAY OBTAINED FROM CITY OF OTTAWA PLAN AND PROFILE RECORD DRAWINGS 2032-1 & 2032-2 (CITY OF OTTAWA RECORD NUMBER 14274) DATED JULY 13, 2006.  
 ALL INFORMATION CONTAINED ON THIS PLAN IS APPROXIMATE. ALL SERVICE LOCATIONS AND ELEVATIONS ARE TO BE CONFIRMED ON SITE AT THE TIME OF CONSTRUCTION.




**EROSION AND SEDIMENT CONTROL NOTES:**

1. THE OWNER AGREES TO PREPARE AND IMPLEMENT AN EROSION AND SEDIMENT CONTROL PLAN TO THE SATISFACTION OF THE CITY OF OTTAWA, APPROPRIATE TO THE SITE CONDITIONS, PRIOR TO UNDERTAKING ANY SITE ALTERATIONS (FILLING, GRADING, REMOVAL OF VEGETATION, ETC.) AND DURING ALL PHASES OF SITE PREPARATION AND CONSTRUCTION IN ACCORDANCE WITH THE CURRENT BEST MANAGEMENT PRACTICES FOR EROSION AND SEDIMENT CONTROL SUCH AS BUT NOT LIMITED TO INSTALLING FILTER CLOTHS ACROSS MANHOLE/CATCHBASIN LIDS TO PREVENT SEDIMENTS FROM ENTERING STRUCTURES AND INSTALL AND MAINTAIN A LIGHT DUTY SILT FENCE BARRIER AS REQUIRED.
2. THE CONTRACTOR SHALL PLACE FILTER CLOTH UNDER THE CATCHBASIN AND MANHOLE GRATES FOR THE DURATION OF CONSTRUCTION AND WILL REMAIN IN PLACE DURING ALL PHASES OF CONSTRUCTION.
3. SILT FENCING FOR ENTIRE PERIMETER OF SITE, SHALL BE UTILIZED TO CONTROL EROSION FROM THE SITE DURING CONSTRUCTION.
4. THE CONTRACTOR ACKNOWLEDGES THAT FAILURE TO IMPLEMENT EROSION AND SEDIMENT CONTROL MEASURES MAY BE SUBJECT TO PENALTIES IMPOSED BY ANY APPLICABLE REGULATORY AGENCY.

**LEGEND**

-  FILTER CLOTH CATCH
-  SILT FENCE PER OPSD 219.110
-  EXISTING STORM PIPE
-  EXISTING CB
-  EXISTING STORM MH
-  EXISTING SANITARY MH



**SCALE**

1:400

1:400

0 4 8 12 16

**1560 SCOTT STREET-  
HOLLAND CROSS PHASE 3  
EROSION AND SEDIMENT  
CONTROL PLAN**

DEC 2013 113150 FIGURE 7

**NOTE:**

M:\2013\113150\CAD\Design\Figures\Figure7.dwg, Figure 6, Dec 13, 2013 - 2:02pm, iandric

**NOVATECH**  
ENGINEERING  
CONSULTANTS LTD.  
ENGINEERS & PLANNERS  
Suite 200, 240 Michael Cowpland Drive  
Ottawa, Ontario, Canada  
K2M 1P6  
Telephone (613) 254-9643  
Facsimile (613) 254-5867  
Email: novainfo@novatech-eng.com

## **APPENDIX D**

### *City of Ottawa Checklist*

**Development Servicing Study Checklist**

| 4.1 General Content  | Addressed (Y/N/NA) | Section | Comments  |
|--|--------------------|---------|---|
| Executive Summary (for larger reports only).   | NA                 |         |   |
| Date and revision number of the report.  | Y                  |         |   |
| Location map and plan showing municipal address, boundary, and layout of proposed development.   | Y                  |         |   |
| Plan showing the site and location of all existing services.   | Y                  |         |   |
| Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.  | N                  |         | Refer to Planning Rationale                                 |
| Summary of Pre-consultation Meetings with City and other approval agencies.  | N                  |         |   |
| Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defensible design criteria.   | NA                 |         |   |
| Statement of objectives and servicing criteria.  | Y                  |         |   |
| Identification of existing and proposed infrastructure available in the immediate area.  | Y                  |         |   |
| Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).   | NA                 |         |   |
| Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighboring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths. | NA                 |         | The proposed building will occupy the majority of the site. |

**Development Servicing Study Checklist**

| 4.1 General Content  | Addressed<br>(Y/N/NA) | Section | Comments |
|--|-----------------------|---------|----------|
| Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts. | NA                    |         |          |
| Proposed phasing of the development, if applicable.  | NA                    |         |          |
| Reference to geotechnical studies and recommendations concerning servicing.  | NA                    |         |          |
| All preliminary and formal site plan submissions should have the following information:  |                       |         |          |
| Metric scale   | Y                     |         |          |
| North arrow (including construction North)   | Y                     |         |          |
| Key plan   | Y                     |         |          |
| Name and contact information of applicant and property owner   | Y                     |         |          |
| Property limits including bearings and dimensions  | Y                     |         |          |
| Existing and proposed structures and parking areas   | Y                     |         |          |
| Easements, road widening and rights-of-way   | Y                     |         |          |
| Adjacent street names  | Y                     |         |          |



**Development Servicing Study Checklist**

| 4.2 Water   | Addressed (Y/N/NA) | Section | Comments           |
|---|--------------------|---------|--------------------|
| Confirm consistency with Master Servicing Study, if available.  | N                  |         | None Known         |
| Availability of public infrastructure to service proposed development.  | Y                  |         |                    |
| Identification of system constraints.   | N                  |         | None Known         |
| Identify boundary conditions.   | Y                  |         | City supplied      |
| Confirmation of adequate domestic supply and pressure.  | Y                  |         |                    |
| Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.   | Y                  |         |                    |
| Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.   | Y                  |         |                    |
| Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design.   | NA                 |         | No phasing planned |
| Address reliability requirements such as appropriate location of shut-off valves.   | Y                  |         |                    |
| Check on the necessity of a pressure zone boundary modification.  | NA                 |         |                    |
| Reference to water supply analysis to show that major infrastructure is capable of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range. | Y                  |         |                    |
| Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants) including special metering provisions.              | Y                  |         |                    |
| Description of off-site required feeder mains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.  | NA                 |         |                    |
| Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.   | Y                  |         |                    |
| Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.   | NA                 |         |                    |

**Development Servicing Study Checklist**

| 4.3 Wastewater   | Addressed (Y/N/NA) | Section | Comments |
|--|--------------------|---------|----------|
| Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).  | Y                  |         |          |
| Confirm consistency with Master Servicing Study and/or justifications for deviations.  | N                  |         |          |
| Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers.  | N                  |         |          |
| Description of existing sanitary sewer available for discharge of wastewater from proposed development.  | Y                  |         |          |
| Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable)   | Y                  |         |          |
| Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.   | Y                  |         |          |
| Description of proposed sewer network including sewers, pumping stations, and forcemains.  | Y                  |         |          |
| Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality). | NA                 |         |          |
| Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.   | NA                 |         |          |
| Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.   | NA                 |         |          |
| Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.   | NA                 |         |          |
| Special considerations such as contamination, corrosive environment etc.   | NA                 |         |          |

**Development Servicing Study Checklist**

| 4.4 Stormwater   | Addressed (Y/N/NA) | Section | Comments   |
|--|--------------------|---------|--|
| Description of drainage outlets and downstream constraints including legality of outlet (i.e. municipal drain, right-of-way, watercourse, or private property).  | Y                  |         |  |
| Analysis of the available capacity in existing public infrastructure.  | N                  |         | Hard surface areas and therefore, storm flows are not being increased. |
| A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns and proposed drainage patterns.   | N                  |         | Drainage patterns are not being altered.                               |
| Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. | Y                  |         |  |
| Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.  | N                  |         | The site will be roof and underground parking (sanitary sewer)         |
| Description of stormwater management concept with facility locations and descriptions with references and supporting information.  | Y                  |         |  |
| Set-back from private sewage disposal systems.   | NA                 |         |  |
| Watercourse and hazard lands setbacks.   | NA                 |         |  |
| Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.  | NA                 |         |  |
| Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.   | NA                 |         |  |
| Storage requirements (complete with calcs) and conveyance capacity for 5 yr and 100 yr events.   | Y                  |         |  |
| Identification of watercourse within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.   | NA                 |         |  |
| Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.   | NA                 |         |  |
| Any proposed diversion of drainage catchment areas from one outlet to another.   | NA                 |         |  |
| Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and SWM facilities.   | NA                 |         |  |
| If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event.   | NA                 |         |  |

**Development Servicing Study Checklist**

| 4.4 Stormwater  | Addressed<br>(Y/N/NA) | Section | Comments |
|---|-----------------------|---------|----------|
| Identification of municipal drains and related approval requirements.   | NA                    |         |          |
| Description of how the conveyance and storage capacity will be achieved for the development.  | NA                    |         |          |
| 100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.  | NA                    |         |          |
| Inclusion of hydraulic analysis including HGL elevations.   | NA                    |         |          |
| Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.  | NA                    |         |          |
| Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions. | NA                    |         |          |
| Identification of fill constrains related to floodplain and geotechnical investigation.   | NA                    |         |          |

**Development Servicing Study Checklist**

| 4.5 Approval and Permit Requirements   | Addressed (Y/N/NA) | Section | Comments |
|--|--------------------|---------|----------|
| Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams as defined in the Act. | NA                 |         |          |
| Application for Certificate of Approval (CofA) under the Ontario Water Resources Act.  | NA                 |         |          |
| Changes to Municipal Drains.   | NA                 |         |          |
| Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation etc.)  | NA                 |         |          |

| 4.6 Conclusion  | Addressed (Y/N/NA) | Section | Comments |
|---|--------------------|---------|----------|
| Clearly stated conclusions and recommendations.   | Y                  |         |          |
| Comments received from review agencies including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency. | Y                  |         |          |
| All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario.   | Y                  |         |          |

# **SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON**

Appendix D Design Criteria and Report Excerpts  
April 20, 2023

## **D.2 JUNE 14, 2022 CITY MEETING MINUTES**

## Johnson, Warren

---

**From:** Fawzi, Mohammed <mohammed.fawzi@ottawa.ca>  
**Sent:** Friday, June 17, 2022 12:06 PM  
**To:** Johnson, Warren  
**Cc:** Kilborn, Kris; Shahzadeh, Serene; Cody, Neal  
**Subject:** RE: 1560 Scott Street  
**Attachments:** Roof Drain Control Letter - Template.docx

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

Hi Warren,

Thank you for the summary.

I've attached the Roof Drain Control Letter, which I kindly ask to be completed and signed and attached as an appendix in the servicing report. Regarding the hydrant classifications and flow that can be considered from a given hydrant, please refer to City of Ottawa Technical Bulletin IST-2018-02 Appendix I Table 1.

Let me know if you wish to discuss further. Thank you.

Best Regards,

**Mohammed Fawzi, P.Eng.**

Project Manager  
Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique  
Development Review - Central Branch  
City of Ottawa | Ville d'Ottawa  
110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1  
613.580.2424 ext./poste 20120, [Mohammed.Fawzi@ottawa.ca](mailto:Mohammed.Fawzi@ottawa.ca)

**\*\*Please note that due to the current situation, I am working remotely. Email is currently the best way to contact me\*\***

---

**From:** Johnson, Warren <Warren.Johnson@stantec.com>  
**Sent:** June 14, 2022 2:37 PM  
**To:** Fawzi, Mohammed <mohammed.fawzi@ottawa.ca>  
**Cc:** Kilborn, Kris <kris.kilborn@stantec.com>; Shahzadeh, Serene <Serene.Shahzadeh@stantec.com>; Cody, Neal <Neal.Cody@stantec.com>  
**Subject:** 1560 Scott Street

**CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.**

**ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.**

Hi Mohammad,

As a follow up from today's meeting see below items discussed:


- FUS is required when OBC calculations exceed 9000 L/min. New boundary conditions will be requested with the revised calculation. A sketch should be provided illustrating the distance from the existing hydrants to the proposed building. Mohammad to provide information regarding hydrant classifications.
- The comment regarding the allowable release rate using a runoff coefficient of 0.5 can be deleted. As per discussion in the previous meeting, given that this is not a full modification to the property a post to pre swim analysis is acceptable (pre-development C being 0.86). We will review correspondence to see if there was an email to this effect from the meeting with Eric.
- The northern drainage area (EXT-1) can be discounted from the allowable release rate since only minor revisions are being made to this area.
- Rooftop storage plans are not required given that the roof plan is subject to change prior to building permit and the servicing report provides a very conservative volume estimate. A line will be added to the report to indicate that the mechanical consultant is required to provide a sign-off letter confirming that they will respect the requirements outlined in the servicing report.
- It was noted that dual water services are required for the building. Pending mechanical confirmation, the secondary service will be provided by the existing water stub off of the Bullman Street access to the north of the proposed building.

If you have any questions let me know.

Thanks,

**Warren Johnson** C.E.T.  
Civil Engineering Technologist  
Direct: 613 784-2272  
Warren.Johnson@stantec.com

Stantec



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

Please consider the environment before printing this email.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.



Appendix E Drawings  
April 20, 2023

## **Appendix E** **DRAWINGS**