

**Site Servicing and Stormwater
Management Report, Holland
Cross Ottawa, ON**

File: 160410274



Prepared for:
LaSalle Investment Management

Prepared by:
Stantec Consulting Ltd.
1331 Clyde Avenue, Suite 400
Ottawa, ON K2C 3G4

March 8, 2023

Revision	Description	Prepared by		Checked by
0	Site Servicing and Stormwater Management Report	Thakshika Rathnasooriya	August 11, 2020	Kris Kilborn
1	Report Updates for Detailed Design Site Plan Approval Submission	Sara Kardash	January 28, 2022	Neal Cody
2	Site Servicing and Stormwater Management Report	Ashmeet Singh Muker	November 25, 2022	Neal Cody
3	Site Servicing and Stormwater Management Report	Warren Johnson	March 8, 2023	Neal Cody

Sign-off Sheet

This document entitled Site Servicing and Stormwater Management Report, Holland Cross Ottawa, ON was prepared by Stantec Consulting Ltd. ("Stantec") for the account of LaSalle Investment Management (the "Client"). Any reliance on this document by any third party is strictly prohibited. The material in it reflects Stantec's professional judgment in light of the scope, schedule and other limitations stated in the document and in the contract between Stantec and the Client. The opinions in the document are based on conditions and information existing at the time the document was published and do not take into account any subsequent changes. In preparing the document, Stantec did not verify information supplied to it by others. Any use which a third party makes of this document is the responsibility of such third party. Such third party agrees that Stantec shall not be responsible for costs or damages of any kind, if any, suffered by it or any other third party as a result of decisions made or actions taken based on this document.



Prepared by _____
(signature)

Warren Johnson, C.E.T.



Reviewed by: _____
(signature)

Kris Kilborn, P.Eng.



Approved by _____
(signature)

Neal Cody, P.Eng



Table of Contents

1.0	INTRODUCTION	1.1
2.0	BACKGROUND	2.1
3.0	WATER SUPPLY SERVICING.....	3.1
3.1	BACKGROUND.....	3.1
3.2	WATER DEMANDS	3.1
3.3	PROPOSED SERVICING.....	3.2
3.4	SUMMARY OF FINDINGS.....	3.4
4.0	WASTEWATER SERVICING	4.1
4.1	BACKGROUND.....	4.1
4.2	DESIGN CRITERIA	4.1
4.3	PROPOSED SERVICING.....	4.1
5.0	STORMWATER MANAGEMENT	5.1
5.1	OBJECTIVES	5.1
5.2	SWM CRITERIA AND CONSTRAINTS	5.1
5.3	STORMWATER MANAGEMENT	5.2
5.3.1	Allowable Release Rate	5.2
5.3.2	Storage Requirements.....	5.3
5.3.3	Results	5.5
6.0	GRADING AND DRAINAGE.....	6.1
7.0	UTILITIES.....	6.1
8.0	APPROVALS.....	8.1
9.0	GEOTECHNICAL INVESTIGATION	9.1
10.0	CONCLUSIONS.....	10.1
10.1	WATER SERVICING	10.1
10.2	SANITARY SERVICING	10.1
10.3	STORMWATER SERVICING	10.1
10.4	GRADING.....	10.1
10.5	UTILITIES.....	10.1
10.6	APPROVALS/PERMITS	10.2

LIST OF TABLES

Table 3.1: Estimated Water Demands.....	3.2
Table 3.2: Boundary Conditions.....	3.3
Table 3.3: Hydrant and Fire Flow Demands.....	3.3
Table 5.1: Target Release Rate	5.3

SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

Table 5.2: 100 Year Summary of Roof Controls.....	5.4
Table 5.3: Subsurface Storage Area (L101A)	5.5
Table 5.4: Uncontrolled Non-Tributary Area (UNC-1)	5.5
Table 5.5: Summary 100 Year Event Release Rates	5.5

LIST OF FIGURES

Figure 1.1: Location Plan	1.1
--	------------

LIST OF APPENDICES

APPENDIX A WATER SUPPLY SERVICING	A.1
A.1 Domestic Water Demand Estimate	A.1
A.2 HYDRAULIC ANALYSIS SHEET	A.2
A.3 Fire Flow Requirements per FUS.....	A.3
A.4 Fire Flow Requirements Per OBC.....	A.4
A.5 Boundary Conditions	A.5
A.6 Architect Confirmations.....	A.6
APPENDIX B WASTEWATER SERVICING	B.1
B.1 Sanitary Sewer Design Sheet.....	B.1
APPENDIX C STORMWATER MANAGEMENT	C.1
C.1 Storm Sewer Design Sheet.....	C.1
C.2 Rational Method Calculations	C.2
APPENDIX D DESIGN CRITERIA AND REPORT EXCERPTS	D.1
D.1 2013 Holland Cross Expansion SWM Report Excerpts	D.1
D.2 June 14, 2022 City Meeting Minutes	D.2
APPENDIX E DRAWINGS.....	E.1

INTRODUCTION
March 8, 2023

1.0 INTRODUCTION

This Site Servicing and Stormwater Management Report has been prepared to support an application for Zoning Amendment for a property known municipally as 1560 Scott Street. The site is currently zoned Mixed-Use Centre Zone (MC) and is located in the City of Ottawa in the northwest quadrant of the intersection of Hamilton Avenue and Bullman Street and is illustrated on **Figure 1.1**. The proposed mixed-use development comprises a single 25 storey building with retail on the first floor and 281 residential apartment units above. The 0.30ha (0.74 acre) site is currently designated as office space.

The intent of this report is to provide a servicing scenario for the site that is free of conflicts, provides on-site servicing in accordance with City of Ottawa design guidelines, and utilizes the existing local infrastructure in accordance with the guidelines outlined per consultation with City of Ottawa staff.

Figure 1.1: Location Plan



SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

BACKGROUND

March 8, 2023

2.0 BACKGROUND

The following background studies have been referenced during the servicing and stormwater management design of the proposed site:

- *Geotechnical Engineering Design Input Holland Cross Expansion, 1560 Scott Street, Ottawa, ON, Golder Associates Inc., May 2020*
- *Servicing & Stormwater Management Report, Holland Cross Expansion, Ottawa, ON, Novatech Engineers, Planners & Landscape Architects, August 2014*
- *City of Ottawa Design Guidelines – Water Distribution, Infrastructure Services Department, City of Ottawa, First Edition, July 2010*
- *City of Ottawa Sewer Design Guidelines, 2nd Ed., City of Ottawa, October 2012*
- *Technical Bulletin ISTB-2018-01 Revision to Ottawa Design Guidelines – Sewer, City of Ottawa, March 2018*
- *Technical Bulletin ISTB-2018-02 Revision to Ottawa Design Guidelines – Water Distribution, City of Ottawa, March 2018*

3.0 WATER SUPPLY SERVICING

3.1 BACKGROUND

The proposed mixed use development is located on the north-western side of the intersection of Bullman Street and Hamilton Avenue in the Hintonburg community of the City of Ottawa. The property is located within the City's Pressure Zone 1W. Average ground elevations of the site are approximately 61.95m. Under normal operating conditions, hydraulic grade lines vary from approximately 107.9m to 114.6m as confirmed through boundary conditions as provided by the City of Ottawa (see **Appendix A**).

According to City of Ottawa District Plans, existing water infrastructure present on the proposed site is a 150 mm diameter PVC watermain branching off a 200 mm PVC watermain running along Hamilton Avenue. Given the size of the development and domestic demand requirements for the proposed high-rise buildings, two separate connections to the main are required separated by a valve for redundancy. The proposed site will be serviced via a dual 150mm building service TVS connection to the existing 200 mm watermain along Hamilton Avenue as shown on the Site Servicing Plan (see **Drawing SSGP-1**). The existing 150 mm diameter water service lateral running east along the site will be blanked at the main and any associated internal plumbing from the existing building will be relocated as required by the mechanical consultant (refer to the **Servicing and Stormwater Management Declaration** provided with the comments response letter).

3.2 WATER DEMANDS

Water demands for the development were estimated using the Ministry of Environment's Design Guidelines for Drinking Water Systems (2008) and the Ottawa Design Guidelines – Water Distribution (2010). A daily rate of 350 L/cap/day has been applied for the population of the proposed site. Population densities have been assumed 2.1 pers./two-bedroom and 1 bedroom plus den apartment units, and 1.4 pers./studio and one-bedroom apartment units. See **Appendix A.1** for detailed domestic water demand estimates. Additionally, commercial and retail domestic demands have been estimated at 28,000L/ha/day of floor area.

The average day demand (AVDY) for the entire site was determined to be 2.07 L/s. The maximum daily demand (MXDY) is 2.5 times the AVDY for residential areas and 1.5 times the AVDY for commercial areas, which sums to 5.12 L/s. The peak hour demand (PKHR) is 2.2 times the MXDY for residential areas and 1.8 times the MXDY for commercial areas, totaling 11.25 L/s. The estimated demands are summarized in **Table 3.1** below.

Table 3.1: Estimated Water Demands

Demand Type	Population	Area (m²)	AVDY (L/s)	MXDY (L/s)	PKHR (L/s)
Residential	500	-	2.02	5.06	11.14
Commercial, Lobby, and Amenity Space	-	1282	0.04	0.06	0.11
Total Site:	500	-	2.07	5.12	11.25

According to the FUS Guidelines, a building of non-combustible construction with unprotected openings is considered for the assessment. Additionally, the building will be sprinklered, with final sprinkler design to conform to the NFPA 13 standards. An occupancy charge for limited combustible material as well as the extraneous fire flows required for the building exposures were considered in the assessment as per the FUS Guidelines. A firewall will be provided between the existing and proposed buildings and 2-hour fire separations will be provided between each floor of the proposed building. Refer to **Appendix A.6** for confirmation from the architect of the assumed criteria. As per the results, the minimum fire flow required is 66.7 L/s (4,000L/min, see **Appendix A.3**).

Furthermore, non-combustible with fire-resistance ratings was considered in the assessment for fire flow requirements according to the Ontario Building Code (OBC) Guidelines. As a residential apartment the building falls under occupancy Class C. Based on calculations per the OBC Guidelines. The minimum required fire flows for this development are 150 L/s (9,000L/min, see **Appendix A.4**).

Therefore, the required fire flow according to FUS methodology is calculated to be 4,000 L/min which is less than the calculated fire flow as per OBC methodology. Thus, to be conservative in approach the fire flow requirement of 9,000 L/min from OBC methodology would be considered for the proposed development.

3.3 PROPOSED SERVICING

Per the boundary conditions provided by the City of Ottawa (**Table 3.2**: Boundary Conditions and based on the elevation on-site of 62.95m, adequate flows are available for the subject site with pressures ranging from 44.95m (63.9psi) to 51.65m (73.4psi).

SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

WATER SUPPLY SERVICING

March 8, 2023

Table 3.2: Boundary Conditions

Demand Scenario	Head (m)	Pressure (psi)
Minimum HGL	107.9	153.4
Maximum HGL	114.6	162.9
Max Day + Fire Flow	104.4	148.5

This pressure range is within the guidelines of 50-80 psi based on Ottawa's Design Guidelines for Water Distribution, therefore pressure reducing valves (PRVs) would not be required to protect from municipal system pressures, but they are required within high pressure zones of the building water distribution system. This is because based on the Hydraulic Analysis calculation sheet attached in **Appendix A.2**, pressures at the 25th level of the building will be below the required 40psi, and as such, booster and fire pumps are to be designed by the mechanical engineering consultant to service the upper levels of the development.

Therefore, any fixtures placed within the high-pressure zones (i.e., fed by the booster pump) and anything connected 5m below ground level fed by the municipal pressure will need PRVs.

Therefore, using boundary conditions for the proposed development under maximum day demands and a fire flow requirement of 9,000L/min per the OBC methodology, it can be confirmed that the system will maintain a residual pressure of approximately 58.9 psi; which is in excess of the required 140 kPa (20 psi). The above demonstrates that the existing watermain within Hamilton Avenue can provide adequate fire and domestic flows in excess of flow requirements for the subject site. An existing hydrant is located east of the subject site and is within 80m of the proposed building siamese connection per OBC requirements.

Two proposed watermain services (sized at 150 mm in diameter) separated by an isolation valve to the existing 203 mm water main in front of the building on Hamilton Avenue North will provide the basic day demand to the building.

As per Technical Bulletin ISTB 2021-03, hydrant classification was done to calculate the overall fire flow demand. The distances between the site and the fire hydrants are shown in **Table 3.3**.

Table 3.3: Hydrant and Fire Flow Demands

Location	Distance to Building (m)	Fire Flow Demand (L/min)	Fire Flow Demand (L/s)
Hamilton Ave N	104.1	3800	63.33
Courtyard	Local	5700	95.00
Total		9500	158.33

As can be seen from the table above, the fire flow demand from the hydrants is more than sufficient for the required Fire Flow requirement of 9,000 L/min for the proposed development.



3.4 SUMMARY OF FINDINGS

The proposed development is located in an area of the City's water distribution system that has sufficient capacity to provide both the required domestic and emergency fire flows. Based on boundary conditions as provided by City of Ottawa staff, fire flows are available for this development based on FUS and OBC guidelines and as per the City of Ottawa water distribution guidelines. Pumps to service the upper levels will need to be designed by the mechanical consultant.

4.0 WASTEWATER SERVICING

4.1 BACKGROUND

The site will be serviced via a proposed 250 mm diameter sanitary service that discharges to the existing 250 mm diameter sanitary sewer within Hamilton Avenue ROW (see **Drawing SSGP-1**). The existing 250 mm diameter sanitary service lateral running east along the site will be abandoned and any associated internal plumbing from the existing building will be relocated as required by the mechanical consultant (refer to the **Servicing and Stormwater Management Declaration**).

4.2 DESIGN CRITERIA

As outlined in the City of Ottawa Sewer Design Guidelines and the MECP's Design Guidelines for Sewage Works, the following criteria were used to calculate estimated wastewater flow rates and to size the sanitary sewers:

- Minimum Velocity – 0.6 m/s (0.8 m/s for upstream sections)
- Maximum Velocity – 3.0 m/s
- Manning roughness coefficient for all smooth wall pipes – 0.013
- Minimum size – 200mm dia. for residential areas
- Average Wastewater Generation – 280L/cap/day
- Peak Factor – 4.0 (Harmon's)
- Extraneous Flow Allowance – 0.33 l/s/ha (conservative value)
- Manhole Spacing – 120 m
- Minimum Cover – 2.5m
- Population density for studio and single-bedroom apartments – 1.4 pers./apartment
- Population density for one-bedroom plus den and two-bedroom apartments – 2.1 pers./bedroom

4.3 PROPOSED SERVICING

The proposed site will be serviced by gravity sewers which will direct the wastewater flows (approx. 6.56 L/s with allowance for infiltration) to the proposed 250 mm diameter sanitary sewer. A sanitary sewer design sheet for the proposed sanitary sewers is included in **Appendix B.1**. Capacity in the downstream sanitary sewer system will be assessed during detailed design. Full port backwater valves are to be installed on all sanitary services within the site to prevent any surcharge from the downstream sewer main from impacting the proposed property.

5.0 STORMWATER MANAGEMENT

5.1 OBJECTIVES

The objective of this stormwater management plan is to determine the measures necessary to control the quantity/quality of stormwater released from the proposed development to criteria established during the pre-consultation/zoning process, and to provide sufficient detail for approval and construction.

5.2 SWM CRITERIA AND CONSTRAINTS

Criteria were established by combining current design practices outlined by the City of Ottawa Design Guidelines (2012), and through consultation with City of Ottawa staff. The following summarizes the criteria, with the source of each criterion indicated in brackets:

General

- Use of the dual drainage principle (City of Ottawa).
- Wherever feasible and practical, site-level measures should be used to reduce and control the volume and rate of runoff. (City of Ottawa)
- Assess impact of 100-year event outlined in the City of Ottawa Sewer Design Guidelines on major & minor drainage system (City of Ottawa)
- The proposed site is not subject to quality control criteria due to the small site size and land usage of the development (City of Ottawa).

Storm Sewer & Inlet Controls

- All stormwater runoff from the proposed site up to and including the 100-year event to be stored on site and released into the minor system at a maximum rate equivalent to 51.5 L/s calculated based on 2-year pre-development rates.
- Proposed site to discharge to the proposed 200mm diameter storm service, directly connecting to the 450mm storm sewer on Hamilton Avenue ROW at the boundary of the subject site (City of Ottawa).
- 100-year Storm HGL to be a minimum of 0.30 m below building foundation footing (City of Ottawa).
- As discussed with the City on June 14, 2022 area EXT-1 can be discounted from the allowable site release rate given that only minor changes to curb works are being proposed in this area.

Surface Storage & Overland Flow

- Building openings to be minimum of 0.15m above the 100-year water level (City of Ottawa)

SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

STORMWATER MANAGEMENT

March 8, 2023

- Maximum depth of flow under either static or dynamic conditions shall be less than 0.35m in the 100-year event (City of Ottawa)
- Provide adequate emergency overflow conveyance off-site (City of Ottawa)

The areas which were examined for stormwater management include BLDG (Building), L101A (Underground Storage Area), and UNC-1 (Uncontrolled Area). Although the drawings show a fourth area, EXT-1, this area has not been considered in the Modified Rational Method (MRM) calculations as this area will remain as it is other than an addition of a small amount of grass, reducing its runoff coefficient slightly.

5.3 STORMWATER MANAGEMENT

The intent of the stormwater management plan presented herein is to mitigate any negative impact that the proposed development will have on the existing storm sewer infrastructure, while providing adequate capacity to service the proposed buildings, parking and access areas. The proposed stormwater management plan is designed to detain runoff on the roof area to ensure that peak flows after construction will not exceed the allowable site release rate detailed below.

Stormwater runoff from the proposed development will be directed to a proposed 200 mm diameter storm sewer and then south along 450mm diameter storm sewer on Hamilton Avenue. The existing 200 mm diameter storm service lateral running east along the site will be abandoned and any associated internal plumbing from the existing building will be relocated as required by the mechanical consultant. The foundation drain is to be independently connected to the storm service downstream of the internal cistern outlet with a sufficiently sized sump pump with appropriate backup power and backflow prevention (refer to the **Servicing and Stormwater Management Declaration**).

A summary of subareas and runoff coefficients is provided in **Appendix C**, and **Drawing SD-1** indicates the stormwater management sub catchments.

5.3.1 Allowable Release Rate

Available topographic information the existing conditions drainage elevations for the site are shown on **Drawing EX-1**; existing drainage areas and runoff coefficients are presented in **Drawing EXSD-1**.

The Modified Rational Method was employed to assess the rate of runoff generated during pre-development conditions. The City of Ottawa Sewer Design Guidelines identify the modified rational method as an acceptable method for determining underground storage requirements for a site of less than 2 ha in area.

The peak 100-year post-development discharge from the subject site is to be limited to the 2-year pre-development rate. The predevelopment release rate for the area has been



SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

STORMWATER MANAGEMENT

March 8, 2023

determined using the rational method and existing runoff coefficient C values for varying surface treatments per below:

- Asphalt/Hard Surface areas – C=0.90
- Gravel areas – C=0.70
- Grassed/Pervious areas – C=0.20

A time of concentration for the predevelopment area (10 minutes) was assigned based on the relatively small site and its proximity to the existing drainage outlet for the site. C coefficient values have been increased by 25% for the post-development 100-year storm event based on MTO Drainage Manual recommendations. Peak flow rates have been calculated using the rational method as follows:

$$Q = 2.78 CiA$$

Where: Q = peak flow rate, L/s

A = drainage area, ha

I = rainfall intensity, mm/hr (per Ottawa IDF curves)

C = site runoff coefficient

The target release rate for the site is summarized in **Table 5.1** below:

Table 5.1: Target Release Rate

Design Storm	Target Flow Rate (L/s)
2-Year and 100-Year (Pre-development Conditions)	51.5

5.3.2 Storage Requirements

To meet the restrictive stormwater release criteria for the proposed development, rooftop storage will be used to promote stormwater detention on building roof tops and reduce the peak outflow from the site. Additionally, an underground stormwater storage (cistern) system is proposed in conjunction with a submersible pump to control flows to the target rate. The proposed ponding areas, and underground storage tank details are specified on **Drawing SD-1**.

5.3.2.1 Rooftop Storage

It is proposed to retain stormwater on the building rooftop by installing restricted flow roof drains. The following calculations assume the roofs will be equipped with standard Watts Model RD-100_A_ADJ Accuflow Roof Drains which will be 100% closed.

Watts Drainage "Accutrol" roof drain weir data has been used to calculate a practical roof release rate and detention storage volume for the rooftops. It should be noted that the "Accutrol" weir has been used as an example only, and that other products may be specified for use,



SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

STORMWATER MANAGEMENT

March 8, 2023

provided that the total roof drain release rate is restricted to match the maximum rate of release indicated in **Table 5.2**, and that sufficient roof storage is provided to meet (or exceed) the resulting volume of detained stormwater. Storage volume and controlled release rate are summarized in **Table 5.2**:

Table 5.2: 100 Year Summary of Roof Controls

Area ID	Design Storm	Depth (mm)	Discharge (L/s)	Volume Stored (m ³)	Drawdown Time (hr)
Roof	2-Year	83	9.46	9.31	0.3
	100-Year	139	9.46	42.73	1.3

The total roof area of the proposed building is approx. 1,300 m² with 80% (1,040 m²) of the roof area assumed to be available for storage, with the runoff coefficient for the roof area as C = 0.90. The roof area drains have been designed to optimize the maximum allowable ponding depth of 0.15m as per the Ontario Building Code. Drain drawdown times for the 2 and 100-year storm event are also shown in **Table 5.2**. Drainage from the roof will directly discharge to the existing 450mm diameter storm sewer on Hamilton Avenue North with the proposed new 200mm storm service downstream of the internal cistern outlet (refer to the **Servicing and Stormwater Management Declaration**).

A *Flow Control Roof Drainage Declaration* letter has been prepared and will be reviewed and signed by mechanical and structural engineers after reviewing this report. The letter will be submitted under separate cover to the City.

5.3.2.2 Subsurface Storage

Per the modified rational method calculations included as part of **Appendix C.2**, the remainder of the site is to be directed towards the catch basins in L101A which will discharge to an internal cistern with a submersible pump with a constant release rate to meet the target peak discharge rate during the 100-year event (refer to the **Servicing and Stormwater Management Declaration**).

The required 19m³ of storage will be detained on the proposed site through a cistern within the underground parking. Controlled release rates and storage volumes required are summarized in Table 5.3.

Table 5.3: Subsurface Storage Area (L101A)

Tributary Area	Design Storm	Design Head (m)	Discharge (L/s)	Orifice Type	V _{required} (m ³)
L101A	2-Year	0.25	18.77	IPEX Tempest HF 133mm Orifice	0.3
	100-Year	0.25	18.77		18.5

5.3.2.3 Uncontrolled Area

Due to grading restrictions, one sub catchment area has been designed without a storage component. The existing catchment area also discharges off-site uncontrolled to the adjacent Hamilton Avenue. Peak discharges from uncontrolled areas have been considered in the overall SWM plan and have been balanced through overcontrolling proposed site discharge rates to meet target levels and are shown in **Table 5.4**.

Table 5.4: Uncontrolled Non-Tributary Area (UNC-1)

Design Storm	Discharge (L/s)
2-Year	8.0
100-Year	23.3

5.3.3 Results

Table 5.5 demonstrates that the proposed stormwater management plan provides adequate attenuation storage to control post-development flows to the target peak outflow rate of the site.

Table 5.5: Summary 100 Year Event Release Rates

Catchment Area	100-Year Peak Discharge (L/s)
Uncontrolled	23.3
Controlled – Subsurface & Roof	28.2
Total	51.5
Target	51.5

6.0 GRADING AND DRAINAGE

The proposed development site measures approximately 0.3ha in area. The topography across the site is relatively flat on the northern boundary with a marginally increased slope on the southern boundary of the proposed building, and currently drains from west to east, with overland flow generally being directed to the adjacent Hamilton Avenue ROW. A grading plan (see **Drawing SSGP-1**) has been provided to satisfy the stormwater management requirements, adhere to any geotechnical restrictions for the site, and provide for minimum cover requirements for storm and sanitary sewers where possible. Site grading has been established to provide emergency overland flow routes required for stormwater management in accordance with City of Ottawa requirements.

The subject site maintains emergency overland flow routes for flows deriving from storm events in excess of the maximum design event to the existing Hamilton Avenue as depicted in **Drawing SSGP-1**.

March 8, 2023

7.0 UTILITIES

Hydro, Bell, Gas and Cable servicing for the proposed development should be readily available within subsurface utility infrastructure within the Hamilton Avenue ROW. Exact size, location and routing of utilities, along with determination of any off-site works required for redevelopment, will be finalized after design circulation.

Enbridge has a plant within the vicinity of the site which will likely have sufficient capacity, however, only after receiving the detail loading criteria will they be able to provide their final design.

Detailed design of the required utility services will be completed by the respective utility companies.

Approvals
March 8, 2023

8.0 APPROVALS

An Ontario Ministry of the Environment, Conservation and Parks (MECP) Environmental Compliance Approval (ECAs, formerly Certificates of Approval C of A) under the Ontario Water Resources Act maybe a requirement if existing sewers are shared to outlet onto Hamilton Avenue as the proposed site is expected to be severed into a separate parcel of land.

Requirement for a MECP Permit to Take Water (PTTW) for pumping during construction of the underground parking levels will be confirmed by the geotechnical consultant.

9.0 GEOTECHNICAL INVESTIGATION

A geotechnical investigation was conducted by Golder Associates Ltd. in May 2020. Subsurface soil conditions within the boundaries of the proposed site were determined by 4 test pits distributed across the site. Some investigations were previously completed in 1986 by McRostie. The subsurface profile across the site described by the previous investigation consists of 2.3m of fill material made up by topsoil, sand gravel, clay, bricks, wood, metal and concrete below the original ground surface and underlain by glacial till.

An organic layer was found to be 0.3m to 0.8m thick near the building in test pits M120/E120 and N150/E120 at depths of 1.7m and 1.35m below ground surface. It is anticipated that during construction of the existing building the noted materials above were removed.

Bedrock elevations were previously encountered at elevations of 59.8 to 61.0m. Groundwater levels have altered since previous investigation and current water levels are influenced by existing building drainage systems.

10.0 CONCLUSIONS

10.1 WATER SERVICING

Based on the supplied boundary conditions for existing watermains and estimated domestic and fire flow demands for the subject site, it is anticipated that the proposed servicing in this development will provide sufficient capacity to sustain both the required domestic demands and emergency fire flow demands of the proposed site. Pumps to service the upper levels and PRVs to protect fixtures from the high pressures will need to be designed by the mechanical consultant.

10.2 SANITARY SERVICING

The existing sanitary sewer network is sufficiently sized to provide gravity drainage of the proposed site. The subjected site will be serviced by a new proposed 250mm dia. gravity sewer service lateral which will direct wastewater flows (approx. 8.3 L/s) to the 250mm dia. sewer along Hamilton Avenue at the eastern boundary of the property. The existing drainage outlet has sufficient capacity to receive sanitary discharge from the site.

10.3 STORMWATER SERVICING

The proposed stormwater management plan is in compliance with local and provincial standards. Rooftop storage and minimal surface storage has been controlled to meet the allowable release rate to the existing 450mm diameter storm sewer within Hamilton Avenue ROW. The downstream receiving sewer has sufficient capacity to receive runoff volumes from the site.

10.4 GRADING

Grading for the site has been designed to provide an emergency overland flow route as per City requirements and reflects the recommendations in the Geotechnical Investigation Report prepared by Golder Associates Ltd. Erosion and sediment control measures will be implemented during construction to reduce the impact on existing facilities.

10.5 UTILITIES

Utility infrastructure exists within the Hamilton Avenue ROW at the eastern boundary of the proposed site. It is anticipated that existing infrastructure will be sufficient to provide a means of distribution for the proposed site. Exact size, location and routing of utilities will be finalized after design circulation.

CONCLUSIONS

March 8, 2023

10.6 APPROVALS/PERMITS

An Ontario Ministry of the Environment, Conservation and Parks (MECP) Environmental Compliance Approval (ECAs, formerly Certificates of Approval C of A) under the Ontario Water Resources Act maybe a requirement if existing sewers are shared to outlet onto Hamilton Avenue as the proposed site is expected to be severed into a separate parcel of land. Requirement for a MECP Permit to Take Water (PTW) for sewer and building construction will be confirmed by the geotechnical consultant.

Appendix A Water Supply Servicing
March 8, 2023

Appendix A **WATER SUPPLY SERVICING**

A.1 **DOMESTIC WATER DEMAND ESTIMATE**

Holland Cross Phase 3 Residential

Project #160410274
3-Jun-22

	Number of Units	Density	Population
Studio	18	1.4	25.2
1 BR	110	1.4	154.0
1BR + Den	51	2.1	107.1
2 BR	101	2.1	212.1
2BR + Den	0	3.1	0.0
Guest	1	1.4	1.4

Building ID	Area (m ²)	Population	Daily Rate of Demand ^{1,2} (L/m ² /day)	Avg Day Demand		Max Day Demand ^{3,4}		Peak Hour Demand ^{3,4}	
				(L/min)	(L/s)	(L/min)	(L/s)	(L/min)	(L/s)
Residential		500	350	121.5	2.02	303.7	5.06	668.1	11.14
Commercial, Lobby and Amenity Space	1,282		28000	2.5	0.04	3.7	0.06	6.7	0.11
Total Site :				124.0	2.07	307.4	5.12	674.9	11.25

¹ Average day water demand for residential areas are equal to 350 L/cap/d

² 28,000 L/gross ha/day is used to calculate water demand for commercial facilities.

³ Water demand criteria used to estimate peak demand rates for residential areas are as follows:

maximum day demand rate = 2.5 x average day demand rate

peak hour demand rate = 2.2 x maximum day demand rate

⁴ Water demand criteria used to estimate peak demand rates for commercial and institutional areas are as follows:

maximum day demand rate = 1.5 x average day demand rate

peak hour demand rate = 1.8 x maximum day demand rate

Appendix A Water Supply Servicing
March 8, 2023

A.2 HYDRAULIC ANALYSIS SHEET



Project:	Holland Cross	No.	160410274
SITE PLAN HYDRAULIC ANALYSIS			
Revision:	00	Prepared By:	AM
Revision Date:	24-Nov-2022	Checked By:	NC

BOUNDARY CONDITIONS (BC)	
Connection at Hamilton Avenue	
Site Plan Revision Date	14-Oct-2022
Min. HGL (m)	107.9
Max. HGL (m)	114.6
Max. Day + Fire Flow (150 L/s)	104.4

Ground Floor Elevation (GFE) (Level 01) (m)	62.95
---	-------

GROUND FLOOR (GF) PRESSURE RANGE				
	GF HGL (m)	GF Pressure (kPa)	GF Pressure (psi)	Outcome
	= BC HGL (m) - FFE (m)	= GF HGL (m) x 9.804 (kPa/m)	= GF Pressure (kPa) x 0.145 (psi/kPa)	If min <50 psi: booster pump If max >100 psi: pressure reducer
Minimum Normal	44.95	440.7	63.9	No Booster Pump Required
Maximum Normal	51.65	506.4	73.4	No Pressure Reducer Required

Number of Floors Not Below Ground	25
Approximate Height of One Storey (m)	3.21
Pressure Drop Per Floor (kPa)	31.5
Pressure Drop Per Floor (psi)	4.6

RESIDUAL PRESSURE RANGE IN MULTI-LEVEL BUILDINGS			
	Residual Pressure (kPa)	Residual Pressure (psi)	Outcome
Top Floor Min	-314.6	-45.6	Booster Pump Required
Top Floor Max	-248.9	-36.1	
Maximum Number of Floors Above Ground at Minimum Pressure	5		

RESIDUAL PRESSURE FROM FIRE FLOW				
	Residual HGL (m)	Residual Pressure (kPa)	Residual Pressure (psi)	Outcome
Ground Floor	41.45	406.4	58.9	Fire Pump Required
Top Floor	-35.59	-348.9	-50.6	

Pressure Check		
	Pressure (kPa)	Pressure (psi)
Pressure Below Minimum	<138	<20
Pressure Below Normal	138-345	20-50
Pressure Within Normal Range	345-552	50-80
Pressure Above Normal Range	552-690	80-100
Pressure Above Maximum	>690	>100

Appendix A Water Supply Servicing
March 8, 2023

A.3 FIRE FLOW REQUIREMENTS PER FUS



FJS Fire Flow Calculation Sheet - 2020 FUS Guidelines

Santec Project #: 160410274
 Project Name: Holland Cross
 Date: 2/24/2023

Fire Flow Calculation #: 1
 Description: 25 Floor Apartment Building with Fire Separations between floors

Notes: 1356m² Floorplate

Step	Task	Notes	Value Used	Req'd Fire Flow (L/min)						
1	Determine Type of Construction	Type II - Noncombustible Construction / Type IV-A - Mass Timber Construction	0.8	-						
2	Determine Effective Floor Area	Sum of Two Largest Floors + 50% of Eight Additional Floors	NO	-						
		1356	1356	-						
3	Determine Required Fire Flow	(F = 220 x C x A ^{1/2}). Round to nearest 1000 L/min	-	6000						
4	Determine Occupancy Charge	Limited Combustible	-15%	5100						
5	Determine Sprinkler Reduction	Conforms to NFPA 13	-30%	2040						
		Standard Water Supply	-10%							
		Not Fully Supervised or N/A	0%							
		% Coverage of Sprinkler System	100%							
6	Determine Increase for Exposures (Max. 75%)	Direction	Exposure Distance (m)	Exposed Length (m)	Exposed Height (Stories)	Length-Height Factor (m x stories)	Construction of Adjacent Wall	Firewall / Sprinklered ?	-	-
		North	0 to 3	49.3	1	41-60	Type III-IV - Unprotected Openings	YES	0%	1020
		East	20.1 to 30	26.5	5	> 100	Type III-IV - Unprotected Openings	NO	5%	
		South	10.1 to 20	49.8	3	> 100	Type V	NO	15%	
		West	0 to 3	23.1	1	21-49	Type III-IV - Unprotected Openings	YES	0%	
7	Determine Final Required Fire Flow	Total Required Fire Flow in L/min, Rounded to Nearest 1000L/min							4000	
		Total Required Fire Flow in L/s							66.7	
		Required Duration of Fire Flow (hrs)							1.50	
		Required Volume of Fire Flow (m ³)							360	

A.4 FIRE FLOW REQUIREMENTS PER OBC

Fire Flow Calculations as per Ontario Building Code (Appendix A)

Job# 1604-10274
Date 24-Feb-23

Designed by: WJ
Checked by: NC
Description: 25 Floor Apt

$$Q = KVS_{tot}$$

Q = Volume of water required (L)

V = Total building volume (m³)

K = Water supply coefficient from Table 1

S_{tot} = Total of spatial coefficient values from property line exposures on all sides as obtained from the formula

$$S_{tot} = 1.0 + [S_{side1} + S_{side2} + S_{side3} + S_{side4}]$$

1	Type of construction	Building Classification		Water Supply Coefficient
	Non-Combustible with Fire-Resistance Ratings	A-2, B-1, B-2, B-3, C, D		10
2	Area of one floor (m ²)	number of floors	height of ceiling (m)	Total Building Volume (m ³)
	1356	25	3.0	102,284
3	Side	Exposure Distance (m)	Spatial Coefficient	Total Spatial Coefficient
	North	0	0.5	2
	East	26	0	
	South	19.1	0	
	West	0	0.5	
4	Established Fire Safety Plan?	Reduction in Volume (%)		Total Volume Reduction
	no	0%		0%
5	Total Volume 'Q' (L)			
				2,045,680
	Minimum Required Fire Flow (L/min)			
			9,000	

Appendix A Water Supply Servicing
March 8, 2023

A.5 BOUNDARY CONDITIONS

Boundary Conditons for Hamilton Avenue - 29 Storey Condo



Legend

- PRIVATE
- PUBLIC

From: [Wu, John](#)
To: [Rathnasooriya, Thakshika](#)
Subject: RE: Boundary Conditions
Date: Thursday, July 30, 2020 4:07:21 PM
Attachments: [Hamilton Avenue July 2020.pdf](#)

Here is the result:

The following are boundary conditions, HGL, for hydraulic analysis on Hamilton Avenue (zone 1E) assumed to be connected to the 203mm on Hamilton Avenue (see attached PDF for location).

Minimum HGL = 107.9m

Maximum HGL = 114.6m

Max Day + FF = 104.4m

These are for current conditions and are based on computer model simulation.

Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermain deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.

John

From: Rathnasooriya, Thakshika <Thakshika.Rathnasooriya@stantec.com>
Sent: July 29, 2020 2:46 PM
To: Wu, John <John.Wu@ottawa.ca>
Cc: Kilborn, Kris <kris.kilborn@stantec.com>
Subject: Boundary Conditions

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi John,

I am looking for watermain hydraulic boundary conditions for Holland Cross Phase 3 residential. The proposed residential building consists of 29 storeys. We anticipate connecting to the existing 150mm watermain service in addition to constructing a secondary connection (basic day demand is greater than 50 m³/day). The service is connected to the existing 200mm diameter watermain on Hamilton Avenue North and Bullman Street. (please see attached figure).


Please see the estimated domestic demands and fire flow requirements for the site as mentioned below:

Average Day Demand - 2.63 L/s

Max Day Demand - 6.55 L/s

Peak Hour Demand - 14.41 L/s

Fire Flow Requirement per OBC were used for the apartment building - 150 L/s (9,000 L/min)



Thank you.

Shika Rathnasooriya, P.Eng.

Direct: 613 724-4081
Thakshika.Rathnasooriya@stantec.com

Stantec
400 - 1331 Clyde Avenue
Ottawa ON K2C 3G4



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

,

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

,

Appendix A Water Supply Servicing
March 8, 2023

A.6 ARCHITECT CONFIRMATIONS

Johnson, Warren

From: Robert Matthews <robertm@n45.ca>
Sent: Friday, February 17, 2023 2:20 PM
To: Shahzadeh, Serene; Yin, David; Holmes, Keith; Johnson, Warren; Cody, Neal
Cc: Barbieri, Sam; Ghajar, Sonia; Meloshe, Nancy
Subject: RE: 1560 Scott - Resubmission Comments

Follow Up Flag: Follow up
Flag Status: Flagged

Serene,

In respect to your letter and item nos. 9 & 10, we respond as follows:-

Item 9

On the Ground Floor attached, the RED line is the fire separation.

Item 10

- The building construction will be non-combustible – concrete.
- Unsupervised sprinklers conforming to NFPA 13 will be provided, the design will be designed by a professional mechanical engineer.
- The floors will be designed as 2hr fire separations as per FUS guidelines.
- The building envelope will be designed at a minimum as a 1hr fire separation. This includes walls, decorative elements, structure, and floors, all as per FUS guidelines.
- The fire hazard of the building contents will conform to FUS guidelines.
- The gross floor area of the largest floor is +/- 970m².

Robert Matthews
Partner
N45 ARCHITECTURE Inc.

I will be out of the office from Tuesday, 21 February, returning on Monday, 13 March.

N45 ARCHITECTURE Inc.

The Sovereign Building
71 Bank St., 7th Floor
Ottawa, ON.
K1P 5N2
O 613-224-0095 x 234
C 613-858-2789

From: Shahzadeh, Serene <Serene.Shahzadeh@stantec.com>
Sent: Monday, January 30, 2023 2:35 PM
To: Robert Matthews <robertm@n45.ca>; Yin, David <david.yin@stantec.com>; Holmes, Keith <Keith_Holmes@golder.com>; Johnson, Warren <Warren.Johnson@stantec.com>; Cody, Neal <Neal.Cody@stantec.com>
Cc: Barbieri, Sam <Sam.Barbieri@lasalle.com>; Ghajar, Sonia <Sonia.Ghajar@lasalle.com>; Meloshe, Nancy <Nancy.Meloshe@stantec.com>
Subject: 1560 Scott - Resubmission Comments

Good afternoon all,

We have received the resubmission comments for the Site Plan Control application on 1560 Scott Street. I have attached the draft response letter for your reference, flagging which comments are to be addressed by whom.

Please have the updates and comments addressed by February 17. Let me know if you have any questions, or if there is anything you need to address the comments.

Thanks,

Serene Shahzadeh

Planner

Serene.Shahzadeh@stantec.com

Stantec
300 - 1331 Clyde Avenue
Ottawa ON K2C 3G4




5th most sustainable corporation in the world, 1st in North America: Proud to be named a Corporate Knights world sustainability leader.

The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

Caution: This email originated from outside of Stantec. Please take extra precaution.

Attention: Ce courriel provient de l'extérieur de Stantec. Veuillez prendre des précautions supplémentaires.

Atención: Este correo electrónico proviene de fuera de Stantec. Por favor, tome precauciones adicionales.



1 GROUND FLOOR PLAN
SCALE 1:150

no.	revision	date
4	RE-ISSUE FOR SITE PLAN APP.	11 Oct. 2022
3	ISSUED FOR SITE PLAN APPLICATION	14 Jan. 2022
2	REISSUED FOR ZONING AMENDMENT	17 Sept. 2021
1	ISSUED FOR ZONING AMENDMENT	30 July 2020

N45 ARCHITECTURE INC.
71 Bank Street, 7th Floor - Ottawa, Ontario, K1P 5N2
tel. 613.224.0095 fax 613.224.9811

project
**HOLLAND CROSS
PHASE 3 RESIDENTIAL**

HOLLAND AVE, OTTAWA, ON.

construction north seal

drawing title GROUND FLOOR PLAN	
scale AS SHOWN	drawn by J. J.
date MAY 2020	checked by R.M.
project number 20-540	drawing number A-101
CONTRACTOR TO VERIFY ALL DIMENSIONS AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES BEFORE WORK COMMENCES. DO NOT SCALE DRAWINGS.	
revision	

Appendix B Wastewater Servicing
March 8, 2023


Appendix B WASTEWATER SERVICING

B.1 SANITARY SEWER DESIGN SHEET

CAP. V PEAK FLOW (%)	VEL. (FULL) (m/s)	VEL. (ACT.) (m/s)
10.82%	1.22	0.67
10.82%	1.22	0.67

Appendix C **STORMWATER MANAGEMENT**

C.1 **STORM SEWER DESIGN SHEET**

	HOLLAND CROSS		STORM SEWER DESIGN SHEET (City of Ottawa)										DESIGN PARAMETERS $I = a / (t+b)^c$ (As per City of Ottawa Guidelines, 2012)																										
	DATE: 2022-01-19		FILE NUMBER: 160410274										a = 732.951	998.071	1174.184	1735.688	MANNING'S n = 0.013	BEDDING CLASS B																					
	REVISION: 2												b = 6.199	6.053	6.014	6.014	MINIMUM COVER: 2.00 m																						
	DESIGNED BY: WAJ												c = 0.810	0.814	0.816	0.820	TIME OF ENTRY 10 min																						
LOCATION			DRAINAGE AREA																	PIPE SELECTION																			
AREA ID NUMBER	FROM M.H.	TO M.H.	AREA (2-YEAR) (ha)	AREA (5-YEAR) (ha)	AREA (10-YEAR) (ha)	AREA (100-YEAR) (ha)	AREA (ROOF) (ha)	C (2-YEAR) (-)	C (5-YEAR) (-)	C (10-YEAR) (-)	C (100-YEAR) (-)	A x C (2-YEAR) (ha)	ACCUM (2YR) (ha)	A x C (5-YEAR) (ha)	ACCUM. (5YR) (ha)	A x C (10-YEAR) (ha)	ACCUM. (10YR) (ha)	A x C (100-YEAR) (ha)	ACCUM. (100YR) (ha)	T of C (min)	I ₂ -YEAR (mm/h)	I ₅ -YEAR (mm/h)	I ₁₀ -YEAR (mm/h)	I ₁₀₀ -YEAR (mm/h)	Q _{CONTROL} (L/s)	ACCUM. (L/s)	Q _{ACT} (CIA/360) (L/s)	LENGTH (m)	PIPE WIDTH (mm)	PIPE HEIGHT (mm)	PIPE SHAPE (-)	MATERIAL (-)	CLASS (-)	SLOPE (%)	Q _{CAP} (L/s)	% FULL (-)	VEL. (FULL) (m/s)	VEL. (ACT) (m/s)	TIME OF FLOW (min)
BLDG, L101A	BLDG	MAIN	0.100	0.00	0.00	0.00	0.13	0.90	0.00	0.00	0.00	0.090	0.090	0.000	0.000	0.000	0.000	0.000	0.000	10.00	76.81	104.19	122.14	178.56	9.5	9.5	28.7	14.0	200	200	CIRCULAR	PVC	SDR 28	1.00	33.3	86.0%	1.05	1.05	0.22

C.2 RATIONAL METHOD CALCULATIONS

Stormwater Management Calculations

File No: 160410274
 Project: Holland Cross
 Date: 19-Jan-22

SWM Approach:
 Post-development to Pre-development flows

Post-Development Site Conditions:

Overall Runoff Coefficient for Site and Sub-Catchment Areas

Runoff Coefficient Table								
Catchment Type	Sub-catchment Area		Area (ha) "A"	Runoff Coefficient "C"		"A x C"	Overall Runoff Coefficient	
	ID / Description							
Controlled - Tributary	L101A	Hard	0.100	0.9	0.090			
		Soft	0.000	0.2	0.000			
	Subtotal			0.1		0.09	0.900	
Uncontrolled - Non-Tributary	UNC-1	Hard	0.039	0.9	0.035			
		Soft	0.011	0.2	0.002			
	Subtotal			0.05		0.0375	0.750	
Roof	BLDG	Hard	0.130	0.9	0.117			
		Soft	0.000	0.2	0.000			
	Subtotal			0.13		0.117	0.900	
Total			0.280		0.245			
Overall Runoff Coefficient= C:							0.87	

Total Roof Areas	0.130 ha
Total Tributary Surface Areas (Controlled and Uncontrolled)	0.100 ha
Total Tributary Area to Outlet	0.230 ha
 Total Uncontrolled Areas (Non-Tributary)	 0.050 ha
 Total Site	 0.280 ha

Roof Drain Design Calculation Sheet

Project #160410274, Holland Cross
 Roof Drain Design Sheet, Area BLDG
 Standard Watts Model R1100 Accutrol Roof Drain

Rating Curve				Volume Estimation				Water Depth (m)
Elevation (m)	Discharge Rate (cu.m/s)	Outlet Discharge (cu.m/s)	Storage (cu. m)	Elevation (m)	Area (sq. m)	Volume (cu. m)		
						Increment	Accumulated	
0.000	0.0000	0.0000	0	0.000	0	0	0	0.000
0.025	0.0003	0.0047	0	0.025	29	0	0	0.025
0.050	0.0006	0.0095	2	0.050	116	2	2	0.050
0.075	0.0006	0.0095	7	0.075	260	5	7	0.075
0.100	0.0006	0.0095	15	0.100	462	9	15	0.100
0.125	0.0006	0.0095	30	0.125	722	15	30	0.125
0.150	0.0006	0.0095	52	0.150	1040	22	52	0.150

Drawdown Estimate			
Total Volume (cu.m)	Total Time (sec)	Vol (cu.m)	Detention Time (hr)
0.0	0.0	0.0	0
1.7	178.1	1.7	0.04946
6.3	483.3	4.6	0.18372
15.2	941.2	8.9	0.44518
29.9	1551.8	14.7	0.87622
51.8	2314.9	21.9	1.51926

Rooftop Storage Summary

Total Building Area (sq.m)	1300	
Assume Available Roof Area (sq. m)	80%	1040
Roof Imperviousness		0.99
Roof Drain Requirement (sq.m/Notch)		232
*** Number of Roof Notches*		15
Max. Allowable Depth of Roof Ponding (m)	0.15	* As per Ontario Building Code section OBC 7.4.10.4.(2)(c).
Max. Allowable Storage (cu.m)		52
Estimated 100 Year Drawdown Time (h)		1.3

From Watts Drain Catalogue

Head (m)	L/s					
	Open	0.75	0.5	0.25	Closed	
0.025	0.3155	0.3155	0.3155	0.3155	0.3155	0.3155
0.05	0.6309	0.6309	0.6309	0.6309	0.6309	0.6309
0.075	0.9464	0.8675	0.7886	0.7098	0.6309	
0.1	1.2618	1.1041	0.9464	0.7886	0.6309	
0.125	1.5773	1.3407	1.1041	0.8675	0.6309	
0.15	1.8927	1.5773	1.2618	0.9464	0.6309	

* Note: Number of drains can be reduced if multiple-notch drain used.

Calculation Results	2yr	100yr	Available
Qresult (cu.m/s)	0.009	0.009	-
Depth (m)	0.083	0.139	0.150
Volume (cu.m)	9.3	42.7	52.0
Drain time (hrs)	0.3	1.3	

Stormwater Management Calculations

Project #160410274, Holland Cross
Modified Rational Method Calculators for Storage

2 yr Intensity City of Ottawa	$I = a/(t + b)$	a = 732.951	t (min)	I (mm/hr)
		b = 6.199	10	76.81
		c = 0.81	20	52.03
			30	40.04
			40	32.86
			50	28.04
			60	24.56
			70	21.91
			80	19.83
			90	18.14
			100	16.75
			110	15.57
			120	14.56

2 YEAR Predevelopment Target Release from Portion of Site

Subdrainage Area: Predevelopment Tributary Area to Outlet
Area (ha): 0.2800
C: 0.86

Typical Time of Concentration

tc (min)	I (2 yr) (mm/hr)	Qtarget (L/s)
10	76.81	51.46

2 YEAR Modified Rational Method for Entire Site

Subdrainage Area: L101A
Area (ha): 0.10
C: 0.90

Controlled - Tributary

tc (min)	I (2 yr) (mm/hr)	Qactual (L/s)	Qrelease (L/s)	Qstored (L/s)	Vstored (m ³)
10	76.81	19.22	18.77	0.45	0.27
20	52.03	13.02	18.77	0.00	0.00
30	40.04	10.02	18.77	0.00	0.00
40	32.86	8.22	18.77	0.00	0.00
50	28.04	7.02	18.77	0.00	0.00
60	24.56	6.14	18.77	0.00	0.00
70	21.91	5.48	18.77	0.00	0.00
80	19.83	4.96	18.77	0.00	0.00
90	18.14	4.54	18.77	0.00	0.00
100	16.75	4.19	18.77	0.00	0.00
110	15.57	3.90	18.77	0.00	0.00
120	14.56	3.64	18.77	0.00	0.00

Storage: Above CB

Orifice Equation: $Q = CdA(2gh)^{0.5}$ Where C = 0.61
Orifice Diameter: 133.00 mm
Invert Elevation: 62.53 m
T/G Elevation: 62.71 m
Max Ponding Depth: 0.07 m
Downstream W/L: 58.20 m

Stage	Head (m)	Discharge (L/s)	Vreq (cu. m)	Vavail (cu. m)	Volume Check
2-year Water Level	62.78	0.25	18.77	0.27	19.00 OK

Subdrainage Area: UNC-1
Area (ha): 0.05
C: 0.75

Uncontrolled - Non-Tributary

tc (min)	I (2 yr) (mm/hr)	Qactual (L/s)	Qrelease (L/s)	Qstored (L/s)	Vstored (m ³)
10	76.81	8.01	8.01		
20	52.03	5.42	5.42		
30	40.04	4.17	4.17		
40	32.86	3.43	3.43		
50	28.04	2.92	2.92		
60	24.56	2.56	2.56		
70	21.91	2.28	2.28		
80	19.83	2.07	2.07		
90	18.14	1.89	1.89		
100	16.75	1.75	1.75		
110	15.57	1.62	1.62		
120	14.56	1.52	1.52		

Subdrainage Area: BLDG
Area (ha): 0.13
C: 0.90

Roof
Maximum Storage Depth: 150 mm

tc (min)	I (2 yr) (mm/hr)	Qactual (L/s)	Qrelease (L/s)	Qstored (L/s)	Vstored (m ³)	Depth (mm)
10	76.81	24.98	9.46	15.52	9.31	82.9
20	52.03	16.92	9.46	7.46	8.95	81.9
30	40.04	13.02	9.46	3.56	6.41	74.5
40	32.86	10.69	9.46	1.23	2.94	55.6
50	28.04	9.12	8.58	0.54	1.61	45.3
60	24.56	7.99	7.63	0.35	1.27	40.3
70	21.91	7.13	6.89	0.24	1.01	36.4
80	19.83	6.45	6.28	0.17	0.79	33.2
90	18.14	5.90	5.79	0.11	0.62	30.6
100	16.75	5.45	5.37	0.08	0.47	28.4
110	15.57	5.06	5.01	0.05	0.34	26.5
120	14.56	4.74	4.70	0.03	0.24	24.8

Storage: Roof Storage

Depth (mm)	Head (m)	Discharge (L/s)	Vreq (cu. m)	Vavail (cu. m)	Discharge Check
2-year Water Level	82.89	0.08	9.46	9.31	52.00 0.00

Project #160410274, Holland Cross
Modified Rational Method Calculators for Storage

100 yr Intensity City of Ottawa	$I = a/(t + b)$	a = 1735.688	t (min)	I (mm/hr)
		b = 6.014	10	178.56
		c = 0.820	20	119.95
			30	91.87
			40	75.15
			50	63.95
			60	55.89
			70	49.79
			80	44.99
			90	41.11
			100	37.90
			110	35.20
			120	32.89

100 YEAR Predevelopment Target Release from Portion of Site

Subdrainage Area: Predevelopment Tributary Area to Outlet
Area (ha): 0.2800
C: 0.86

100 YEAR Modified Rational Method for Entire Site

Subdrainage Area: L101A
Area (ha): 0.10
C: 1.00

Controlled - Tributary

tc (min)	I (100 yr) (mm/hr)	Qactual (L/s)	Qrelease (L/s)	Qstored (L/s)	Vstored (m ³)
10	178.56	49.64	18.77	30.87	18.52
20	119.95	33.35	18.77	14.58	17.49
30	91.87	25.54	18.77	6.77	12.19
40	75.15	20.89	18.77	2.12	5.09
50	63.95	17.78	18.77	0.00	0.00
60	55.89	15.54	18.77	0.00	0.00
70	49.79	13.84	18.77	0.00	0.00
80	44.99	12.51	18.77	0.00	0.00
90	41.11	11.43	18.77	0.00	0.00
100	37.90	10.54	18.77	0.00	0.00
110	35.20	9.79	18.77	0.00	0.00
120	32.89	9.14	18.77	0.00	0.00

Storage: Surface Storage Above CB

Orifice Equation: $Q = CdA(2gh)^{0.5}$ Where C = 0.61
Orifice Diameter: 133.00 mm
Invert Elevation: 62.53 m
T/G Elevation: 62.71 m
Max Ponding Depth: 0.07 m
Downstream W/L: 58.20 m

Stage	Head (m)	Discharge (L/s)	Vreq (cu. m)	Vavail (cu. m)	Volume Check
100-year Water Level	62.78	0.25	18.77	18.52	19.00 OK

0.48

Subdrainage Area: UNC-1
Area (ha): 0.05
C: 0.94

Uncontrolled - Non-Tributary

tc (min)	I (100 yr) (mm/hr)	Qactual (L/s)	Qrelease (L/s)	Qstored (L/s)	Vstored (m ³)
10	178.56	23.27	23.27		
20	119.95	15.63	15.63		
30	91.87	11.97	11.97		
40	75.15	9.79	9.79		
50	63.95	8.33	8.33		
60	55.89	7.28	7.28		
70	49.79	6.49	6.49		
80	44.99	5.86	5.86		
90	41.11	5.36	5.36		
100	37.90	4.94	4.94		
110	35.20	4.59	4.59		
120	32.89	4.29	4.29		

Subdrainage Area: BLDG
Area (ha): 0.13
C: 1.00

Roof
Maximum Storage Depth: 150 mm

tc (min)	I (100 yr) (mm/hr)	Qactual (L/s)	Qrelease (L/s)	Qstored (L/s)	Vstored (m ³)	Depth (mm)
10	178.56	64.53	9.46	55.07	33.04	128.4
20	119.95	43.35	9.46	33.89	40.66	137.1
30	91.87	33.20	9.46	23.74	42.73	139.4
40	75.15	27.16	9.46	17.69	42.47	139.1
50	63.95	23.11	9.46	13.65	40.95	137.4
60	55.89	20.20	9.46	10.74	38.65	134.8
70	49.79	17.99	9.46	8.53	35.83	131.5
80	44.99	16.26	9.46	6.80	32.62	127.9
90	41.11	14.86	9.46	5.39	29.13	123.4
100	37.90	13.70	9.46	4.23	25.41	117.0
110	35.20	12.72	9.46	3.26	21.51	110.4
120	32.89	11.89	9.46	2.42	17.46	103.5

Storage: Roof Storage

Depth (mm)	Head (m)	Discharge (L/s)	Vreq (cu. m)	Vavail (cu. m)	Discharge Check
100-year Water Level	139.42	0.14	9.46	42.73	52.00 0.00

Stormwater Management Calculations

Project #160410274, Holland Cross
Modified Rational Method Calculatons for Storage

SUMMARY TO OUTLET				
		Vrequired	Vavailable*	
Tributary Area	0.230 ha			
Total 2yr Flow to Sewer	28.2 L/s	10	71 m ³	Ok
Non-Tributary Area	0.050 ha			
Total 2yr Flow Uncontrolled	8.0 L/s			
Total Area	0.280 ha			
Total 2yr Flow	36.2 L/s			
Target	51.5 L/s			

Project #160410274, Holland Cross
Modified Rational Method Calculatons for Storage

SUMMARY TO OUTLET				
		Vrequired	Vavailable*	
Tributary Area	0.230 ha			
Total 100yr Flow to Sewer	28.2 L/s	61	71 m ³	Ok
Non-Tributary Area	0.050 ha			
Total 100yr Flow Uncontrolled	23.3 L/s			
Total Area	0.280 ha			
Total 100yr Flow	51.5 L/s			
Target	51.5 L/s			

Appendix D **DESIGN CRITERIA AND REPORT EXCERPTS**

D.1 **2013 HOLLAND CROSS EXPANSION SWM REPORT EXCERPTS**

Engineering

Land / Site
Development
Municipal
Infrastructure
Environmental /
Water Resources
Traffic/
Transportation
Structural
Recreational

Planning

Land/Site
Development
Planning
Application
Management
Municipal
Planning
Documents &
Studies
Expert Witness
(OMB)
Wireless Industry

Landscape Architecture

Urban Design &
Streetscapes
Recreation & Parks
Planning
Environmental
Restoration
Sustainable Design



HOLLAND CROSS EXPANSION CITY OF OTTAWA

SERVICING & STORMWATER MANAGEMENT REPORT

**HOLLAND CROSS EXPANSION
CITY OF OTTAWA**

SERVICING & STORMWATER MANAGEMENT REPORT

Prepared For:

Colonnade Development Ltd.
16 Concourse Gate, Suite 200
Ottawa, Ontario
K2E 7S8

Prepared By:

NOVATECH
Suite 200, 240 Michael Cowpland Drive
Ottawa, Ontario
K2M 1P6

December 2013
Revised August 2014

Novatech File: 113150
Ref: R-2013-108

August 25, 2014

City of Ottawa
Planning and Growth Management Department
Development Review (Urban) Services Branch
Infrastructure Approvals Division
110 Laurier Avenue West
Ottawa, ON K1P 1J1

Attention: Kristin Bazinet

Dear Madam:

**Re: 1560 Scott Street – Holland Cross Expansion
Servicing Design Brief
Our File No.: 113150**

Please find enclosed six (6) copies of the Holland Cross Expansion – Servicing and Stormwater Management Report, dated August 2014. This report has been revised per City comments and is hereby submitted for approval.

If you have any questions, please contact the undersigned.

Yours truly,

NOVATECH



Cara Ruddle, P.Eng.
Project Manager

cc: Kelly Rhodenizer, Colonnade Development Ltd.

TABLE OF CONTENTS

1.0	INTRODUCTION	1
2.0	EXISTING AND PROPOSED DEVELOPMENT.....	1
3.0	WATERMAIN SERVICING	1
3.1	Domestic Water Demand	1
3.2	Fire Demand	2
4.0	SANITARY SERVICING	2
5.0	STORM SERVICING	2
5.1	Existing Drainage and Servicing.....	2
5.2	Proposed Site Drainage	3
5.3	Stormwater Management.....	3
6.0	EROSION AND SEDIMENT CONTROL MEASURES	3
6.1	Temporary Measures	3
7.0	CONCLUSIONS AND RECOMMENDATIONS	4

List of Figures

Figure 1	Key Plan
Figure 2	Existing Site Conditions
Figure 3	Proposed Site Plan
Figure 4	Existing Servicing
Figure 5	Downstream Sanitary Drainage Areas
Figure 6	General Plan of Grading and Servicing
Figure 7	Erosion and Sediment Control Plan

List of Appendices

Appendix A	Watermain Information
Appendix B	Sanitary Sewer Information
Appendix C	Engineering Figures
Appendix D	City of Ottawa Checklist

1.0 INTRODUCTION

Novatech Engineering Consultants Ltd. has been retained by Colonnade Development Ltd. to prepare a Servicing and Stormwater Management Report in support of the rezoning and site plan applications. The site is located at 1560 Scott Street on the southeast corner of the intersection of Scott Street and Holland Street in the City of Ottawa. Figure 1 is a Key Plan showing the site location.

2.0 EXISTING AND PROPOSED DEVELOPMENT

The property is approximately 3.2 hectares in size and is currently occupied by an existing seven storey tall complex consisting of two six storey office towers on top of a 1 storey retail podium. The site is bounded by office buildings to the north (Holland Cross), residential housing to the east and west, and residential condominiums to the south. Figure 2 shows the existing conditions of the site.

It is proposed to demolish part of the existing 1 storey retail building, and to construct a 12 storey office building (approximately 18,000ft² per floor) over the existing parking garage. Therefore, the building footprint will remain the same. Underground parking is already provided as part of the previous development. Refer to Figure 3 – Proposed Site Plan for details.

3.0 WATERMAIN SERVICING

The existing building complex is serviced by two 150mm diameter water services from Holland Ave and Bullman St, and one 50mm diameter water service from Scott Street. These existing water services connect to the municipal water system surrounding the existing development. The internal building water system will be extended to service the proposed development. Refer to Figure 4 – Existing Services for details on the existing water system.

Hydraulic boundary conditions were provided by the City of Ottawa and are as follows:


Minimum HGL = 107.4m
Maximum HGL = 115.8m
Max Day + FF = 77.5m

3.1 Domestic Water Demand

The following domestic water demands are based on the City of Ottawa Water Distribution Guidelines (Gross Site Area), and the Ontario Building Code, OBC, (Gross Floor Area). The Gross Floor Area method results in a more conservative value, which is used for this report. Refer to Appendix A for detailed calculations.

Estimated water demands for the entire complex including the proposed expansion are as follows:

$$\begin{aligned} Q_{\text{avg day}} &= (47,409\text{m}^2 / 9.3 \text{ m}^2/\text{pers}) \times 75\text{L}/\text{pers}/\text{day} \\ Q_{\text{avg day}} &= 382,331\text{L}/\text{day} = 4.43 \text{ L/s} \end{aligned}$$




M:\2013\113150\CAD\Design\Figures\Figure1.dwg, Sheet Bx11 portrait, Dec 09, 2013 - 3:22pm, bthurber

NOVATECH
ENGINEERING
CONSULTANTS LTD.
 ENGINEERS & PLANNERS
 Suite 200, 240 Michael Cowpland Drive
 Ottawa, Ontario, Canada
 K2M 1P6
 Telephone (613) 254-9643
 Facsimile (613) 254-5867
 Email: novainto@novatech-eng.com

1560 SCOTT STREET -
 HOLLAND CROSS PHASE 3

KEY PLAN

DEC 2013 113150 FIGURE 1




SITE

M:\2013\113150\CAD\Design\Figures\Figure2.dwg, figure2, Dec 09, 2013 - 3:21pm, bthurber

NOVATECH
ENGINEERING
CONSULTANTS LTD.
 ENGINEERS & PLANNERS
 Suite 200, 240 Michael Cowpland Drive
 Ottawa, Ontario, Canada
 K2M 1P6
 Telephone: (613) 254-9643
 Facsimile: (613) 254-5867
 Email: novainfo@novatech-eng.com

SCALE
 1:1250
 1:1250
 0 10 20 30 40 50

1560 SCOTT STREET -
 HOLLAND CROSS PHASE 3
 EXISTING SITE
 CONDITIONS
 DEC 2013 113150 FIGURE 2




M:\2013\113150\CAD\Design\Figures\Figure3.dwg, Dec 09, 2013 - 3:21pm, bthurber

NOVATECH
ENGINEERING CONSULTANTS LTD.
 ENGINEERS & PLANNERS
 Suite 200, 240 Michael Cowpland Drive
 Ottawa, Ontario, Canada
 K2M 1P6
 Telephone (613) 254-9643
 Facsimile (613) 254-5867
 Email: novainfo@novatech-eng.com

SCALE
 1:1250
 1:1250
 0 10 20 30 40 50


1560 SCOTT STREET -
 HOLLAND CROSS PHASE 3
PROPOSED SITE PLAN
 DEC 2013 113150 FIGURE 3



M:\2013\113150\CAD\Design\Figures\Figure4.dwg, figure4 1 1500, Dec 09, 2013 - 3:21pm, bhuber

- LEGENDS:**
- SANITARY
 - STORMWATER
 - WATERMAIN

NOVATECH
ENGINEERING
CONSULTANTS LTD.
 ENGINEERS & PLANNERS
 Suite 200, 240 Michael Cowpland Drive
 Ottawa, Ontario, Canada
 K2M 1P6
 Telephone (613) 254-9643
 Facsimile (613) 254-5867
 Email: novainfo@novatech-eng.com



**1560 SCOTT STREET -
 HOLLAND CROSS PHASE 3**

EXISTING SERVICING

DEC 2013 113150 **FIGURE 4**

3.2 Fire Demand

For this type of building, the existing underground parking garage is classified as "Ordinary Hazard" (Group 1), and the new office building is classified as "Light Hazard." The calculations for required fire flow are based on the existing garage; therefore there is only a marginal increase in the required fire flow for the new addition.

The required fire demand is calculated using the Fire Underwriters Survey (FUS) Guidelines. The required fire demand is calculated to be 100L/s using the FUS method. Using the National Fire Protection Association (NFPA) Standard for Sprinkler Systems the supply requirement is 41.0L/s for the sprinklers and hoses. Refer to Appendix A for detailed calculations.

According to the hydraulic boundary conditions provided by the City, the existing 200mm dia. watermain on Hamilton Street and Bullman Avenue has a hydraulic grade line of 77.5m at the maximum day demand plus a fire demand of 92.7L/s. This results in 92.7L/s of fire flow available at 22.4psi. Therefore the existing municipal watermain can provide the fire demand at a pressure greater than 20 psi.

4.0 SANITARY SERVICING

The existing building is serviced by a 150mm diameter sanitary which connects to an existing 250mm diameter sanitary sewer within the Hamilton Street right-of-way. It is proposed to extend the internal plumbing to service the proposed development.

A review of the existing downstream sewer system is required to ensure there are no capacity issues. The sanitary flows from the proposed development are calculated to be 2.8L/s. Drainage areas and flows have been calculated for the downstream area and input into a sanitary sewer design sheet. There appears to be no issue with capacity in the existing sanitary sewer system due to the proposed development. Refer to Appendix B for flow calculations, the drainage area plan and sanitary sewer design sheet.

5.0 STORM SERVICING

5.1 Existing Drainage and Servicing

As indicated previously, the site is currently developed with single storey building as part of an existing office and retail development. The existing building is serviced by an existing 200mm storm service that connects to a 450mm diameter storm sewer at the Hamilton Avenue / Bullman Street intersection.

Stormwater from the building areas flow into roof drains and outlets to storm services which connect to the City storm sewer system along Scott Street, Holland Avenue and Hamilton Avenue. The remaining parking area sheet drains to catchbasins which outlet to the City storm sewer system on Scott Street.

5.2 Proposed Site Drainage

Stormwater from the proposed development will drain to roof drains and outlet to the existing storm service per existing conditions and continue to outlet to the existing storm sewer on Hamilton Avenue.

5.3 Stormwater Management

The building footprint will not change from existing conditions. Therefore, there is no increase in storm flows from the proposed development and stormwater management is not required.

6.0 EROSION AND SEDIMENT CONTROL MEASURES

6.1 Temporary Measures

Temporary erosion and sediment control measures will be implemented during construction. Silt fence and filter cloth catches will be used as erosion and sediment control measures. Details are provided on Figure 7.

Filter cloth catches should be inspected daily, and after every rain event to determine maintenance, repair or replacement requirements. Sediments or granulars that enter site sewers shall be removed immediately by the contractor. These measures will be implemented prior to the commencement of construction and maintained in good order until vegetation has been established.

7.0 CONCLUSIONS AND RECOMMENDATIONS

The conclusions of this report are as follows:

- Water servicing, including both domestic and fire protection, can be provided by connection to the existing watermain infrastructure along Bullman Street.
- Sanitary flows for the proposed development have been calculated and there is sufficient capacity within the existing City sanitary sewer system along Bullman Street to service the development.
- Quantity and quality control of stormwater is not required, as there will be no change to the existing stormwater drainage.
- The existing overland flow route will be maintained.
- Erosion and sediment control measures will be implemented during construction.

NOVATECH

Prepared by:



Cara Ruddle, P.Eng.
Project Manager

Reviewed by:

A handwritten signature in blue ink, appearing to read "J. Lee Sheets".

J. Lee Sheets, CET
Sr. Project Manager

APPENDIX A
Watermain Information

The following are boundary conditions (provided by the City of Ottawa), HGL, for hydraulic analysis at 150 Holland Avenue assumed to be connected to the 200mm on Hamilton Street and Bullman Avenue.

Minimum HGL = 107.4m

Maximum HGL = 115.8m

Max Day + FF (92.7 L/s) = 77.5m

These are for current conditions and are based on computer model simulation.

Pressure Check:

Centreline of road at the intersection of Hamilton Street and Bullman Avenue = 61.7m
(refer to the City as-built drawings)

2.31ft = 1 psi

Maximum HGL = (115.8m - 61.7m) x 3.281ft/m ÷ 2.31ft/1psi = 76.8psi

Minimum HGL = (107.4m - 61.7m) x 3.281ft/m ÷ 2.31ft/1psi = 64.9psi

- The system has adequate pressure under peak hour demand condition.

Fire Flow Check

Max Day + FF (92.7L/s) = (77.5m - 61.7m) x 3.281ft/m ÷ 2.31ft/1psi = 22.4psi

- The system has adequate pressure for fire flow conditions.

12 Storey New Expansion Water Demand				
Node	Area	Demand (L/s)		
		Average Day	Max. Daily	Peak Hour
Gross Floor Area (m²)				
New	19564	1.83	2.74	3.29
Existing	27845	2.60	3.90	7.02
Total	47409	4.43	6.64	10.30
Gross Site Area (ha)				
New	0.0	0.00	0.00	0.00
Existing	1.7	0.53	0.80	1.44
Total	1.7	0.53	0.80	1.44

Notes:

1. All water demand calculations based on the City of Ottawa Design Guidelines for Water Distribution Table 4.2.
2. Water Demand is based assuming all lands to be Other Commercial with a demand of 28,000L/gross ha/d.
3. Peaking Factors: Maximum Daily Demand = 1.5 average daily demand ; Peak Hour = 1.8 max daily demand.
4. Gross Floor Area demand calculations based on Ontario Building Code; 9.3 m²/pers and 75 L/pers/day

12 Storey Office Building

Fire Flow Calculations - Holland Cross Expansion

As per Fire Underwriter's Survey Guidelines

PROJECT: Holland Cross Expansion
JOB#: 113150

DATE: December 12, 2013

C	Coefficient related to type of construction	<u>[yes/no]</u>	
	♦ Wood frame		1.5
	♦ Ordinary construction		1
	♦ Non-combustible construction		0.8
	♦ Fire resistive construction (> 3 hrs)	yes	0.6
	♦ Interpolation (Using FUS Tables)		
	Foot Print of New Tower		18,610 ft ²
	Gross Floor area of Expanded Common Podium		99,060 ft ²
	Gross Floor area of Existing Garage		129,920 ft ²
A	Area of structure considered (m²)	5,320	<==> 57,269 ft²
	<i>(All floors excluding Basement, under 2-Storeys)</i>		
	*Note: This assumes protected openings, and considers 40% of the common 1 storey podium, plus 25% of the GFA of each of the two adjacent floors (New Tower + 40% of Garage)		
F	Required fire flow (L/min)		<u><u>10,000 L/min</u></u>
	$F = 220 C (A)^{0.5}$		
	Occupancy hazard reduction of surcharge	<u>[yes/no]</u>	
	♦ Non-combustible		-25%
	♦ Limited combustible	yes	-15% * Due to Parking Garage
	♦ Combustible		0%
	♦ Free burning		15%
	♦ Rapid burning		25%
			<u><u>8,500 L/min (1)</u></u>
	Sprinkler Reduction		
	♦ Non-combustible - Fire Resistive (3)	yes	50% <u><u>4,250 L/min (2)</u></u>
	Exposure surcharge (cumulative (%))	<u>[yes/no]</u>	
	0 - 3 m		25%
	3.1 - 10 m		20%
	10.1 - 20 m	yes	15% 1 side 15%
	20.1 - 30 m	yes	10% 1 side 10%
	30.1- 45 m	no	5% 1 side
			Cumulative Total 25%
			2,125 L/min
	Fire Wall Separation		
	♦ Number of Party Walls * 1000 L/min		
	<i>(As per City of Ottawa Standard)</i>		<u><u>2,125 L/min (3)</u></u>
	REQUIRED FIRE FLOW [(1) - (2) + (3)]		6,000 L/min
	(2,000 L/min < Fire Flow < 45,000 L/min)	or	100 L/s
	Rounded to nearest 1000L/min	or	1,321 IGPM
	BY: Alex McAuley		

6-4.5.9* For individual fasteners, the loads determined in 6-4.5.6 shall not exceed the allowable loads provided in Figure 6-4.5.9.

The type of fasteners used to secure the bracing assembly to the structure shall be limited to those shown in Figure 6-4.5.9. For connections to wood, through bolts with washers on each end shall be used. Holes for through bolts shall be $1/16$ in. (1.6 mm) greater than the diameter of the bolt.

Exception No. 1: Where it is not practical to install through bolts due to the thickness of the member or inaccessibility, lag screws shall be permitted. Holes shall be pre-drilled $1/8$ in. (3.2 mm) smaller than the maximum root diameter of the lag screw.

Exception No. 2: Other fastening methods are acceptable for use if certified by a registered professional engineer to support the loads determined in accordance with the criteria in 6-4.5.9. Calculations shall be permitted where required by the authority having jurisdiction.

6-4.5.10 Sway bracing assemblies shall be listed for a maximum load rating. The loads shall be reduced as shown in Table 6-4.5.10 for loads that are less than 90 degrees from vertical.

Exception: Where sway bracing utilizing pipe, angles, flats, or rods as shown in Table 6-4.5.8 is used, the components do not require listing. Bracing fittings and connections used with those specific materials shall be listed.

Table 6-4.5.10 Allowable Horizontal Load on Brace Assemblies Based on the Weakest Component of the Brace Assembly

Brace Angle	Allowable Horizontal Load
30-40 degrees from vertical	Listed load rating divided by 2.000
45-59 degrees from vertical	Listed load rating divided by 1.414
60-89 degrees from vertical	Listed load rating divided by 1.155
90 degrees from vertical	Listed load rating

6-4.5.11 Bracing shall be attached directly to feed and cross mains. Each run of pipe between changes in direction shall be provided with both lateral and longitudinal bracing.

Exception: Pipe runs less than 12 ft (3.6 m) in length shall be permitted to be supported by the braces on adjacent runs of pipe.

6-4.5.12 A length of pipe shall not be braced to sections of the building that will move differentially.

6-4.6 Restraint of Branch Lines.

6-4.6.1* Restraint is considered a lesser degree of resisting loads than bracing and shall be provided by use of one of the following:

- (1) A listed sway brace assembly
- (2) A wraparound U-hook satisfying the requirements of 6-4.5.3, Exception No. 3
- (3) No. 12, 440-lb (200-kg) wire installed at least 45 degrees from the vertical plane and anchored on both sides of the pipe
- (4) Other approved means

Wire used for restraint shall be located within 2 ft (610 mm) of a hanger. The hanger closest to a wire restraint shall be of a type that resists upward movement of a branch line.

6-4.6.2 The end sprinkler on a line shall be restrained against excessive vertical and lateral movement.

6-4.6.3* Where upward or lateral movement would result in an impact against the building structure, equipment, or finish materials, branch lines shall be restrained at intervals not exceeding 30 ft (9 m).

6-4.6.4* Sprig-ups 4 ft (1.2 m) or longer shall be restrained against lateral movement.

6-4.7 Hangers and Fasteners Subject to Earthquakes.

6-4.7.1 C-type clamps (including beam and large flange clamps) used to attach hangers to the building structure in areas subject to earthquakes shall be equipped with a restraining strap. The restraining strap shall be listed for use with a C-type clamp or shall be a steel strap of not less than 16 gauge thickness and not less than 1 in. (25.4 mm) wide for pipe diameters 8 in. (203 mm) or less and 14 gauge thickness and not less than $1\frac{1}{4}$ in. (31.7 mm) wide for pipe diameters greater than 8 in. (203 mm). The restraining strap shall wrap around the beam flange not less than 1 in. (25.4 mm). A lock nut on a C-type clamp shall not be used as a method of restraint. A lip on a "C" or "Z" purlin shall not be used as a method of restraint.

Where purlins or beams do not provide an adequate lip to be secured by a restraining strap, the strap shall be through-bolted or secured by a self-tapping screw.

6-4.7.2 C-type clamps (including beam and large flange clamps), with or without restraining straps, shall not be used to attach braces to the building structure.

6-4.7.3 Powder-driven fasteners shall not be used to attach braces to the building structure.

Exception: Powder-driven fasteners shall be permitted where they are specifically listed for service in resisting lateral loads in areas subject to earthquakes.

6-4.7.4 Powder-driven fasteners shall not be used to attach hangers to the building structure where the systems are required to be protected against earthquakes using a horizontal force factor exceeding $0.50 W_p$, where W_p is the weight of the water-filled pipe.

Exception: Powder-driven fasteners shall be permitted where they are specifically listed for horizontal force factors in excess of $0.50 W_p$.

Chapter 7 Design Approaches

7-1 General.

7-1.1 Water demand requirements shall be determined from the occupancy hazard fire control approach of Section 7-2.

Exception: Special design approaches as permitted in Section 7-9.

7-1.2 For buildings with two or more adjacent occupancies that are not physically separated by a barrier or partition capable of delaying heat from a fire in one area from fusing sprinklers in the adjacent area, the required sprinkler protection for the more demanding occupancy shall extend 15 ft (4.6 m) beyond its perimeter.

7-2 Occupancy Hazard Fire Control Approach.

7-2.1 Occupancy Classifications.

7-2.1.1 Occupancy classifications for this standard relate to sprinkler installations and their water supplies only. They shall not be used as a general classification of occupancy hazards.

7-2.1.2 Occupancies or portions of occupancies shall be classified according to the quantity and combustibility of contents, the expected rates of heat release, the total potential for energy release, the heights of stockpiles, and the presence of flammable and combustible liquids, using the definitions contained in Section 1-4. Classifications are as follows:

- Light hazard
- Ordinary hazard (Groups 1 and 2)
- Extra hazard (Groups 1 and 2)
- Special occupancy hazard (*see Section 7-10*)

7-2.2 Water Demand Requirements — Pipe Schedule Method.

7-2.2.1 Table 7-2.2.1 shall be used in determining the minimum water supply requirements for light and ordinary hazard occupancies protected by systems with pipe sized according to the pipe schedules of Section 8-5. Pressure and flow requirements for extra hazard occupancies shall be based on the hydraulic calculation methods of 7-2.3. The pipe schedule method shall be permitted only for new installations of 5000 ft² (465 m²) or less or for additions or modifications to existing pipe schedule systems sized according to the pipe schedules of Section 8-5. Table 7-2.2.1 shall be used in determining the minimum water supply requirements.

Exception No. 1: The pipe schedule method shall be permitted for use in systems exceeding 5000 ft² (465 m²) where the flows required in Table 7-2.2.1 are available at a minimum residual pressure of 50 psi (3.4 bar) at the highest elevation of sprinkler.

Exception No. 2: The pipe schedule method shall be permitted for additions or modifications to existing extra hazard pipe schedule systems.

7-2.2.2 The lower duration value of Table 7-2.2.1 shall be acceptable only where remote station or central station water-flow alarm service is provided.

7-2.2.3* The residual pressure requirement of Table 7-2.2.1 shall be met at the elevation of the highest sprinkler. (*See the Exceptions to 7-2.2.1*).

7-2.2.4 The lower flow figure of Table 7-2.2.1 shall be permitted only where the building is of noncombustible construction or the potential areas of fire are limited by building size or compartmentation such that no open areas exceed 3000 ft² (279 m²) for light hazard or 4000 ft² (372 m²) for ordinary hazard.

Table 7-2.2.1 Water Supply Requirements for Pipe Schedule Sprinkler Systems

Occupancy Classification	Minimum Residual Pressure Required (psi)	Acceptable Flow at Base of Riser (Including Hose Stream Allowance) (gpm)	Duration (minutes)
Light hazard	15	500–750	30–60
Ordinary hazard	20	850–1500	60–90

For SI units, 1 gpm = 3.785 L/min; 1 psi = 0.0689 bar.

7-2.3 Water Demand Requirements — Hydraulic Calculation Methods.

7-2.3.1 General.


7-2.3.1.1* The minimum water supply requirements for a hydraulically designed occupancy hazard fire control sprinkler system shall be determined by adding the hose stream demand from Table 7-2.3.1.1 to the water supply for sprinklers determined in 7-2.3.1.2. This supply shall be available for the minimum duration specified in Table 7-2.3.1.1.

Exception No. 1: An allowance for inside and outside hose shall not be required where tanks supply sprinklers only.

Exception No. 2: Where pumps taking suction from a private fire service main supply sprinklers only, the pump need not be sized to accommodate inside and outside hose. Such hose allowance shall be considered in evaluating the available water supplies.

7-2.3.1.2 The water supply for sprinklers only shall be determined either from the area/density curves of Figure 7-2.3.1.2 in accordance with the method of 7-2.3.2 or be based upon the room design method in accordance with 7-2.3.3, at the discretion of the designer. For special areas under consideration, as described in 7-2.3.4, separate hydraulic calculations shall be required in addition to those required by 7-2.3.2 or 7-2.3.3.

Figure 7-2.3.1.2 Area/density curves.



7-2.3.1.3 Regardless of which of the two methods is used, the following restrictions shall apply:

(a) For areas of sprinkler operation less than 1500 ft² (139 m²) used for light and ordinary hazard occupancies, the density for 1500 ft² (139 m²) shall be used. For areas of sprinkler operation less than 2500 ft² (232 m²) for extra hazard occupancies, the density for 2500 ft² (232 m²) shall be used.

(b) *For buildings having unsprinklered combustible concealed spaces (as described in 5-13.1.1 and 5-13.7), the minimum area of sprinkler operation shall be 3000 ft² (279 m²).

Exception No. 1: Combustible concealed spaces filled entirely with noncombustible insulation.

*Exception No. 2: *Light or ordinary hazard occupancies where noncombustible or limited combustible ceilings are directly attached to the bottom of solid wood joists so as to create enclosed joist spaces 160 ft³ (4.8 m³) or less in volume.*

*Exception No. 3: *Concealed spaces where the exposed surfaces have a flame spread rating of 25 or less and the materials have been demonstrated to not propagate fire in the form in which they are installed in the space.*

(c) Water demand of sprinklers installed in racks or water curtains shall be added to the ceiling sprinkler water demand at the point of connection. Demands shall be balanced to the higher pressure. (See Chapter 8.)

(d) Water demand of sprinklers installed in concealed spaces or under obstructions such as ducts and cutting tables need not be added to ceiling demand.

(e) Where inside hose stations are planned or are required, a total water allowance of 50 gpm (189 L/min) for a single hose station installation or 100 gpm (378 L/min) for a multiple hose station installation shall be added to the sprinkler requirements. The water allowance shall be added in 50-gpm (189-L/min) increments beginning at the most remote hose station, with each increment added at the pressure required by the sprinkler system design at that point.

(f) When hose valves for fire department use are attached to wet pipe sprinkler system risers in accordance with 5-15.5.2, the water supply shall not be required to be added to standpipe demand as determined from NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*.

Exception No. 1: Where the combined sprinkler system demand and hose stream allowance of Table 7-2.3.1.1 exceeds the requirements of NFPA 14, Standard for the Installation of Standpipe and Hose Systems, this higher demand shall be used.

Exception No. 2: For partially sprinklered buildings, the sprinkler demand, not including hose stream allowance, as indicated in Table 7-2.3.1.1 shall be added to the requirements given in NFPA 14, Standard for the Installation of Standpipe and Hose Systems.

(g) Water allowance for outside hose shall be added to the sprinkler and inside hose requirement at the connection to the city water main or a yard hydrant, whichever is closer to the system riser.

(h) The lower duration values in Table 7-2.3.1.1 shall be permitted where remote station or central station waterflow alarm service is provided.

(i) Where pumps, gravity tanks, or pressure tanks supply sprinklers only, requirements for inside and outside hose need not be considered in determining the size of such pumps or tanks.

7-2.3.1.4 Total system water supply requirements shall be determined in accordance with the hydraulic calculation procedures of Section 8-4.

7-2.3.2 Area/Density Method.

7-2.3.2.1 The water supply requirement for sprinklers only shall be calculated from the area/density curves in Figure 7-2.3.1.2 or from Section 7-10 where area/density criteria is specified for special occupancy hazards. When using Figure 7-2.3.1.2, the calculations shall satisfy any single point on the appropriate area/density curve as follows:

- (1) Light hazard area/density curve 1
- (2) Ordinary hazard (Group 1) area/density curve 2
- (3) Ordinary hazard (Group 2) area/density curve 3
- (4) Extra hazard (Group 1) area/density curve 4
- (5) Extra hazard (Group 2) area/density curve 5

It shall not be necessary to meet all points on the selected curve.

Exception: Sprinkler demand for storage occupancies as determined in Sections 7-3 through 7-8.

7-2.3.2.2 For protection of miscellaneous storage, miscellaneous tire storage, and storage up to 12 ft (3.7 m) in height, the discharge criteria in Table 7-2.3.2.2 shall apply.

TO BE CONSERVATIVE
-CURVE 2
 $4000 \text{ ft}^2 \times 0.10 \text{ gpm/ft}^2 = 400 \text{ gpm}$
SPRINKLERS
 $\frac{400 \text{ gpm}}{400 \text{ gpm}} \Rightarrow 25.2 \text{ L/s}$
HOSE DEMAND
 $250 \text{ gpm} \Rightarrow 15.8 \text{ L/s}$
TOTAL SUPPLY REQUIREMENT
 $650 \text{ gpm} \Rightarrow 41.0 \text{ L/s}$

Table 7-2.3.1.1† Hose Stream Demand and Water Supply Duration Requirements for Hydraulically Calculated Systems

Occupancy or Commodity Classification	Inside Hose (gpm)	Total Combined Inside and Outside Hose (gpm)	Duration (minutes)
Light hazard	0, 50, or 100	100	30
Ordinary hazard	0, 50, or 100	250	60-90
Extra hazard	0, 50, or 100	500	90-120
Rack storage, Class I, II, and III commodities up to 12 ft (3.7 m) in height	0, 50, or 100	250	90
Rack storage, Class IV commodities up to 10 ft (3.1 m) in height	0, 50, or 100	250	90
Rack storage, Class IV commodities up to 12 ft (3.7 m) in height	0, 50, or 100	500	90
Rack storage, Class I, II, and III commodities over 12 ft (3.7 m) in height	0, 50, or 100	500	90
Rack storage, Class IV commodities over 12 ft (3.7 m) in height and plastic commodities	0, 50, or 100	500	120
General storage, Class I, II, and III commodities over 12 ft (3.7 m) up to 20 ft (6.1 m)	0, 50, or 100	500	90
General storage, Class IV commodities over 12 ft (3.7 m) up to 20 ft (6.1 m)	0, 50, or 100	500	120
General storage, Class I, II, and III commodities over 20 ft (6.1 m) up to 30 ft (9.1 m)	0, 50, or 100	500	120
General storage, Class IV commodities over 20 ft (6.1 m) up to 30 ft (9.1 m)	0, 50, or 100	500	150
General storage, Group A plastics ≤ 5 ft (1.5 m)	0, 50, or 100	250	90
General storage, Group A plastics over 5 ft (1.5 m) up to 20 ft (6.1 m)	0, 50, or 100	500	120
General storage, Group A plastics over 20 ft (6.1 m) up to 25 ft (7.6 m)	0, 50, or 100	500	150

† For SI units, 1 gpm = 3.785 L/min.

Alex McAuley

From: White, Joshua <Joshua.White@ottawa.ca>
Sent: October-29-13 3:49 PM
To: Alex McAuley
Cc: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Good eye Alex. There was a mistake in the model. We are looking into it please find the revision below to the HGL.

The Max Day + FF HGL is actually 77.5m, not 112.2m.

Cheers

Josh

From: Alex McAuley [mailto:a.mcauley@novatech-eng.com]
Sent: October 11, 2013 11:28 AM
To: White, Joshua
Cc: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Josh,

Can you please double check the HGL below? The Max Day + Fire Flow is 4.8m above the Min HGL, which is unusual.

Thank you,

Alex McAuley, P.Eng
Project Engineer

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643

Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Alex McAuley
Sent: October-11-13 11:22 AM
To: 'White, Joshua'
Cc: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Thank you Josh,

Regards,

Alex McAuley, P.Eng
Project Engineer

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: White, Joshua [<mailto:Joshua.White@ottawa.ca>]
Sent: October-11-13 9:44 AM
To: Alex McAuley
Cc: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Hi Alex,

I have received the revised boundary conditions.

Cheers

Josh

Please find attached the revised boundary conditions for the above noted

******The following information may be passed on to the consultant, but do NOT forward this e-mail directly.******

The following are boundary conditions, HGL, for hydraulic analysis at 1560 Scott Street (zone 1W) assumed to be connected to the existing 152mm on Bullman (see attached PDF for location).

Minimum HGL = 107.4 m

Maximum HGL = 115.8 m

Max Day + FF (92.7 L/s) = 112.2 m

These are for current conditions and are based on computer model simulation.

Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.

From: Alex McAuley [<mailto:a.mcauley@novatech-eng.com>]
Sent: October 08, 2013 10:04 AM
To: White, Joshua
Cc: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Hi Josh,

Thank you for the information.

We will be reusing the existing 150mm diameter water service that is fed from the corner of Bullman Street and Hamilton Ave N. The information provided below is for the Holland Street service, and gives us approximately 22.8psi during fire flow conditions which is sufficient. We are close to the Scott Street trunk watermain, so I wouldn't anticipate a major drop, but will there be any change to the HGL at that location?

I attached a sketch with the location of the service we are proposing to use.

Regards,

Alex McAuley, P.Eng
Project Engineer

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: White, Joshua [<mailto:Joshua.White@ottawa.ca>]
Sent: October-07-13 11:10 AM
To: Alex McAuley
Subject: RE: Holland Cross - 1560 Scott Street

Hi Alex,

Here is the results of the water boundary condition modeling.

Cheers

Josh

The following are boundary conditions, HGL, for hydraulic analysis at 1560 Scott Street (zone 1W) assumed to be connected to the existing 152mm on Holland Avenue (see attached PDF for location).

Minimum HGL = 108.8 m
Maximum HGL = 115.3 m
Max Day + FF (92.7 L/s) = 77.0 m

These are for current conditions and are based on computer model simulation.

Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.

From: Alex McAuley [<mailto:a.mcauley@novatech-eng.com>]
Sent: September 27, 2013 10:36 AM
To: White, Joshua
Subject: RE: Holland Cross - 1560 Scott Street

Hi Josh,

We will be reusing the existing water connection.

Alex McAuley, P.Eng
Engineer

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: White, Joshua [<mailto:Joshua.White@ottawa.ca>]
Sent: September-26-13 1:19 PM
To: Alex McAuley
Subject: RE: Holland Cross - 1560 Scott Street

Hi Alex,

Just to confirm the water connection will be from the internal private water main, or are you planning on installing a connection to the water main in the street.

Cheers

Josh

From: Alex McAuley [<mailto:a.mcauley@novatech-eng.com>]
Sent: September 26, 2013 11:44 AM
To: White, Joshua
Cc: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Josh,

Per our phone conversation yesterday, I have revised our fire flow calculations for the new addition based on FUS for a sprinklered office building with fire resistive construction.

I have calculated the fire flows and demands based on the new expansion only, as the existing two towers have independent services.

Fire Flow (FUS) = 92.7 L/s
Average Daily Flow = 1.88 L/s
Max Day Flow = 2.81 L/s
Max hourly Flow = 3.38 L/s

Please let me know if you require additional information.

Regards,

Alex McAuley, P.Eng
Engineer

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Cara Ruddle
Sent: September-19-13 11:02 AM
To: Alex McAuley
Subject: FW: Holland Cross - 1560 Scott Street

Cara Ruddle, P.Eng.
Project Manager

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643 x 220
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: White, Joshua [<mailto:Joshua.White@ottawa.ca>]
Sent: September-19-13 11:05 AM
To: Cara Ruddle
Subject: RE: Holland Cross - 1560 Scott Street

Hi Cara,

The fire flow should be based off of the Fire Under Writers Survey. Also the may I please have the following information;

Average Daily Flow: l/s
Max Day Flow: l/s
Max hourly Flow: l/s

I have put in a request to our ISD regarding possible servicing constraints in the area and I will relay them to you once I have received them.

Cheers

Josh

From: Cara Ruddle [<mailto:c.ruddle@novatech-eng.com>]
Sent: September 19, 2013 10:43 AM
To: White, Joshua
Subject: Holland Cross - 1560 Scott Street

Josh:
Using the NFPA 13 Sprinkler/Hose demands and a max day office demand we have calculated a fire flow requirement of 650gpm (43.82L/s) for the new 12 storey building. We would use the existing 150mm water service at the corner of Bullman and Hamilton.

Sanitary flows are calculated to be just less than 3.0 L/s. The sanitary connection for the building is also by the intersection of Bullman and Hamilton.

As discussed, please provide boundary conditions for the water system and any servicing constraints that you are aware of for this development.

Please call or email if you have any questions. Thanks.

Cara Ruddle, P.Eng.
Project Manager

Novatech Engineering Consultants Ltd
200-240 Michael Cowpland Drive
Ottawa . Ontario . Canada . K2M 1P6

Office: 613-254-9643 x 220
Fax: 613-254-5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this communication and any copy immediately. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Si vous avez reçu le message par erreur, veuillez m'en aviser par téléphone (au numéro précité) ou par courriel, puis supprimer sans délai la version originale de la communication ainsi que toutes ses copies. Je vous remercie de votre collaboration.

APPENDIX B
Sanitary Sewer Information

SANITARY SEWER DESIGN SHEET

PROJECT : 113150
 DESIGNED BY: ARM
 CHECKED BY: CJR
 DATE: 09-Dec-13
 DATE REVISED:



LOCATION				JOBS & POPULATION								PROPOSED SEWER PIPE						CHECK			
STREET	FROM	TO	AREA (ha)	Jobs (per ha)	Population (per ha)	CUMULATIVE			Jobs/Commercial		Population		PEAK EXTRAN. FLOW Q(i) (L/s)	PEAK DESIGN FLOW Q(d) (L/s)	DIA. (mm)	PIPE ID (mm)	TYPE OF PIPE	SLOPE (%)	CAPACITY (L/s)	FULL FLOW VELOCITY (m/s)	Qpeak/Qcap
						Jobs	POP.	AREA (ha)	PEAK FACTOR (M)	FLOW Q(p) (L/s)	PEAK FACTOR (M)	POP. FLOW Q(p) (L/s)									
				207	48							0.28									
Hamilton Av N	Oxford	Bullman	1.05	217	50	217	50	1.05	1.50	0.28	4.00	0.81	0.29	1.39	250	251.5	DR 35	0.24	29.6	0.60	4.7%
12 Storey Office	Bullman			2161	0	2161	0	1.05	1.50	2.81	4.00	0.00	0.29	3.11	250	251.5	DR 35	0.24	29.6	0.60	10.5%
Bullman	Hamilton	Parkdale	0.36	75	17	2453	67	2.46	1.50	3.19	4.00	1.09	0.69	4.97	250	251.5	DR 35	0.24	29.6	0.60	16.8%
Parkdale	Oxford	Bullman	1.30	269	62	2722	129	3.76	1.50	3.54	4.00	2.09	1.05	6.69	250	251.5	DR 35	0.24	29.6	0.60	22.6%
Parkdale	Bullman	Scott	0.75	155	36	2877	165	4.51	1.50	3.75	4.00	2.67	1.26	7.68	250	251.5	DR 35	0.24	29.6	0.60	26.0%
Scott		Parkdale	1.62	335	78	335	78	1.62	1.50	0.44	4.00	1.26	0.45	2.15	250	251.5	DR 35	0.24	29.6	0.60	7.3%
Scott	Parkdale	Pinehurst	0.17	35	8	3247	251	6.30	1.50	4.23	4.00	4.07	1.76	10.06	250	251.5	DR 35	0.24	29.6	0.60	34.0%
Scott	Pinehurst		2.25	466	108	3713	359	8.55	1.50	4.83	4.00	5.82	2.39	13.05	300	299.4	DR 35	0.19	41.9	0.60	31.1%
Scott		Carruthers	1.50	311	72	4024	431	10.05	1.50	5.24	4.00	6.98	2.81	15.04	300	299.4	DR 35	0.19	41.9	0.60	35.9%
Scott	Carruthers	Stirling	1.40	290	67	4314	498	11.45	1.50	5.62	3.98	8.02	3.21	16.84	300	299.4	DR 35	0.19	41.9	0.60	40.2%
Scott	Stirling	Pinhey	1.47	304	71	4618	569	12.92	1.50	6.01	3.94	9.09	3.62	18.72	300	299.4	DR 35	0.19	41.9	0.60	44.7%
Scott	Pinhey	Merton	1.72	356	83	4974	652	14.64	1.50	6.48	3.91	10.33	4.10	20.91	300	299.4	DR 35	0.19	41.9	0.60	49.9%

* Note: Assumed minimum slope

Notes:

1. $Q(d) = Q(p) + Q(i)$, where

Q(d) = Design Flow (L/sec)
 Q(p) = Population Flow (L/sec)
 Q(i) = Extraneous Flow (L/sec)

2. $Q(i) = 0.28$ L/sec/ha


3. $Q(p) = (P \times q \times M / 86.4)$, where

P = Persons (Population = 48/ha, Jobs=207/ha)
 q = Average per capita flow = 350 L/cap/day
 M = Harmon Formula (maximum of 4.0)

4. Depth of flow/Diameter from Hydraulic properties of circular pipes flowing partially full

5. Population/Jobs Target Density 2031 = 250/ha (17915 jobs, 4204 pop = 255/ha density at 2031) per Figure 30 for Tunney's-Quad area (Residential Land Strategy for Ottawa 2006-2031, City of Ottawa Feb 2009)

Breakdown	Jobs	Population
Projected	17915	4204
Percentage	81.0%	19.0%
At 255/ha =	207	48




M:\2013\113150\CAD\Design\Figures\Figure5.dwg, figure5_13000, Dec 09, 2013 - 3:20pm, bhurber

NOVATECH
ENGINEERING
CONSULTANTS LTD.
 ENGINEERS & PLANNERS
 Suite 200, 240 Michael Cowpland Drive
 Ottawa, Ontario, Canada
 K2M 1P6
 Telephone: (613) 254-9643
 Facsimile: (613) 254-5867
 Email: novainfo@novatech-eng.com

SCALE
 1:3000
 1:3000
 0 30 60 90 120

**1560 SCOTT STREET -
 HOLLAND CROSS PHASE 3
 DOWNSTREAM SANITARY
 DRAINAGE AREAS**
 DEC 2013 113150 FIGURE 5

APPENDIX C
Engineering Figures



M:\2013\113150\CAD\Design\Figures\Figure6.dwg, Figure 6, Dec 12, 2013 - 3:31pm, iandric

NOVATECH
ENGINEERING
CONSULTANTS LTD.
 ENGINEERS & PLANNERS
 Suite 200, 240 Michael Cowpland Drive
 Ottawa, Ontario, Canada
 K2M 1P6
 Telephone (613) 254-9643
 Facsimile (613) 254-5867
 Email: novainfo@novatech-eng.com

SCALE

1:400

1:400


**1560 SCOTT STREET-
 HOLLAND CROSS PHASE 3
 GRADING AND SERVICING**

DEC 2013 113150 FIGURE 6

NOTE:

ALL UNDERGROUND INFORMATION WITHIN PROPERTY LIMITS OBTAINED FROM RYBKA, SMITH AND GINSLER LIMITED CONSULTING ENGINEERS PLAN TITLED "SITE PLAN-MECHANICAL" DATED AUGUST 26, 1987. ALL UNDERGROUND INFORMATION WITHIN CITY OF OTTAWA RIGHT OF WAY OBTAINED FROM CITY OF OTTAWA PLAN AND PROFILE RECORD DRAWINGS 2032-1 & 2032-2 (CITY OF OTTAWA RECORD NUMBER 14274) DATED JULY 13, 2006.







ALL INFORMATION CONTAINED ON THIS PLAN IS APPROXIMATE. ALL SERVICE LOCATIONS AND ELEVATIONS ARE TO BE CONFIRMED ON SITE AT THE TIME OF CONSTRUCTION.




EROSION AND SEDIMENT CONTROL NOTES:

1. THE OWNER AGREES TO PREPARE AND IMPLEMENT AN EROSION AND SEDIMENT CONTROL PLAN TO THE SATISFACTION OF THE CITY OF OTTAWA, APPROPRIATE TO THE SITE CONDITIONS, PRIOR TO UNDERTAKING ANY SITE ALTERATIONS (FILLING, GRADING, REMOVAL OF VEGETATION, ETC.) AND DURING ALL PHASES OF SITE PREPARATION AND CONSTRUCTION IN ACCORDANCE WITH THE CURRENT BEST MANAGEMENT PRACTICES FOR EROSION AND SEDIMENT CONTROL SUCH AS BUT NOT LIMITED TO INSTALLING FILTER CLOTHS ACROSS MANHOLE/CATCHBASIN LIDS TO PREVENT SEDIMENTS FROM ENTERING STRUCTURES AND INSTALL AND MAINTAIN A LIGHT DUTY SILT FENCE BARRIER AS REQUIRED.
2. THE CONTRACTOR SHALL PLACE FILTER CLOTH UNDER THE CATCHBASIN AND MANHOLE GRATES FOR THE DURATION OF CONSTRUCTION AND WILL REMAIN IN PLACE DURING ALL PHASES OF CONSTRUCTION.
3. SILT FENCING FOR ENTIRE PERIMETER OF SITE, SHALL BE UTILIZED TO CONTROL EROSION FROM THE SITE DURING CONSTRUCTION.
4. THE CONTRACTOR ACKNOWLEDGES THAT FAILURE TO IMPLEMENT EROSION AND SEDIMENT CONTROL MEASURES MAY BE SUBJECT TO PENALTIES IMPOSED BY ANY APPLICABLE REGULATORY AGENCY.

LEGEND

-  FILTER CLOTH CATCH
-  SILT FENCE PER OPSD 219.110
-  EXISTING STORM PIPE
-  EXISTING CB
-  EXISTING STORM MH
-  EXISTING SANITARY MH



SCALE

1:400

1:400

0 4 8 12 16

NOTE:

1560 SCOTT STREET-
HOLLAND CROSS PHASE 3
EROSION AND SEDIMENT
CONTROL PLAN

DEC 2013 113150 FIGURE 7

NOVATECH
ENGINEERING
CONSULTANTS LTD.
ENGINEERS & PLANNERS

Suite 200, 240 Michael Cowpland Drive
Ottawa, Ontario, Canada
K2M 1P6

Telephone (613) 254-9643
Facsimile (613) 254-5867
Email: novainfo@novatech-eng.com

M:\2013\113150\CAD\Design\Figures\Figure7.dwg, Figure 6, Dec 13, 2013 - 2:02pm, iandric

APPENDIX D

City of Ottawa Checklist

Development Servicing Study Checklist

4.1 General Content	Addressed (Y/N/NA)	Section	Comments
Executive Summary (for larger reports only).	NA		
Date and revision number of the report.	Y		
Location map and plan showing municipal address, boundary, and layout of proposed development.	Y		
Plan showing the site and location of all existing services.	Y		
Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.	N		Refer to Planning Rationale
Summary of Pre-consultation Meetings with City and other approval agencies.	N		
Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defensible design criteria.	NA		
Statement of objectives and servicing criteria.	Y		
Identification of existing and proposed infrastructure available in the immediate area.	Y		
Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).	NA		
Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighboring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths.	NA		The proposed building will occupy the majority of the site.

Development Servicing Study Checklist

4.1 General Content	Addressed (Y/N/NA)	Section	Comments
Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.	NA		
Proposed phasing of the development, if applicable.	NA		
Reference to geotechnical studies and recommendations concerning servicing.	NA		
All preliminary and formal site plan submissions should have the following information:			
Metric scale	Y		
North arrow (including construction North)	Y		
Key plan	Y		
Name and contact information of applicant and property owner	Y		
Property limits including bearings and dimensions	Y		
Existing and proposed structures and parking areas	Y		
Easements, road widening and rights-of-way	Y		
Adjacent street names	Y		

Development Servicing Study Checklist

4.2 Water	Addressed (Y/N/NA)	Section	Comments
Confirm consistency with Master Servicing Study, if available.	N		None Known
Availability of public infrastructure to service proposed development.	Y		
Identification of system constraints.	N		None Known
Identify boundary conditions.	Y		City supplied
Confirmation of adequate domestic supply and pressure.	Y		
Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.	Y		
Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.	Y		
Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design.	NA		No phasing planned
Address reliability requirements such as appropriate location of shut-off valves.	Y		
Check on the necessity of a pressure zone boundary modification.	NA		
Reference to water supply analysis to show that major infrastructure is capable of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range.	Y		
Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants) including special metering provisions.	Y		
Description of off-site required feeder mains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.	NA		
Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.	Y		
Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.	NA		

Development Servicing Study Checklist

4.3 Wastewater	Addressed (Y/N/NA)	Section	Comments
Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).	Y		
Confirm consistency with Master Servicing Study and/or justifications for deviations.	N		
Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers.	N		
Description of existing sanitary sewer available for discharge of wastewater from proposed development.	Y		
Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable)	Y		
Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.	Y		
Description of proposed sewer network including sewers, pumping stations, and forcemains.	Y		
Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).	NA		
Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.	NA		
Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.	NA		
Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.	NA		
Special considerations such as contamination, corrosive environment etc.	NA		

Development Servicing Study Checklist

4.4 Stormwater	Addressed (Y/N/NA)	Section	Comments
Description of drainage outlets and downstream constraints including legality of outlet (i.e. municipal drain, right-of-way, watercourse, or private property).	Y		
Analysis of the available capacity in existing public infrastructure.	N		Hard surface areas and therefore, storm flows are not being increased.
A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns and proposed drainage patterns.	N		Drainage patterns are not being altered.
Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.	Y		
Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.	N		The site will be roof and underground parking (sanitary sewer)
Description of stormwater management concept with facility locations and descriptions with references and supporting information.	Y		
Set-back from private sewage disposal systems.	NA		
Watercourse and hazard lands setbacks.	NA		
Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.	NA		
Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.	NA		
Storage requirements (complete with calcs) and conveyance capacity for 5 yr and 100 yr events.	Y		
Identification of watercourse within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.	NA		
Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.	NA		
Any proposed diversion of drainage catchment areas from one outlet to another.	NA		
Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and SWM facilities.	NA		
If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event.	NA		

Development Servicing Study Checklist

4.4 Stormwater	Addressed (Y/N/NA)	Section	Comments
Identification of municipal drains and related approval requirements.	NA		
Description of how the conveyance and storage capacity will be achieved for the development.	NA		
100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.	NA		
Inclusion of hydraulic analysis including HGL elevations.	NA		
Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.	NA		
Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.	NA		
Identification of fill constrains related to floodplain and geotechnical investigation.	NA		

Development Servicing Study Checklist

4.5 Approval and Permit Requirements	Addressed (Y/N/NA)	Section	Comments
Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams as defined in the Act.	NA		
Application for Certificate of Approval (CofA) under the Ontario Water Resources Act.	NA		
Changes to Municipal Drains.	NA		
Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation etc.)	NA		

4.6 Conclusion	Addressed (Y/N/NA)	Section	Comments
Clearly stated conclusions and recommendations.	Y		
Comments received from review agencies including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.	Y		
All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario.	Y		

SITE SERVICING AND STORMWATER MANAGEMENT REPORT, HOLLAND CROSS OTTAWA, ON

Appendix D Design Criteria and Report Excerpts
March 8, 2023

D.2 JUNE 14, 2022 CITY MEETING MINUTES

Johnson, Warren

From: Fawzi, Mohammed <mohammed.fawzi@ottawa.ca>
Sent: Friday, June 17, 2022 12:06 PM
To: Johnson, Warren
Cc: Kilborn, Kris; Shahzadeh, Serene; Cody, Neal
Subject: RE: 1560 Scott Street
Attachments: Roof Drain Control Letter - Template.docx

Follow Up Flag: Follow up
Flag Status: Completed

Hi Warren,

Thank you for the summary.

I've attached the Roof Drain Control Letter, which I kindly ask to be completed and signed and attached as an appendix in the servicing report. Regarding the hydrant classifications and flow that can be considered from a given hydrant, please refer to City of Ottawa Technical Bulletin IST-2018-02 Appendix I Table 1.

Let me know if you wish to discuss further. Thank you.

Best Regards,

Mohammed Fawzi, P.Eng.
Project Manager
Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique
Development Review - Central Branch
City of Ottawa | Ville d'Ottawa
110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1
613.580.2424 ext./poste 20120, Mohammed.Fawzi@ottawa.ca

****Please note that due to the current situation, I am working remotely. Email is currently the best way to contact me****

From: Johnson, Warren <Warren.Johnson@stantec.com>
Sent: June 14, 2022 2:37 PM
To: Fawzi, Mohammed <mohammed.fawzi@ottawa.ca>
Cc: Kilborn, Kris <kris.kilborn@stantec.com>; Shahzadeh, Serene <Serene.Shahzadeh@stantec.com>; Cody, Neal <Neal.Cody@stantec.com>
Subject: 1560 Scott Street

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Mohammad,

As a follow up from today's meeting see below items discussed:

- FUS is required when OBC calculations exceed 9000 L/min. New boundary conditions will be requested with the revised calculation. A sketch should be provided illustrating the distance from the existing hydrants to the proposed building. Mohammad to provide information regarding hydrant classifications.
- The comment regarding the allowable release rate using a runoff coefficient of 0.5 can be deleted. As per discussion in the previous meeting, given that this is not a full modification to the property a post to pre swim analysis is acceptable (pre-development C being 0.86). We will review correspondence to see if there was an email to this effect from the meeting with Eric.
- The northern drainage area (EXT-1) can be discounted from the allowable release rate since only minor revisions are being made to this area.
- Rooftop storage plans are not required given that the roof plan is subject to change prior to building permit and the servicing report provides a very conservative volume estimate. A line will be added to the report to indicate that the mechanical consultant is required to provide a sign-off letter confirming that they will respect the requirements outlined in the servicing report.
- It was noted that dual water services are required for the building. Pending mechanical confirmation, the secondary service will be provided by the existing water stub off of the Bullman Street access to the north of the proposed building.

If you have any questions let me know.

Thanks,

Warren Johnson C.E.T.
Civil Engineering Technologist

Direct: 613 784-2272
Warren.Johnson@stantec.com

Stantec



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.
Please consider the environment before printing this email.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

Appendix E Drawings
March 8, 2023

Appendix E **DRAWINGS**