

## GENERAL NOTES:

1) COORDINATE AND SCHEDULE ALL WORK WITH OTHER TRADES AND CONTRACTORS.

- DETERMINE THE EXACT LOCATION, SIZE, MATERIAL AND ELEVATION OF ALL EXISTING UTILITIES PRIOR TO COMMENCING CONSTRUCTION. PROTECT AND ASSUME RESPONSIBILITY FOR ALL EXISTING UTILITIES WHETHER OR NOT SHOWN ON THIS DRAWING.
- 3) OBTAIN ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF OTTAWA BEFORE COMMENCING CONSTRUCTION.
- 4) BEFORE COMMENCING CONSTRUCTION OBTAIN AND PROVIDE PROOF OF COMPREHENSIVE, ALL RISK AND OPERATIONAL LIABILITY INSURANCE FOR \$2,000,000.00. INSURANCE POLICY TO NAME OWNERS, ENGINEERS AND ARCHITECTS AS CO-INSURED AND THE CITY OF OTTAWA AS THIRD PARTY.
- 5) RESTORE ALL DISTURBED AREAS ON-SITE AND OFF-SITE, INCLUDING TRENCHES AND SURFACES ON PUBLIC ROAD ALLOWANCES TO EXISTING CONDITIONS OR BETTER TO THE SATISFACTION OF THE CITY OF OTTAWA AND ENGINEER.
- 6) REMOVE FROM SITE ALL EXCESS EXCAVATED MATERIAL, ORGANIC MATERIAL AND DEBRIS UNLESS OTHERWISE INSTRUCTED BY ENGINEER. EXCAVATE AND REMOVE FROM SITE ANY CONTAMINATED MATERIAL. ALL CONTAMINATED MATERIAL SHALL BE DISPOSED OF AT A LICENSED LANDFILL FACILITY.
- 7) ALL ELEVATIONS ARE GEODETIC. SITE BENCHMARK IS A HYDRANT LOCATED IN FRONT OF THE SUBJECT SITE.
- 8) REFER TO ARCHITECT'S AND LANDSCAPE ARCHITECT'S DRAWINGS FOR BUILDING AND HARD SURFACE AREAS AND DIMENSIONS.9) SAW CUT AND KEY GRIND ASPHALT AT ALL ROAD CUTS AND ASPHALT TIE IN POINTS AS PER CITY OF OTTAWA STANDARDS (R10).
- ALL ROAD CUTS TO BE REINSTATED WITH FULL MILL OVERLAY AS PER CITY OF OTTAWA STANDARDS (R10). 10) CONTRACTOR TO PROVIDE THE CONSULTANT WITH A GENERAL PLAN OF SERVICES INDICATING ALL SERVICING AS-BUILT INFORMATION SHOWN ON THIS PLAN. AS-BUILT INFORMATION MUST INCLUDE: PIPE MATERIAL, SIZES, LENGTHS, SLOPES, INVERT AND T/G ELEVATIONS, STRUCTURE LOCATIONS, VALVE AND HYDRANT LOCATIONS, T/WM ELEVATIONS AND ANY ALIGNMENT
- CHANGES, AND ALL SURFACE ELEVATION AS-BUILT GRADES.
- 11) NO EXCESS DRAINAGE SHALL BE DIRECTED ONTO NEIGHBOURING PROPERTY.12) NO ALTERATIONS TO EXISTING GRADES ARE PERMITTED BEYOND THE PROPERTY LINE.
- 13) REFER TO ARCHITECT'S DRAWINGS FOR ADDITIONAL DETAILS ON THE PROPOSED BUILDING ADDITION / RETROFITS.
- 14) REFER TO LANDSCAPE ARCHITECT'S DRAWINGS FOR ADDITIONAL DETAILS ON THE HARDSCAPE AND SOFTSCAPE AREAS, AND PLANTINGS.
- 15) REFER TO THE 'SERVICING BRIEF AND STORMWATER MANAGEMENT REPORT' (R-2022-011) DATED FEBRUARY 2, 2022 PREPARED BY NOVATECH FOR ADDITIONAL DETAILS ON THE SITE SERVICING AND STORMWATER MANAGEMENT FOR THE SUBJECT SITE.

## WATERMAIN NOTES:

| ) SPECIFICATIONS:                      |           |
|--|-----------|
|  | SPEC. No. |
| WATERMAIN TRENCHING                    | W17       |
| THERMAL INSULATION IN SHALLOW TRENCHES | W22       |
| THERMAL INSULATION AT OPEN STRUCTURES  | W23       |
| WATERMAIN CORSSING ABOVE SEWERS        | W25.2     |
| WATERMAIN SER∨ICE (150mmØ)             | PVC DR 18 |
| WATER METER                            | W32       |

| <b>REFERENCE</b> |
|------------------|
| CITY OF OTTAW    |
|                  |

 2) SUPPLY AND CONSTRUCT ALL WATERMAINS AND APPURTENANCES IN ACCORDANCE WITH THE CITY OF OTTAWA STANDARD AND SPECIFICATIONS. EXCAVATION, INSTALLATION, BACKFILL AND RESTORATION OF ALL WATERMAINS BY THE CONTRACTOR. CONNECTIONS AND SHUT-OFFS AT THE MAIN AND CHLORINATION OF THE WATER SYSTEM SHALL BE PERFORMED BY CITY FORCES.
3) WATERMAIN SERVCE SHALL BE MINIMUM 2.4m DEPTH BELOW GRADE UNLESS OTHERWISE INDICATED.

4) PROVIDE MINIMUM 0.5m CLEARANCE BETWEEN OUTSIDE OF PIPES AT ALL CROSSINGS, UNLESS OTHERWISE INDICATED.

| SEWER NOTES:   |   |                                  |
|--|---|----------------------------------|
| 1) SPECIFICATIONS:<br>ITEM   | SPEC. No.   | REFERENCE                        |
| SEWER TRENCH<br>BEDDING (GRANULAR A)<br>COVER (GRANULAR A OR GRANULAR I<br>WITH MAXIMUM PARTICLE SIZE=25mm | S6 & S7<br>3 TYPE I WITH MAXIMUM PARTICLE SIZE :                              | CITY OF OTTAWA<br>= 25mm)        |
| SANITARY SERVICE<br>STORM SEWER<br>STORM SERVICE (FOUNDATION)<br>SEWER CONNECTIONS<br>BACKWATER VALVE TYPE | PVC DR 28<br>PVC DR 35<br>PVC DR 28<br>S 11<br>S 14 AND EITHER S14.1 OR S14.2 | CITY OF OTTAWA<br>CITY OF OTTAWA |
|  |   |                                  |

2) SUPPLY AND CONSTRUCT ALL SEWERS AND APPURTENANCES IN ACCORDANCE WITH THE CITY OF OTTAWA STANDARD AND SPECIFICATIONS.

3) ALL STORM AND SANITARY SERVICE LATERALS SHALL BE EQUIPPED WITH BACKFLOW PREVENTERS WITHIN THE BUILDING FOOTPRINT AS PER CITY OF OTTAWA STANDARD DETAILS S14, AND S14.1 OR S14.2. REFER TO MECANICAL PLANS FOR DETAILS.

4) INSULATE ALL SEWER PIPES THAT HAVE LESS THAN 2.0m COVER WITH HI-40 INSULATION. PROVIDE 150mm CLEARANCE BETWEEN PIPE AND INSULATION.

5) FLEXIBLE CONNECTIONS ARE REQUIRED FOR CONNECTING PIPES TO MANHOLES (FOR EXAMPLE KOR-N-SEAL, PSX: POSITIVE SEAL AND DURASEAL). THE CONCRETE CRADLE FOR THE PIPE CAN BE ELIMINATED.

6) PIPE BEDDING, COVER AND BACKFILL ARE TO BE COMPACTED TO AT LEAST 98% OF THE STANDARD PROCTOR MAXIMUM DRY DENSITY THE USE OF CLEAR CRUSHED STONE AS A BEDDING LAYER SHALL NOT BE PERMITTED.

| STORM MANHOLE AND CATCHBASIN TABLE |               |                                      |   |  |  |
|------------------------------------|---------------|--------------------------------------|---|--|--|
| CB No.                             | T/G ELEVATION | INVERT                               | DESCRIPTION   |  |  |
| CB2                                | 68.35         | 67.22                                | 600mm x 600mm CB (OPSD 705.010), W/ 600mm SUMP & S19.1 COVE |  |  |
| STM MH001                          | 68.94         | N. =67.14<br>S. =67.15<br>SE. =67.15 | 1200mmØ MH (OPSD 701.010), W/ S19 FRAME & COVER             |  |  |

| 69                    |        |   |
|-----------------------|--------|---|
| 68                    |        |   |
| 67                    |        | PROI<br>CROSSING OV<br>CITY OF OT                     |
| 66                    |        | NOTE(S):<br>1) WATERI<br>EXCAVA<br>2) SEWER<br>EXCAVA |
| C/L ROAD              | 10.02  | 0.80  |
| COMBINED<br>EWER INV. |        |   |
| TOP OF<br>ATERMAIN    |        | 00.01   |
| CHAINAGE              | UCUT C | 020+0   |
|                       |        |   |

|        |                         | DIAMETER OF | 2-YEAR         |                |                | 100-YEAR       |                |                |
|--------|-------------------------|-------------|----------------|----------------|----------------|----------------|----------------|----------------|
| CB No. | ICD TYPE (IPEX MODEL #) | OUTLET PIPE | DESIGN<br>FLOW | DESIGN<br>HEAD | WATER<br>ELEV. | DESIGN<br>FLOW | DESIGN<br>HEAD | WATER<br>ELEV. |
| CB2    | TEMPEST VORTEX LMF 105  | 300mm Ø     | 10.5 L/s       | 1.15m          | 68.52m         | 11.0 L/s       | 1.27m          | 68.64m         |

| C | SSING TABLE            |                      |
|---|------------------------|----------------------|
| 1 | 150mmØ TOP OF WM=67.69 |                      |
| 2 | 150mmØ TOP OF WM=67.69 | 150mmØ STM OBV=67.09 |
| 3 | 150mmØ TOP OF WM=67.69 | 150mmØ SAN OBV=67.17 |

|     |                           |           |     | SCALE | DESIGN   | FOR REVIEW ONLY    |
|-----|---------------------------|-----------|-----|-------|----------|--------------------|
|     |                           |           |     |       | AN       |                    |
| _   |                           |           |     | 1:200 | BCS      | DPROFESSIONAL ST   |
| 5.  | ISSUED FOR CITY REVIEW    | APR 04/22 | BHB |       | DRAWN    |                    |
| 4.  | REVISED PER CITY COMMENTS | MAR 29/22 | BHB |       | AN       | B. C. SWEET THE    |
| 3.  | ISSUED FOR CITY REVIEW    | FEB 02/22 | BHB | 1:200 | CHECKED  | April 4, 2022      |
| 2.  | ISSUED FOR COORDINATION   | JAN 21/22 | BHB |       | BCS      |                    |
| 1.  | ISSUED FOR COORDINATION   | JAN 11/22 | BHB |       | APPROVED | BOLINCE OF ONTARIO |
| No. | REVISION                  | DATE      | BY  |       | BHB      |                    |

