



April 08, 2022

Planning and Development
City of Ottawa,
110 Laurier Ave West,
Ottawa, ON,
K1P 1J1

Attention:

**Subject: Site Lighting – CEPEO ELEMENTARY SCHOOL, KANATA
755 Cope Drive, Stittsville, ON, K2S 1S3**

Our File: 219-00014-00

To whom it may concern,

I, the undersigned, verify that site lighting from the site plan application at 755 Cope Drive, Stittsville will not exceed 5.38 lux (0.5 fc) on the adjacent properties in all areas.

Furthermore, all lighting fixtures proposed on the aforementioned site plan will meet the criteria for Full Cut-Off Classification, as recognized by the Illumination Engineering Society of North America (IESNA or IES).

Yours Very Truly,



Serghei Saronov, P.Eng.
Electrical Engineer