

OTTAWA SOUTH UNITED SOCCER ASSOCIATION

HYDROGEOLOGICAL STUDY AND TERRAIN ANALYSIS

OTTAWA SOCCER UNITED CLUBHOUSE, 5650
MITCH OWENS DRIVE, MANOTICK, ON





HYDROGEOLOGICAL STUDY AND TERRAIN ANALYSIS

OTTAWA SOCCER UNITED
CLUBHOUSE, 5650 MITCH
OWENS DRIVE,
MANOTICK, ON

OTTAWA SOUTH UNITED SOCCER
ASSOCIATION

TYPE OF DOCUMENT (VERSION)
DRAFT

PROJECT NO.: 211-13935-00
CLIENT REF:
DATE: DECEMBER 22, 2022

WSP
SUITE 300
2611 QUEENSVIEW DRIVE
OTTAWA, ON, CANADA K2B 8K2

T: +1 613 829-2800
F: +1 613 829-8299
WSP.COM



December 22, 2022

Ottawa South United Soccer Association
1128 Clapp Lane
Manotick, Ontario
K4M 1A7

Attention: Jim Lianos

Dear Sir:

Subject: Hydrogeological Study and Terrain Analysis, Ottawa South United Soccer Association, 5650 Mitch Owens Road, Manotick, ON

As per your request, WSP Canada Inc. (WSP) has completed a hydrogeological evaluation of the potable water supply well that was drilled 5650 Mitch Owens Road in Ottawa, Ontario. WSP has also completed a sewage system capacity assessment at the site. These works have been completed and summarized in this report, in support of the proposed fieldhouse development at the site.

This report has been prepared, in draft form, as per the expectations of the Senior Hydrogeologist at the City of Ottawa. It is expected that the Hydrogeologist will review our preliminary findings and engage in a follow up meeting to provide comments to facilitate the finalization of the report and seek to expedite the acceptance of the report findings in support of the proposed redevelopment of the site.

As a brief summary, the hydrogeological study has found that there is an ample quantity of groundwater available to the facility with negligible offsite impacts anticipated. The water is potable and has some colour exceedences that will require specific treatment via granular activated carbon to be palatable for use within the facility. A cautionary note regarding sodium will also be required to be posted at the facility.

With respect to the sewage system capacity assessment we completed as part of this assignment, the Site is not considered to be hydrogeologically sensitive and long term groundwater impacts from nitrate-nitrogen are not anticipated to be on any concern.

Yours truly,

Robert A. Passmore, P. Eng.
Technical Lead – Senior Rural
Development Engineer

WSP ref.: 211-13935-00

SUITE 300
2611 QUEENSVIEW DRIVE
OTTAWA, ON, CANADA K2B 8K2

T: +1 613 829-2800
F: +1 613 829-8299
wsp.com

REVISION HISTORY

FIRST ISSUE

<Date>	<Remarks>			
Prepared by	Reviewed by	Approved By		
<preparer, title>	<reviewer, title>	<approver, title>		
REVISION 1				
<Date>	<Remarks>			
Prepared by	Reviewed by	Approved By		
<preparer, title>	<reviewer, title>	<approver, title>		
REVISION 2				
<Date>	<Remarks>			
Prepared by	Reviewed by	Approved By		
<preparer, title>	<reviewer, title>	<approver, title>		

[Remove these instructions prior to document release.

In the case of multiple Reviewers, use the additional spaces in the table to record all Reviewers. An Approver may also be a Reviewer if technically qualified. Where an Approver is not required, delete this entry from the table and remove it from the following Signature Page.]

SIGNATURES

PREPARED BY

DRAFT

Zara King, B.Eng.
Rural Servicing Specialist

Date

DRAFT

Valyn Bernard, P.Eng.
Project Engineer

Date

APPROVED¹ BY

DRAFT

Robert A. Passmore, P.Eng.
Senior Environmental Engineer (Geo-
Hydrogeology)

Date

WSP Canada Inc prepared this report solely for the use of the intended recipient, OTTAWA SOUTH UNITED SOCCER ASSOCIATION, in accordance with the professional services agreement. The intended recipient is solely responsible for the disclosure of any information contained in this report. The content and opinions contained in the present report are based on the observations and/or information available to WSP at the time of preparation. If a third party makes use of, relies on, or makes decisions in accordance with this report, said third party is solely responsible for such use, reliance or decisions. WSP does not accept responsibility for damages, if any, suffered by any third party as a result of decisions made or actions taken by said third party based on this report. This limitations statement is considered an integral part of this report.

The original of this digital file will be conserved by WSP for a period of not less than 10 years. As the digital file transmitted to the intended recipient is no longer under the control of WSP, its integrity cannot be assured. As such, WSP does not guarantee any modifications made to this digital file subsequent to its transmission to the intended recipient.



TABLE OF CONTENTS

1	INTRODUCTION	1
1.1	Background.....	1
1.2	Description of Proposed Development.....	1
1.3	Existing Site Conditions	1
2	PHYSICAL SETTING	2
2.1	Regional Physiography	2
2.2	Topography and Drainage	2
2.3	Regional Surficial Geology.....	2
2.3.1	Site Specific Geology	2
2.4	Regional Bedrock Geology	3
2.5	Regional Hydrogeology	3
2.5.1	Site Specific Hydrogeology.....	4
2.5.2	Regional Aquifer Water Quality	4
3	STUDY METHODOLOGY	7
3.1	Hydrogeological Assessment.....	7
3.1.1	Water Well Assessment- Existing Well.....	7
3.1.2	Aquifer Analysis.....	7
3.1.3	Pumping Test Summary	7
4	AQUIFER ANALYSIS	8
4.1	Water Quantity	8
4.2	Groundwater Geochemistry Assessment.....	9
4.2.1	Laboratory Water Quality Analysis	9
4.3	Water Supply Aquifer Summary	11
4.3.1	Water Quantity.....	11
4.3.2	Water Quality.....	11
4.4	Treatability of Raw Water	12
4.5	Potential Offsite Well Interference.....	13

5	GROUNDWATER IMPACT ASSESSMENT .	13
5.1	Conceptual Hydrogeological Model	13
5.2	Sewage System Capacity Assessment.....	14
5.2.1	Sewage System Design Parameters	16
6	CONCLUSION	16
7	REFERENCES	17

Draft

TABLES

TABLE 2-1	SUMMARY OF AQUIFER ANALYSIS OF NEIGHBOURING WATER SUPPLY WELL – 5765 LONGHEARTH WAY	5
TABLE 4-1	SUMMARY OF AQUIFER ANALYSIS OF EXISTING WATER SUPPLY WELL	8

FIGURES (FOLLOWING TEXT)

FIGURE 1	SEWAGE SYSTEM LAYOUT PLAN
----------	---------------------------

APPENDICES

A	MECP WATER WELL RECORDS
B	LABORATORY CERTIFICATES OF ANALYSES
C	PUMPING TEST DATA FOR TEST WELL
D	LANGELIER SATURATION INDEX CALCULATIONS
E	CLIMATIC WATER BUDGET CALCULATIONS
F	NITRATE IMPACT ASSESSMENT

1 INTRODUCTION

1.1 BACKGROUND

WSP Canada Inc. (WSP) was retained by Ottawa South United Soccer Association (the Client) to carry out a hydrogeological study and terrain analysis to support a Site Plan Approval (SPA) application for the proposed development of a field house and office at 5650 Mitch Owens Road, in Manotick, Ontario (Site).

These works have been completed in general accordance with the present City of Ottawa industry standard which seeks to utilize the following Ontario Ministry of Environment (MOE) guidance documents in the completion of hydrogeological assessments:

- 1 Guideline D-5: Planning for Sewage and Water Services (August 1996)
- 2 Procedure D-5-5: Technical Guideline for Private Wells: Water Supply Assessment (August 1996)
- 3 Procedure D-5-4: Technical Guideline for Individual Onsite Sewage System: Water Quality Impact Risk Assessment (August 1996)

The following report has been prepared specifically and solely for the aforementioned project which is described herein. It contains our findings and recommendations pertaining to the private services for the subject development as it is understood at the time of preparation of this report.

1.2 DESCRIPTION OF PROPOSED DEVELOPMENT

The Site (also known as George Nelms Park) is currently occupied by six (6) soccer fields and paved parking areas. It is currently proposed by the Client to re-develop the Site with a two (2) storey field house, with an outdoor observation deck overlooking the soccer pitches on the mezzanine floor and office rooms.

1.3 EXISTING SITE CONDITIONS

Based on available mapping from GeoOttawa, the existing Site area is approximately 129,531 m² and is situated on the south side of Mitch Owens Road, to the west of Dozois Road and St. Mark High School.

With respect to neighbouring development, there is a residential subdivision located to the south of the Site. To the west of the site exists vacant, undeveloped lands. To the north of the site, beyond Mitch Owen's Road, is a combination of strip lot residential dwellings and a small commercial operation (Burger and Shakes and Driving Range).

2 PHYSICAL SETTING

2.1 REGIONAL PHYSIOGRAPHY

Based on Ontario Geological Survey (OGS) mapping, the Site is located within the North Gower Drumlin Field physiographic region, just south of the Ottawa Valley Clay Plains. According to Chapman and Putnam (1984 and 2007), this physiographic region is described as having the majority of the area covered by clay or silt deposited between the drumlins by the Champlain Sea.

2.2 TOPOGRAHY AND DRAINAGE

The site topography is generally flat, with a gradual increase in elevation just east and south of the site. Runoff from the site is currently being directed to a surficial drainage swale style system with a discharge point to the west of the property and into the adjacent watercourse.

2.3 REGIONAL SURFICIAL GEOLOGY

The surficial geology of the site has been evaluated based on OGS Earth data and boreholes from previous geotechnical studies completed by others. The Ontario Ministry of the Environment, Conservation and Parks (MECP) published Water Well Records (WWR) for wells within 500 m of the site were also reviewed for surficial geology, primarily to confirm overburden thickness in the general vicinity of the Site. A summary of the review of surficial geology is discussed below.

Based OGS Earth data, the soils at the Site underlain by fine-textured glaciomarine deposits described as silt and clay with minor sand and gravel inclusions. Immediately northwest and east and southeast of the Site, Till deposits described as stone-poor, sandy silt to silty sand-textured till on Paleozoic terrain are present. Based on available MECP WWRs, topsoil was generally encountered at the surface, underlain by overburden soil consisting of 1m to 2m of a non-cohesive silty sand a modestly thick layer of stiff to very stiff silty clay. Underlying the silty clay, a compact to hard glacial till layer is present overlying the limestone bedrock of the Oxford Formation.

2.3.1 SITE SPECIFIC GEOLOGY

Paterson Group (Paterson) conducted a geotechnical investigation on June 25, 2015, for the Northeast field area on site where the proposed soccer fields and fieldhouse would be constructed. As part of the work program, eleven (11) boreholes were completed to a maximum depth of 6.1 m.

Topsoil:

A thin layer of topsoil was encountered in all boreholes. Topsoil is thickest at the center of the site at 0.66m and varies from 0.1m to 0.25m for the rest of the site. Based on the borehole logs, the moisture content is about 18%.

Silty Sand/ Sandy Silt:

All eleven (11) boreholes encountered a silty sand/sandy silt fill with some clay below the topsoil. This fill extended to depths ranging from 0.10 m to 1.90 m below the existing ground surface.

The SPT “N” values within the fill ranged from 1 blow to 12 blows per 305 mm of penetration indicating a loose to compact state of packing. This layer reported moisture content of 20%-25%

Silty Clay

A layer of sensitive silty clay was encountered underlying the fill in both boreholes drilled in this area. This deposit generally consists of interlayered clay and silty clay. This layer extended to depth of 1.3 m and 6.1 m in boreholes

This layer is classified as a soft to firm grey silty clay with some sand and has an increasing moisture content with depth that ranges between 25% to 60 %.

Additionally, in January 2022, WSP placed two (2) boreholes to confirm the soil content. Both test pits, located on the southwest portion of the site showed a 0.2m layer of topsoil underlain by 1.3m of a sandy clay to clayey sand (with a T-time of 35min/cm).

The site is not considered to be hydrogeologically sensitive and, as such, no special precautions need to be considered with respect to sewage system design, well construction, and minimum Ontario Building Code horizontal/vertical clearance distances for sewage system design.

Hydrogeologic sensitivity, as it applies in this instance, relates to the thickness, composition and consistency of the overburden soils. Thin, permeable soils overlying bedrock are considered to be hydrogeologically sensitive in most cases unless it can be demonstrated that the underlying bedrock aquifer system is isolated via the composition and consistency of the bedrock itself.

Percolation rates of native soils at the Site are estimated to be 35 min/cm based on the soil conditions observed during WSP’s tactile examination of soils at the Site. The northeast portion of the grass field area was identified to be the most suitable location for a new subsurface disposal system (see Figure 1).

2.4 REGIONAL BEDROCK GEOLOGY

Based on the available OGS bedrock mapping (1991), WSP’s extensive local knowledge of the aquifer systems in the Ottawa area, and combined with the findings of a preliminary hydrogeological study completed by Golder Associates Ltd. (Golder) in 2013, the Site is situated over limestone belonging to the Oxford Formation which, in turn, is underlain by alternating limestone and sandstone layers of the March Formation and then the readily identifiable white sandstone of the Nepean Formation.

There are no faults located within 4.5km of the Site. Furthermore, the Site is situated approximately eight to 10 km west of the Gloucester Fault.

2.5 REGIONAL HYDROGEOLOGY

A review of the available MECP WWRs related to aquifer data generally reveals the following trends:

1. The wells located to the immediate northwest and west of the site have intercepted a shallow aquifer located within the upper 5 to 15 m of the Oxford Formation. Conversely, few, if any wells located further

east from the western limits of the Site, based on the WWR's reviewed, intercepted this upper Oxford Formation;

2. Wells constructed on, and east (also north and south) of the site reveal the presence of two (2) deeper aquifer intercept ranges between 30 m and 50 m below ground surface (bgs) which corresponds to the likely basement of the Oxford Formation and upper limits of the March Formation;
3. Well yields in all aquifer intercepts exceeded the order of 5 USgpm; and
4. No dry holes were reported.

2.5.1 SITE SPECIFIC HYDROGEOLOGY

An existing water well (MECP WWR A199999, provided in Appendix A) has been previously constructed at the Site in 2017 by Capital Water Supply Ltd (the "Well Contractor"). A review of this WWR reveals that the casing was advanced through the overburden (14.93m bgs) and seated approximately 1.5 m into the underlying limestone bedrock using mud drilling. The annular space around the casing was sealed with a bentonite grout slurry. The open borehole was noted to intercept water bearing zones at approximately 41.1 m bgs and 50.8 m bgs in "grey & white sandstone" which is most probably the March Formation. The well was originally noted to be flowing at a rate of the order of 45.5 L/min (10 IGM). The March Formation has been extensively documented to have significant confining pressures with artesian conditions often resulting in free-flowing artesian wells in several areas within the City of Ottawa, ON.

The one-hour pumping test, completed by the Well Contractor, was conducted at 54.6 L/min (12 IGM). Drawdown after 60 minutes of continuous pumping was measured at 4.76m below top of casing (water level was at 0.00 m below casing at start of test). Full recovery was noted within approximately 20 minutes of termination of pumping.

Based on the pumping test information, the specific capacity of the well appears to be of the order of 11.5 L/min/m of drawdown.

2.5.2 REGIONAL AQUIFER WATER QUALITY

Water quality data was collected from a neighbouring property located at 5765 Longhearth Way (Well Tag A059485) on November 24th, 2022. This well was used as an observation well during the pump test conducted on December 1st, 2022. A copy of the WWR can be found in **Appendix A** (MECP WWR No. A059485). The laboratory Certificates of Analyses are compiled in **Appendix B**.

The water quality results are summarized in the **Table 2.1** below.

Table 2-1 Summary of Aquifer Analysis of Neighbouring Water Supply Well – 5765 Longhearth Way

PARAMETER	UNITS	MDL	GROUNDWATER	ONTARIO	REASONABLE	
			ANALYTICAL	DRINKING WATER	TREATABLE	LIMIT AS PER
			RESULTS	STANDARDS	D5-5	
			LAB ID: 1664952	TYPE	LIMIT	
MICROBIOLOGICAL						
Total Coliforms	CFU/100mL	0	0	MAC	0	-
<i>E.coli</i>	CFU/100mL	0	0	MAC	0	-
MINERAL						
Chloride	mg/L	1	160	AO	250	250
Fluoride	mg/L	0.10	<0.10	MAC	2.4	-
Nitrite	mg/L	0.1	<0.10	MAC	1.0	-
Nitrate	mg/L	0.1	<0.10	MAC	10.0	-
Total Kjeldahl Nitrogen	mg/L	0.05	0.304	-	-	-
Turbidity (Lab)	mg/L	0.1	10.0	MAC/AO	1.0/5.0	5
PHYSICAL						
Alkalinity	mg/L	5	368	OG	500	-
Colour	TCU	2	42	AO	5	7
DOC	mg/L	0.5	4.0	AO	5	10
Sulfide	mg/L	0.02	<0.01	AO	0.05	
pH	unitless	1	7.42	AO	6.5-8.5	-

PARAMETER	UNITS	MDL	GROUNDWATER	ONTARIO		REASONABLE
			ANALYTICAL	DRINKING WATER	TREATABLE	
			RESULTS	STANDARDS	LIMIT	LIMIT AS PER
			LAB ID: 1664952			PROCEDURE
						D5-5
Sulphate	mg/L	3	140	AO	500	500
Hardness	mg/L	1	568	OG	100	-
Sodium	mg/L	2	72	AO	20(200)	200
Iron	mg/L	0.03	1.08	AO	0.3	10
Manganese	mg/L	0.01	0.05	AO	0.05	1
Total Dissolved Solids	mg/L	1	832	AO	500	-
Ammonia	mg/L	0.010	0.092	-	-	-
Calcium	mg/L	1	135	-	-	-
Conductivity	uS/cm	5	1280	-	-	-
Ion Balance	Unitless	0.01	0.99	-	-	-
Magnesium	mg/L	1	56	-	-	-
Phenols	mg/L	0.001	<0.001	-	-	-
Potassium	mg/L	1	4	-	-	-
Tannin & Lignin	mg/L	0.1	1.1	-	-	-

Note: Parameters highlighted in blue represent Ontario Drinking Water Standards aesthetic/operational exceedances. Parameters highlighted in orange represent ODWS health warning (for Sodium only).

The groundwater geochemistry obtained from the neighbouring water supply well at 5765 Longhearth Way represents the intercepted aquifer system at that property, as it relates to health and aesthetic water quality parameters. A review of the water quality data indicates that it meets the health related parameter requirements specified by the Ontario Drinking Water Standards (ODWS) for the parameters tested.

With respect to aesthetic related water quality parameters results of colour, hardness and total dissolved solids, turbidity, were reported at concentrations higher than the ODWS values.

3 STUDY METHODOLOGY

3.1 HYDROGEOLOGICAL ASSESSMENT

3.1.1 WATER WELL ASSESSMENT- EXISTING WELL

As mentioned above, an existing water supply well (WSW), has been previously constructed at the Site in 2017 by Capital Water Supply Ltd of Stittsville Ontario. A copy of the published WWR for the existing well is provided in **Appendix A** (MECP WWR No. A199999).

A review of this WWR reveals that the casing was advanced through the overburden (14.93m bgs) and seated approximately 1.5 m into the underlying limestone bedrock using mud drilling. The annular space around the casing was sealed with a bentonite grout slurry. The open borehole was noted to intercept water bearing zones at approximately 41.1 m bgs and 50.8 m bgs in “grey & white sandstone” which is most probably the March Formation. The well was originally noted to be flowing at a rate of the order of 45.5 L/min (10 IGPM).

3.1.2 AQUIFER ANALYSIS

To evaluate the yield and collect data on the aquifer system intercepted by the existing water well on site, WSP carried out a constant rate pumping test on December 1st, 2022. The results of the pumping test were used to determine the relevant aquifer characteristics to assess long term well yield, etc.

3.1.3 PUMPING TEST SUMMARY

To facilitate the pumping test, given that the pump size and diameter of the discharge line (i.e. 50 mm dia.), WSP coordinated with Air Rock Drilling Company Ltd. to install a diverter on the existing discharge piping assembly which was connected to the existing irrigation system for the soccer fields rather than bring in a crane to lift the piping off the pitless adapter and connect to separate discharge pipes. The discharge piping was connected to the diverter and the piping was extended upwards of 30 m away from the well. The discharge water was conveyed away from the well area via an existing grassed swale sloping westward.

Initially, WSP had intended to complete a step test on the well, but given that the drawdown response was minimal when the pump was turned on and allowed to operate at full, unadjusted rates, it was decided to proceed with a full rate test until 50,000 L had been pumped. As such, the constant rate test was run at a rate of 202 L/min for a duration of A constant rate pumping test was carried out on the existing water supply well at a rate of approximately

202 L/min for approximately 245 minutes before the pump was shut off. A total of approximately 49,500 L of water was withdrawn from the pumping well with a corresponding total net drawdown of approximately 1.96 m.

Drawdown and recovery were monitored using pressure transducer installed in and beside the well. Two observation wells were used during this test. One observation well is located north of the site at Burger and' Shakes, and one observation well is located at a nearby residence on Longhearth Way. Drawdown data was gathered prior to the start of pumping and beyond the termination of pumping to assess aquifer drift characteristics where drawdown and recovery values differ.

Upon return to the Site on December 14, 2022, WSP was unable to retrieve the pressure transducer installed at the WSW during the pumping test. WSP suspects that the pressure transducer may have encountered wiring from the pump components in the well, which is preventing staff from pulling the loggers out of the well. Coordination with a licenced well technician is underway at the time of preparation this draft report to facilitate the retrieval of the pressure transducer. Manual measurements recorded during the constant rate pumping rate were used to provide a preliminary assessment of aquifer properties intercepted by the WSW. WSP will update the aquifer analysis results upon retrieval of data from the installed pressure transducers.

4 AQUIFER ANALYSIS

4.1 WATER QUANTITY

The results of the pumping test are provided in **Appendix C** and the aquifer characteristics determined from the constant rate pumping test carried out on the existing WSW, which are indicative of the underlying aquifer system are summarized in **Table 3-1** below:

Table 4-1 SUMMARY OF AQUIFER ANALYSIS OF EXISTING WATER SUPPLY WELL

AQUIFER PARAMETER

Pumping Rate (L/min)	202.8
Static Water Level (m) (below top of casing)	Overflowing
Depth of Well (m)	53.33
Available Drawdown (m) (inferred based on recommended depth from the well driller at time of initial pumping test)	30.47
Total Drawdown During Pumping of Well (m)	1.96
Specific Capacity (L/min./m of drawdown)	103.5
Time to 95% Recovery from Drawdown Test (minutes)	<1

Note: 1. Available drawdown estimated based on recommended pump depth available in MECP WWR.

4.2 GROUNDWATER GEOCHEMISTRY ASSESSMENT

4.2.1 LABORATORY WATER QUALITY ANALYSIS

A raw groundwater sample was collected from the site well on December 1st, 2022, in conjunction with the constant rate pump test. The analytical results from raw groundwater chemistry obtained are provided in **Table 3-2**. The laboratory Certificates of Analyses are compiled in **Appendix B**.

Table 3-2- SUMMARY OF GROUNDWATER GEOCHEMISTRY OBTAINED THROUGH PUMPING OF EXISTING DRILLED WELL

PARAMETER	UNITS	MDL	GROUNDWATER			REASONABLE TREATABLE LIMIT AS PER PROCEDURE D5-5
			ANALYTICAL RESULTS	ONTARIO DRINKING WATER STANDARDS	REASONABLE TREATABLE LIMIT AS PER PROCEDURE D5-5	
			LAB ID: 1666217	TYPE	LIMIT	
MICROBIOLOGICAL						
Total Coliforms	CFU/100mL	0	0	MAC	0	-
<i>E.coli</i>	CFU/100mL	0	0	MAC	0	-
Chloride	mg/L	1	91	AO	250	250
Fluoride	mg/L	0.10	0.19	MAC	2.4	-
Nitrite	mg/L	0.1	<0.10	MAC	1.0	-
Nitrate	mg/L	0.1	<0.10	MAC	10.0	-
Total Kjeldahl Nitrogen	mg/L	0.05	0.116	-	-	-
Turbidity (Lab)	mg/L	0.1	1.7	MAC/AO	1.0/5.0	5

GROUNDWATER
R

ANALYTICAL
RESULTS

ONTARIO DRINKING
WATER STANDARDS

REASONABLE
TREATABLE LIMIT AS
PER PROCEDURE D5-5

PARAMETER	UNITS	MDL	LAB ID: 1666217	TYPE	LIMIT	
Alkalinity	mg/L	5	255	OG	500	-
Colour	TCU	2	13	AO	5	7
DOC	mg/L	0.5	1.9	AO	5	10
Sulfide	mg/L	0.02	<0.01	AO	0.05	
pH	unitless	1	7.41	AO	6.5-8.5	-
Sulphate	mg/L	3	58	AO	500	500
Hardness	mg/L	1	351	OG	100	-
Sodium	mg/L	2	48	AO	20(200)	200
Iron	mg/L	0.03	0.20	AO	0.3	10
Manganese	mg/L	0.01	0.05	AO	0.05	1
Total Dissolved Solids	mg/L	1	535	AO	500	-
Ammonia	mg/L	0.010	0.084	-	-	-
Calcium	mg/L	1	81	-	-	-
Conductivity	uS/cm	5	823	-	-	-

GROUNDWATER
R
ANAYLTICAL RESULTS ONTARIO DRINKING WATER STANDARDS REASONABLE TREATABLE LIMIT AS PER PROCEDURE D5-5

PARAMETER	UNITS	MDL	LAB ID: 1666217	TYPE	LIMIT	
Ion Balance	Unitless	0.01	1.04	-	-	-
Magnesium	mg/L	1	36	-	-	-
Phenols	mg/L	0.001	<0.001	-	-	-
Potassium	mg/L	1	4	-	-	-
Tannin & Lignin	mg/L	0.1	0.8	-	-	-

Note: Parameters highlighted in blue represent Ontario Drinking Water Standards aesthetic/operational exceedances. Parameters highlighted in orange represent ODWS health warning (for Sodium only).

4.3 WATER SUPPLY AQUIFER SUMMARY

4.3.1 WATER QUANTITY

Based on the information summarized in **Table 3-1**, it is apparent that the water supply aquifer located beneath the subject lands has considerable yield. Based on the calculated specific capacity, the minimum long term well yield of the existing WSW is in excess of 1000 L/min, based on an estimated available drawdown of 30 m. This is significantly higher than the minimum yield necessary for the intended use (i.e. 4 L/min).

Based on the minimum long term yield, and considering the fast rate of recovery after termination of pumping after minimal drawdown during pumping, it is opined that there is ample yield within the intercepted aquifer system to accommodate the proposed re-development and addition of a field house and office building.

4.3.2 WATER QUALITY

The groundwater geochemistry obtained from the existing WSW, representative of the intercepted aquifer system on the subject property, as it relates to health and aesthetic water quality parameters, is presented in **Table 3-2**. A review of the water quality data indicates that it meets the health related parameter requirements specified by the Ontario Drinking Water Standards (ODWS) for the parameters tested.

With respect to aesthetic related water quality parameters results of colour, hardness and total dissolved solids were reported at concentrations higher than the ODWS values. A discussion of these aesthetic parameters, as it relates to its' control through the use of water treatment equipment, is provided in Section 3.4, below.

4.4 TREATABILITY OF RAW WATER

The following aesthetic parameters were noted to be present in concentrations exceeding the Ontario Drinking Water Standards:

- Colour;
- Hardness;
- Sodium; (special statement) and
- Total Dissolved Solids

The measured concentration of colour (13 TCU) exceeds the Table 3 of Procedure D-5-5 maximum concentration considered reasonably treatable (7 TCU). Activated carbon filters have been shown to effectively reduce the concentration of colour by 60-90% by adsorbing organic and inorganic water components on the surfaces of the activate carbon. A commercial grade activated carbon filter is recommended to lower the colour in the raw water, and to reduce the potential for trihalomethane formation during chlorination, if this method of disinfection is implemented at the development.

The hardness was measured to be of the order of 351 mg/L and is considered to be very hard. While this value is above the operational guideline of 100 mg/L, Table 3 of Procedure D-5-5 does not specify a maximum treatable limit for hardness. Rather, at the concentration measured during the water supply assessment, a commerical grade water softener can be used to condition the water to a more functional state (i.e. less scale formation). Due to the reported hardness concentration, a water conditioning professional should be retained to select the necessary grain value to effectively condition the water. Also, all backwash water should be directed to an infiltration gallery and not to the sewage system.

It is further recommended that either potassium salt be used as the regeneration salt for the softener resin or a separate drinking water tap be installed to supply raw water if sodium chloride salt is used. This is due to the fact that the softening process will displace sodium ions into the conditioned water as it removed calcium and magnesium ions in the process. As a result, the sodium concentration can easily increase to a point where it is above the aesthetic limit of 200 mg/L in the treated water.

In addition to the above discussion regarding sodium, the measured concentration in the raw water exceeds the cautionary limit of 20 mg/L. As such, it is required to notify the Medical Officer of Health for the City of Ottawa to allow for the dissemination of this information for persons with dietary restrictions for sodium. The sodium concentration is below the aesthetic limit of 200 mg/L set by Procedure D-5-5.

With respect to total dissolved solids (TDS), the laboratory results showed a concentration of the order of 535 mg/L. The Langelier Saturation Index was calculated for the raw water at temperatures at 8 C and 56 C to evaluate the stability of the water over the cold and hot water environments. At 8 C, the water is expected to be slightly corrosive but non-scale forming in its raw form. Above 56 C, the water is expected to be slightly scale forming and non-corrosive. A copy of the calculations appear in **Appendix D**. Raw water at the temperature of 8C is anticipated to be undersaturated with respect to calcium carbonate and has a tendency to remove existing calcium carbonate

protective coatings in pipelines and equipment. Consideration should be made adjusting the pH for corrosion control immediately prior to water distribution at the lower temperature ranges, to minimize corrosion effects on piping and equipment.

4.5 POTENTIAL OFFSITE WELL INTERFERENCE

Given the minimal drawdown observed at a rate of the order of 202 L/min. combined with the rapid recovery of the water level to 100% upon termination of pumping, and in direct consideration of the density of surrounding development, adverse offsite impacts on adjacent wells is expected to be minimal. WSP intends to confirm whether or not there was any measurable response to pumping in the observation wells once the datalogger from the pumping well has been successfully retrieved and the data properly analyzed.

5 GROUNDWATER IMPACT ASSESSMENT

5.1 CONCEPTUAL HYDROGEOLOGICAL MODEL

The Site is present within the southern portions of the Ottawa Valley Clay Plains. The general overburden stratigraphy, below the topsoil layer, consists of a 1 m to 2 m of a non-cohesive silty sand a modestly thick layer of stiff to very stiff silty clay. Underlying the silty clay is, as evidenced in the available WWR's and based on WSP's local experience, a compact to hard glacial till layer is present overlying the limestone bedrock of the Oxford Formation.

It is likely that infiltrating surface precipitation will pass through the topsoil and silty sand transition layer with relative ease. Vertical infiltration will be significantly retarded/reduced once the infiltrate reaches the surface of the silty clay. Looking at the deeper borehole data from the 2015 Paterson report, the silty clay was noted to have a soft to firm consistency in the upper few metres of the layer, becoming stiff to hard towards the base of the layer. This suggests that the overburden groundwater is present generally at the interface between the silty sand and the silty clay layer, and has, over a long period of time, vertically percolated into the clay layer by several metres. The lower moisture content and stiffer consistency/increase in shear strength deeper into the silty clay layer supports our supposition that the overburden groundwater is generally perched in this area.

As such, overburden groundwater is believed to generally migrate laterally along the surface of the silty clay layer, at the Site, significantly influenced by surficial topography and nearby drainage networks. Given the general topographic relief of the site, surface drainage appears to be directed westward towards the watercourse which meanders along the western limits of the property.

With respect to additional overburden aquifers, it is WSP's general experience, that an overburden aquifer generally exists near the basal contact area between the glacial till and the limestone bedrock.

In consideration of the above, it is WSP's opinion that the site is not considered hydrogeologically sensitive to receiving sewage system effluent. There is a lack of existing geotechnical information that would allow a confirmation of hydraulic isolation, and, as such, a groundwater impact assessment for nitrate-nitrogen will be required.

5.2 SEWAGE SYSTEM CAPACITY ASSESSMENT

The potential for impacts to occur within the local groundwater regime is dependent upon the local hydrogeologic setting, as well as the volume of sewage effluent being discharged and concentration of nutrients contained within the effluent. MECP Procedure D-5-4 - Technical Guideline for Individual On-Site Sewage Systems: Water Quality Impact Risk Assessment (August, 1996) (Procedure D-5-4) describes a three-step process for the assessment of potential groundwater impact(s) associated with development proposals outside of areas designated for reasonable use assessments under B-7.

The purpose of this assessment is to “...ensure that the combined effluent discharges from all the individual on-site sewage systems in a development will have a minimal effect on the groundwater and the present or potential use of the adjacent property”. In this regard, Procedure D-5-4 utilizes the 10 mg/L (as N) Ontario Drinking-Water Quality Standard (MECP, 2006) for nitrate-nitrogen as the primary indicator for groundwater impact potential where surface waters are not located directly downgradient of the subject property being evaluated.

To determine the representative existing background nitrate nitrogen levels in the receiving groundwater, WSP collected groundwater samples from water supply wells located on and adjacent lands to the site. Water samples were collected at the Site on December 1, 2022 during the 4-hour constant rate pumping test and at the nearby property located at 5765 Longhearth Way on November 24, 2022. Based on the analytical results, the concentration of nitrate reported for both samples were below laboratory method detection limits of 0.10 mg/L and existing background nitrate nitrogen levels in the intercepted aquifer are considered non-detectable.

To assess the potential groundwater impacts of the proposed on-site sewage system at the boundary of the Site, WSP has completed the groundwater quality impact risk assessment by first completing a site-specific water budget analysis for the Site. Climate data was obtained from the Ottawa McDonald Cartier Airport Station for the period from 1981 until 2010. Mean monthly temperatures were calculated by averaging mean monthly minimum and maximum temperatures. Temperature data were derived from the 30-year (1981-2010) climate data summaries. The Thornthwaite-Mather method was used to estimate potential and actual evapotranspiration on a monthly basis. The Thornthwaite-Mather method is based on an empirical relationship between potential evapotranspiration and mean air temperature and was used to estimate the potential water surplus at the Site. The water budget analysis is summarized in **Appendix E**.

Based on the location of the Site and the parent soil stratum present within the footprint of the proposed sewage system described at sandy clay to clayey sand, a water surplus of 351 mm per year was calculated to be available for infiltration. This infiltrate, for the purposes of the Procedure D-5-4 Impact Risk Assessment, is expected to dilute the sewage system effluent that is discharged through the leaching beds and into the natural environment beyond the property.

Using the surplus water value obtained from the site-specific water budget, WSP has completed a predictive groundwater impact risk analysis for the underlying groundwater aquifer system using the following critical assumptions:

- The Ontario Drinking Water Standard value for Nitrates in groundwater of 10 mg/L will be used as the maximum allowable downgradient concentration.
- Infiltration factor derivation will be reflective of conservative post-development conditions as follows:
 - Topography = 0.2 (Rolling Land)

- Soil = 0.1 (Clay)
- Cover = 0.05 (Grassed Areas)
- Percentage of impervious surfaces in the post-development scenario is assumed to be 10% (associated with building rooftops, driveways and parking areas)
- Concentration of nitrate in effluent is 40 mg/L
- No additional infiltration from landscaping is occurring

Based on the groundwater quality impact risk assessment results with the conservative assumptions outlined above, the sewage system nitrate attenuative capacity of the Site is estimated to be 14,800 L/day. At this estimated daily sewage flow, the concentration of nitrates in the infiltrate at the downstream receiving water supply aquifer system at the property boundary beneath the site is 9.9 mg/L. The groundwater quality impact risk assessment results are provided in **Appendix F**.

The current theoretical total daily design sanitary sewage flow (TDDSSF) for the subject property has been based on the Ontario Building Code 2012, as amended with consideration of the Manual Policy, Procedures and Guidelines for Onsite Sewage Systems, MECP (1982). The TDDSSF has been based on the combined theoretical sewage flows, of the players per team, the portion of players who use the facility to shower, and the number of office staff. The breakdown of the estimated flows, and the averaged balanced flow considered for design are outlined below:

On weeknights:

- Fieldhouse: 15 players and 3 spectators per team, with 6 teams =114 people total. $114 \times 8\text{L/day} = 912\text{L/day}$
- Office: 5 staff per day $\times 75\text{L/day} = 375\text{L/day}$
- Meeting room: Meeting of 20 people $\times 8\text{L/day} = 160\text{L/day}$
- Fitness facility: 20 people $\times 30\text{L/day} = 600$
- Showering facilities: 1 in 4 players uses the shower. Therefore 23 players $\times 22\text{L/day} = 506\text{L/day}$ comes from the showers
- Weeknight total average of **2,553L/day**

On weekends:

- Fieldhouse: 19 players and 4 spectators per team, with 40 teams= 760 people total. $760 \times 8\text{L/day} = 6080\text{L/day}$
- Office: 5 staff per day $\times 75\text{L/day} = 375\text{L/day}$
- Fitness facility: 20 people $\times 30\text{L/day} = 600$
- Showering facilities: 1 in 4 players uses the shower. Therefore, 150 players $\times 22\text{L/day} = 600\text{L/day}$
- Weekend total average of 10,355L/day

Considering the flows, the TDDSSF for the proposed facility load is:

$$\begin{aligned} \text{TDDSSF} &= [(5 \times 2, 553\text{L/day}) + (2 \times 10,355\text{L/day})] / 7 \\ &= 4, 782\text{L/day} \sim \mathbf{4,800 \text{ L/day}} \text{ (balanced flow)} \end{aligned}$$

Based on the TDDSSF currently being considered at the Site, the groundwater quality impact assessment estimated the long-term nitrate concentration in the infiltrate at the downstream receiving water supply aquifer system at the property boundary beneath the site is 3.8 mg/L. This resulting value is below the maximum acceptable concentration (MAC) for nitrate-nitrogen of 10 mg/L as noted by the ODWQS. As such, impacts to the groundwater quality down-gradient in the long-term resulting from the construction of the proposed sewage system is anticipated to be acceptable. The groundwater quality impact risk assessment results are provided in **Appendix F**.

Based on information provided in the Paterson Geotechnical Investigation Report (June 2015) and the shallow soil investigations completed by WSP in January 2022, the surficial geology at the site is generally underlain by topsoil cover ranging in thickness between 0.10 m to 0.66 m, overlying silty sand to sandy silt fill to depths ranging between 0.10m to 1.90 m below the existing ground surface and silty clay deposits extending to depths of 1.3 and 6.1 m in the boreholes advanced at the site. Based on the soil conditions observed, the site is not considered to be hydrogeologically sensitive and, as such, no special precautions need to be considered with respect to sewage system design, well construction, and minimum Ontario Building Code horizontal/vertical clearance distances for sewage system design.

5.2.1 SEWAGE SYSTEM DESIGN PARAMETERS

As the theoretical daily design sewage flow for the Site is less than 10,000 L/day, the Ontario Building code is the regulatory guideline for the proposed sewage disposal system.

6 CONCLUSION

Based on the information contained within the body of this assessment, the following conclusions can be drawn:

1. The Site is underlain by silty sand to sandy silt fill, extending to depths ranging from 0.10 m to 1.90 m below the existing ground surface. A layer of sensitive silty clay was encountered underlying the fill in boreholes drilled in this area, extending to depths of 1.3 and 6.1 m. This layer is classified as a soft to firm grey silty clay with some sand and has an increasing moisture content with depth that ranges between 25% to 60 %. The existing water supply well at the Site encountered up to 14.9 m of overburden, underlain by limestone and sandstone bedrock, likely of the Oxford and March Formations, respectively.
2. The water supply aquifer intercepted by the existin water supply well is strong and capable of significant well yields. Given the rapid recovery of the water level to 100% upon termination of pumping, combined with the surrounding low-density development, drawdown in neighbouring offsite wells is anticipated to be negligible.
3. The water supply aquifer intercepted by the existing water supply well contains a water supply that shows concentrations of colour, hardness and total dissolved solids were reported at concentrations higher than the ODWS aesthetic. The installation of activated carbon filters and water softening measures are recommended to reduce the concentrations of the colour, hardness and total dissolved solids.
4. The site is underlain by a silty sand to sandy silt transition soil to a soft to firm silty clay layer. Bedrock was not encountered within the depths of the boreholes advanced at the site, to a maximum depth of 6.1 m. As such, the subject land are not considered to be hydrogeologically sensitive to receiving sewage system effluent and require no special engineering design recommendations. Hydraulic isolation could not be

confirmed with the available geotechnical information, as such a groundwater impact assessment for nitrate-nitrogen was completed.

5. Based on the groundwater quality impact risk assessment results, the sewage system nitrate attenuative capacity of the Site is estimated to be 14,800 L/day. At this estimated daily sewage flow, the concentration of nitrates in the infiltrate at the downstream receiving water supply aquifer system at the property boundary beneath the site is 9.9 mg/L.
6. Using a theoretical total daily design sanitary sewage flow (TDDSSF) for the subject property for 4,800 L/day, the concentration of nitrates in the infiltrate at the downstream receiving water supply aquifer system at the property boundary beneath the site is 3.8 mg/L. This resulting value is below the maximum acceptable concentration (MAC) for nitrate-nitrogen of 10 mg/L as noted by the ODWQS. As such, impacts to the groundwater quality down-gradient in the long term resulting from the construction of the proposed sewage system is anticipated to be minimal.

7 REFERENCES

- Chapman, L.J., & Putnam, D. F. (1984). Physiography of Southern Ontario. Miscellaneous Release, Data 228 ISBN 0-7743-9422-6. Ontario Geological Survey.
- Chapman, L.J., & Putnam, D. F. (2007). Physiography of Southern Ontario. Miscellaneous Release, Data 228 ISBN 978-1-4249-5158-1. Ontario Geological Survey
- Ontario Geological Survey (1991). Bedrock Geology of Ontario, Southern Sheet; Ontario Geological Survey, Map 2544, scale 1: 1,000,000
- Ontario Geological Survey 2010. Surficial geology of Southern Ontario; Ontario Geological Survey, Miscellaneous Release--Data 128-REV

FIGURES

Draft



2611 QUEENSVIEW DR #300
OTTAWA, ONTARIO
CANADA K2B 8K2
PHONE: 613-829-2900
WWW.WSP.COM

CLIENT:
OTTAWA SOUTH UNITED

CLIENT REF. #:
PROJECT:
PROPOSED FIELD HOUSE

5650 MITCHELLS ROAD, OTTAWA

DRAFT

0	2022/07/28	ISSUED FOR PERMIT
---	------------	-------------------

PROJECT NO:	211-13935-00	DATE:	JANUARY 2022
-------------	--------------	-------	--------------

ORIGINAL SCALE:	1:500	IF THIS BAR IS NOT 25mm LONG, ADJUST YOUR PLOTTING SCALE.
-----------------	-------	---

DESIGNED BY:	RAP
DRAWN BY:	BA
CHECKED BY:	RAP

DISCIPLINE:
RURAL DEVELOPMENT


TITLE:
SEWAGE SYSTEM LAYOUT PLAN

SHEET NUMBER:
SHEET #: **1** OF **2**

ISSUE:
DATE OF: **SSD-01**

REV #
0



- TEST HOLE LOCATION
- EXISTING GROUND SURFACE ELEVATION (m)
- PROPOSED GROUND SURFACE ELEVATION (m)
- PROPOSED SWALE ELEVATION AND SLOPE (m)
- SLOPE AND DIRECTION OF OVERLAND FLOW (%)
- MFL MAIN FLOOR LEVEL
- TFW TOP OF FOUNDATION WALL
- BFL BASEMENT FLOOR LEVEL
- USF UNDERSIDE OF FOOTING
- TERRACING (3:1)
- PROPERTY LINE



DESIGN CALCULATIONS
 AVERAGE DAILY DESIGN FLOW = 4,800
 MINIMUM BALANCING TANK SIZE = 18,500 L
 PROPOSED BALANCING TANK SIZE = 18,500 L
 MINIMUM SEPTIC TANK SIZE = 3Q = 14,400 L
 PROPOSED SEPTIC TANK SIZE = 18,500 L
 PERCOLATION RATE OF NATIVE SOILS = 35 min/cm = T
 PROPOSED TREATMENT DISPOSAL SYSTEM = IN-GROUND ENVIRO-SEPTIC TREATMENT SYSTEM (REFER TO BMEC AUTHORIZATION #18-05-386, DATE OF ISSUANCE SEPT. 27, 2018, DATE EXPIRATION SEPT. 27, 2023)
 MINIMUM ADVANCED ENVIRO-SEPTIC (AES) PIPE = NAES = Q / 126 = 38.1
 MINIMUM LINEAR LENGTH OF ADVANCED ENVIRO-SEPTIC (AES) PIPE = 38.1 (3.05 m EACH PIPE) = 116.2 m
 PROPOSED LINEAR LENGTH OF ADVANCED ENVIRO-SEPTIC (AES) PIPE = 128.1 m (6 RUNS @ 21.35 m, 7 UNITS PER RUN, TOTAL = 42 PIPES)
 MINIMUM CONTACT AREA = Q T / 400 = 420 m²
 PROPOSED CONTACT AREA = 432.9m² (18.0 m X 24.05 m)
 MAXIMUM DOSAGE VOLUME = Q / 6 = 800 L/DOSE
 MINIMUM DOSING VOLUME = Q / 8 = 600 L/DOSE
 PROPOSED DOSING PUMP = LITTLE GIANT SUBMERSIBLE EFFLUENT PUMP

SOILS INFORMATION

NOTE: T-TIME ESTIMATES SHOWN IN THIS SECTION REFLECT PROFESSIONAL TACTILE EXAMINATION BY A QUALIFIED ENGINEER



Soccer Fields Weeknight (FLOW 1)		Soccer Fields Weekend (FLOW 2)	
19	players per team (15 players + 4 spectators)	19	players per team (15 players + 4 spectators)
6	teams per night	40	teams
1A	114 total people	2A	760 total people
8	L/day	8	L/day
912	Field	6,080	Field
1B	375 Office (5 staff x 75L/day)	2B	375 Office (5 staff x 75L/day)
1C	160 meeting (20 x 8L/day)	2C	600 Fitness (20 ppl x 30L/day)
1D	600 Fitness (20 ppl x 30L/day)	2E	3,300 150x22L/day
1E	506 (1/4 players shower) 23 * (22L/day)	2F	10,355 TOTAL OF FLOW 2
	2,553 TOTAL OF FLOW 1		
	4,782 Average for 7 days		
	4,782 AVERAGE DAILY FLOW		

CLIENT:

OTTAWA SOUTH UNITED

CLIENT REF. #:

PROJECT:

PROPOSED FIELD HOUSE

5650 MITCH OWENS ROAD, OTTAWA

DRAFT

0	2022/07/29	ISSUED FOR PERMIT
---	------------	-------------------

IS RE DATE DESCRIPTION

PROJECT NO:	211-13935-00	DATE:	JANUARY 2022
-------------	--------------	-------	--------------

ORIGINAL SCALE:	AS SHOWN	IF THIS BAR IS NOT 25mm LONG, ADJUST YOUR PLOTTING SCALE.
-----------------	----------	---

DESIGNED BY:	RAP
--------------	-----

DRAWN BY:	BA
-----------	----

CHECKED BY:	RAP	25mm
-------------	-----	------




DISCIPLINE:	RURAL DEVELOPMENT
-------------	-------------------

TITLE:	SEWAGE SYSTEM DETAILS AND NOTES
--------	---------------------------------

SHEET NUMBER:	2 OF 2
---------------	--------


ISSUE:	SSD-02	REV #	0
--------	--------	-------	---

DATE OF:	
----------	--



GENERAL NOTES

- SEWAGE SYSTEM DESIGNED FOR AVERAGE DAILY FLOW OF 4,800 L/DAY.
- ALL PVC FITTINGS AND PIPES BETWEEN TANKS ARE SCHEDULE 40.
- PRESSURE PIPES SHALL BE HIGH DENSITY JOINTLESS POLYETHYLENE.
- ALL WORK SHALL BE IN ACCORDANCE WITH RELEVANT CODES AND GUIDELINES BY A LICENSED INSTALLER TRAINED BY MAKE-WAY ENVIRONMENTAL TECHNOLOGIES INC. FOR THE INSTALLATION OF ADVANCED ENVIRO-SEPTIC TREATMENT SYSTEM.
- PRIOR TO COMMENCEMENT OF EXCAVATIONS, UNDERGROUND SERVICES SHALL BE LOCATED.
- CONTRACTOR MUST REPORT ANY DISCREPANCIES TO THE PROJECT ENGINEER TO DETERMINE THE IMPACT.
- ANY CHANGES MUST BE APPROVED BY THE PROJECT ENGINEER.
- ALL JOINT SEALS TO BE DONE WITH PRIMER AND MASTIC BAND, OR AS PER THE MANUFACTURER'S REQUIREMENTS.
- ALL HOLES AROUND PIPES GOING THROUGH CONCRETE STRUCTURE AND RISER SEAMS SHALL BE SEALED WITH NON-SHRINKING GROUT.
- ALL RISERS SHALL EXTEND TO SURFACE, COMPLETE WITH CHILD PROOF, TAMPER PROOF, LIDS.
- ALL GRAVITY CONNECTIONS SHALL HAVE A MINIMUM 2% GRADE BETWEEN TANKS/BUILDING(S). GRAVITY CONNECTION FROM THE DISTRIBUTION BOX TO THE LEACHING BED SHALL HAVE MINIMUM 1% SLOPE.
- IF HIGH GROUNDWATER CONDITIONS ARE ENCOUNTERED, TANKS WITH DYNAMIC WATER LEVELS MUST BE ANCHORED.
- ALL CONCRETE TANKS ARE TO HAVE A MAXIMUM BURIAL DEPTH OF 1.0 m IN NON TRAFFIC AREAS. EXTRA REINFORCEMENT IS REQUIRED FOR TRAFFIC AREAS AND/OR DEEP BURIAL.
- ALL SANITARY PIPES / FORCEMANS SHALL BE INSULATED OR BURIED BENEATH FROST LINE.
- TANK SEAMS AFFECTED BY HIGH GROUNDWATER ELEVATIONS MUST BE WATERPROOFED WITH AN EXTERIOR MEMBRANE.
- THE SEPTIC TANK SHALL BE OUTFITTED WITH AN EFFLUENT FILTER AT THE OUTLET. THE FILTER SHALL HAVE A HANDLE THAT EXTENDS WITHIN 0.3 m OF THE TANK LID FOR MAINTENANCE PURPOSES MEETING THE REQUIREMENTS OF THE ONTARIO BUILDING CODE.
- NO VEHICLES SHALL DRIVE OVER, OR PARK ON, THE LEACHING BED OR SEWAGE TANK AREA.
- TANKS SHALL BE INSTALLED ON 50 mm OF LOOSE SAND SPREAD EVENLY OVER MINIMUM 200 mm OF COMPACTED GRAVEL OR CRUSHED STONE.
- TANK EXCAVATIONS SHALL BE LEVEL AND APPROPRIATELY COMPACTED TO AVOID SETTLING.
- ALL CONSTRUCTION MATERIAL MUST MEET AT MINIMUM, THE ONTARIO BUILDING CODE (2012) SPECIFICATIONS, AND THE BMEC AUTHORIZATION NO. 13-03-365.
- SYSTEM SAND MUST HAVE AN EFFECTIVE DIAMETER (D₁₀) BETWEEN 0.2 AND 0.5 mm; COEFFICIENT OF UNIFORMITY (C_u) 4.5; LESS THAN 3 % OF MATERIAL SMALLER THAN 80 μm, AND LESS THAN 20 % OF MATERIAL LARGER THAN 2.5 mm.
- TOPSOIL SHALL BE OF GOOD LANDSCAPING QUALITY WITH LESS THAN 30 % FINES (SILT) TO ALLOW FOR AIR TRANSFER INTO SUBSURFACE.
- ENTRY VENT SHALL BE A MINIMUM OF 2.0 m ABOVE GRADE AND ANCHORED ON A SECURED POST OR EQUIVALENT. THE EXIT VENT MUST BE 3.0 m ABOVE THE ENTRY VENT. VENTS SHALL BE GOOSE-NECK VENT OUTFITTED WITH AN ACTIVATED CARBON FILTER TO MINIMIZE ODOURS. VENTS SHALL NOT BE OBSTRUCTED.
- NO LANDSCAPING INVOLVING WALKWAYS OR FENCING IS PERMITTED ON THE LEACHING BED AREA.
- NO LAWN WATERING (VIA SPRINKLER DEVICES OR OTHER) SHOULD OCCUR ON OR NEAR ENOUGH TO THE BED TO CAUSE ADVERSE EFFECTS.
- THE LEACHING BED COVER SHALL BE MAINTAINED AS SHORT MANICURED GRASS AND SHALL BE FREE OF SHRUBS/TREE/ROOTS.
- BUILDING DOWNSPOUTS SHOULD BE DIRECTED AWAY FROM THE LEACHING BED AREA.
- THE BUILDING'S SUMP, FLOOR DRAINS, AND/OR WATER TREATMENT SYSTEM, AND/OR GARBORATOR SHOULD NOT BE CONNECTED TO THE SEWAGE SYSTEM.
- AUDIBLE AND VISUAL HIGH LEVEL ALARM SHOULD BE INSTALLED AT AN APPROPRIATE LOCATION TO WARN OF PUMP FAILURE / HYDRAULIC OVERLOADING.
- TREES LOCATED ON OR DIRECTLY ADJACENT TO THE PROPOSED LEACHING BED MUST BE REMOVED.
- THE OWNER MUST ENTER INTO A SERVICING CONTRACT WITH MAKE-WAY ENVIRONMENTAL TECHNOLOGIES INC. (OR AUTHORIZED AGENT) FOR THE ONGOING SERVICE OF THE UNIT AS REQUIRED BY THE O&C.
- GREASE, SOLVENTS, PAINT, ETC. MUST NOT BE DISPOSED OF DOWN THE DRAIN AS THEY MAY IMPACT THE FUNCTIONALITY OF THE SEWAGE SYSTEM.
- WSP MUST BE PRESENT DURING CONSTRUCTION ACTIVITIES TO VERIFY DESIGN ASSUMPTIONS AND TO DOCUMENT THE CONSTRUCTION OF THE SYSTEM FOR CERTIFICATION. THIS DESIGN CANNOT BE RELIED UPON WITHOUT THIS SUPERVISION.
- A DETAILED GRADING / DRAINAGE PLAN AND PLANTING PLAN SHALL BE COMPLETED BY OTHERS UNDER SEPARATE COVER BASED ON THE PROPOSED FINISHED GRADES OF THE LEACHING BED.
- DISTRIBUTION BOX INLET PIPE SHALL TERMINATE WITH A VERTICAL TEE FITTING INSIDE THE BOX.
- SANITARY OUTLET AT BUILDING IS ASSUMED TO BE AT AN ELEVATION OF 342.30 OR SHALLOWER.
- THE FORCEMAIN SHALL DISCHARGE INTO A MINIMUM 3.0 m LONG, 100 mm DIA., SOLID PVC PIPE PRIOR TO ENTERING THE DISTRIBUTION BOX IN ORDER TO REDUCE THE VELOCITY OF THE INCOMING EFFLUENT.
- EXIT VENT FROM DISTRIBUTION BOX RISER IS VENTED VIA A 100 mm DIA., INSULATED SOLID PVC VENT PIPE BELOW GRADE BACK TO AIR GAP OF SEPTIC TANK.
- THE SEPTIC TANK SHALL BE PUMPED OUT ON AN AS-NEEDED BASIS IN ORDER TO ENSURE THAT THE ACCUMULATED SCUM AND SLUDGE VOLUME DOES NOT EXCEED 33% OF THE TANK CAPACITY.
- THE OWNER SHALL MAINTAIN THE SYSTEM IN ACCORDANCE WITH THE ENVIRO-SEPTIC USER MANUAL.



APPENDIX

A MECP WATER WELL RECORDS

Address of Well Location (Street Number/Name, RR) #5765 Longhearth Way Township Ossegoe P/L 1 Concession 2
 County/District/Municipality Ottawa-Carleton City/Town/Village Greely Province Ontario Postal Code
 UTM Coordinates Zone Easting Northing GPS Unit Make Model Mode of Operation: Undifferentiated Averaged
 NAD 83 18 449587500 0416 magellan 200 Differentiated, specify

General Colour		Most Common Material	Other Materials	General Description	Depth (Metres)	
From	To				From	To
		Sand	Boulders	Gravel	0	8.53
		Grey	limestone		8.53	21.33
		Grey	sandstone		21.33	36.57

* Plan 4M-1254 S/L 2 *

Annular Space/Abandonment Sealing Record		
Depth Set at (Metres)	Type of Sealant Used (Material and Type)	Volume Placed (Cubic Metres)
10.36	Neat cement slurry	.2724
7.31	Bentonite slurry	.490


Results of Well Yield Testing			
Time (Min)	Water Level (Metres)	Recovery	
		Time (Min)	Water Level (Metres)
Static Level	6.30	Static Level	28.1
1	9.64	1	21.0
2	10.78	2	15.20
3	12.40	3	10.13
4	13.59	4	8.90
5	14.68	5	6.60
10	18.25	10	6.30
15	20.90	15	
20	23.40	20	
25	24.35	25	
30	25.55	30	
40	27.18	40	
50	27.64	50	
60	28.1	60	

Check box if after test of well yield, water was:
 Clear and sand free
 Cannot develop to sand-free state
 If pumping discontinued, give reason:
 Pumping test method: Sub pump
 Pump intake set at (Metres): 30.47
 Pumping rate (Litres/min): 91.00
 Duration of pumping: 1 hrs + 0 min
 Final water level end of pumping (Metres): 28.1
 Recommended pump type: Shallow Deep
 Recommended pump depth: 30.47 Metres
 Recommended pump rate (Litres/min): 91.00
 If flowing give rate (Litres/min): 91.00

Method of Construction		Water Use		
<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Diamond	<input type="checkbox"/> Public	<input type="checkbox"/> Commercial	<input type="checkbox"/> Not used
<input type="checkbox"/> Rotary (Conventional)	<input type="checkbox"/> Jetting	<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Municipal	<input type="checkbox"/> Dewatering
<input type="checkbox"/> Rotary (Reverse)	<input type="checkbox"/> Driving	<input type="checkbox"/> Livestock	<input type="checkbox"/> Test Hole	<input type="checkbox"/> Monitoring
<input type="checkbox"/> Rotary (Air)	<input type="checkbox"/> Digging	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Cooling & Air Conditioning	
<input checked="" type="checkbox"/> Air percussion	<input type="checkbox"/> Boring	<input type="checkbox"/> Industrial		
<input type="checkbox"/> Other, specify		<input type="checkbox"/> Other, specify		

Status of Well		
<input checked="" type="checkbox"/> Water Supply	<input type="checkbox"/> Dewatering Well	<input type="checkbox"/> Observation and/or Monitoring Hole
<input type="checkbox"/> Replacement Well	<input type="checkbox"/> Abandoned, Insufficient Supply	<input type="checkbox"/> Alteration (Construction)
<input type="checkbox"/> Test Hole	<input type="checkbox"/> Abandoned, Poor Water Quality	<input type="checkbox"/> Other, specify
<input type="checkbox"/> Recharge Well	<input type="checkbox"/> Abandoned, other, specify	

Location of Well
 Please provide a map below showing:
 - all property boundaries, and measurements sufficient to locate the well in relation to fixed points,
 - an arrow indicating the North direction
 - detailed drawings can be provided as attachments no larger than legal size (8.5" by 14")
 - vidigital pictures of inside of well can also be provided



Water Details	
Water found at Depth <u>32.91</u> Metres	Kind of Water: <input type="checkbox"/> Gas <input type="checkbox"/> Fresh <input type="checkbox"/> Salty <input type="checkbox"/> Sulphur <input type="checkbox"/> Minerals
Water found at Depth _____ Metres	Kind of Water: <input type="checkbox"/> Gas <input type="checkbox"/> Fresh <input type="checkbox"/> Salty <input type="checkbox"/> Sulphur <input type="checkbox"/> Minerals
Water found at Depth _____ Metres	Kind of Water: <input type="checkbox"/> Gas <input type="checkbox"/> Fresh <input type="checkbox"/> Salty <input type="checkbox"/> Sulphur <input type="checkbox"/> Minerals

Casing Used	Screen Used	Casing and Well Details
<input type="checkbox"/> Galvanized	<input type="checkbox"/> Galvanized	Diameter of the Hole (Centimetres) <u>15.55</u>
<input checked="" type="checkbox"/> Steel	<input type="checkbox"/> Steel	Depth of the Hole (Metres) <u>36.57</u>
<input type="checkbox"/> Fibreglass	<input type="checkbox"/> Fibreglass	Wall Thickness (Metres) <u>.48 cm</u>
<input type="checkbox"/> Plastic	<input type="checkbox"/> Plastic	Inside Diameter of the Casing (Metres) <u>15.80</u>
<input type="checkbox"/> Concrete	<input checked="" type="checkbox"/> Concrete	Depth of the Casing (Metres) <u>10.97</u>
No Casing and Screen Used		
<input checked="" type="checkbox"/> Open Hole <u>10.36</u> <u>36.57</u>		
Disinfected? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

Date Well Completed (yyyy/mm/dd) <u>2007-10-25</u>	Was the well owner's information package delivered? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Date the Well Record and Package Delivered to Well Owner (yyyy/mm/dd) <u>2007-10-30</u>
Well Contractor and Well Technician Information		
Business Name of Well Contractor <u>Air Rock Drilling Co LTD</u>	Well Contractor's Licence No. <u>11119</u>	
Business Address (Street No./Name, number, RR) <u>RR#1</u>	Municipality <u>Richmond</u>	
Province <u>Ont</u>	Postal Code <u>K0A2Z0</u>	Business E-mail Address
Bus. Telephone No. (inc. area code) <u>613 838 2170</u>	Name of Well Technician (Last Name, First Name) <u>Desautniers, Ken</u>	
Well Technician's Licence No. <u>T4</u>	Signature of Technician <u>[Signature]</u>	Date Submitted (yyyy/mm/dd) <u>2007-12-03</u>

Ministry Use Only	
Audit No. <u>z69705</u>	Well Contractor No.
Date Received (yyyy/mm/dd) <u>DEC 14 2007</u>	Date of Inspection (yyyy/mm/dd)
Remarks	



A199999

Measurements recorded in: Metric Imperial

Tag#: A199999

Page ___ of ___

Well Owner's Information

First Name, Last Name / Organization, E-mail Address, Mailing Address, Municipality, Province, Postal Code, Telephone No.

Well Location

Address of Well Location, Township, Lot, Concession, County/District/Municipality, City/Town/Village, Province, Postal Code, UTM Coordinates, Municipal Plan and Sublot Number

Overburden and Bedrock Materials/Abandonment Sealing Record

Table with columns: General Colour, Most Common Material, Other Materials, General Description, Depth From, Depth To

Annular Space: Depth Set at, Type of Sealant Used, Volume Placed

Method of Construction, Well Use: Cable Tool, Rotary, Boring, etc.

Construction Record - Casing: Inside Diameter, Open Hole OR Material, Wall Thickness, Depth, Status of Well

Construction Record - Screen: Outside Diameter, Material, Slot No., Depth

Water Details, Hole Diameter: Water found at Depth, Kind of Water, Depth, Diameter

Well Contractor and Well Technician Information: Business Name, Licence No., Address, Province, Postal Code, Business E-mail Address

Well Technician's Licence No., Signature of Technician and/or Contractor, Date Submitted

Results of Well Yield Testing: After test of well yield, water was, Draw Down, Recovery, Pumping rate, Duration of pumping, Final water level end of pumping, etc.

Map of Well Location: Please provide a map below following instructions on the back. Includes handwritten notes: 'Geologic wells soccer', 'PITLESS', 'SOCCER FIELDS', '#5650', 'MITCH OWENS D.C. #8'

Comments:

Ministry Use Only: Well owner's information package delivered, Date Package Delivered, Date Work Completed, Audit No., Received

APPENDIX

B

LABORATORY CERTIFICATES OF ANALYSES

Client: WSP (Ottawa)
Address: 2611 Queensview Drive
City: Ottawa
Postal Code: K2B 8K2

Workorder No: **1990867**
C-O-C Number: 219741

Fax To:
Attention: Mr. Robert Passmore

Client Project: 211-13935-00
Date Received: 2022-12-01
Due Date: 2022-12-08
Rush Y/N? N

The following samples were submitted to Eurofins for analysis. Please review the details of testing to be performed and contact the laboratory if changes are required. In all inquiries, please reference the Eurofins work order number listed above.

Sample Matrix: Water
Other Sample Info:
Date of Sampling: 2022-12-01
Eurofins Record #: 1666217

Client Sample ID: **221201LW**
Temperature: 11
Guideline: ODWSOG

REQUESTED ANALYSES

Escherichia Coli	Mn	Mg	Pb
Sb	Ion Balance	Hardness as CaCO3	S2-
B	F	N-NO2	DOC
Cu	Cr	Conductivity	Cl
Cd	Ca	Ba	Fe
SO4	Al	Alkalinity as CaCO3	Colour (Apparent)
TDS (COND - CALC)	Zn	U	Turbidity
Total Kjeldahl Nitrogen	Hg	Tannin & Lignin	N-NH3
Sr	Na	Se	K
Phenols	pH	N-NO3	As
Total Coliforms			

Client: WSP (Ottawa)
2611 Queensview Drive
Ottawa, ON
K2B 8K2
Attention: Mr. Robert Passmore
PO#:
Invoice to: WSP Canada Inc.

Report Number: 1990549
Date Submitted: 2022-11-25
Date Reported: 2022-12-05
Project: 211-13935-00
COC #: 219755

Page 1 of 7

Dear Robert Passmore:

Please find attached the analytical results for your samples. If you have any questions regarding this report, please do not hesitate to call (613-727-5692).

Report Comments:

APPROVAL: _____

Emma-Dawn Ferguson, Chemist

All analysis is completed at Eurofins Environment Testing Canada Inc. (Ottawa, Ontario) unless otherwise indicated.

Eurofins Environment Testing Canada Inc. (Ottawa, Ontario) is accredited by CALA, Canadian Association for Laboratory Accreditation to ISO/IEC 17025 for tests which appear on the scope of accreditation. The scope is available at: <https://directory.cala.ca/>.

Eurofins Environment Testing Canada Inc. (Ottawa, Ontario) is licensed by the Ontario Ministry of the Environment, Conservation, and Parks (MECP) for specific tests in drinking water (license #2318). A copy of the license is available upon request.

Eurofins Environment Testing Canada Inc. (Ottawa, Ontario) is accredited by the Ontario Ministry of Agriculture, Food, and Rural Affairs for specific tests in agricultural soils.

Please note: Field data, where presented on the report, has been provided by the client and is presented for informational purposes only. Guideline values listed on this report are provided for ease of use (informational purposes) only. Eurofins recommends consulting the official provincial or federal guideline as required. Unless otherwise stated, measurement uncertainty is not taken into account when determining guideline or regulatory exceedances.

Client: WSP (Ottawa)
 2611 Queensview Drive
 Ottawa, ON
 K2B 8K2
 Attention: Mr. Robert Passmore
 PO#:
 Invoice to: WSP Canada Inc.

Report Number: 1990549
 Date Submitted: 2022-11-25
 Date Reported: 2022-12-05
 Project: 211-13935-00
 COC #: 219755

Lab I.D. 1664952
 Sample Matrix Water
 Sample Type
 Sampling Date 2022-11-24
 Sample I.D. WS - 5765 LW

Group	Analyte	MRL	Units	Guideline	
Anions	Cl	1	mg/L	AO 250	160
	F	0.10	mg/L	MAC 1.5	<0.10
	N-NO2	0.10	mg/L	MAC 1.0	<0.10
	N-NO3	0.10	mg/L	MAC 10.0	<0.10
	SO4	1	mg/L	AO 500	140
General Chemistry	Alkalinity as CaCO3	5	mg/L	OG 30-500	368
	Colour (Apparent)	2	TCU	AO 5	42*
	Conductivity	5	uS/cm		1280
	DOC	0.5	mg/L	AO 5	4.0
	pH	1.00		6.5-8.5	7.42
	Phenols	0.001	mg/L		<0.001
	S2-	0.01	mg/L	AO 0.05	<0.01
	TDS (COND - CALC)	1	mg/L	AO 500	832*
Turbidity	0.1	NTU	AO 5	10.0*	
Hardness	Hardness as CaCO3	1	mg/L	OG 80-100	568*
Indices/Calc	Ion Balance	0.01			0.99
Metals	Al	0.01	mg/L	OG 0.1	<0.01
	As	0.001	mg/L	IMAC 0.01	0.001
	B	0.01	mg/L	IMAC 5.0	0.07
	Ba	0.01	mg/L	MAC 1.0	0.12
	Ca	1	mg/L		135
	Cd	0.0001	mg/L	MAC 0.005	<0.0001
	Cr	0.001	mg/L	MAC 0.05	<0.001
	Cu	0.001	mg/L	AO 1	<0.001
	Fe	0.03	mg/L	AO 0.3	1.08*

Guideline = ODWSOG

* = Guideline Exceedence

Results relate only to the parameters tested on the samples submitted.
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: WSP (Ottawa)
 2611 Queensview Drive
 Ottawa, ON
 K2B 8K2
 Attention: Mr. Robert Passmore
 PO#:
 Invoice to: WSP Canada Inc.

Report Number: 1990549
 Date Submitted: 2022-11-25
 Date Reported: 2022-12-05
 Project: 211-13935-00
 COC #: 219755

Lab I.D. 1664952
 Sample Matrix Water
 Sample Type
 Sampling Date 2022-11-24
 Sample I.D. WS - 5765 LW

Group	Analyte	MRL	Units	Guideline	
Metals	Hg	0.0001	mg/L	MAC 0.001	<0.0001
	K	1	mg/L		4
	Mg	1	mg/L		56
	Mn	0.01	mg/L	AO 0.05	0.05
	Na	1	mg/L	AO 200	72
	Pb	0.001	mg/L	MAC 0.010	<0.001
	Sb	0.0005	mg/L	IMAC 0.006	<0.0005
	Se	0.001	mg/L	MAC 0.05	<0.001
	Sr	0.001	mg/L		0.963
	U	0.001	mg/L	MAC 0.02	0.004
	Zn	0.01	mg/L	AO 5	0.02
Microbiology	Escherichia Coli	0	ct/100mL	MAC 0	0
	Total Coliforms	0	ct/100mL	MAC 0	0
Nutrients	N-NH3	0.020	mg/L		0.092
	Total Kjeldahl Nitrogen	0.100	mg/L		0.304
Subcontract	Tannin & Lignin	0.1	mg/L		1.1

Guideline = ODWSOG

* = Guideline Exceedence

Results relate only to the parameters tested on the samples submitted.
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: WSP (Ottawa)
 2611 Queensview Drive
 Ottawa, ON
 K2B 8K2
 Attention: Mr. Robert Passmore
 PO#:
 Invoice to: WSP Canada Inc.

Report Number: 1990549
 Date Submitted: 2022-11-25
 Date Reported: 2022-12-05
 Project: 211-13935-00
 COC #: 219755

QC Summary

Analyte	Blank	QC % Rec	QC Limits
Run No 433924 Analysis/Extraction Date 2022-11-26 Analyst DRA Method AMBCOLM1			
Escherichia Coli			
Total Coliforms			
Run No 433950 Analysis/Extraction Date 2022-11-26 Analyst CK Method C SM2130B			
Turbidity	<0.1 NTU	101	70-130
Run No 433968 Analysis/Extraction Date 2022-11-28 Analyst ACG Method C SM2120C			
Colour (Apparent)	<2 TCU	105	90-110
Run No 434011 Analysis/Extraction Date 2022-11-28 Analyst SD Method EPA 200.8			
Aluminum	<0.01 mg/L	107	80-120
Arsenic	<0.001 mg/L	90	80-120
Boron (total)	<0.01 mg/L	99	80-120
Barium	<0.01 mg/L	91	80-120
Cadmium	<0.0001 mg/L	95	80-120
Chromium Total	<0.001 mg/L	97	80-120
Copper	<0.001 mg/L	96	80-120

Guideline = ODWSOG

* = Guideline Exceedence

Results relate only to the parameters tested on the samples submitted.
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: WSP (Ottawa)
 2611 Queensview Drive
 Ottawa, ON
 K2B 8K2
 Attention: Mr. Robert Passmore
 PO#:
 Invoice to: WSP Canada Inc.

Report Number: 1990549
 Date Submitted: 2022-11-25
 Date Reported: 2022-12-05
 Project: 211-13935-00
 COC #: 219755

QC Summary

Analyte	Blank	QC % Rec	QC Limits
Iron	<0.03 mg/L	104	80-120
Mercury	<0.0001 mg/L	111	80-120
Manganese	<0.01 mg/L	107	80-120
Lead	<0.001 mg/L	99	80-120
Antimony	<0.0005 mg/L	87	80-120
Selenium	<0.001 mg/L	96	80-120
Strontium	<0.001 mg/L	91	80-120
Uranium	<0.001 mg/L	93	80-120
Zinc	<0.01 mg/L	96	80-120
Run No 434152 Analysis/Extraction Date 2022-11-29 Analyst ML Method EPA 350.1			
N-NH3	<0.020 mg/L	90	80-120
Run No 434154 Analysis/Extraction Date 2022-11-29 Analyst ACG Method SM2320,2510,4500H/F			
Alkalinity (CaCO3)	<5 mg/L	98	90-110
Conductivity	<5 uS/cm	101	90-110
F	<0.10 mg/L	100	90-110
pH		99	90-110

Guideline = ODWSOG

*** = Guideline Exceedence**

Results relate only to the parameters tested on the samples submitted.
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: WSP (Ottawa)
 2611 Queensview Drive
 Ottawa, ON
 K2B 8K2
 Attention: Mr. Robert Passmore
 PO#:
 Invoice to: WSP Canada Inc.

Report Number: 1990549
 Date Submitted: 2022-11-25
 Date Reported: 2022-12-05
 Project: 211-13935-00
 COC #: 219755

QC Summary

Analyte	Blank	QC % Rec	QC Limits
Run No 434254 Analysis/Extraction Date 2022-11-30 Analyst SKH Method EPA 351.2			
Total Kjeldahl Nitrogen	<0.100 mg/L	113	70-130
Run No 434257 Analysis/Extraction Date 2022-11-30 Analyst AaN Method SM 4110			
N-NO2	<0.10 mg/L	107	90-110
N-NO3	<0.10 mg/L	103	90-110
Run No 434269 Analysis/Extraction Date 2022-12-01 Analyst AaN Method SM 4110			
Chloride	<5 mg/L		90-110
SO4	<5 mg/L	105	90-110
Run No 434278 Analysis/Extraction Date 2022-12-01 Analyst Z S Method M SM3120B-3500C			
Calcium	<1 mg/L	100	90-110
Potassium	<1 mg/L	100	87-113
Magnesium	<1 mg/L	97	76-124
Sodium	<1 mg/L	100	82-118
Run No 434287 Analysis/Extraction Date 2022-12-01 Analyst ACG Method C SM5310C			

Guideline = ODWSOG

* = Guideline Exceedence

Results relate only to the parameters tested on the samples submitted.
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: WSP (Ottawa)
 2611 Queensview Drive
 Ottawa, ON
 K2B 8K2
 Attention: Mr. Robert Passmore
 PO#:
 Invoice to: WSP Canada Inc.

Report Number: 1990549
 Date Submitted: 2022-11-25
 Date Reported: 2022-12-05
 Project: 211-13935-00
 COC #: 219755

QC Summary

Analyte	Blank	QC % Rec	QC Limits
DOC	<0.5 mg/L	85	84-116
Run No 434359 Analysis/Extraction Date 2022-12-02 Analyst ACG Method C SM4500-S2-D			
S2-	<0.01 mg/L	98	80-120
Run No 434360 Analysis/Extraction Date 2022-12-02 Analyst SKH Method C SM2340B			
Hardness as CaCO3			
Ion Balance			
TDS (COND - CALC)			
Run No 434388 Analysis/Extraction Date 2022-12-02 Analyst IP Method SM5530D/EPA420.2			
Phenols	<0.001 mg/L	107	50-120
Run No 434466 Analysis/Extraction Date 2022-12-01 Analyst AET Method SUBCONTRACT-A			
Tannin & Lignin	<0.10 mg/L	94	

Guideline = ODWSOG

* = Guideline Exceedence

Results relate only to the parameters tested on the samples submitted.
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

APPENDIX

C

PUMPING TEST DATA
FOR TEST WELL



WSP Canada Inc.
2611 Queensview Drive, Suite 300
Ottawa, Canada K2B 8K3

Pumping Test Analysis Report

Project: HG Study and Terrain Analysis

Number: 211-13935-00

Client: Ottawa South United Soccer Association

Location: 5650 Mitch Owens Drive,

Pumping Test: Pumping Test 1

Pumping Well: WSW

Test Conducted by: RP/ZK

Test Date: 2022-12-22


Analysis Performed by: VB

Time-Drawdown

Analysis Date: 2022-12-22

Aquifer Thickness:

Discharge Rate: 3.39 [l/s]



APPENDIX

D

LANGELIER
SATURATION INDEX
CALCULATIONS



Langelier Saturation Index Calculator

This calculator helps you determine the scaling potential of the water by using the Langelier Saturation Index.

Give the values of your water analysis. All the fields with * are required.

Table 1: Input table

pH	<input type="text" value="7.41"/>	*
Conductivity / TDS	<input type="text" value="535"/>	mg/L
[Ca ²⁺]	<input type="text" value="81"/>	mg/L
[HCO ₃]	<input type="text" value="255"/>	mg/L
Water temperature	<input type="text" value="8"/>	degree C

If you do not have a water analysis you can use the values in table 2. Click on a button at the bottom of table 2

Table 2 : Additional data

pH =	7.7	8	8.6	
TDS =	20	34483	273	mg/l
[Ca ²⁺] =	5	400	49	mg/l
[HCO ₃] =	10	140	121	mg/l
T =	20	20	20	degree C

Table 3: Results Langelier Saturation Index

pH _s	<input type="text" value="7.7"/>
LSI	<input type="text" value="-0.31"/>

Indication based on Langelier (1936)

Water is undersaturated with respect to calcium carbonate. Undersaturated water has a tendency to remove existing calcium carbonate protective coatings in pipelines and equipment.

The Langelier Saturation Index formula is

$$LSI = pH - pH_s$$

For an explanation of the formula click here.

Indication based on improved Langelier by Carrier (1965)

Slightly corrosive but non-scale forming.

The indications for the LSI and the improved LSI by Carrier are based on the following values:

LSI Indication

LSI<0 Water is undersaturated with respect to calcium carbonate. Undersaturated water has a tendency to remove existing calcium carbonate protective coatings in pipelines and equipment.

LSI=0 Water is considered to be neutral. Neither scale-forming nor scale removing.

LSI>0 Water is supersaturated with respect to calcium carbonate (CaCO₃) and scale forming may occur.

LSI (Carrier)

Indication

-2,0<-0,5	Serious corrosion
-0,5<0	Slightly corrosion but non-scale forming
LSI = 0,0	Balanced but pitting corrosion possible
0,0<0,5	Slightly scale forming and corrosive
0,5<2	Scale forming but non corrosive

References:

- [1] : Kevin Rafferty, Scaling in geothermal heat pump systems, U.S. Department of Energy (july 1999)
- [2] : Metcalf and Eddy, Wastewater Engineering Treatment and Reuse 2003

Explanation of the Langelier Saturation formula.

Other calculators

Warning: Lenntech BV cannot be held responsible for errors in the calculation, the program itself or the explanation. For questions or remarks please contact us.



[More from 'Calculators'](#)



Langelier Saturation Index Calculator

This calculator helps you determine the scaling potential of the water by using the Langelier Saturation Index.

Give the values of your water analysis. All the fields with * are required.

Table 1: Input table

pH *

Conductivity / TDS *

[Ca²⁺] *

[HCO₃⁻] *

Water temperature *

If you do not have a water analysis you can use the values in table 2. Click on a button at the bottom of table 2

Table 2 : Additional data

pH =	7.7	8	8.6	
TDS =	20	34483	273	mg/l
[Ca ²⁺] =	5	400	49	mg/l
[HCO ₃ ⁻] =	10	140	121	mg/l
T =	20	20	20	degree C

Table 3: Results Langelier Saturation Index

pH_s

LSI

Indication based on Langelier (1936)

Water is undersaturated with respect to calcium carbonate. Undersaturated water has a tendency to remove existing calcium carbonate protective coatings in pipelines and equipment.

The Langelier Saturation Index formula is

$$LSI = pH - pH_s$$

For an explanation of the formula click here.

Indication based on improved Langelier by Carrier (1965)

Slightly corrosive but non-scale forming.

The indications for the LSI and the improved LSI by Carrier are based on the following values:

LSI Indication

LSI<0 Water is undersaturated with respect to calcium carbonate. Undersaturated water has a tendency to remove existing calcium carbonate protective coatings in pipelines and equipment.

LSI=0 Water is considered to be neutral. Neither scale-forming nor scale removing.

LSI>0 Water is supersaturated with respect to calcium carbonate (CaCO₃) and scale forming may occur.

LSI (Carrier)

Indication

-2,0<-0,5

Serious corrosion

-0,5<0

Slightly corrosion but non-scale forming

LSI = 0,0

Balanced but pitting corrosion possible

0,0<0,5

Slightly scale forming and corrosive

0,5<2

Scale forming but non corrosive

References:

[1] : Kevin Rafferty, Scaling in geothermal heat pump systems, U.S. Department of Energy (july 1999)

[2] : Metcalf and Eddy, Wastewater Engineering Treatment and Reuse 2003

Explanation of the Langelier Saturation formula.

Other calculators

Warning: Lenntech BV cannot be held responsible for errors in the calculation, the program itself or the explanation. For questions or remarks please contact us.



[More from 'Calculators'](#)



Langelier Saturation Index Calculator

This calculator helps you determine the scaling potential of the water by using the Langelier Saturation Index.

Give the values of your water analysis. All the fields with * are required.

Table 1: Input table

pH *

Conductivity / TDS *

[Ca²⁺] *

[HCO₃⁻] *

Water temperature *

If you do not have a water analysis you can use the values in table 2. Click on a button at the bottom of table 2

Table 2 : Additional data

pH =	7.7	8	8.6	
TDS =	20	34483	273	mg/l
[Ca ²⁺] =	5	400	49	mg/l
[HCO ₃ ⁻] =	10	140	121	mg/l
T =	20	20	20	degree C

Table 3: Results Langelier Saturation Index

pH_s

LSI

Water is supersaturated with respect to calcium carbonate (CaCO₃) and scale forming may occur.

The Langelier Saturation Index formula is

$$LSI = pH - pH_s$$

For an explanation of the formula click here.

Indication based on Langelier (1936)

Slightly scale forming and corrosive.

Indication based on improved Langelier by Carrier (1965)

The indications for the LSI and the improved LSI by Carrier are based on the following values:

LSI Indication

LSI<0 Water is undersaturated with respect to calcium carbonate. Undersaturated water has a tendency to remove existing calcium carbonate protective coatings in pipelines and equipment.

LSI=0 Water is considered to be neutral. Neither scale-forming nor scale removing.

LSI>0 Water is supersaturated with respect to calcium carbonate (CaCO₃) and scale forming may occur.

LSI (Carrier)

Indication

-2,0<-0,5	Serious corrosion
-0,5<0	Slightly corrosion but non-scale forming
LSI = 0,0	Balanced but pitting corrosion possible
0,0<0,5	Slightly scale forming and corrosive
0,5<2	Scale forming but non corrosive

References:

- [1] : Kevin Rafferty, Scaling in geothermal heat pump systems, U.S. Department of Energy (july 1999)
- [2] : Metcalf and Eddy, Wastewater Engineering Treatment and Reuse 2003

Explanation of the Langelier Saturation formula.

Other calculators

Warning: Lenntech BV cannot be held responsible for errors in the calculation, the program itself or the explanation. For questions or remarks please contact us.



[More from 'Calculators'](#)



Langelier Saturation Index Calculator

This calculator helps you determine the scaling potential of the water by using the Langelier Saturation Index.

Give the values of your water analysis. All the fields with * are required.

Table 1: Input table

pH *

Conductivity / TDS *

[Ca²⁺] *

[HCO₃⁻] *

Water temperature *

If you do not have a water analysis you can use the values in table 2. Click on a button at the bottom of table 2

Table 2 : Additional data

pH =	7.7	8	8.6	
TDS =	20	34483	273	mg/l
[Ca ²⁺] =	5	400	49	mg/l
[HCO ₃ ⁻] =	10	140	121	mg/l
T =	20	20	20	degree C

Table 3: Results Langelier Saturation Index

pH_s

LSI

Water is supersaturated with respect to calcium carbonate (CaCO₃) and scale forming may occur.

The Langelier Saturation Index formula is

$$LSI = pH - pH_s$$

For an explanation of the formula click here.

Indication based on Langelier (1936)

Scale forming but non corrosive.

Indication based on improved Langelier by Carrier (1965)

The indications for the LSI and the improved LSI by Carrier are based on the following values:

LSI Indication

LSI<0 Water is undersaturated with respect to calcium carbonate. Undersaturated water has a tendency to remove existing calcium carbonate protective coatings in pipelines and equipment.

LSI=0 Water is considered to be neutral. Neither scale-forming nor scale removing.

LSI>0 Water is supersaturated with respect to calcium carbonate (CaCO₃) and scale forming may occur.

LSI (Carrier)

Indication

-2,0<-0,5	Serious corrosion
-0,5<0	Slightly corrosion but non-scale forming
LSI = 0,0	Balanced but pitting corrosion possible
0,0<0,5	Slightly scale forming and corrosive
0,5<2	Scale forming but non corrosive

References:

- [1] : Kevin Rafferty, Scaling in geothermal heat pump systems, U.S. Department of Energy (july 1999)
- [2] : Metcalf and Eddy, Wastewater Engineering Treatment and Reuse 2003

Explanation of the Langelier Saturation formula.

Other calculators

Warning: Lenntech BV cannot be held responsible for errors in the calculation, the program itself or the explanation. For questions or remarks please contact us.



More from 'Calculators'

APPENDIX

E

CLIMATIC WATER
BUDGET
CALCULATIONS

TABLE E-1
CLIMATIC WATER BUDGET: CLIMATE NORMAL 1981-2010 (OTTAWA MACDONALD-CARTIER INT'L A)
 Ontario Soccer United
 Preliminary Nitrate Impact Assessment

Thornthwaite (1948)								
Month	Mean Temperature (°C)	Heat Index	Potential Evapo-transpiration (mm)	Daylight Correction Value	Adjusted Potential Evapo-transpiration (mm)	Total Precipitation (mm)	Surplus (mm)	Deficit (mm)
January	-10.3	0.0	0.0	0.7742	0.00	65.4	65.4	0.0
February	-8.1	0.0	0.0	0.8679	0.00	54.3	54.3	0.0
March	-2.3	0.0	0.0	0.9871	0.00	64.4	64.4	0.0
April	6.3	1.4	28.5	1.1300	32.23	74.5	42.3	0.0
May	13.3	4.4	64.0	1.2387	79.30	80.3	1.0	0.0
June	18.5	7.2	91.5	1.2900	118.04	92.8	0.0	25.2
July	21	8.8	105.0	1.2677	133.06	91.9	0.0	41.2
August	19.8	8.0	98.5	1.1710	115.32	85.5	0.0	29.8
September	15	5.3	72.9	1.0400	75.84	90.1	14.3	0.0
October	8	2.0	36.9	0.9097	33.60	86.1	52.5	0.0
November	1.5	0.2	6.0	0.7900	4.77	81.9	77.1	0.0
December	-6.2	0.0	0.0	0.7258	0.00	76.4	76.4	0.0
TOTALS		37.4			592.1	943.6	447.7	96.2

TOTAL WATER SURPLUS 351.5 mm

NOTES:

- 1) Water budget adjusted for latitude and daylight.
- 2) (°C) - Represents calculated mean of daily temperatures for the month.
- 3) Precipitation and Temperature data from the OTTAWA MACDONALD-CARTIER INT'L A Climate Station located at latitude 45°19'21.000" N, longitude 75°40'09.000" W, elevation 114.0 m.
- 4) Total Water Surplus (Thornthwaite, 1948) is calculated as total precipitation minus adjusted potential evapotranspiration.
- 5) Total Moisture Surplus (Thornthwaite and Mather, 1957) is calculated as total precipitation minus actual evapotranspiration.

APPENDIX

F

**NITRATE IMPACT
ASSESSMENT**

Nitrate Impact Assessment

Project: Ottawa Soccer United Clubhouse
File: 211-13935-00
Condition: Overall Site Attenuative Capacity

Groundwater Flow Calculation

Background Nitrate Concentration (C_b) = 0 mg/L
 Hydraulic Conductivity (k) = 0 m/s
 Horizontal Gradient (i) = 0
 Length (L) = 0 m
 Aquifer Thickness (t) = 0 m
 Groundwater Flow (Q_b) = 0 m³/day

Weighted Infiltration Factors

Topography 0.20
 Soil 0.1
 Cover 0.1
Total 0.4

Septic Effluent

Concentration of Effluent (C_s) = 40 mg/L
 Number of Lots: 1
 Daily Sewage Flow (Q_s) = 14.8 m³

Infiltration Calculation

Nitrate Concentration in Precipitation (C_i) = 0 mg/L
 Surplus Water (Environment Canada) 351 mm/yr
 Factored Water Surplus = 140.40 mm/yr
 Additional Surplus from Landscape Runoff = 0 mm/yr
 Infiltration Flow Entering the System (Q_i) = 44.84 m³/day

Site Characteristics

Area of Site : 129,531 m²
 Roof and Driveway Areas: 12,953 m²
 Length of Street (6 m wide): - m

Mass Balance Model (MOEE 1995)

$$C_T = (Q_b C_b + Q_e C_e + Q_i C_i) / (Q_b + Q_e + Q_i) = \text{Cumulative Nitrate Concentration}$$

Impervious Area 12,953 m²
 Percent Impervious Area = 10 %
 Infiltration Area = 116,578 m²

where: Q_b = flow entering the system across the upgradient area = 0 m³/day
 C_b = background nitrate concentration = 0 mg/L
 Q_e = flow entering the system from the septic drainfield = 14.8 m³/day
 C_e = concentration of nitrates in the septic effluent = 40 mg/L
 Q_i = flow entering the system from infiltration = 44.84 m³/day
 C_i = Concentration of nitrates in the infiltrate = 0 mg/L

Therefore: **$C_T = 9.926$ mg/L**

Nitrate Impact Assessment

Project: Ottawa Soccer United Clubhouse
File: 211-13935-00
Condition: TDDSF of 4,800 L/day

Groundwater Flow Calculation

Background Nitrate Concentration (C_b) =	0 mg/L
Hydraulic Conductivity (k) =	0 m/s
Horizontal Gradient (i) =	0
Length (L) =	0 m
Aquifer Thickness (t) =	0 m
Groundwater Flow (Q_b) =	0 m ³ /day

Weighted Infiltration Factors

Topography	0.20
Soil	0.1
Cover	<u>0.1</u>
Total	0.4

Infiltration Calculation

Nitrate Concentration in Precipitation (C_i) =	0 mg/L
Surplus Water (Environment Canada)	351 mm/yr
Factored Water Surplus =	140.40 mm/yr
Additional Surplus from Landscape Runoff =	0 mm/yr
Infiltration Flow Entering the System (Q_i) =	44.84 m ³ /day

Septic Effluent

Concentration of Effluent (C_s) =	40 mg/L
Number of Lots:	1
Daily Sewage Flow (Q_s)=	4.8 m ³

Site Characteristics

Area of Site :	129,531 m ²
Roof and Driveway Areas:	12,953 m ²
Length of Street (6 m wide):	- m

Mass Balance Model (MOEE 1995)

$$C_T = (Q_b C_b + Q_e C_e + Q_i C_i) / (Q_b + Q_e + Q_i) = \text{Cumulative Nitrate Concentration}$$

where:	Q_b = flow entering the system across the upgradient area =	0 m ³ /day
	C_b = background nitrate concentration =	0 mg/L
	Q_e = flow entering the system from the septic drainfield =	4.8 m ³ /day
	C_e = concentration of nitrates in the septic effluent =	40 mg/L
	Q_i = flow entering the system from infiltration =	44.84 m ³ /day
	C_i = Concentration of nitrates in the infiltrate =	0 mg/L

Impervious Area	12,953 m ²
Percent Impervious Area =	10 %
Infiltration Area =	116,578 m ²

Therefore: **$C_T = 3.868$ mg/L**