



Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3
613 230 1186 f 613 230 2598 smithandandersen.com

2022-06-23

City of Ottawa

Infrastructure Services and Community Sustainability
110 Laurier Avenue West
Ottawa, ON
K1P 1J1

ATTENTION: CITY BUILDING OFFICIAL

**RE: 770 BROOKFIELD RESIDENCE – PHASE 2
770 BROOKFIELD ROAD, OTTAWA, ONTARIO
S+A PROJECT # 18327.002**

Dear City Building Official:

This letter is to confirm that the resulting light spillage onto adjacent properties is below the maximum allowable spillage (0.5 fc) by the City of Ottawa, and that the exterior light fixtures used for this project meet the criteria for full cut-off classification as recognized by the IESNA.

Yours truly,

SMITH + ANDERSEN

Andre Drouin, P.Eng.

Principal

18327.002.e200.ltr001.Site_ltg.docx

C.C. Josephine Jordan – Smith + Andersen

