



March 30, 2023

Roderick Lahey Architecture  
50 Beech Street  
Ottawa, ON K1S 3J6

**Attention: Mr. Robert Verch**

**Re: 112 Montreal Road, Ottawa**

Dear Robert,

This is to confirm that light fixtures specified on this project will be Full Cut-off (Sharp Cut-off) classification as recognized by the Illuminating Engineering Society of North America. The spillage onto the adjacent properties will not be more than 0.5 foot candles.

Yours very truly,

D. Jain, M.Eng., M.B.A., P.Eng., C.E.M., L.A.P.



**Jain Sustainability Consultants Inc.**  
7405 East Danbro Crescent,  
Mississauga, Ontario, L5N 6P8 Canada

(905) 285-9900  
(905) 567-5246  
mail@jainconsultants.com  
www.jainconsultants.com



thinking globally, delivering locally