

December 16, 2022

Huntington Construction & Development
1306 Wellington Street West Suite 200
Ottawa, ON
K1Y 3B2

ATTENTION: MATHIEU DESJARDINS, DEVELOPMENT COORDINATOR

**SUBJECT: 60 DENZIL-DOYLE CRES., KANATA SOUTHWEST SELF STORAGE
GWAL PROJECT NO. 2021-566**

We have designed the site lighting for the [new one (1) storey CAW/TCA office building, located at 60 Denzil- Doyale Cres., Ottawa, ON, in accordance with the following guidelines as requested by the City of Ottawa:

It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;

It must result in minimal light spillage onto adjacent properties. As a guideline, 0.5 fc is normally the maximum allowable spillage.

Yours very truly,

GOODKEY, WEEDMARK & ASSOCIATES LTD.



Divyakant (Raj) Vyas, P.Eng., MIEEE | Partner, Sr.
Electrical Engineer

DRV/sm