

WATER SERVICE PROFILE TABLE

MATERIAL:
100mm PVC PRESSURE CLASS 150 DR18

STATION	DESCRIPTION	GRADE ELEVATION	TOP OF PIPE	DEPTH OF COVER	NOTES
A+00.0	400mm x 100mm TEE CONNECTION IN 400mm MUNICIPAL WATERMAIN TO CITY OF OTTAWA STANDARDS	75.18	±72.60	±2.58	START OF 50mm THICK, 1200mm WIDE INSULATION
A+02.3	100mm VALVE & VALVE BOX TO CITY OF OTTAWA STANDARDS	75.30	72.60	2.70	ON PROPERTY LINE
A+06.7	5° HORIZONTAL BEND	75.30	72.60	2.70	—
A+12.4 B+00.0	CONNECTION TO 50mm WATERMAIN	75.30	72.60	2.70	
A+14.5	—	75.30	72.60	2.70	CROSSING 150 SAN INV 73.14 WM TOP 72.60 – 540mm CLEARANCE (MIN. 500mm REQ'D)
A+15.0 C+00.0	CONNECTION TO 50mm WATERMAIN	75.30	72.60	2.70	—
A+15.3	—	75.30	72.60	2.70	CROSSING 150 ST INV 73.14 WM TOP 72.60 – 540mm CLEARANCE (MIN. 500mm REQ'D)
A+16.3	100mm END CAP TO CITY OF OTTAWA STANDARDS	75.30	72.60	2.70	—

MATERIAL:
50mm PEX TUBING TO AWWA C-904 SDR 9 (CTS)

STATION	DESCRIPTION	GRADE ELEVATION	TOP OF PIPE	DEPTH OF COVER	NOTES
B+00.0 A+12.4	CONNECTION TO 100mm WATERMAIN	75.30	72.60	2.70	—
B+03.1	—	75.30	72.22	3.08	CROSSING 200 ST INV 72.72 WM TOP 72.22 – 500mm CLEARANCE (MIN. 500mm REQ'D)
B+04.2	—	75.30	72.10	3.20	CROSSING 300 ST INV 72.60 WM TOP 72.10 – 500mm CLEARANCE (MIN. 500mm REQ'D)
B+06.0	—	75.45	72.41	3.04	CROSSING 200 SAN TOP 72.15 WM U/S 72.40 – 250mm CLEARANCE (MIN. 250mm REQ'D)
B+6.8	50mm CURB STOP & SERVICE POST TO CITY OF OTTAWA STANDARDS	75.47	72.80	2.67	—
B+07.8	—	75.48	72.80	2.68	ENTRY INTO BUILDING
A+00.0 C+15.0	CONNECTION TO 100mm WATERMAIN	75.30	72.60	2.70	—
C+01.0	50mm CURB STOP & SERVICE POST TO CITY OF OTTAWA STANDARDS	75.46	72.83	2.63	—
C+02.0	—	75.48	72.99	2.49	ENTRY INTO BUILDING

