GENERAL

- 1. DRAWINGS TO BE READ IN CONJUNCTION WITH ARCHITECTURAL AND LANDSCAPE DRAWINGS.
- 2. ALL SERVICES, MATERIALS, CONSTRUCTION METHODS AND INSTALLATIONS SHALL BE IN ACCORDANCE WITH THE LATEST STANDARDS AND REGULATIONS OF THE: CITY OF OTTAWA STANDARD SPECIFICATIONS AND DRAWINGS, ONTARIO PROVINCIAL SPECIFICATION STANDARD SPECIFICATION (OPSS) AND ONTARIO PROVINCIAL STANDARD DRAWINGS (OPSD), UNLESS OTHERWISE SPECIFIED, TO THE SATISFACTION OF THE CITY AND THE CONSULTANT.
- 3. THE POSITION OF EXISTING POLE LINES, CONDUITS, WATERMAINS, SEWERS AND OTHER UNDERGROUND AND ABOVEGROUND UTILITIES, STRUCTURES AND APPURTENANCES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWING, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL SATISFY HIMSELF OF THE EXACT LOCATION OF ALL SUCH UTILITIES AND STRUCTURES, AND SHALL ASSUME ALL LIABILITY FOR DAMAGE TO THEM DURING THE COURSE OF CONSTRUCTION. ANY RELOCATION OF EXISTING UTILITIES REQUIRED BY THE DEVELOPMENT OF SUBJECT LANDS IS TO BE UNDERTAKEN AT CONTRACTOR'S EXPENSE.
- 4. THE CONTRACTOR MUST NOTIFY ALL EXISTING UTILITY COMPANY OFFICIALS FIVE (5) BUSINESS DAYS PRIOR TO START OF CONSTRUCTION AND HAVE ALL EXISTING UTILITIES AND SERVICES LOCATED IN THE FIELD OR EXPOSED PRIOR TO THE START OF CONSTRUCTION, INCLUDING BUT NOT LIMITED TO HYDRO, BELL, CABLE TV, AND CONSUMERS GAS LINES.
- 5. ALL TRENCHING AND EXCAVATIONS TO BE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE OCCUPATIONAL HEALTH AND SAFETY ACT AND REGULATIONS FOR CONSTRUCTION PROJECTS. ALL INFORMATION SHALL BE CONFIRMED PRIOR TO COMMENCEMENT OF CONSTRUCTION.
- 6. REFER TO ARCHITECTS PLANS FOR BUILDING DIMENSIONS, ELEVATIONS, LAYOUT AND REMOVALS. REFER TO LANDSCAPE PLAN FOR LANDSCAPED DETAILS AND OTHER RELEVANT INFORMATION. ALL INFORMATION SHALL BE CONFIRMED PRIOR TO COMMENCEMENT OF CONSTRUCTION.
- 7. TOPOGRAPHIC SURVEY COMPLETED AND PROVIDED BY STANTEC GEOMATICS LTD. DATED JUNE 18, 2024. CONTRACTOR TO VERIFY IN THE FIELD PRIOR TO CONSTRUCTION OF ANY WORK AND NOTIFY THE ENGINEER OF ANY DISCREPANCIES.
- 8. ALL ELEVATIONS ARE GEODETIC AND UTILIZE METRIC UNITS. VERIFY THAT JOB BENCHMARKS HAVE NOT BEEN ALTERED OR DISTURBED.
- 9. ALL GROUND SURFACES SHALL BE EVENLY GRADED WITHOUT PONDING AREAS AND WITHOUT LOW POINTS EXCEPT WHERE APPROVED SWALE OR DRAIN OUTLETS ARE PROVIDED.
- 10. ALL EDGES OF DISTURBED PAVEMENT SHALL BE SAW CUT TO FORM A NEAT AND STRAIGHT LINE PRIOR TO PLACING NEW PAVEMENT. PAVEMENT REINSTATEMENT SHALL BE WITH STEP JOINTS OF 500mm WIDTH MINIMUM.
- 11. ALL DISTURBED AREAS OUTSIDE PROPOSED GRADING LIMITS TO BE RESTORED TO ORIGINAL ELEVATIONS AND CONDITIONS UNLESS OTHERWISE SPECIFIED. EXISTING PARKING LOT SHALL BE RE-ASPHALTED AT EXISTING GRADES EXCEPT AS NOTED TO EVEN OUT GRADES. ALL RESTORATION SHALL BE COMPLETED WITH THE GEOTECHNICAL REQUIREMENTS FOR BACKFILL AND COMPACTION.
- 12. ABUTTING PROPERTY GRADES TO BE MATCHED.
- 13. CONTRACTOR SHALL OBTAIN AND PAY FOR ALL NECESSARY PERMITS AND APPROVALS FROM THE MUNICIPAL AUTHORITIES PRIOR TO COMMENCING CONSTRUCTION, INCLUDING WATER PERMIT AND ROAD CUT PERMIT
- MINIMIZE DISTURBANCE TO EXISTING VEGETATION DURING THE EXECUTION OF ALL WORKS.
- 15. REMOVE FROM SITE ALL EXCESS EXCAVATED MATERIAL UNLESS OTHERWISE DIRECTED FROM THE ENGINEER. EXCAVATE AND REMOVE ALL ORGANIC MATERIAL AND DEBRIS LOCATED WITHIN THE PROPOSED BUILDING, PARKING AND ROADWAY LOCATIONS.
- 16. AT PROPOSED UTILITY CONNECTION POINTS AND CROSSINGS (I.E. STORM SEWER, SANITARY SEWER, WATER, ETC.) THE CONTRACTOR SHALL DETERMINE THE PRECISE LOCATION AND DEPTH OF EXISTING UTILITIES AND REPORT ANY DISCREPANCIES OR CONFLICTS TO THE ENGINEER BEFORE COMMENCING WORK.
- 17. PRIOR TO CONSTRUCTION, A GEOTECHNICAL ENGINEER REGISTERED IN THE PROVINCE OF ONTARIO IS TO INSPECT ALL SUB-SURFACES FOR FOOTINGS, SERVICES AND PAVEMENT STRUCTURES.
- 18. CONTRACTOR TO OBTAIN POST-CONSTRUCTION TOPOGRAPHIC SURVEY PERFORMED BY CERTIFIED OLS OR P.ENG. CONFIRMING COMPLIANCE WITH DESIGN GRADING AND SERVICING. SURVEY IS TO INCLUDE LOCATION AND INVERTS FOR BURIED UTILITIES.
- 19. PROVIDE CCTV INSPECTION REPORT FOR ALL SEWERS AND CATCHBASIN LEADS 200MM DIAMETER AND LARGER. REPEAT CCTV INSPECTION FOLLOWING RECTIFICATION OF ANY DEFICIENCIES.
- 20. REPORT REFERENCES
- 20.1. GEOTECHNICAL INVESTIGATION PROPOSED EVENT CENTRE LANSDOWNE PARK REDEVELOPMENT, REPORT NO. PG6655-1, MAY
- 20.2. FUNCTIONAL SERVICING AND STORMWATER MANAGEMENT REPORT FOR LANSDOWNE LIVE OTTAWA SPORT AND ENTERTAINMENT GROUP, PROJECT NO. 09-378, JANUARY 2012, BY DSEL.
- FUNCTIONAL SERVICING AND STORMWATER MANAGEMENT STUDY FOR LANSDOWNE PARK REDEVELOPMENT 2.0, PROJECT NO. CA0000286.1662, SEPTEMBER 2023, BY WSP.
- STORMWATER MANAGEMENT DESIGN REPORT FOR LANSDOWNE URBAN PARK, FEBRUARY 2012, BY STANTEC CONSULTING LTD. SERVICING REPORT FOR LANSDOWNE PARK EVENT CENTRE, REPORT NO.CA0033920.1056, JANUARY 2025, PREPARED BY WSP. SOTRMWATER MANAGEMENT DESIGN REPORT FOR LANSDOWNE PARK EVENT CENTRE, REPORT NO.CA0033920.1056 JANUARY
- PARKING LOT AND WORK IN PUBLIC RIGHTS OF WAY

2025, PREPARED BY WSP.

- 1. CONTRACTOR TO REINSTATE ROAD CUTS AS PER CITY OF OTTAWA DETAIL R10.
- GEOTECHNICAL INVESTIGATION PROPOSED EVENT CENTRE LANSDOWNE PARK REDEVELOPMENT, REPORT NO. PG6655-1, MAY 2024, BY PATTERSON GROUP.
- 3. CONTRACTOR TO PREPARE SUBGRADE, INCLUDING PROOFROLLING, TO THE SATISFACTION OF THE GEOTECHNICAL CONSULTANT PRIOR TO THE COMMENCEMENT OF PLACEMENT OF GRANULAR B MATERIAL.
- 4. FILL TO BE PLACED AND COMPACTED PER THE GEOTECHNICAL REPORT REQUIREMENTS.
- 5. CONTRACTOR TO SUPPLY, PLACE AND COMPACT GRANULAR B MATERIAL IN ACCORDANCE WITH THE RECOMMENDATIONS OF THE GEOTECHNICAL CONSULTANT. CONTRACTOR TO PROVIDE CONSULTANT WITH SAMPLES OF GRANULAR B MATERIAL FOR TESTING AND CERTIFICATION FROM THE GEOTECHNICAL CONSULTANT THAT THE MATERIAL MEETS THE GRADATION REQUIREMENTS SPECIFIED IN THE GEOTECHNICAL REPORT.
- 6. GRANULAR A MATERIAL TO BE PLACED ONLY UPON APPROVAL BY THE GEOTECHNICAL CONSULTANT OF GRANULAR B PLACEMENT.
- 7. CONTRACTOR TO SUPPLY, PLACE AND COMPACT GRANULAR A MATERIAL IN ACCORDANCE WITH THE RECOMMENDATIONS OF THE GEOTECHNICAL CONSULTANT. CONTRACTOR TO PROVIDE CONSULTANT WITH SAMPLES OF GRANULAR A MATERIAL FOR TESTING AND CERTIFICATION FROM THE GEOTECHNICAL CONSULTANT THAT THE MATERIAL MEETS THE GRADATION REQUIREMENTS SPECIFIED IN THE GEOTECHNICAL REPORT.
- 8. ASPHALT MATERIAL TO BE PLACED ONLY UPON APPROVAL BY THE GEOTECHNICAL CONSULTANT OF GRANULAR A PLACEMENT.
- 9. CONTRACTOR TO SUPPLY, PLACE AND COMPACT ASPHALT MATERIAL IN ACCORDANCE WITH THE RECOMMENDATIONS OF THE GEOTECHNICAL CONSULTANT. CONTRACTOR TO PROVIDE CONSULTANT WITH SAMPLES OF ASPHALT MATERIAL FOR TESTING AND CERTIFICATION FROM THE GEOTECHNICAL CONSULTANT THAT THE MATERIAL MEETS THE REQUIREMENTS SPECIFIED IN THE GEOTECHNICAL REPORT.
- 10. CONTRACTOR IS RESPONSIBLE FOR ESTABLISHING LINE AND GRADE IN ACCORDANCE WITH THE PLANS, AND FOR PROVIDING THE CONSULTANT WITH VERIFICATION PRIOR TO PLACEMENT.
- 11. ALL EXCESS MATERIAL TO BE HAULED OFFSITE AND DISPOSED OF AT AN APPROVED DUMP SITE. SHOULD THE CONTRACTOR DISCOVER ANY HAZARDOUS MATERIAL, CONTRACTOR IS TO NOTIFY CONSULTANT. CONSULTANT TO DETERMINE APPROPRIATE DISPOSAL METHOD/LOCATION.
- 12. PAVEMENT STRUCTURE (MATERIAL TYPES AND THICKNESS) TO BE AS SPECIFIED IN THE GEOTECHNICAL REPORT.

STORM SEWERS AND STRUCTURES

- 1. ALL STORM SEWER MATERIALS AND CONSTRUCTION METHODS SHALL CONFORM TO THE CURRENT CITY OF OTTAWA STANDARDS AND SPECIFICATIONS. PROVIDE CCTV INSPECTION REPORTS FOR ALL NEW STORM SEWERS, SERVICES AND CB LEADS.
- 2. STORM SEWERS 450mm DIAMETER AND SMALLER SHALL BE PVC SDR-35, WITH RUBBER GASKET PER CSA A-257.3.
- STORM SEWER LARGER THAN 450mm SHALL BE REINFORCED CONCRETE CLASS 100D.
- 4. SEWER BEDDING AS PER CITY OF OTTAWA DETAIL S6.
- ALL STORM MANHOLES TO BE AS PER STORM STRUCTURE TABLE.
- ANY NEW OR EXISTING STORM SEWER WITH LESS THAN 2.0m COVER REQUIRES THERMAL INSULATION AS PER CITY OF OTTAWA STANDARD W22. OR APPROVED BY THE ENGINEER.
- 7. ALL CATCHBASIN LEADS TO BE MINIMUM 200mm DIAMETER AT MINIMUM 1.0% SLOPE UNLESS OTHERWISE
- STORM CATCHBASINS AS PER OPSD 705.010 AND FRAME/COVER AS PER CITY STANDARD DRAWINGS S19. STORM

CBMH'S AS INDICATED IN TABLE WITH SUMP, ADJUSTMENT SECTIONS SHALL BE AS PER OPSD 704.010.

- 9. INSTALLATION OF FLOW CONTROL ICD'S TO BE VERIFIED BY QUALITY VERIFICATION ENGINEER RETAINED BY
- 10. PROVIDE BACKWATER VALVE ON FOUNDATION DRAIN, STORM DISCHARGE, AND OVERFLOW DISCHARGE PER
- 11. ALL CATCHBASINS EXCLUDING LANDSCAPE CATCHBASINS TO HAVE 150 MMØ PERFORATED PIPE FOR 3.0M ON ALL AVAILABLE SIDES AT AN ELEVATION OF 300mm BELOW SUBGRADE LEVEL AS PER CITY OF OTTAWA STANDARD DRAWING 'R1'

SANITARY SEWER AND STRUCTURES

- ALL SANITARY SEWER, SANITARY SEWER APPURTENANCES AND CONSTRUCTION METHODS SHALL CONFORM TO THE CURRENT CITY OF OTTAWA STANDARDS AND SPECIFICATIONS. PROVIDE CCTV INSPECTION REPORTS FOR ALL NEW SANITARY PIPING.
- 2. SANITARY SEWER PIPE SIZE 150mm DIAMETER AND GREATER TO BE PVC SDR-35 (UNLESS SPECIFIED OTHERWISE) WITH RUBBER GASKET TYPE JOINTS IN CONFORMANCE WITH CSA B-182.2,3,4.
- 3. SEWER BEDDING AS PER CITY OF OTTAWA DETAIL S6.
- ALL SANITARY MANHOLES 1200mm IN DIAMETER TO BE AS PER OPSD 701.01. FRAME AND COVER TO BE AS PER CITY OF OTTAWA STANDARD S25 AND S24.
- MAINTENANCE HOLE BENCHING AND PIPE OPENING ALTERNATIVES AS PER THE OPSD 701.021
- 6. ANY SANITARY SEWER WITH LESS THAN 2.0m COVER REQUIRES THERMAL INSULATION AS PER CITY OF OTTAWA STANDARD W22, OR APPROVED BY THE ENGINEER.
- 7. PROVIDE BACKWATER VALVE FOR BUILDING SANITARY SERVICES PER \$14.1

in-situ soil or fill

- ALL WATERMAIN AND WATERMAIN APPURTANANCES, MATERIALS, CONSTRUCTION AND TESTING METHODS SHALL CONFORM TO THE CURRENT CITY OF OTTAWA AND MINISTRY OF ENVIRONMENT STANDARDS AND SPECIFICATIONS.
- 2. ALL WATERMAIN 300mm DIAMETER AND SMALLER TO BE POLY VINYL CHLORIDE (PVC) CLASS 150 DR 18 MEETING AWWA SPECIFICATION C900.
- ALL WATERMAIN TO BE INSTALLED AT MINIMUM COVER OF 2.4m BELOW FINISHED GRADE. WHERE WATERMAINS CROSS OVER OTHER UTILITIES, A MINIMUM 0.30m CLEARANCE SHALL BE MAINTAINED; WHERE WATERMAINS CROSS UNDER OTHER UTILITIES. A MINIMUM 0.50m CLEARANCE SHALL BE MAINTAINED. WHERE THE MINIMUM SEPARATION CANNOT BE ACHIEVED, THE WATERMAIN SHALL BE INSTALLED AS PER CITY OF OTTAWA STANDARDS W25 AND W25.2. WHERE 2.4m MINIMUM DEPTH CANNOT BE ACHIEVED, THERMAL INSULATION SHALL BE PROVIDED AS PER CITY OF OTTAWA STANDARD W22. WHERE A WATERMAIN IS IN CLOSE PROXIMITY TO AN OPEN STRUCTURE, THERMAL INSULATION SHALL BE PROVIDED AS PER CITY OF OTTAWA STANDARD W23.
- 4. CONCRETE THRUST BLOCKS AND MECHANICAL RESTRAINTS ARE TO BE INSTALLED AT ALL TEES, BENDS, HYDRANTS, REDUCERS, ENDS OF MAINS AND CONNECTIONS 100mm AND LARGER, IN ACCORDANCE WITH CITY OF OTTAWA STANDARDS W25.3 & W25.4.
- 5. CATHODIC PROTECTION REQUIRED FOR ALL IRON FITTINGS AS PER CITY OF OTTAWA STANDARD W40 & W42.
- 6. ALL VALVES AND VALVE BOXES AND CHAMBERS, HYDRANTS, AND HYDRANT VALVES AND ASSEMBLES SHALL BE INSTALLED AS PER CITY OF OTTAWA STANDARD
- 7. FIRE HYDRANT LOCATION AND INSTALLATION AS PER CITY OF OTTAWA STANDARD W18 & W19. CONTRACTOR TO
- PROVIDE FLOW TEST AND PAINTING OF NEW HYDRANT IN ACCORDANCE WITH CITY STANDARDS.
- 8. IF WATER MAIN MUST BE DEFLECTED TO MEET ALIGNMENT, ENSURE THAT THE AMOUNT OF DEFLECTION USED IS LESS THAN HALF THAT RECOMMENDED BY THE MANUFACTURER.

Table 2 - Recommended Light Duty Asphalt Pavement Structure - Car Only Parking

Tickness (mm)	Material Description				
50	Wear Course - HL-3 or Superpave 12.5 Asphaltic Concrete				
150	Base - OPSS Granular A Crushed Stone				
300	SUBBASE - OPSS Granular B Type II				
SUBGRADE - Either ap	SUBGRADE - Either approved fill, in-situ, or OPSS Granular B Type I or II material placed o				

Table 3 - Recommended Asphalt Pavement Structure - Access Lanes and Heavy

Tickness (mm)	Material Description					
40	Wear Course - Superpave 12.5 Asphaltic Concrete					
50	Binder Course - Superpave 19.0 Asphaltic Concrete					
150	Base - OPSS Granular A Crushed Stone					
300	SUBBASE - OPSS Granular B Type II					
SUBGRADE - Either a	pproved fill, in-situ, or OPSS Granular B Type I or II material placed on					
n-situ soil or fill						

EROSION AND SEDIMENT CONTROL


CONTRACTOR IS RESPONSIBLE FOR ALL INSTALLATION, MONITORING, REPAIR AND REMOVAL OF ALL EROSION AND SEDIMENT CONTROL FEATURES. **

- PRIOR TO START OF CONSTRUCTION: 1.1. INSTALL SILT FENCE IN LOCATION SHOWN.
- INSTALL SILT SACK FILTERS IN ALL THE CATCHBASINS AND MANHOLES TO REMAIN DURING
- CONSTRUCTION WITHIN THE SITE.
- 1.3. INSPECT MEASURES IMMEDIATELY AFTER INSTALLATION.
- 1.4. INSTALL MUD MAT AT CONSTRUCTION ENTRANCES

DURING CONSTRUCTION:

- 2.1. MINIMIZE THE EXTENT OF DISTURBED AREAS AND THE DURATION OF EXPOSURE AND IMPACTS
- PERIMETER VEGETATION TO REMAIN IN PLACE UNTIL PERMANENT STORM WATER MANAGEMENT IS IN PLACE. OTHERWISE, IMMEDIATELY INSTALL SILT FENCE WHEN THE EXISTING SITE IS DISTURBED AT THE PERIMETER.
- PROTECT DISTURBED AREAS FROM OVERLAND FLOW BY PROVIDING TEMPORARY SWALES TO THE SATISFACTION OF THE FIELD ENGINEER. TIE-IN TEMPORARY SWALE TO EXISTING CB'S AS
- 2.4. PROVIDE TEMPORARY COVER SUCH AS SEEDING OR MULCHING IF DISTURBED AREA WILL NOT BE REHABILITATED WITHIN 30 DAYS.
- INSPECT SILT FENCES, FILTER FABRIC FILTERS AND CATCH BASIN SUMPS WEEKLY AND WITHIN 24 HOURS AFTER A STORM EVENT. CLEAN AND REPAIR WHEN NECESSARY. DOWNSTREAM STORM INFRASTRUCTURE SHALL BE PROTECTED FROM UNFILTERED RUNOFF
- DURING ON-SITE STORM INFRASTRUCTURE DEMOLITION. DRAWING TO BE REVIEWED AND REVISED AS REQUIRED DURING CONSTRUCTION.
- EROSION CONTROL FENCING TO BE ALSO INSTALLED AROUND THE BASE OF ALL STOCKPILES. 2.9. DO NOT LOCATE TOPSOIL PILES AND EXCAVATION MATERIAL CLOSER THAN 2.5m FROM ANY PAVED SURFACE, OR ONE WHICH IS TO BE PAVED BEFORE THE PILE IS REMOVED. ALL TOPSOIL PILES ARE TO BE SEEDED IF THEY ARE TO REMAIN ON SITE LONG ENOUGH FOR SEEDS TO GROW (LONGER THAN 30 DAYS).
- CONTROL WIND-BLOWN DUST OFF SITE BY SEEDING TOPSOIL PILES AND OTHER AREAS TEMPORARILY (PROVIDE WATERING AS REQUIRED AND TO THE SATISFACTION OF THE ENGINEER).
- 2.11. NO ALTERNATE METHODS OF EROSION PROTECTION SHALL BE PERMITTED UNLESS APPROVED BY THE FIELD ENGINEER.
- 2.12. CITY ROADWAY AND SIDEWALK TO BE CLEANED OF ALL SEDIMENT FROM VEHICULAR TRACKING AS REQUIRED.
- 2.13. DURING WET CONDITIONS, TIRES OF ALL VEHICLES/EQUIPMENT LEAVING THE SITE ARE TO BE SCRAPED.
- ANY MUD/MATERIAL TRACKED ONTO THE ROAD SHALL BE REMOVED IMMEDIATELY BY HAND OR RUBBER TIRE LOADER.
- 2.15. TAKE ALL NECESSARY STEPS TO PREVENT BUILDING MATERIAL, CONSTRUCTION DEBRIS OR WASTE BEING SPILLED OR TRACKED ONTO ABUTTING PROPERTIES OR PUBLIC STREETS DURING CONSTRUCTION AND PROCEED IMMEDIATELY TO CLEAN UP ANY AREAS SO AFFECTED.
- ALL EROSION CONTROL STRUCTURE TO REMAIN IN PLACE UNTIL ALL DISTURBED GROUND 2.16. SURFACES HAVE BEEN STABILIZED EITHER BY PAVING OR RESTORATION OF VEGETATIVE GROUND COVER.
- THE CONTRACTOR SHALL IMPLEMENT BEST MANAGEMENT PRACTICES, TO PROVIDE FOR PROTECTION OF THE AREA DRAINAGE SYSTEM AND THE RECEIVING WATERCOURSE, DURING CONSTRUCTION ACTIVITIES. THE CONTRACTOR ACKNOWLEDGES THAT FAILURE TO IMPLEMENT APPROPRIATE EROSION AND SEDIMENT CONTROL MEASURES MAY BE SUBJECT TO PENALTIES IMPOSED BY ANY APPLICABLE REGULATORY AGENCY.

EXISTING LEGEND:



REMOVALS LEGEND:

CURB REMOVAL

STORM REMOVAL

SA STORM REMOVAL

WATERMAIN REMOVAL RETAINING WALL REMOVAL RETAINING WALL REMOVAL SUB DRAIN REMOVAL
FULL DEPTH ASPHALT REMOVAL
GREEN AREA/ INTERLOCK AREA REMOVAL CONCRETE SIDEWALK REMOVAL
GRAVEL ROAD REMOVAL
RAMP REMOVAL
CATCH BASIN REMOVAL STORM MANHOLE REMOVAL SANITARY MANHOLE REMOVAL
FIRE HYDRANT REMOVAL
EXISTING TREES REMOVAL
BOLLAR REMOVAL


LIGHT STAND REMOVAL

PROPOSED LEGE	PROPOSED LEGEND:						
W	EXISTING BOUNDARY NEW WATERMAIN NEW STORM SEWER NEW HDPE SUBDRAIN NEW SANITARY SEWER HIGH POINT 100 YEAR PONDING LIMIT						
© □ □ • • • • • • • • • • • • • • • • •	NEW STORM CATCH BASIN MANHOLE NEW STORM MANHOLE NEW CATCH BASIN/ DITCH INLET NEW SANITARY MANHOLE NEW WATERMAIN VALVE NEW WATERMAIN CONNECTION NEW WATERMAIN 45° BEND NEW SERVICING CAP PROPOSED ELEVATION PROPOSED SURFACE SLOPE OVER FLOW DIRECTION						
	PROPOSED TRENCH DRAIN PROPOSED INTERLOCK						
	PROPOSED INTERLOCK PROPOSED ASPHALT PAVEMENT PROPOSED INSULATION						
·	PROPOSED TREES						

ESC LEGEND:

LIGHT DUTY SILT FENCE (OPSD 219.110) FILTER CLOTH PROTECTION MUD MAT

DRAINAGE AREA LEGEND







14 DUNCAN ST 4TH FLOOR TORONTO, ON M5H 3G8 (416) 591-8999

ENTUITIVE

135 LAURIER AVE WEST, SUITE 413 OTTAWA, ON K1P 5J2 (343) 308-9274 STRUCTURAL ENGINEER



90 SHEPPARD AVE EAST, SUITE 500 TORONTO, ON M2N 3A (416) 751-2520 ELEC, LIGHTING ENGINEER

> 530 N. WOOD STREET #C CHICAGO, IL 60622

(224) 717-1999

FOOD AND BEVERAGE

319 MCRAE AVENUE, SUITE 502 OTTAWA, ONTARIO K1Z 0B9 (613) 729-4536 LANDSCAPE ARCHITECT

2011 QUEENSVIEW DR. OTTAWA, ONTARIO K2B 8K2 (613) 829-2800 CIVIL ENGINEER

REVISED AS PER CITY COMMENTS ISSUED FOR COORDINATION
ISSUED FOR 90% DD - CLASS B ESTIMATE

REVISED AS PER CITY COMMENTS
I ISSUED FOR SPA **REVISIONS/ISSUES**

CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND REPORT ANY OMISSIONS OR DISCREPANCIES TO THE ARCHITECT BEFORE PROCEEDING WITH THE WORK DO NOT SCALE THE DRAWINGS



2025-01-15

2025/01/15 CHECKED

LANSDOWNE EVENT **CENTRE**

945 & 1015 BANK STREET

NOTES AND DETAILS


DWG. TITLE

AS SHOWN CA0033920.1056

DWG. NO.


				STORM	STRUCTU	RE TABLE				
STRUCTURE	TOP OF GRATE	STRUC							OUTLET	
		INLET	INLET	INLET	OUTLET	SIZE	OPSD	COVER	DIAMETER	TYPE
CB01	65.00				63.600	600X600mm	OPSD 705.010	S19.1	250	PVC SDR-35
CB02	65.58				64.010	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB03	66.28				64.190	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB04	66.02				64.220	600X600mm	OPSD 705.010	S19.1	250	PVC SDR-35
CB05	64.91				63.740	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB06	64.91				63.760	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB07	64.90				63.690	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB08	64.90				63.190	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB09	65.20				64.070	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB10	65.30				63.620	600X600mm	OPSD 705.010	S19.1	250	PVC SDR-35
CB11	65.93				64.000	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB12	66.24				63.660	600X600mm	OPSD 705.010	S19.1	250	PVC SDR-35
CB13	65.74				63.680	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB14	67.22				64.370	REFER TO	O TRENCH DRAI	N DESIGN	250	PVC SDR-35
CB15	65.15				63.830	600X600mm	OPSD 705.010	S19.1	250	PVC SDR-35
STMH201(OGS)	65.35			63.080	63.060	1800mm DIA.	OPSD 701.010	S24.1	900	PVC SDR-35
STMH202	65.42		63.380	63.150	63.060	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH203	68.26			63.210	63.190	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH204	71.50			63.260	63.240	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH205	66.72		64.070	63.320	63.290	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH206	67.11			63.370	63.350	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH207	66.15			63.420	63.390	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH208	66.39		63.900	63.520	63.440	1800mm DIA.	OPSD 701.010	S24.1	1050	CONC
STMH209	66.41			63.620	63.580	1800mm DIA.	OPSD 701.010	S24.1	900	CONC
CBMH210	64.90		63.520	63.200	63.180	1200mm DIA.	OPSD 701.010	S28.1	600	CONC
STMH211	65.75		63.240	63.220	63.220	1200mm DIA.	OPSD 701.010	S24.1	600	CONC
STMH212	65.37			63.360	63.290	1200mm DIA.	OPSD 701.010	S24.1	600	CONC
STMH213	65.05	63.380	63.380	63.110	63.060	1200mm DIA.	OPSD 701.010	S24.1	250	PVC SDR-35
STMH214	66.14	64.110	63.680	63.600	63.060	1200mm DIA.	OPSD 701.010	S24.1	250	PVC SDR-35
STMH215	66.09	64.110	63.380	63.060	64.110	1200mm DIA.	OPSD 701.010	S24.1	250	PVC SDR-35


			S	AN STR	UCTURE TA	ABLE		
STRUCTUR	TOP OF		IN'	VERT			DESCRIPTION	
E ID	GRATE	INLET	INLET	INLET	OUTLET	SIZE	OPSD	COVER
SAMH201	65.27			62.410	62.380	1200mm DIA.	OPSD-701.010	S24
SAMH202	66.13			62.510	62.480	1200mm DIA.	OPSD-701.010	S24
SAMH202A	67.02		64.510	62.570	62.570	1200mm DIA.	OPSD-701.010	S24
SAMH203	71.50			62.690	62.670	1200mm DIA.	OPSD-701.010	S24
SAMH204	66.65			62.760	62.740	1200mm DIA.	OPSD-701.010	S24
SAMH205	66.90			62.820	62.800	1200mm DIA.	OPSD-701.010	S24
SAMH206	66.93			62.880	62.860	1200mm DIA.	OPSD-701.010	S24
SAMH207	66.43		63.340	62.940	62.920	1200mm DIA.	OPSD-701.010	S24
SAMH208	66.42			63.100	63.040	1200mm DIA.	OPSD-701.010	S24
SAMH208A	66.46		65.840	63.020	63.020	1200mm DIA.	OPSD-701.010	S24
SAMH209	65.67			62.680	62.660	1200mm DIA.	OPSD-701.010	S24
SAMH210	65.36			62.820	62.760	1200mm DIA.	OPSD-701.010	S24



MUD MAT DETAIL - PLAN VIEW

FIRE HYDRANT ABOVE PARKING GARAGE





Γ			Obvert	Invert			Obvert	Invert	
F	1	1050mmø CONC STM	64.373	63.190	0.188	Clearance Above	63.002	62.627	375mmø PVC SAN
F	•	1000111110 00140 01111	01.070	00.100	0.100	Clourarios / wove	00.002	02.021	0,01111191 10 0,41
	2	375mmØ PVC SAN	62.729	62.354	0.103	Clearance Under	64.341	62.832	EX. 1350mm Ø CONC STM
	3	375mmø PVC SAN	62.768	62.393	0.083	Clearance Above	62.310	62.110	EX.200mm Ø PVC W/M
	4	375mmø PVC SAN	62.794	62.419	0.164	Clearance Under	63.979	62.958	900mmø CONC STM
	5	EX.200mmøPVC W/M	62.130	61.930	0.825	Clearance Under	63.976	62.955	900mmø CONC STM
	6	375mmø PVC SAN	62.855	62.480	1.289	Clearance Under	64.394	64.144	250mmø PVC STM
	7	375mmø PVC SAN	63.208	62.833	1.272	Clearance Under	64.680	64.480	200mmø PVC W/M
	8	1050mmø CONC STM	64.556	63.373	0.363	Clearance Above	63.010	62.810	200mmø PVC W/M
H	9	375mmø PVC SAN	63.300	62.925	0.605	Clearance Under	64.505	63.905	600mmø PVC STM
		0701111191 10 0741	1 00.000	02.020	0.000	Glodianos Gnasi	0 1.000	00.000	Occining i ve erivi
	10	200mmø PVC W/M	64.060	63.860	0.209	Clearance Above	63.651	63.351	EX.300mm Ø PVC SAN
	11	200mmø PVC W/M	63.570	63.370	0.378	Clearance Under	64.643	63.948	EX.600mmøPVC STM
	12	200mmø PVC W/M	64.060	63.860	0.458	Clearance Above	63.402	63.027	375mmø PVC SAN
	13	200mmø PVC SAN	65.339	65.089	0.500	Clearance Above	64.589	63.568	900mmø CONC STM
	14	250mmø PVC STM	63.976	63.726	0.884	Clearance Above	62.841	62.591	EX.250mm Ø PVC SAN
	15	250mmø PVC STM	64.209	63.959	1.012	Clearance Above	62.947	62.572	EX.375mmøPVC SAN
	16	250mmø PVC STM	63.194	62.944	0.097	Clearance Above	62.847	62.472	EX.375mmøPVC SAN
	17	200mmø PVC W/M	63.960	63.760	0.282	Clearance Above	63.478	63.103	375mmø PVC SAN
	18	600mmø PVC STM	63.987	63.387	0.343	Clearance Above	63.044	62.794	EX.250mm Ø PVC SAN
			I						
	19	600mmø PVC STM	63.850	63.250	0.332	Clearance Above	62.918	62.668	EX.250mmøPVC SAN
	20	375mmø PVC SAN	63.318	62.943	0.542	Clearance Under	64.060	63.860	200mmø PVC W/M
	21	1050mmø CONC STM	64.511	63.328	0.378	Clearance Above	62.950	62.750	200mmø PVC W/M
	22	1050mmø CONC STM	64.463	63.280	2.267	Clearance Under	66.930	66.730	200mmø PVC W/M
	23	375mmØ PVC SAN	63.141	62.766	3.429	Clearance Under	66.770	66.570	200mmø PVC W/M
	24	375mmø PVC SAN	63.141	62.766	1.009	Clearance Under	64.350	64.150	200mmø PVC W/M
	25	900mmø CONC STM	64.537	63.516	0.306	Clearance Above	63.210	63.010	200mmø PVC W/M
	26	900mmø CONC STM	64.591	63.570	0.330	Clearance Above	63.240	63.040	200mmø PVC W/M
	27	200mmø PVC W/M	62.860	62.660	0.349	Clearance Under	63.904	63.209	EX.600mm@CONC STM
	28	200mmø PVC W/M	62.340	62.140	0.310	Clearance Under	62.900	62.650	EX.250mmøPVC SAN
	29	200mmø PVC W/M	64.320	64.120	1.150	Clearance Above	62.970	62.595	EX.375mm Ø PVC SAN
	30	250mmø PVC STM	64.516	64.266	1.290	Clearance Above	62.976	62.601	375mmø PVC SAN
			1 0 1.010	- 1.200	00	5.54141100 / IDOVO	32.070	<u>001</u>	3.3

	WATERMAIN SC	HEDULE		
STATION	DESCRIPTION	FINISHED	TOP OF	cov
SIATION	DESCRIP HON	GRADE	WATERMAIN	COV
	200mm W/M (FROM CONNECT TO	EX.W/M TO E	BUILDING)	
0+000	Connect to EX. W/M	65.00	62.600	2.
0+018.61	Crossing with 375mm PVC SAN	66.75	64.350	2.
0+020.82	Crossing with 1050mm CONC STM	66.85	62.950	3.
0+027.87	Connect to building	67.11	64.710	2.

MATERNAAINI COUEDIU E							
	WATERMAIN SC	HEDULE					
STATION	DESCRIPTION	FINISHED	TOP OF	COVER			
	DESCRIP HON	GRADE	WATERMAIN	COVER			
	200mm W/M (FROM BU	LDING TO END)				
1+000	Connect to proposed building	66.04	50.040	2 40			
		66.24	63.840	2.40			
1+000.90	200mm VB	66.27	63.870	2.40			
1+004.78	Crossing with 900mm CONC STM	66.41	63.210	3.20			
1+006.27	Crossing with 375mm PVC SAN	64.06	61.660	2.40			
1+006.81	45° Bend	66.48	64.080	2.40			
1+007.85	150X200mm Tee connection	66.49	64.090	2.40			
1+008.90	45° Bend	66.49	64.090	2.40			
1+060.64	200x 200mm TEE Connection	66.48	64.080	2.40			
1+069.54	Crossing with 375mm PVC SAN	66.42	64.020	2.40			
1+072.29	Watermain cap	66.37	63.970	2.40			

WATERMAIN SCHEDULE								
CTATION	DESCRIPTION	FINISHED	TOP OF	60\ /ED				
STATION	DESCRIPTION	GRADE	WATERMAIN	COVER				
200mm W/M (TEE CONNECTION TO BUILDING)								
2+000	200x 200mm TEE Connection	66.48	64.080	2.40				
2+001.98	Crossing with 375mm PVC SAN	66.46	64.060	2.40				
2+003.48	Crossing with 900mm CONC STM	66.44	63.240	3.20				
2+008.86	Connect to proposed building	66.37	63.970	2.40				

WATERMAIN SCHEDULE								
STATION	DESCRIPTION	FINISHED	TOP OF	60) (ED				
	DESCRIPTION	GRADE	WATERMAIN	COVER				
200mm W/M (FROM CONNECT TO EX.W/M TO BUILDING)								
3+000	Connect to EX. W/M	66.18	63.780	2.40				
3+004.31	Crossing with 375mm PVC SAN	67.08	64.680	2.40				
3+006.16	Crossing with 1050mm CONC STM	67.11	63.010	4.10				
3+007.37	200mm VB	67.11	64.710	2.40				
3+008.05	Connect to proposed building	67.12	64.720	2.40				

WATERMAIN SCHEDULE									
STATION	DESCRIPTION	SCRIPTION FINISHED		COVER					
STATION	DESCRIPTION	GRADE	WATERMAIN	COVER					
	200mm W/M (FROM CONNECT TO EX.W/M TO BUILDING)								
4+000	Connect to EX. W/M	65.13	62.730	2.40					
4+019.81	Crossing with 375mm PVC SAN	69.17	66.770	2.40					
4+021.66	Crossing with 1050mm CONC STM	69.33	66.930	2.40					
4+026.48	Connect to building	68.23	65.830	2.40					

WATERMAIN SCHEDULE									
STATION	DESCRIPTION	FINISHED	TOP OF	COVER					
		GRADE	WATERMAIN						
150mm FIRE HYDRANT (CLOSE TO EVENT CENTER)									
5+000	150x 200mm Tee connection	66.49	64.090	2.40					
5+004.77	45° Bend	66.47	64.070	2.40					
5+010.07	Conncet to Fire Hydrant	66.42	64.020	2.40					

WATERMAIN SCHEDULE									
STATION	DESCRIPTION	FINISHED	TOP OF	COVER					
		GRADE	WATERMAIN						
	150mm FIRE HYDRANT (ON LANDSCAPE AREA)								
	Connect to EX.W/M with Tee								
6+000	Connection	66.60	64.200	2.40					
6+010.21	45° Bend	66.79	64.390	2.40					
6+016.90	Conncet to Fire Hydrant	67.00	64.600	2.40					

WATERMAIN SCHEDULE								
STATION	DESCRIPTION	FINISHED	TOP OF	COVER				
		GRADE	WATERMAIN					
200mm W/M (FROM CONNECT TO EX.W/M TO END)								
7+000	Connect to EX. W/M	65.94	63.540	2.40				
7+009.51	45° Bend	65.85	63.450	2.40				
7+012.50	Crossing with 600mm CONC STM	65.76	62.860	2.90				
7+016.18	Crossing with 250mm PVC SAN	65.64	62.340	3.30				
7+051.88	45° Bend	65.37	62.970	2.40				
7+053.12	22.5° Bend	65.37	62.970	2.40				
7+065.36	Watermain cap	65.32	62.920	2.40				





14 DUNCAN ST 4TH FLOOR TORONTO, ON M5H 3G8 (416) 591-8999

ENTUITIVE

135 LAURIER AVE WEST, SUITE 413 OTTAWA, ON K1P 5J2 (343) 308-9274



(416) 499-8000 MECH, PLUMB, FIRE PROTECTION ENGINEER

STRUCTURAL ENGINEER

FOOD AND BEVERAGE

90 SHEPPARD AVE EAST, SUITE 500 TORONTO, ON M2N 3A

(416) 751-2520 ELEC, LIGHTING ENGINEER

530 N. WOOD STREET #C CHICAGO, IL 60622 (224) 717-1999

319 MCRAE AVENUE, SUITE 502 OTTAWA, ONTARIO K1Z 0B9 (613) 729-4536

2011 QUEENSVIEW DR. OTTAWA, ONTARIO K2B 8K2 (613) 829-2800 CIVIL ENGINEER

5 REVISED AS PER CITY COMMENTS
4 ISSUED FOR COORDINATION
3 ISSUED FOR 90% DD - CLASS B ESTIMATE
2 REVISED AS PER CITY COMMENTS
1 ISSUED FOR SPA
DESCRIPTION

REVISIONS/ ISSUES

CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND REPORT ANY OMISSIONS OR DISCREPANCIES TO THE ARCHITECT BEFORE PROCEEDING WITH THE WORK. DO NOT SCALE THE DRAWINGS





J.T 2025/01/15 CHECKED

LANSDOWNE EVENT CENTRE


945 & 1015 BANK STREET


DWG. TITLE


DETAILS


AS SHOWN


CA0033920.1056





























PROPOSED NON-WOVEN GEOTEXTILE AND SOFT SOIL OR HARD CAP
SCALE: 1:400

FI

LAWN AREA PLAN

SCALE

1:400
PROJ. NO.

CA0033920.1056

DWG. NO.


CO9

CENTRE


945 & 1015 BANK STREET

LANSDOWNE 2.0 RISK

MANAGEMENT GREAT



A UNDERGROUND CHAMBER CROSS SECTION A FIG.2 SCALE: H 1:200, V 1:40



B UNDERGROUNG CHARMBER CROSS SECTION B SCALE: H 1:200, V 1:40





14 DUNCAN ST 4TH FLOOR TORONTO, ON M5H 3G8 (416) 591-8999

ARCHITECT

ENTUITIVE

135 LAURIER AVE WEST, SUITE 413 OTTAWA, ON K1P 5J2 (343) 308-9274

STRUCTURAL ENGINEER

200 KING. ST. WEST, SUITE 310 TORONTO, ON M5H 3T4 (416) 499-8000 MECH, PLUMB, FIRE PROTECTION ENGINEER

90 SHEPPARD AVE EAST, SUITE 500 TORONTO, ON M2N 3A (416) 751-2520

ELEC, LIGHTING ENGINEER

530 N. WOOD STREET #C CHICAGO, IL 60622 (224) 717-1999

FOOD AND BEVERAGE

319 MCRAE AVENUE, SUITE 502 OTTAWA, ONTARIO K1Z 0B9 (613) 729-4536

LANDSCAPE ARCHITECT

115[] 2011 QUEENSVIEW DR.

OTTAWA, ONTARIO K2B 8K2 (613) 829-2800 CIVIL ENGINEER


5 REVISED AS PER CITY COMMENTS
4 ISSUED FOR COORDINATION
3 ISSUED FOR 90% DD - CLASS B ESTIMATE
2 REVISED AS PER CITY COMMENTS
1 ISSUED FOR SPA
NO. DESCRIPTION

REVISIONS/ ISSUES CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS

AND REPORT ANY OMISSIONS OR DISCREPANCIES TO THE ARCHITECT BEFORE PROCEEDING WITH THE WORK.

DO NOT SCALE THE DRAWINGS





J.T

DATE 2025/01/15 CHECKED W.Y

LANSDOWNE EVENT CENTRE

945 & 1015 BANK STREET

DWG. TITLE UNDERGROUND CHAMBER **CROSS SECTION**

SCALE

PROJ. NO.

1:200

DWG. NO.

FIG.2 CA0033920.1056

