

Legend

- PROPOSED WATERMAIN
PROPOSED VALVE AND VALVE BOX
PROPOSED VALVE CHAMBER
PROPOSED REDUCER
PROPOSED FIRE HYDRANT
PROPOSED VALVE AND DMA CHAMBER AS PER CITY STD W3
WATER METER
REMOTE WATER METER
PROPOSED SANITARY SEWER
PROPOSED STORM SEWER
PROPOSED CATCH-BASIN
EXISTING CULVERT
EXISTING WATERMAIN
EXISTING VALVE AND VALVE BOX
EXISTING VALVE CHAMBER
EXISTING FIRE HYDRANT
EXISTING SANITARY SEWER
PROPOSED DEPRESSURED CURB LOCATIONS
PROPOSED BARRIER CURB
THERMAL INSULATION ON STORM SEWER WHERE COVER IS LESS THAN 1.5m. THERMAL INSULATION ON WATERMAIN WHERE COVER IS LESS THAN 2.4m AS PER W22.
EX. TREE TO BE REMOVED
EX. TREE TO BE RETAINED
ROAD CUT RE-INSTATEMENT PER CITY STD R10

Notes

6	REVISED PER NEW SITE PLAN	MJS	DT	25.07.11
5	REVISED AS PER SITE PLAN AND CITY COMMENTS	MJS	DT	24.12.02
4	REVISED AS PER SITE PLAN AND CITY COMMENTS	MJS	DT	24.04.08
3	REVISED WATERMAIN SEE	MJS	DT	22.04.08
2	REVISED AS PER CITY COMMENTS	MJS	TR	21.05.07
1	ISSUED FOR REVIEW	MJS	TR	20.11.23
Revision		By	Appd.	YY.MM.DD

File Name:	160401570.DB	MJS	AMP	MJS	20.08.17
		Drawn	Checked	Designed	YY.MM.DD

Permit-Seal



Client/Project

BRIGIL

100 STEACIE DRIVE

OTTAWA, ON

Title

STORM POND SECTION CROSSING
EX. SANITARY TRUNK AND RAILWAY
SECTION B-B

Project No.	Scale	0 5 15 25m
160401570	1:500	
Drawing No.	Sheet	Revision

SEC-2

12 of 12

6

PLAN# 18327

