



940 Belfast road, Suite 203
Ottawa, ON K1G 4A2
Tél: (819) 243-8383
info@groupeelca.ca

Ottawa, Tuesday, July 23rd 2024

Attn: Matt Blasioli
Project Manager
Wiesshorn
(613) 355-5591
Matt@Wiesshorn.com

Project: 193 Norice
Object: Fire Suppression Demand Attestation

Mr. Blasioli,

Following the receipt of the SPA feedback form from the city of Ottawa for the new building located at 193 Norice street, in Ottawa, this attestation letter is in response to comment #15 copied below:

“Based on the report by DSEL the fire suppression demands for this property were taken as 1,893 L/s as determined by the building mechanical engineer. Please provide a letter for the mechanical engineering confirming that the current proposed building’s fire demand.”

An important note is that there is an error in the comment since the building fire suppression demand is most likely 1,893 L/m (not 1,893 L/s). We attest that the fire suppression demand for this building is 1,893 L/m.

A handwritten signature in blue ink, appearing to read 'PO Campeau', written over a horizontal line.

2024-07-23

Pier-Olivier Campeau, P. Eng.
Associate – Director of Operations