

Prepared for:

12714001 CANADA INC.
100-768 Boulevard St-Joseph
Gatineau, QC
J8Y 4B8

Prepared by:

J.L. RICHARDS & ASSOCIATES LIMITED
343 Preston Street, Suite 900 and 1000
Ottawa, ON
K1S 1N4

Site Servicing Report

**NAVAN RESIDENTIAL AND COMMERCIAL
BLOCK 14
2983 Navan Road**



Site Servicing Report

2983 Navan Road

Table of Contents

1.0	INTRODUCTION.....	1
1.1	General	1
1.2	Site Description.....	1
1.3	Proposed Development	1
1.4	Proposed Connections to Existing Infrastructure.....	1
1.5	Consultation and Permits.....	1
2.0	WATER SERVICING	2
2.1	Water Supply Design Criteria	2
2.2	Domestic Water Demands.....	2
2.3	Fire Flow Requirements.....	3
2.4	Proposed Water Servicing, Boundary Conditions and Water Model	3
2.4.1	Proposed Water Servicing	3
2.4.2	Boundary Conditions.....	3
2.4.3	Water Model.....	4
2.5	Simulation Results	4
2.5.1	Peak Hour	4
2.5.2	Maximum Day Plus Fire Flow	4
2.5.3	Maximum Pressure	5
2.6	Internal Pumping Requirements	5
2.7	Summary and Conclusions	5
3.0	WASTEWATER SERVICING.....	5
3.1	Design Criteria	5
3.2	Proposed Sanitary Servicing and Design Flows	6
3.3	Summary and Conclusions	7
4.0	STORM SERVICING AND STORMWATER MANAGEMENT	7
4.1	Design Criteria	7
4.2	Proposed Stormwater Management Approach.....	8
4.3	Proposed Minor System Servicing.....	8
4.4	Stormwater Management Modelling Approach.....	8
4.4.1	Dual Drainage Model	8
4.4.2	Boundary Conditions.....	9
4.4.3	Hydrological Modelling Parameters	9
4.4.4	Simulation of Storm Distributions	10
4.5	Simulation Results	10
4.5.1	Low Point Ponding Analysis.....	10
4.5.2	Roof Drainage	11
4.5.3	Parking Lot Drainage	11
4.5.4	Landscape Drainage	11
4.5.5	Building Release Rates	12
4.6	Summary and Conclusions	12
5.0	Erosion and Sedimentation Control	13

Site Servicing Report

2983 Navan Road

List of Tables

Table 1: Water Demands	3
Table 2: Hydraulic Boundary Conditions.....	4
Table 3: Watermain Internal Diameters and C-Factors	4
Table 4: Wastewater Key Design Parameters	6
Table 5: Sanitary Design Flow Summary.....	6
Table 6: Catchbasin Ponding Depths	10
Table 7: Parking Area ICD Capture Analysis.....	11

List of Appendices

Appendix A	Concept Plan and Topographical Plan
Appendix B	Pre-consultation notes and Servicing Study Checklist
Appendix C	Water Servicing
Appendix D	Storm Servicing and Stormwater Management
Appendix E	Sanitary Servicing

Site Servicing Report

2983 Navan Road

1.0 INTRODUCTION

1.1 General

In 2023, J.L. Richards & Associates Limited (JLR) was retained by 12714001 Canada Inc. (the Owner) to prepare the detailed design of municipal infrastructure for Site Plan Approval (SPA) of the Mixed-Use Site Plan (Block 14). This Site Servicing Report (SSR) presents the servicing constraints and strategies for water, wastewater, stormwater servicing, and stormwater management in accordance with the City of Ottawa Design Guidelines, the associated technical bulletins and relevant design excerpts.

1.2 Site Description

The Mixed-Use Site Plan (Block 14) is located within the City of Ottawa's Official Plan boundary and consists of a 0.57 ha parcel bounded by Brian Coburn to the northwest, existing Page properties to the northeast and the proposed East Ridge Orleans Subdivision in the remaining directions (refer to the East Ridge Orleans Subdivision Site Servicing Report prepared by J.L. Richards and Associates, dated September 22, 2023). The legal description of the subject property can be found in the Draft Plan of Subdivision attached to Appendix A.

A topographical survey was completed by Stantec Inc. in August 2023 (Appendix A1). The survey indicates that the existing ground surface generally slopes in a southerly direction towards the future subdivision lands.

1.3 Proposed Development

The proposed development will consist of two mid-rise residential condominiums (Building A and B) with combined underground parking garage. Building A has 48 units whereas Building B has 36 units and one (1) storey of commercial space on the first floor. The Concept Plan for the Mixed-Use Site Plan (Block 14) is attached to Appendix A.

1.4 Proposed Connections to Existing Infrastructure

Block 14 is proposed to be serviced by the infrastructure that is part of the East Ridge Orleans Subdivision. One sanitary, storm and water service lateral will extend to the parking garage footprint from the subdivision as shown in the servicing drawings.

1.5 Consultation and Permits

A pre-consultation meeting was held on September 13, 2023, to discuss the planning process, design criteria, and servicing constraints. A copy of the pre-consultation meeting notes and the site servicing checklist has been provided in Appendix B.

Site Servicing Report

2983 Navan Road

2.0 WATER SERVICING

2.1 Water Supply Design Criteria

A Hydraulic Network Analysis (HNA) was completed as part of the detailed design for the East Ridge Orleans subdivision to confirm that the proposed watermains could provide adequate supply while complying with both the Ottawa Design Guidelines for Water Distribution (July 2010) and Technical Bulletins ISDTB-2014-02, ISTB-2018-02 and ISTB-2021-03. These documents are herein referred to as the Design Guidelines and TB-2014-02, TB-2018-02, and TB-2021-03, respectively.

The HNA completed as part of the East Ridge Orleans Subdivision design included water demands for the Mixed Used Site Plan (Block 14). The HNA has since been updated to reflect the proposed water service lateral for Block 14 but is based on the same demands and the boundary conditions used in the original East Ridge Orleans Subdivision HNA (refer to Appendix C for a copy of City correspondence for boundary conditions).

Section 4.2.2 of the Design Guidelines states the following criteria for development additions to the public water distribution system:

- Under maximum hourly demand conditions (peak hour), the residual pressures shall not be less than 276 kPa (40 psi);
- During periods of maximum day and fire flow demand, the residual pressure at any point in the distribution system shall not be less than 140 kPa (20 psi);
- In accordance with the Ontario Building Code (OBC) in areas that may be occupied, the static pressure at any fixture shall not exceed 552 kPa (80 psi);
- The maximum pressure at any point in the distribution system in unoccupied areas shall not exceed 689 kPa (100 psi); and
- Feedermains, which have been provided primarily for the purpose of redundancy, shall meet, at a minimum, the basic day plus fire flow demand.

2.2 Domestic Water Demands

The water demands presented in this section are based on the site layout and unit count shown in the Site Plan (Appendix A) and commercial flows. Domestic water demands were calculated for 84 apartment units with an average density of 1.8 persons per unit, giving a total population of 151 people. Commercial flows were calculated for a commercial area of 0.09 ha.

The residential and commercial consumption rates for average day, maximum day, and peak hour demand were set in accordance with Table 4-2 of the Design Guidelines. Table 1 summarizes the water consumption rates and peaking factors used in the HNA.

Site Servicing Report

2983 Navan Road

Table 1: Water Demands

Demand Scenario	Residential Water Consumption or Peaking Factor	Commercial Water Consumption or Peaking Factor	Total Demands (L/s)
Average Day Demand	280 L/c/d	28,000 L/ ha /d	0.52
Maximum Day Demand	2.5 x Avg Day	1.5 x Avg Day	1.27
Peak Hour Demand	2.2 x Max Day	1.8 x Max Day	2.78

2.3 Fire Flow Requirements

The City has specified that the Fire Underwriters Survey (FUS) method shall be used for any public or private site where new fire hydrants are being designed. Specifically, the required fire flow (RFF) for each structure was calculated in accordance with TB-2018-02.

The required fire flow for the Mixed-Use Site Plan (Block 14) was calculated to be 233 L/s. Refer to Appendix C for the detailed RFF calculations for the critical fire area.

Both buildings within Block 14 will be equipped with a fully supervised automatic sprinkler designed and installed in accordance with NFPA 13. In the analysis, a sprinkler flow of 1500 L/min (25 L/s) was applied to each building as recommended by the Owner's Mechanical Engineer (refer to Appendix C).

2.4 Proposed Water Servicing, Boundary Conditions and Water Model

2.4.1 Proposed Water Servicing

Water will be supplied to the Mixed-Use Site Plan (Block 14) by a 150 mm diameter water service that will connect to the 200 mm diameter watermain loop within the East Ridge Orleans subdivision. Fire protection will be provided by each building's sprinkler system, proposed hydrants within the East Ridge Orleans Subdivision, and a new proposed hydrant for Block 14 off the 150 mm diameter water service lateral. The Siamese connection for each building is shown on the Servicing Drawings and is located no more than 45 m away from a hydrant as required by the OBC (refer to hydrant coverage markup in Appendix C).

2.4.2 Boundary Conditions

Hydraulic boundary conditions were provided by the City at the two proposed connection locations for the East Ridge Orleans subdivision (Connection 1-Page Road and Connection 2-Navan Road East). Table 2 summarizes the hydraulic boundary conditions received (refer to Appendix C for a copy of the City correspondence).

Site Servicing Report

2983 Navan Road

The City boundary condition for fire flow demand scenario #3 was used in this HNA (Max Day plus Fire Flow #3), as this considers the most critical fire flow of 233 L/s required for Block 14.

Table 2: Hydraulic Boundary Conditions

Demand Scenarios	Connection 1 Head (m)	Connection 2 Head (m)
Maximum HGL	130.7	130.7
Peak Hour	127.0	126.8
Max Day plus Fire Flow #3 14,000 L/min (233 L/s)	124.9	122.7

2.4.3 Water Model

A hydraulic water model within the WaterCAD® software platform was used to carry out the HNA (refer to the overall schematic presented in Appendix C). The water demands from Table 1 and the boundary conditions from Table 2 were input into the model for each demand scenario. Table 3 summarizes the watermain diameters and roughness coefficients used in the model, based on Sections 4.2.12 and 4.3.5 of the Design Guidelines.

Table 3: Watermain Internal Diameters and C-Factors

Nominal Diameter	Inside Diameter	C-Factor
150 mm	155 mm	100
200 mm	204 mm	110
300 mm	297 mm	120

2.5 Simulation Results

The HNA was carried out under steady-state peak hour, maximum day plus fire flow, and maximum pressure conditions to confirm that the proposed water servicing can meet the design criteria outlined in Section 2.1.

2.5.1 Peak Hour

The simulation results found the minimum pressure at the site (node J-22 in the model) during the peak hour condition to be 396 kPa (57.44 psi) (refer to Appendix C), which exceeds the minimum pressure criterion of 276 kPa (40 psi) per the Design Guidelines.

2.5.2 Maximum Day Plus Fire Flow

Fire water supply will be provided by the fully automatic sprinkler system, the hydrants within the East Ridge Orleans subdivision, and by a proposed hydrant off the 150 mm

Site Servicing Report

2983 Navan Road

diameter water lateral within Block 14. To ensure adequate fire protection, the maximum day demand shown in Table 1 was analyzed simultaneously with the fire flow requirements. As mentioned in Section 2.3, a sprinkler system flow of 1500 L/min (25 L/s) was applied for Block 14, and it was assumed that only one (1) building would require fire flow at once.

Once the maximum day demands, the sprinkler system demands and the 14,000 L/min (233 L/s) boundary condition provided by the City (refer to Table 2) were input in the model, the fire flow simulation was carried out by allowing WaterCAD® to calculate the available fire flow that can be drawn from a hydrant without allowing any part of the system to experience pressures less than 140 kPa (20 psi).

From the simulation results, the system is expected to deliver 14,000 L/min (233 L/s) to the site through the contribution of the sprinkler system and the nearby hydrants. Attached to Appendix C is a map of the hydrant coverage for Block 14 which confirms that both buildings within the block meet the RFF of 233 L/s through the aggregate sum of hydrant flows. Based on Appendix I of TB-2018-02 hydrants within 75 m of a building can provide 95 L/s of fire flow and hydrants within 75 to 150 m of a building can provide 63 L/s of fire flow.

2.5.3 Maximum Pressure

Based on a zero (0 L/s) demand condition, the simulation results found the maximum pressure at the site (node J-22) to be 435 kPa (63.09 psi). This value is below the maximum pressure constraint of 552 kPa (80 psi), therefore pressure reducing valves (PRVs) are not anticipated to be required.

2.6 Internal Pumping Requirements

Based on the results presented above, internal building pumps are anticipated to be required due to the height of the building. The pumps should be designed by the Owner's mechanical engineer.

2.7 Summary and Conclusions

Based on the water simulation results, the proposed development can be serviced by the proposed 150 mm water service lateral connected to the 200 mm watermain loop within the East Ridge Orleans Subdivision. Furthermore, adequate fire water supply can be achieved with the proposed hydrants within the East Ridge Orleans Subdivision and the proposed hydrant off the 150 mm water lateral servicing Block 14. Internal building pumps are anticipated to be required.

3.0 WASTEWATER SERVICING

3.1 Design Criteria

The sanitary sewer system within the Mixed-Use Site Plan (Block 14) is designed in accordance with the Ottawa Sewer Design Guidelines and subsequent technical bulletins. The design parameters are applied under two scenarios as per ISTB Technical Bulletin 2018-01. The key design parameters have been summarized in the table below.

Site Servicing Report

2983 Navan Road

Table 4: Wastewater Key Design Parameters

Design Parameter	Design Value
Commercial Average Flow	28,000 L/gross ha/Day
Residential Average Flow	280 L/Cap/Day
Residential Peaking Factor	Harmon's Formula
Commercial Peaking Factor	1.5
Harmon's Correction Factor (K)	0.8
Infiltration Allowance	0.33 L/s/ha
Manning's Roughness Coefficient (n)	0.013
Allowable Slopes	Varies (Refer to Section 6.1.2.2 of ODSG)
Allowable Velocities	0.6 m/s – 3.0 m/s
Allowable Freeboard	-

3.2 Proposed Sanitary Servicing and Design Flows

Wastewater generated from Block 14 will be conveyed via a proposed 200 mm diameter sanitary service lateral, which will then discharge into the East Ridge Orleans Subdivision. Based on the design criteria above and the site constraints, a total design peak flow of 1.97 L/s is calculated for the development. The table below summarizes the peak sanitary flow for the site plan. A detailed design sheet can be found in Appendix E.

Table 5: Sanitary Design Flow Summary

Area	Site Area	Unit Count	Unit Density	Pop.	Harmon's Peaking Factor	Res. Peak Flow	Comm. Peak Flow	Infilt. Flow	Total Flow
Block 14	0.57 ha	84	1.8 ppu	151 persons	3.55	1.74 L/s	0.05 L/s	0.19 L/s	1.97 L/s

A 200 mm diameter sanitary service lateral is expected to have sufficient capacity to convey the wastewater flows for the site. The flows from this block were already incorporated in the design of the sanitary sewer for the subdivision (refer to the East Ridge Orleans Subdivision Site Servicing Report prepared by J.L. Richards and Associates, dated February 16, 2024). As shown in this report, the subdivision will consist of 200 mm diameter pipes which will have, at minimum, 20.24 L/s of capacity. Furthermore, the overall subdivision inclusive of the Site Plan Blocks 14, 15 and 17 is expected to generate 12.98 L/s of wastewater flows which is less than the minimum expected capacity of the pipes by 35%. Therefore, it is anticipated that the sanitary sewer system downstream will have sufficient capacity for the 1.97 L/s of wastewater flows generated by Block 14.

Furthermore, it has been confirmed by the Owner's Mechanical Engineer that a 200mm diameter service will be sufficient to convey the flows generated by the mechanical fixtures (refer to Appendix E).

Site Servicing Report

2983 Navan Road

3.3 Summary and Conclusions

Wastewater servicing for Block 14 will be designed in accordance with the City of Ottawa Sewer Design Guidelines, the associated technical bulletins, and various background documents as highlighted throughout this section. Wastewater will be conveyed via a proposed 200 mm diameter sanitary service lateral which will then discharge into the East Ridge Orleans Subdivision. It is recommended that this wastewater servicing plan be implemented to provide adequate sanitary servicing for the proposed development.

4.0 STORM SERVICING AND STORMWATER MANAGEMENT

4.1 Design Criteria

Storm and stormwater management servicing for the Mixed-Use Site Plan (Block 14) was developed in accordance with the City of Ottawa 2012 Sewer Design Guidelines (OSDG) and the more recent Technical Bulletin PIEDTB-2016-01 (September 6, 2016). These two documents are herein referred to as the Design Guidelines in this section. A summary of the key storm and stormwater management criteria follows:

- Control minor system flows to the allowable release rates of 58 L/s as identified in Table 5-3 Site Servicing Report 2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario (JLR November 2024);
- The runoff coefficients (C-factors) to be calculated based on the ratio of pervious and impervious surfaces depicted on proposed site plans;
- Minimum roadway slope of 0.1% from crest-to-crest for overland flow route;
- Minimum rear yard slope in the absence of perforated pipe system of 1.5% along with swale side slopes of 3 horizontal to 1 vertical;
- Maximum parking ponding depth of 350 mm (static and dynamic) as per the Design Guidelines and maximum depth of surface flow to be 300 mm;
- Minimum vertical clearance of 0.15 m between the spill elevation on the street and the finished grade (garage elevation);
- Minimum vertical clearance of 0.30 m between the surface spill elevation and the ground elevation at the building in the rear yards;
- Major system flows, up to and including the 1:100-year design storm event, are contained within the site using the parking lot area and surface drainage.
- Quality control will be accommodated by Pond #3 to meet an MECP Enhanced Level of Protection (80% TSS removal) as identified in Site Servicing Report 2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario (JLR November 2024).
- Provide measures to ensure that site preparation and construction is in accordance with the current Best Management Practices for Erosion and Sediment Control.

Site Servicing Report

2983 Navan Road

4.2 Proposed Stormwater Management Approach

In order to achieve the allowable release rates, the stormwater management of the site will include:

- Rooftop control with rooftop storage and released at a cumulative controlled release rate of 2 L/s for each building; per WATTS RD-200 detail for Small Area Roof Drain (Appendix D) and as recommended by the landowner's mechanical engineer.
- Surface storage within the parking lots in greater than a 1:2-year event with captured flows conveyed to the building plumbing system and internal cistern;
- Ramp runoff captured and conveyed to the building plumbing system and internal cistern;
- Storage in the building cistern with flows pumped at a controlled rate to the minor system with a backwater valve at the connection; and,
- Controlled release of the flows captured in the ditch drainage system for the surrounding landscaped areas.

Foundation drains will be connected to the internal building plumbing system therefore no HGL analysis is required.

4.3 Proposed Minor System Servicing

A minor system connection will be provided from the building envelope to the minor system within the subdivision. The connection will be sized based on the 1:2-year release from the site. The runoff coefficient is based on the ratio of impervious surfaces and grassed or landscaped areas. The breakdown between pervious and impervious surfaces is shown on the figure entitled Overall Site Imperviousness in Appendix D. A design sheet for sizing of the connection is provided in Appendix D.

4.4 Stormwater Management Modelling Approach

4.4.1 Dual Drainage Model

The analysis of both major and minor drainage systems was carried out to demonstrate their compliance with respect to the design criteria described in Section 4.1. The performance of the major overland system and minor storm sewer system was analyzed with PCSWMM. This software is a dynamic model which allows both hydrologic and hydraulic components to be simulated in the same platform and also allows the simulation of the interaction between the major and minor systems. The PCSWMM software platform was used to:

- Generate the surface runoff hydrograph for each sub-area under various recurrences.
- Subdivide each inflow hydrograph into its minor and major system components based on the proposed inlet capture rates and roadway sag storage.
- Assess cascading, if any, and carry out dynamic routing of storm flows to determine flow depths along the roadways. As previously stated, the maximum

Site Servicing Report

2983 Navan Road

major overland flow depths within the parking lot areas are to be limited to 350 mm or less, as per Technical Bulletin PIEDTB-2016-01.

PCSWMM was set-up to evaluate the proposed servicing as detailed on Drawing C01 and C02. Subcatchments were delineated for the structure roof areas, parking lot low points and landscaped low points. Model schematics are prepared in Appendix D.

4.4.2 Boundary Conditions

Boundary conditions are taken from the downstream subdivision model issued as part of the Site Servicing Report 2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario (JLR 2023).

The downstream 1:100-year HGL at the connection to the Subdivision at MH525 from the building internal system outlet is identified as 81.17 m, which is lower than the proposed building connection and therefore there is no backflow from the boundary condition and no impacts on the system.

There are two connections to the subdivision system from landscaped areas, one connection is a T-connection into the pipe from MH526-MH525 which has controlled release. The HGL at this point in the system is 81.45 m which is below the catchbasin invert of 83.09m and therefore there is no backflow from the boundary condition and no impacts on HGL.

A second landscaped area connection is a connection directly into MH 527 upstream of the inline ICD. The HGL at this manhole is 85.11m which is higher than the catch basin invert of 83.9 meters. For this reason, a timeseries representing the head in the manhole over the storm period has been applied to the outfall representing MH 527 in the Block 14 PCSWMM model.

4.4.3 Hydrological Modelling Parameters

The following parameters were used in the hydrologic component of PCSWMM:

- **Areas and Imperviousness:** Catchment ID and drainage areas used by PCSWMM match those shown on either Drawing DST or Figure E-1 (Appendix E1).
- **Catchment Width:** The catchment width is estimated at the width of overland sheet flow based on the grading of the catchment and slope direction.
- **Manning's Roughness Coefficient:** Manning's Roughness Coefficients of 0.013 and 0.25 were used for the impervious and pervious surfaces, respectively.

Site Servicing Report

2983 Navan Road

- **Horton Infiltration parameters:** City of Ottawa OSDG Horton Infiltration Parameters have been used in the modelling.
- **Initial Abstraction:** Initial abstraction of 4.67 mm and 1.57 mm was used for the pervious and impervious surfaces respectively, consistent with the OSDG.

4.4.4 Simulation of Storm Distributions

To assess peak flow rates and peak volume storage requirements the 3-hour Chicago storm has been simulated for the site for the 1:2-year event and 1:100-year event and the 24-hour SCS storms for the 1:100-year event.

4.5 Simulation Results

4.5.1 Low Point Ponding Analysis

Ponding depths in the low points in the parking area and landscaped areas are shown in Table 6.

Table 6: Catchbasin Ponding Depths

Low Point ID	Top of Grate (m)	Maximum Static Depth (mm)	3-hour Chicago 1:2 year Depth (mm)	3-hour Chicago 1:100 year Depth (mm)	24-hour SCS 1:100 year Depth (mm)
1	85.70	150	20*	40	30
2	85.50	150	20*	40	30
3	85.60	300	0	130	130
4	85.65	300	0	80	80
5	85.05	250	0	230	210
6	85.70	150	20*	30	20

Those values marked with * are greater than 0 mm in the 2-year event due to the model setup. In order to represent the Zurn inlet control device, the orifice has been set at the top of grate elevation as the control is at the surface. Therefore, the model requires a head buildup over the structure for simulation of flows.

The simulation results compiled in Table 6 shows that:

- No ponding nor dynamic flow will occur in the 1:2-year event;
- Maximum ponding depth of 230 mm during the 1:100-year event; and,
- There is no spill from the site in the 1:100-year event.

Site Servicing Report

2983 Navan Road

4.5.2 Roof Drainage

The roof drainage system is to be designed by the Mechanical Engineer to achieve a flow rate of 2L/s from each roof structure. The maximum depth of ponding required, assuming storage across 60% of the rooftop area, is 90 mm.

4.5.3 Parking Lot Drainage

The parking lot drainage system connects to the building cistern and is controlled by the ZURN_Z150F-6NH (detail provided in Appendix D) to allow the 1:2-year event to drain and for the surface to provide storage during greater events up to the 1:100 year. Capture rates are shown in Table 7.

Table 7: Parking Area ICD Capture Analysis

Low Point	Control Structure	1:2 year Rational Flow (l/s)	1:100 year 3-hour Chicago Flow (l/s)	1:100 year 3-hour Chicago Head (m)
1	ZURN_Z150F-6NH	9	24	0.04
2		11	30	0.04
6		7	19	0.03

The table shows that the parking lot control structures capture the 1:2-year design flow.

4.5.4 Landscaped Drainage

The landscaped drainage consists of two outlets into the subdivision minor system. The drainage system represents a typical rear yard system of swales and perforated pipes. At one downstream end the MHF_IPEX_TYPE_B ICD provides flow control to 38 L/s and discharges into the pipe downstream of MH 526 in the 1:100-year event with a head of 2.19 m. The release rare meets the 1:2-year rational method 1:2-year design flow of 14 L/s for the combined upstream catchments.

At the second outlet, the Vortex ICD 70 provides flow control to 6 L/s into MH 527 in the 1:100-year event with a head of 1.83 m. The release rare meets the 1:2-year rational flow of 6 L/s for the upstream catchments.

Low Point	Control Structure	1:2 year Rational Flow (l/s)	1:100 year 3-hour Chicago Flow (l/s)	1:100 year 3-hour Chicago Head (m)
3	NO ICD	4		1.53
4	Vortex ICD 70	2	6	1.83
5	MHF_IPEX_TYPE_B	14	38	2.19
	Total:	20	44	-

The table shows that the landscaped control structures capture the 1:2-year design flow.

Site Servicing Report

2983 Navan Road

4.5.5 Building Release Rates

To maintain overall release rate from the site at the allowable flow rate of 58 L/s, the building drainage system must be controlled to 10 L/s. Based on a pumped rate of 10 L/s a cistern size of 64 m³ is required in the building basement.

4.6 Summary and Conclusions

The stormwater servicing achieves a release rate from the site to the minor system limited to the allowable release rate and contains up to the 1:100 year on site.

Site Servicing Report

2983 Navan Road

5.0 Erosion and Sedimentation Control

Erosion and sediment control measures, as outlined in the Ontario Ministry of Natural Resources (MNR) Guidelines on Erosion and Sediment Control for Urban Construction Sites, will be implemented to trap sediment on site. The following erosion and sediment control measures can be implemented during construction as shown on the Erosion and Sediment Control Plan (Drawing ESC):

- Supply and installation of a silt fence barrier, as per OPSD 219.110.
- Supply and installation of siltsack or sentinel CB inserts between the frame and cover of catch basins and maintenance holes adjacent to the project area during construction, to prevent sediment from entering the sewer system.
- Stockpiling of material during construction is to be located along flat areas away from drainage paths. For material placed on sloped areas, stockpiles are to be enclosed with a silt fence to protect watercourses.
- All catch basins are to be equipped with sumps, inspected frequently, and cleaned as required.
- Temporary ICD to be placed blocking part of the sanitary sewer pipe in the connecting maintenance holes to eliminate construction debris from entering the existing sanitary sewer system. The ICDs are to be removed after the proposed sanitary sewers have been fully cleaned.

The proposed removal and reinstatement measures as well as the erosion control measures shall conform to the following documents:

- "Guidelines on Erosion and Sediment Control for Urban Construction Sites" published by Ontario Ministries of Natural Resources, Environment, Municipal Affairs, and Transportation & Communication, Association of Construction Authorities of Ontario and Urban Development Institute, Ontario, May 1987.
- "MTO Drainage Manual", Chapter F: "Erosion of Materials and Sediment Control", Ministry of Transportation & Communications, 1985.
- "Erosion and Sediment Control" Training Manual by Ministry of Environment, Spring 1998.
- Applicable Regulations and Guidelines of the Ministry of Natural Resources.

Site Servicing Report

2983 Navan Road

This report has been prepared by J.L. Richards & Associates Limited for 12714001 CANADA INC.'s exclusive use. Its discussions and conclusions are summary in nature and cannot properly be used, interpreted or extended to other purposes without a detailed understanding and discussions with the client as to its mandated purpose, scope and limitations. This report is based on information, drawings, data, or reports provided by the named client, its agents, and certain other suppliers or third parties, as applicable, and relies upon the accuracy and completeness of such information. Any inaccuracy or omissions in information provided, or changes to applications, designs, or materials may have a significant impact on the accuracy, reliability, findings, or conclusions of this report.

This report was prepared for the sole benefit and use of the named client and may not be used or relied on by any other party without the express written consent of J.L. Richards & Associates Limited, and anyone intending to rely upon this report is advised to contact J.L. Richards & Associates Limited in order to obtain permission and to ensure that the report is suitable for their purpose.

J.L. RICHARDS & ASSOCIATES LIMITED

Water and Wastewater
Prepared by:



Mahad Musse, EIT
Engineering Graduate

Stormwater
Prepared by:



Mathieu Lacelle, EIT
Engineering Graduate

Reviewed by:



Karla Ferrey, P.Eng.,
Senior Associate, Manager, Ottawa, Civil
Development, Senior Civil Engineer

Reviewed by:



Bobby Pettigrew, P. Eng.,
Associate, Senior Water Resources Engineer,
Water Resources Practice Lead

Site Servicing Report

2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario

Appendix A

Concept Plan, Draft Plan of
Subdivision and Topographical
Survey

NAVAN ROAD
DEVELOPMENT2983, Navan Road, Orleans,
ON K1C 7G4

OWNER

ARCHITECTURAL

(416) 651-8954
INFO@PMAARCHITECTES.COM
3070, CHEMIN DES QUATRE-BOURGEOIS
QUEBEC (QC) G1W 2K4
PMAARCHITECTES.COM

53 BOUL. SAINT-JOSEPH, SUITE 100,
GATINEAU, QC J8Y 1R8

ENGINEERS / PLANNER



ENGINEERS-ARCHITECTS-PLANNERS

1565 CARLING AVENUE, SUITE 700,
OTTAWA, ON K1Z 8R1

SURVEYOR

1331 CLYDE AVENUE, SUITE 400,
OTTAWA, ON K2C 3G4

KEY PLAN

ARCHITECT SEAL

REVISIONS

11 FOR CITY REVIEW 2024-07-17

10 FOR CITY REVIEW 2024-09-25

9 FOR COORDINATION 2024-07-17

8 FOR COORDINATION 2024-11-28

7 FOR COORDINATION 2022-11-01

6 FOR COORDINATION 2022-11-01

5 FOR COORDINATION 2023-06-14

4 FOR COORDINATION 2023-06-14

3 FOR COORDINATION 2023-08-30

2 FOR COORDINATION 2023-08-30

1 FOR COORDINATION 2023-08-18

NO DESCRIPTION DATE

NOTE

IT IS THE RESPONSIBILITY OF THE APPROPRIATE

CONTRACTOR TO CHECK AND VERIFY ALL DIMENSIONS

ON THE SITE AND TO REPORT ALL ERRORS AND/OR

OMISSIONS TO THE ARCHITECT. ALL CONTRACTORS

MADE IN THIS DRAWING ARE THE RESPONSIBILITY OF

THE CONTRACTOR.

DO NOT SCALE DRAWINGS

THIS DOCUMENT AND ITS CONTENT IS COPYRIGHTED.

ANY REPRODUCTION IS PROHIBITED UNLESS GRANTED

BY THE ARCHITECT.

DO NOT USE FOR

CONSTRUCTION

DATE 2024-07-17

DESIGNED P.POMERLEAU

DRAWN P.POMERLEAU

PROJECT No 20054

CHECKED P.MARTIN

SHEET TITLE

GLOBAL SITE PLAN

SHEET No


A100

LOTS AREAS			
LOT NUMBER	AREAS (M2)	LOT NUMBER	AREAS (M2)
B01-1	394	B06-4	154
B01-2	184	B06-5	163
B01-3	184	B06-6	154
B01-4	189	B06-7	369
B01-5	189	B07	2,002
B01-6	184	B08-1	525
B01-7	184	B08-2	174
B01-8	299	B08-3	184
B02-1	281	B08-4	174
B02-2	176	B08-5	184
B02-3	184	B08-6	174
B02-4	184	B08-7	234
B02-5	174	B09-1	234
B02-6	233	B09-2	174
B03-1	250	B09-3	184
B03-2	182	B09-4	184
B03-3	182	B09-5	174
B03-4	182	B09-6	234
B03-5	182	B10-1	234
B03-6	182	B10-2	174
B03-7	250	B10-3	184
B04-1	233	B10-4	184
B04-2	174	B10-5	174
B04-3	184	B10-6	487
B04-4	174	B11-1	748
B04-5	184	B11-2	286
B04-6	174	B11-3	265
B04-7	278	B11-4	246
B05-1	368	B11-5	242
B05-2	154	B11-6	242
B05-3	163	B11-7	321
B05-4	163	B12	240
B05-5	154	B13	1,232
B05-6	206	B14	5,728
B06-1	206	B16	7,811
B06-2	154	B17	5,312
B06-3	163		

SITE PLAN LEGEND	
EXISTING BUILDING	LOT LINE
NEW BUILDING	SETBACKS
NEW BUILDING WITH COMMERCIAL SPACE AT-GRADE	NEW TREE
GRASS	FIREWALL
ASPHALT	SIDEWALK

SITE INFORMATION & DEVELOPMENT STATISTICS	
LOTS	PIN
	04756 - 0303
	04756 - 0315
	04756 - 0316
	04756 - 1337
ZONING	GM[2546] H[14.5]
SITE AREA	
TOTAL SITE AREA:	~53,441.14 m ² (5.34ha)
TOTAL DEVELOPABLE AREA:	~45,956.28 m ² (4.59ha)
NET SITE AREA:	~38,956.28 m ² (3.89ha)
UNITS	
TOWNHOUSES:	67 UNITS
BLOCK 01:	
1 X RESIDENTIAL APARTMENT BUILDING	48 UNITS
1 X MIXED USE BUILDING	
RESIDENTIAL:	36 UNITS
COMMERCIAL SPACES:	~899 m ²
BLOCK 02:	
1 X RESIDENTIAL APARTMENT BUILDING	47 UNITS
1 X MIXED USE BUILDING	
RESIDENTIAL:	36 UNITS
COMMERCIAL SPACES:	~899 m ²
BLOCK 03:	
2 X RESIDENTIAL APARTMENT BUILDING	96 UNITS
TOTAL NUMBER OF UNITS:	330 UNITS
TOTAL COMMERCIAL SPACES:	~1,798 m ²
REQUIRED	PROVIDED
MAXIMUM DENSITY	NO MAX. 84.8 units/net ha
MINIMUM LOT WIDTH	NO MIN. 5.8 m
MINIMUM LOT AREA	NO MIN. 174 m ²
MAXIMUM BUILDING HEIGHT	14.5 m 14.5 m
SETBACKS	
MINIMUM FRONT YARD:	3 m 3 m
MINIMUM CORNER SIDE YARD:	3 m 3 m
MINIMUM INTERIOR SIDE YARD:	
NON-RESIDENTIAL OR MIXED-USE:	5 m 5 m
LOW-RISE RESIDENTIAL :	1.2 m 1.2 m
MID-RISE RESIDENTIAL :	3 m 3 m
MINIMUM REAR YARD:	
ABUTTING A STREET:	3 m 3 m
FROM A RESIDENTIAL ZONE:	7.5 m 7.5 m
FOR A RESIDENTIAL BUILDING:	7.5 m 7.5 m
PARKING RATES	
R9 - TOWNHOUSES:	1 p/unit = 67 67 (GARAGES)
VISITOR:	0 67 DRIVE AISLES
BLOCK 14:	
R12 - APPARTEMENTS	1.0 p/unit = 84 84 (UNDERGROUND)
VISITOR:	0.2 p/unit = 17 18 (UNDERGROUND)
N79 - RETAIL STORE:	3.4 p/100 m ² GFA = 30.6 32 (EXTERIOR)
TOTAL:	134
BLOCK 15:	
R12 - APPARTEMENTS	1.0 p/unit = 83 83 (UNDERGROUND)
VISITOR:	0.2 p/unit = 16.6 16 (UNDERGROUND)
N79 - RETAIL STORE:	3.4 p/100 m ² GFA = 30.6 32 (EXTERIOR)
TOTAL:	131
BLOCK 17:	
R12 - APPARTEMENTS	1.0 p/unit = 96 96 (UNDERGROUND)
VISITOR:	0.2 p/unit = 19.2 19 (15 EXT. + 4 UND.)
TOTAL:	115
GROSS FLOOR AREA	
TOWNHOUSE A:	267 m ²
TOWNHOUSE B:	239 m ²
TOWNHOUSE C:	232 m ²
TOWNHOUSE C (CORNER UNIT):	236 m ²
TOWNHOUSE D:	225 m ²
TOTAL MODEL 01 (ABBBBBBA)	1,968 m ²
TOTAL MODEL 02 (ABBBBBBA)	1,729 m ²
TOTAL MODEL 03 (ABBBBA)	1,490 m ²
TOTAL MODEL 04 (CCCCDC)	1,611 m ²
TOTAL MODEL 05 (CCCCDC)	1,386 m ²
MIXED USE BUILDING (TOTAL OF 2 BUILDINGS):	TOTAL: 3,926 m ²
RESIDENTIAL:	3,027 m ²
COMMERCIAL:	899 m ²
RESIDENTIAL APARTMENT BUILDING (TOTAL OF 4 BUILDINGS):	TOTAL: 3,927 m ²
RESIDENTIAL:	3,927 m ²
NOTE	
1. ASSUMES TYPICAL RESIDENTIAL FLOOR HEIGHT OF 3m.	
2. THE BASE PLAN (LOT LINES, EXISTING ROADS AND SURROUNDING AREAS) IS BASED ON THE TOPOGRAPHICAL PLAN OF SURVEY, SURVEYED STANTEC GEOMATICS LTD.	
3. DISTANCES SHOWN ON THIS PLAN ARE IN METRES AND CAN BE CONVERTED TO FEET BY DIVIDING BY 0,3048.	





NAVAN ROAD DEVELOPMENT

2983, Navan Road, Orleans
ON K1C 7G4



GROUP

ARCHITECTURA



651-8954
@PMAARCHITECTES.COM
, CHEMIN DES QUATRE-BOURGEOIS
BEC (QC) G1W 2K4
ARCHITECTES.COM


L'Atelier
architectes

Digitized by srujanika@gmail.com



J.L.Richards
ENGINEERS · ARCHITECTS · PLANNERS

6 CARLING AVENUE, SUITE 700,
OTTAWA, ON K1Z 8R1



JRDWARA ROAD, UNIT 200,
AWA, ON K2E 7X6

For more information about the study, please contact Dr. [REDACTED] at [REDACTED].



CLYDE AVENUE, SUITE 400,
AWA, ON K2C 3G4

REVISION	
DESCRIPTION	DATE
FOR CITY REVIEW	2024-07-17
FOR CITY REVIEW	2024-03-04
FOR CITY REVIEW	2023-12-14


NOT
THE RESPONSIBILITY OF THE APPROPRIATE
CTOR TO CHECK AND VERIFY ALL DIMENSION
ITE AND TO REPORT ALL ERRORS AND/OR
NS TO THE ARCHITECT. ALL CONTRACTORS
MPLY WITH ALL PERTINENT CODES AND BY-
DO NOT SCALE DRAWINGS.

UMENT AND ITS CONTENT IS COPYRIGHTED.
RODUCTION IS PROHIBITED UNLESS GRANTE
RCHITECT.

DO NOT USE FOR

DATE	DESIGNEE
2024-07-17	P.POMERLEAU
DRAWN BY	
	P.POMERLEAU
PROJECT No	CHECKED
20054	P.MARTIN

For more information about the study, please contact Dr. John Smith at (555) 123-4567 or via email at john.smith@researchinstitute.org.



Site Servicing Report

2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario

Appendix B

Pre Consultation Meeting
Notes and Site Servicing Report
Checklist



File No.: PC2023-0226

Carmine Zayoun
12714001 Canada Inc (Zayoun Group)
Via email: carmine@zayoungroup.com

Subject: Pre-Consultation: Meeting Feedback
Proposed Site Plan Application – 2983 Navan Road
Four residential and two mixed-use buildings – PC2023-0226

Please find below information regarding next steps as well as consolidated comments from the above-noted pre-consultation meeting held on September 13, 2023.

Pre-Consultation Preliminary Assessment

1 <input type="checkbox"/>	2 <input type="checkbox"/>	3 <input type="checkbox"/>	4 <input checked="" type="checkbox"/>	5 <input type="checkbox"/>
----------------------------	----------------------------	----------------------------	---------------------------------------	----------------------------

One (1) indicates that considerable major revisions are required while five (5) suggests that the proposal appears to meet the City's key land use policies and guidelines. This assessment is purely advisory and does not consider technical aspects of the proposal or in any way guarantee application approval.

Next Steps

1. A review of the proposal and materials submitted for the above-noted pre-consultation has been undertaken. Please proceed to complete a Phase 2 / Phase 3 Pre-consultation Application Form and submit it together with the necessary studies and/or plans to planningcirculations@ottawa.ca.
2. In your subsequent pre-consultation submission, please ensure that all comments or issues detailed herein are addressed. A detailed cover letter stating how each issue has been addressed must be included with the submission materials. Please coordinate the numbering of your responses within the cover letter with the comment number(s) herein.
3. Please note, if your development proposal changes significantly in scope, design, or density before the Phase 3 pre-consultation, you may be required to complete or repeat the Phase 2 pre-consultation process.

Supporting Information and Material Requirements

1. The attached **Study and Plan Identification List** outlines the information and material that has been identified, during this phase of pre-consultation, as either required (R) or advised (A) as part of a future complete application submission.
 - a. The required plans and studies must meet the City's Terms of Reference (ToR) and/or Guidelines, as available on Ottawa.ca. These ToR and Guidelines outline



the specific requirements that must be met for each plan or study to be deemed adequate.

Consultation with Technical Agencies

1. You are encouraged to consult with technical agencies early in the development process and throughout the development of your project concept. A list of technical agencies and their contact information is enclosed.

Planning

Comments:

1. In the Official Plan the subject site is designated as Neighbourhood is modified with the Evolving Neighbourhood overlay. Brian Coburn Boulevard is also designated as a Minor Corridor. The property is further identified as Low-density residential in the EUC – Phases 1 Community Design Plans (CDP). The subject lands are currently zoned GM[2546]H(14.5) General Mixed-Use, Exception and DR Development Reserve.
2. Committee of Adjustment

No variances have been identified at this point. I would be supportive of reducing the parking requirement for the residential units if it will result in addition landscaping and tree cover. Staff will set up a meeting with a Committee of Adjustment Plan if any required.

3. Design guidelines

The following guidelines are meant as a starting place to help guide the design. I realize that they are specifically related to your project. [Urban Design Guidelines for Low-rise Infill Housing](#)

4. Landscape requirements

All required yards are to be landscaped with parking located between the buildings. Green spaces and tree canopy needs to be maximized.

5. Parking requirements

Parking should comply with Sections 100, 101, 106, 109 and 111

Vehicle and bicycle parking should be situated with easily access while minimizing pavement.

6. Easements

Will there be any easements required?



7. Commercial units should be orientated to the streets as much as possible.
8. Provide locations of signage and ensure that space is made available for tree planting

Urban Design

9. This proposal does not run along or does not meet the threshold in one of the City's Design Priority Areas and need not attend the City's UDRP. Staff will be responsible for evaluating the Urban Design Brief and providing design direction.
10. An Urban Design Brief is a required submittal Re-zoning applications. The Urban Design Brief should be structured by generally following the headings highlighted under Section 3 – Contents of these Terms of Reference. Please see the Urban Design Brief Terms of Reference provided.
11. We recommend further detail be provided about the low-rise apartments to better understand their relationship to the surrounding buildings and properties.
12. If this site is located outside the greenbelt, a shadow analysis will be required.
13. We recommend the low-rise buildings fronting City streets consider grade related units accessed from the street to further 'fit-in' with the surrounding low-rise residential community where feasible.
14. We recommend additional landscaping detail be provided around the low-rise apartments to better understand how the buildings relate to their context.
15. We recommend additional detail be provided of the front yards of the townhouse units facing City streets to better understand how they will integrate with the public realm.
16. We recommend tree planting in front yards facing public right-of-way.
17. When a wind and/or shadow studies are required please refer to the Terms of Reference for the wind analysis and shadow analysis to conduct the studies and evaluate the impacts.
18. Note. The Urban Design Brief submittal should have a section which addresses these pre-consultation comments.



This is an exciting project in an area full of potential. We look forward to helping you achieve its goals with the highest level of design resolution. We are happy to assist and answer any questions regarding the above. Feel free to contact the Urban Design Planner, Christopher Moise, at Christopher.Moise@ottawa.ca, for follow-up questions.

Engineering

Comments:

19. The Stormwater Management Criteria, for the subject site, is to be based on the following:

- a. The 5-yr storm event using the IDF information derived from the Meteorological Services of Canada rainfall data, taken from the MacDonald Cartier Airport, collected 1966 to 1997.
- b. For separated sewer system built pre-1970 the design of the storm sewers are based on a 2 year storm.
- c. The pre-development runoff coefficient or a maximum equivalent 'C' of 0.5, whichever is less (§ 8.3.7.3).
- d. A calculated time of concentration (Cannot be less than 10 minutes).
- e. Flows to the storm sewer in excess of the 5-year storm release rate, up to and including the 100-year storm event, must be detained on site.
- f. For a combined sewer system the maximum C= 0.4 or the pre-development C value, whichever is less. In the absence of other information the allowable release rate shall be based on a 2 year storm event.

20. Deep Services (Storm, Sanitary & Water Supply)

- a. Provide existing servicing information and the recommended location for the proposed connections. Services should ideally be grouped in a common trench to minimize the number of road cuts.
- b. Connections to trunk sewers and easement sewers are typically not permitted.
- c. Provide information on the monitoring manhole requirements – should be located in an accessible location on private property near the property line (ie. Not in a parking area).
- d. Review provision of a high-level sewer.

- e. Sewer connections to be made above the springline of the sewermain as per:
 - i. Std Dwg S11.1 for flexible main sewers – connections made using approved tee or wye fittings.
 - ii. Std Dwg S11 (For rigid main sewers) – lateral must be less than 50% the diameter of the sewermain,
 - iii. Std Dwg S11.2 (for rigid main sewers using bell end insert method) – for larger diameter laterals where manufactured inserts are not available; lateral must be less than 50% the diameter of the sewermain,
 - iv. Connections to manholes permitted when the connection is to rigid main sewers where the lateral exceeds 50% the diameter of the sewermain. – Connect obvert to obvert with the outlet pipe unless pipes are a similar size.
 - v. No submerged outlet connections.

~~21. Water Boundary condition requests must include the location of the service (map or plan with connection location(s) indicated) and the expected loads required by the proposed development, including calculations. Please provide the following information:~~

~~no BCR will be requested for res site~~

~~plans, no watermains built, navan connection already provided as part of subdivision~~

- a. Location of service
- b. Type of development and the amount of fire flow required (as per FUS).
- c. Average daily demand: ____ l/s.
- d. Maximum daily demand: ____ l/s.
- e. Maximum hourly daily demand: ____ l/s.

22. An MECP Environmental Compliance Approval [Industrial Sewage Works or Municipal/Private Sewage Works] will be required for the proposed development. Please contact the Ministry of the Environment, Conservation and Parks, Ottawa District Office to arrange a pre-submission consultation:

- a. Charlie Primeau at (613) 521-3450, ext. 251 or Charlie.Primeau@ontario.ca
- b. Emily Diamond at (613) 521-3450, ext. 238 or Emily.Diamond@ontario.ca

General Comments:

23. Review of the Phase 3 submission for this application will not occur until the detailed design of the subdivision that it is within (D07-16-21-0027) is approved.
24. At the stage of site plan approval, a condition will be imposed detailing that a commencement work notification will not be issued until the subdivision's infrastructure is in-service.

25. Engineering Studies:

26. All engineering studies (detailed in the Study and Plan Identification List form) are to follow the to be approved draft plan of subdivision D07-16-21-0027

Feel free to contact Derek Unrau, Infrastructure Project Manager, for follow-up questions.

Noise

Comments:

27. Noise report is required to identify and mitigate traffic noise from Brian Coburn Boulevard and Navan Road

Feel free to contact the Senior Transportation Engineer, Mike Giampa, at Mike.Giampa@ottawa.ca , for follow-up questions.

Transportation

Comments:

- a. A full TIA is not required as this site is covered under the recent subdivision TIA.
- b. A memo including the pertinent subdivision trips is sufficient.
- c. The right of way protection on Brian Coburn and Navan Roads is 40m and 37.5m, respectively

Feel free to contact the Senior Transportation Engineer, Mike Giampa, at Mike.Giampa@ottawa.ca , for follow-up questions.

Planning Forestry

Comments:



28. A Tree Conservation Report and Landscape Plan must be submitted with both SPC applications
29. A permit is required prior to any tree removal on site. The tree permit will be released upon site plan approval. Please contact the File Lead or the Planning Forester, Hayley Murray (hayley.murray@ottawa.ca) for information on obtaining the tree permit.
30. If marine clay soils are present, setbacks on City properties must adhere to the 2017 SMC guidelines (attached). The Geotechnical report must address the implications of these soils, if present, on tree planting in relation to private land.
31. If underground parking is planned, a design must be provided for the site to support tree planting
32. We expect a very strong landscape plan to re-establish canopy cover across the properties. Tree planting and protecting existing urban forest canopy is imperative to reach the City's target of 40% canopy cover.

Feel free to contact Hayley Murray, Planning Forester, for follow-up questions.

Parkland

Comments:

33. Parkland contributions were made through the Subdivision process.

Feel free to contact Jessica Button, Parks Planner, for follow-up questions

Conservation Authority

Comments:

34. The Rideau Valley Conservation authority will be commenting on this application

Feel free to contact RVCA, for follow-up questions.

Other

35. The High Performance Development Standard (HPDS) is a collection of voluntary and required standards that raise the performance of new building projects to achieve sustainable and resilient design. The HPDS was passed by Council on April 13, 2022.



- a. At this time, the HPDS is not in effect and Council has referred the 2023 HPDS Update Report back to staff with direction to bring forward an updated report to Committee with recommendations for revised phasing timelines, resource requirements and associated amendments to the Site Plan Control By-law by no later than Q1 2024.
- b. Please refer to the HPDS information attached and ottawa.ca/HPDS for more information.

Submission Requirements and Fees

1. Outlines the application type/subtype required and the associated fees
 - a. Additional information regarding fees related to planning applications can be found [here](#).
2. The attached **Study and Plan Identification List** outlines the information and material that has been identified as either required (R) or advised (A) as part of a future complete application submission.
 - a. The required plans and studies must meet the City's Terms of Reference (ToR) and/or Guidelines, as available on [Ottawa.ca](#). These ToR and Guidelines outline the specific requirements that must be met for each plan or study to be deemed adequate.
3. All of the above comments or issues should be addressed to ensure the effectiveness of the application submission review.

Should there be any questions, please do not hesitate to contact myself or the contact identified for the above areas / disciplines.

Yours Truly,
Steve Belan

cc.

Tim Chadder
Raad Akrawi
Madelen Fellows
Karla Ferrey
Tatyana Roumie
Christopher Moise
Derek Unrau
Mike Giampa
Haley Murray
Jessica Button

12714001 Canada Inc – Mixed Use Site Plan (Block 14)
2983, 3053 and 3079 Navan Road & 2690 Pagé Road
SITE SERVICING REPORT CHECKLIST

REFERENCED STUDIES AND REPORTS	REFERENCE
Site Servicing Report for 12714001 Canada Inc, Mixed Used Site Plan (Block 14) 2983, 3053 and 3079 Navan Road & 2690 Pagé Road (J.L. Richards & Associates Limited, December 8, 2023)	Site Servicing Report

4.1	GENERAL CONTENT	REFERENCE
<input type="checkbox"/>	Executive Summary (for larger reports only).	N/A
<input checked="" type="checkbox"/>	Date and revision number of the report.	Site Servicing Report
<input checked="" type="checkbox"/>	Location map and plan showing municipal address, boundary, and layout of proposed development.	Site Servicing Report (Appendix A) All Drawings
<input checked="" type="checkbox"/>	Plan showing the site and location of all existing services.	Servicing Plan
<input checked="" type="checkbox"/>	Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.	Site Servicing Report
<input checked="" type="checkbox"/>	Summary of Pre-consultation Meetings with City and other approval agencies.	Site Servicing Report (Appendix 'A')
<input checked="" type="checkbox"/>	Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defendable design criteria.	Reference made to Stantec 2005 EUC ISSU
<input checked="" type="checkbox"/>	Statement of objectives and servicing criteria.	Site Servicing Report
<input checked="" type="checkbox"/>	Identification of existing and proposed infrastructure available in the immediate area.	Site Servicing Report Servicing Plan
<input type="checkbox"/>	Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).	N/A

<input checked="" type="checkbox"/>	Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighbouring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths.	Grading Plan
<input type="checkbox"/>	Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.	N/A
<input type="checkbox"/>	Proposed phasing of the development, if applicable.	N/A
<input checked="" type="checkbox"/>	Reference to geotechnical studies and recommendations concerning servicing.	Site Servicing Report and Drawings
<input checked="" type="checkbox"/>	All preliminary and formal site plan submissions should have the following information: <ul style="list-style-type: none"> ▪ Metric scale ▪ North arrow (including construction North) ▪ Key plan ▪ Name and contact information of applicant and property owner ▪ Property limits, including bearings and dimensions ▪ Existing and proposed structures and parking areas ▪ Easements, road widening and rights-of-way ▪ Adjacent street names 	All Drawings

4.2	SITE SERVICING REPORT: WATER	REFERENCE
<input type="checkbox"/>	Confirm consistency with Master Servicing Study, if available.	N/A
<input checked="" type="checkbox"/>	Availability of public infrastructure to service proposed development.	Site Servicing Report (Section 2.0) Servicing Plan
<input checked="" type="checkbox"/>	Identification of system constraints.	Site Servicing Report (Section 2.0) Servicing Plan
<input checked="" type="checkbox"/>	Identify boundary conditions.	Site Servicing Report (Section 2.0)
<input checked="" type="checkbox"/>	Confirmation of adequate domestic supply and pressure.	Site Servicing Report (Section 2.0)
<input checked="" type="checkbox"/>	Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.	Site Servicing Report (Section 2.0)
<input checked="" type="checkbox"/>	Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.	Site Servicing Report (Section 2.0)

<input type="checkbox"/>	Definition of phasing constraints. Hydraulic modelling is required to confirm servicing for all defined phases of the project, including the ultimate design.	N/A
<input checked="" type="checkbox"/>	Address reliability requirements, such as appropriate location of shutoff valves.	Site Servicing Report (Section 2.0)
<input type="checkbox"/>	Check on the necessity of a pressure zone boundary modification.	N/A
<input checked="" type="checkbox"/>	Reference to water supply analysis to show that major infrastructure can deliver sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range.	Site Servicing Report (Section 2.0)
<input checked="" type="checkbox"/>	Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants), including special metering provisions.	Site Servicing Report (Section 2.0) Servicing Plan
<input type="checkbox"/>	Description of off-site required feedermains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.	N/A
<input checked="" type="checkbox"/>	Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.	Site Servicing Report (Section 2.0)
<input checked="" type="checkbox"/>	Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.	Site Servicing Report (Section 2.0)

4.3	SITE SERVICING REPORT: WASTEWATER	REFERENCE
<input checked="" type="checkbox"/>	Summary of proposed design criteria (Note: Wet weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).	Site Servicing Report (Section 3.0),
<input type="checkbox"/>	Confirm consistency with Master Servicing Study and/or justifications for deviations.	Stantec 2005 EUC ISSU
<input type="checkbox"/>	Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the Guidelines. This includes groundwater and soil conditions, and age and condition of sewers.	N/A
<input checked="" type="checkbox"/>	Description of existing sanitary sewer available for discharge of wastewater from proposed development.	Site Servicing Report (Section 3.0) Servicing Plan

<input checked="" type="checkbox"/>	Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable.)	Site Servicing Report (Section 3.0)
<input checked="" type="checkbox"/>	Calculations related to dry weather and wet weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.	Site Servicing Report (Section 3.0)
<input checked="" type="checkbox"/>	Description of proposed sewer network, including sewers, pumping stations and forcemains.	Site Servicing Report (Section 3.0) Servicing Plan
<input type="checkbox"/>	Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).	N/A
<input type="checkbox"/>	Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.	N/A
<input type="checkbox"/>	Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.	N/A
<input type="checkbox"/>	Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.	N/A
<input type="checkbox"/>	Special considerations, such as contamination, corrosive environment, etc.	N/A

4.4	SITE SERVICING REPORT: STORMWATER	REFERENCE
<input checked="" type="checkbox"/>	Description of drainage outlets and downstream constraints, including legality of outlets (i.e., municipal drain, right-of-way, watercourse, or private property).	Site Servicing Report (Section 4.0)
<input checked="" type="checkbox"/>	Analysis of available capacity in existing public infrastructure.	Site Servicing Report (Section 4.0)
<input checked="" type="checkbox"/>	A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern.	Servicing, Grading and Drainage Plans
<input checked="" type="checkbox"/>	Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.	Site Servicing Report (Section 4.0)

<input checked="" type="checkbox"/>	Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.	Site Servicing Report (Section 4.0)
<input checked="" type="checkbox"/>	Description of the stormwater management concept with facility locations and descriptions with references and supporting information.	Site Servicing Report (Section 4.0) Servicing, Grading and Drainage Plans
<input type="checkbox"/>	Setback from private sewage disposal systems.	N/A
<input type="checkbox"/>	Watercourse and hazard lands setbacks.	N/A
<input checked="" type="checkbox"/>	Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.	Site Servicing Report (Appendix 'A')
<input type="checkbox"/>	Confirm consistency with subwatershed and Master Servicing Study, if applicable study exists.	Stantec 2005 EUC ISSU
<input checked="" type="checkbox"/>	Storage requirements (complete with calculations) and conveyance capacity for minor events (1:2 year return period) and major events (1:100 year return period).	Site Servicing Report (Section 4.0)
<input type="checkbox"/>	Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.	N/A
<input checked="" type="checkbox"/>	Calculate pre- and post-development peak flow rates, including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.	Site Servicing Report (Section 4.0)
<input checked="" type="checkbox"/>	Any proposed diversion of drainage catchment areas from one outlet to another.	Site Servicing Report (Section 4.0)
<input checked="" type="checkbox"/>	Proposed minor and major systems, including locations and sizes of stormwater trunk sewers, and stormwater management facilities.	Servicing, Grading and Drainage Plans
<input type="checkbox"/>	If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event.	Quantity control proposed per Site Servicing Report (Section 4.0)
<input type="checkbox"/>	Identification of potential impacts to receiving watercourses.	N/A
<input type="checkbox"/>	Identification of municipal drains and related approval requirements.	N/A
<input checked="" type="checkbox"/>	Description of how the conveyance and storage capacity will be achieved for the development.	Site Servicing Report (Section 4.0)

<input checked="" type="checkbox"/>	100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.	Site Servicing Report (Section 4.0) Servicing, Grading and Drainage Plans
<input checked="" type="checkbox"/>	Inclusion of hydraulic analysis, including hydraulic grade line elevations.	Site Servicing Report (Section 4.0)
<input checked="" type="checkbox"/>	Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.	Site Servicing Report (Section 5.0) Servicing Plan
<input type="checkbox"/>	Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.	N/A
<input type="checkbox"/>	Identification of fill constraints related to floodplain and geotechnical investigation.	N/A

4.5 APPROVAL AND PERMIT REQUIREMENTS		REFERENCE
The Site Servicing Report shall provide a list of applicable permits and regulatory approvals necessary for the proposed development, as well as the relevant issues affecting such approval. The approval and permitting shall include but not be limited to the following:		
<input type="checkbox"/>	Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams, as defined in the Act.	N/A
<input type="checkbox"/>	Application for Environmental Compliance Approval (ECA) under the Ontario Water Resources Act.	As part of future submission
<input type="checkbox"/>	Changes to Municipal Drains.	N/A
<input type="checkbox"/>	Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation, etc.).	N/A

4.6 CONCLUSION CHECKLIST		REFERENCE
<input checked="" type="checkbox"/>	Clearly stated conclusions and recommendations.	Site Servicing Report
<input checked="" type="checkbox"/>	Comments received from review agencies, including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.	Not yet applicable

<input checked="" type="checkbox"/>	All draft and final reports shall be signed and stamped by a Professional Engineer registered in Ontario.	Site Servicing Report All Drawings

Site Servicing Report
2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario

Appendix C

Water Servicing

WATERMAIN DEMAND CALCULATION SHEET

PROJECT : NAVAN ROAD DEVELOPMENT PROJECT
LOCATION : CITY OF OTTAWA
DEVELOPER : 12714001 Canada Inc.

NODE	RESIDENTIAL			NON-RESIDENTIAL			AVERAGE DAILY DEMAND (l/s)			MAXIMUM DAILY DEMAND (l/s)			PEAK HOUR DEMAND (l/s)		
	UNITS		POP'N	COMM		(ha.)	Res.	Non-res.	Total	Res.	Non-res.	Total	Res.	Non-res.	Total
	Townhouses (TH)	Condo Units (CU)		0.09	0.49		0.49	0.03	0.52	1.23	0.05	1.27	2.70	0.08	2.78
J-22	0	84	151												
TOTALS	0	84	151				0.09	0.49	0.52	1.23	0.05	1.27	2.70	0.08	2.78

ASSUMPTIONS					
RESIDENTIAL DENSITIES		AVG. DAILY DEMAND		MAX. HOURLY DEMAND	
- Townhouse (TH)	<u>2.7</u> p / p / u	- Residential	<u>280</u> l / cap / day	- Residential	<u>1,540</u> l / cap / day
- Condo Units (CU)	<u>1.8</u> p / p / u	- Institutional	<u>28,000</u> l / ha / day	- Institutional	<u>75,600</u> l / ha / day
p / p / u		- Commercial	<u>28,000</u> l / ha / day	- Commercial	<u>75,600</u> l / ha / day
		MAX. DAILY DEMAND			
		- Residential	<u>700</u> l / cap / day		
		- Institutional	<u>42,000</u> l / ha / day		
		- Commercial	<u>42,000</u> l / ha / day		

FUS Fire Flow Calculations

NAVAN ROAD DEVELOPMENT PROJECT - Commercial Building
(JLR 29899-002)

Step	Parameter	Value	Note
A	Type of Construction	Wood Frame	Building A (4 Story Mixed Use Condominium Building)
	Coefficient (C)	1.5	
B	Ground Floor Area	929	m ²
C	Height in storeys	4	storeys
	Total Floor Area	3716	m ²
D	Fire Flow Formula	$F=220C\sqrt{A}$	
	Fire Flow	20116	L/min
	Rounded Fire Flow	20000	L/min
			Flow rounded to nearest 1000 L/min.
E	Occupancy Class	Limited Combustible	Residential buildings have a limited combustible occupancy.
	Occupancy Charge	-15%	
	Occupancy Increase or Decrease	-3000	
	Fire Flow	17000	L/min
F	Sprinkler Protection	Automatic Fully Supervised	
	Sprinkler Credit	-50%	
	Decrease for Sprinkler	-8500	L/min
G	North Side Exposure		
	Exposing Wall:	Wood Frame	Building A
	Exposed Wall:	Wood Frame	Townhomes
	Length of Exposed Wall:	15.1	m
	Height of Exposed Wall:	2	storeys
	Length-Height Factor	30.1	m-storeys
	Separation Distance	10.41	m
	North Side Exposure Charge	12%	
	East Side Exposure		
	Exposing Wall:	Wood Frame	Building A
	Exposed Wall:	Wood Frame	Townhomes
	Length of Exposed Wall:	14.4	m
	Height of Exposed Wall:	0	storeys
	Length-Height Factor	0.0	m-storeys
	Separation Distance	25.84	m
	East Side Exposure Charge	8%	
	South Side Exposure		
	Exposing Wall:	Wood Frame	Building A
	Exposed Wall:	Wood Frame	Building B
	Length of Exposed Wall:	39.2	m
	Height of Exposed Wall:	4	storeys
	Length-Height Factor	156.8	m-storeys
	Separation Distance	25.25	m
	South Side Exposure Charge	10%	
	West Side Exposure		
	Exposing Wall:	Wood Frame	
	Exposed Wall:	Wood Frame	
	Length of Exposed Wall:	0.0	m
	Height of Exposed Wall:	0	storeys
	Length-Height Factor	0.0	m-storeys
	Separation Distance	50	m
	West Side Exposure Charge	0%	
	Total Exposure Charge	30%	The total exposure charge is below the maximum value of 75%.
	Increase for Exposures	5100	L/min
H	Fire Flow	13600	L/min
	Rounded Fire Flow	14000	L/min
			Flow rounded to nearest 1000 L/min.
City Cap	Required Fire Flow (RFF)	14000	L/min
		233	L/s

Fire Underwriters Survey (FUS) Fire Flow Calculations
In accordance with City of Ottawa Technical Bulletin ISTB-2018-02 dated March 21, 2018

FUS Fire Flow Calculations

NAVAN ROAD DEVELOPMENT PROJECT - Commercial Building
(JLR 29899-002)

Step	Parameter	Value	Note
A	Type of Construction	Wood Frame	Building B (4 Story Mixed Use Condominium Building)
	Coefficient (C)	1.5	
B	Ground Floor Area	929	m ²
C	Height in storeys	4	storeys
	Total Floor Area	3716	m ²
D	Fire Flow Formula	$F=220C\sqrt{A}$	
	Fire Flow	20116	L/min
	Rounded Fire Flow	20000	L/min
			Flow rounded to nearest 1000 L/min.
E	Occupancy Class	Limited Combustible	Residential buildings have a limited combustible occupancy.
	Occupancy Charge	-15%	
	Occupancy Increase or Decrease	-3000	
	Fire Flow	17000	L/min
F	Sprinkler Protection	Automatic Fully Supervised	
	Sprinkler Credit	-50%	
	Decrease for Sprinkler	-8500	L/min
G	North Side Exposure		
	Exposing Wall:	Wood Frame	Building B
	Exposed Wall:	Wood Frame	Building A
	Length of Exposed Wall:	39.2	m
	Height of Exposed Wall:	4	storeys
	Length-Height Factor	156.8	m-storeys
	Separation Distance	25.25	m
	North Side Exposure Charge	10%	
	East Side Exposure		
	Exposing Wall:	Wood Frame	Building B
	Exposed Wall:	Wood Frame	Townhomes
	Length of Exposed Wall:	14.3	m
	Height of Exposed Wall:	0	storeys
	Length-Height Factor	0.0	m-storeys
	Separation Distance	28.76	m
	East Side Exposure Charge	8%	
	South Side Exposure		
	Exposing Wall:	Wood Frame	Building B
	Exposed Wall:	Wood Frame	Building C
	Length of Exposed Wall:	36.1	m
	Height of Exposed Wall:	4	storeys
	Length-Height Factor	144.5	m-storeys
	Separation Distance	26.02	m
	South Side Exposure Charge	10%	
	West Side Exposure		
	Exposing Wall:	Wood Frame	
	Exposed Wall:	Wood Frame	
	Length of Exposed Wall:	0.0	m
	Height of Exposed Wall:	0	storeys
	Length-Height Factor	0.0	m-storeys
	Separation Distance	50	m
	West Side Exposure Charge	0%	
	Total Exposure Charge	28%	The total exposure charge is below the maximum value of 75%.
	Increase for Exposures	4760	L/min
H	Fire Flow	13260	L/min
	Rounded Fire Flow	13000	L/min
			Flow rounded to nearest 1000 L/min.
City Cap	Required Fire Flow (RFF)	13000	L/min
		217	L/s

Fire Underwriters Survey (FUS) Fire Flow Calculations
In accordance with City of Ottawa Technical Bulletin ISTB-2018-02 dated March 21, 2018

LOTS AREAS

LOT NUMBER	AREAS (M2)	LOT NUMBER	AREAS (M2)
B01-1	394	B06-4	154
B01-2	184	B06-5	163
B01-3	184	B06-6	154
B01-4	189	B06-7	369
B01-5	189	B07	2,002
B01-6	184	B08-1	525
B01-7	184	B08-2	174
B01-8	299	B08-3	184
B02-1	281	B08-4	174
B02-2	176	B08-5	184
B02-3	184	B08-6	174
B02-4	184	B08-7	234
B02-5	174	B09-1	234
B02-6	233	B09-2	174
B03-1	250	B09-3	184
B03-2	182	B09-4	184
B03-3	182	B09-5	174
B03-4	182	B09-6	234
B03-5	182	B10-1	234
B03-6	182	B10-2	174
B03-7	250	B10-3	184
B04-1	233	B10-4	184
B04-2	174	B10-5	174
B04-3	184	B10-6	487
B04-4	174	B11-1	748
B04-5	184	B11-2	286
B04-6	174	B11-3	265
B04-7	278	B11-4	246
B05-1	368	B11-5	242
B05-2	154	B11-6	242
B05-3	163	B11-7	321
B05-4	163	B12	1,232
B05-5	154	B13	1,232
B05-6	206	B14	5,728
B06-1	206	B15	5,399
B06-2	154	B16	7,811
B06-3	163	B17	5,312

SITE PLAN LEGEND

EXISTING BUILDING	LOT LINE
NEW BUILDING	SETBACKS
NEW BUILDING WITH COMMERCIAL SPACE AT-GRADE	NEW TREE
GRASS	FIREWALL
ASPHALT	SIDEWALK

SITE INFORMATION & DEVELOPMENT STATISTICS

LOTS	PIN	04756 - 0303
		04756 - 0315
		04756 - 0316
		04756 - 1337
ZONING	GM	(2546) H(14.5)
SITE AREA	TOTAL SITE AREA:	~53,441.14 m ² (5.34ha)
	TOTAL DEVELOPABLE AREA:	~45,956.28 m ² (4.59ha)
	NET SITE AREA:	~38,956.28 m ² (3.89ha)
UNITS	TOWNHOUSES:	67 UNITS
BLOCK 01:	1 X RESIDENTIAL APARTMENT BUILDING	48 UNITS
	1 X MIXED USE BUILDING	36 UNITS
	RESIDENTIAL:	~929 m ²
	COMMERCIAL SPACES:	
BLOCK 02:	1 X RESIDENTIAL APARTMENT BUILDING	47 UNITS
	1 X MIXED USE BUILDING	36 UNITS
	RESIDENTIAL:	~929 m ²
	COMMERCIAL SPACES:	
BLOCK 03:	2 X RESIDENTIAL APARTMENT BUILDING	96 UNITS
	TOTAL NUMBER OF UNITS:	330 UNITS
	TOTAL COMMERCIAL SPACES:	~1,858 m ²
	REQUIRED	PROVIDED
MAXIMUM DENSITY	NO MAX.	84.8 units/net ha
MINIMUM LOT WIDTH	NO MIN.	5.8 m
MINIMUM LOT AREA	NO MIN.	174 m ²
MAXIMUM BUILDING HEIGHT	14.5 m	14.5 m
SETBACKS		
MINIMUM FRONT YARD:	3 m	3 m
MINIMUM CORNER SIDE YARD:	3 m	3 m
MINIMUM INTERIOR SIDE YARD:		
NON-RESIDENTIAL OR MIXED-USE:	5 m	5 m
LOW-RISE RESIDENTIAL :	1.2 m	1.2 m
MID-RISE RESIDENTIAL :	3 m	3 m
MINIMUM REAR YARD:		
ABUTTING A STREET:	3 m	3 m
FROM A RESIDENTIAL ZONE:	7.5 m	7.5 m
FOR A RESIDENTIAL BUILDING:	7.5 m	7.5 m
PARKING RATES		
R9 - TOWNHOUSES:	1 p/unit = 67	67 (GARAGES)
VISITOR:	0	67 DRIVE AISLES
BLOCK 14:		
R12 - APPARTMENTS	1.2 p/unit = 101	101 (UNDERGROUND)
VISITOR:	0.2 p/unit = 17	17 (UNDERGROUND)
N79 - RETAIL STORE:	3.4 p/100 m ² GFA = 32	32 (EXTERIOR)
		TOTAL: 150
BLOCK 15:		
R12 - APPARTMENTS	1.2 p/unit = 100	100 (UNDERGROUND)
VISITOR:	0.2 p/unit = 17	17 (UNDERGROUND)
N79 - RETAIL STORE:	3.4 p/100 m ² GFA = 32	32 (EXTERIOR)
		TOTAL: 150
BLOCK 18:		
R12 - APPARTMENTS	1.2 p/unit = 116	145 (UNDERGROUND)
VISITOR:	0.2 p/unit = 17	17 (8 EXT. + 12 UND.)
		TOTAL: 162
GROSS FLOOR AREA		
TOWNHOUSE A:		267 m ²
TOWNHOUSE B:		239 m ²
TOWNHOUSE C:		232 m ²
TOWNHOUSE C (CORNER UNIT):		236 m ²
TOWNHOUSE D:		225 m ²
TOTAL MODEL 01 (BBBBBB)		1,968 m ²
TOTAL MODEL 02 (BBBBBA)		1,729 m ²
TOTAL MODEL 03 (ABBBBA)		1,490 m ²
TOTAL MODEL 04 (CDCDCD)		1,611 m ²
TOTAL MODEL 05 (CDCDC)		1,386 m ²
MIXED USE BUILDING (TOTAL OF 2 BUILDINGS):	TOTAL: 4,130 m ²	
RESIDENTIAL:	3,201 m ²	
COMMERCIAL:	929 m ²	
RESIDENTIAL APARTMENT BUILDING (TOTAL OF 4 BUILDINGS):	TOTAL: 4,130 m ²	
RESIDENTIAL:	4,130 m ²	
NOTE		
1. ASSUMES TYPICAL RESIDENTIAL FLOOR HEIGHT of 3m.		
2. THE BASE PLAN (LOT LINES, EXISTING ROADS AND SURROUNDING AREAS) IS BASED ON THE TOPOGRAPHICAL PLAN OF SURVEY, SURVEYED STANTEC GEOMATICS LTD.		
3. DISTANCES SHOWN ON THIS PLAN ARE IN METRES AND CAN BE CONVERTED TO FEET BY DIVIDING BY 0.3048.		
8	FOR CITY REVIEW	2022-11-28
7	FOR COORDINATION	2022-11-03
6	FOR COORDINATION	2022-04-14
5	FOR COORDINATION	2022-04-14
4	FOR COORDINATION	2022-03-30
3	FOR COORDINATION	2022-03-30
2	FOR COORDINATION	2022-03-30
1	FOR COORDINATION	2022-03-30
NO	DESCRIPTION	2022-03-30

NOTE
IT IS THE RESPONSIBILITY OF THE APPROPRIATE CONTRACTOR TO CHECK AND VERIFY ALL DIMENSIONS ON THE SITE AND TO REPORT ALL ERRORS AND/OR OMISSIONS TO THE ARCHITECT. ALL CONTRACTORS MUST FOLLOW ALL PERTINENT CODES AND LAWS. DO NOT SCALE DRAWINGS.

THIS DOCUMENT AND ITS CONTENT IS COPYRIGHTED. ANY REPRODUCTION IS PROHIBITED UNLESS GRANTED BY THE ARCHITECT.

DO NOT USE FOR CONSTRUCTION

DATE	2023-11-29	DESIGNED	PP
DRAWN	PP		
PROJECT No	20054	CHECKED	PM
SHEET TITLE	SITE PLAN		
SHEET No	A100		





Table 1. Maximum flow to be considered from a given hydrant

Block 14

Hydrant Class	Distance to asset/structure/building (m) ^a	Contribution to required fire flow (L/min) ^b
AA	≤ 75	5,700
	> 75 and ≤ 150	3,800
A	≤ 75	3,800
	> 75 and ≤ 150	2,850
B	≤ 75	1,900
	> 75 and ≤ 150	1,500
C	≤ 75	800
	> 75 and ≤ 150	800

Required Fire Flow = 233 L/s



William Rugamba

From: William Rugamba
Sent: July 22, 2024 8:18 AM
To: William Rugamba
Subject: FW: Re-confirmation of Mechanical Items for Servicing Report

William Rugamba, M.Eng., B.A.Sc., EIT
Civil Engineering Graduate
Ottawa, ON
Work: [343-804-4374](tel:343-804-4374)

From: Sarith Lopez <slopez@qmeengineering.com>
Sent: Wednesday, July 17, 2024 8:07 PM
To: Mahad Musse <mmusse@jlrichards.ca>; Chuck Clark <CWC@qmeengineering.com>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>
Subject: RE: Re-confirmation of Mechanical Items for Servicing Report

[CAUTION] This email originated from outside JLR. Do not click links or open attachments unless you recognize the sender and know the content is safe. Do not forward suspicious emails, if you are unsure, please send a separate message to Helpdesk.

Hi Mahad,

All items below confirmed

Regards

Sarith López
Project Manager

9 Gurdwara Road, Unit 200
Ottawa, ON K2E 7X6
T: 613-366-4763 ext. 129
slopez@qmeengineering.com



From: Mahad Musse <mmusse@jlrichards.ca>
Sent: Tuesday, July 16, 2024 3:08 PM
To: Sarith Lopez <slopez@qmeengineering.com>; Chuck Clark <CWC@qmeengineering.com>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>
Subject: Re-confirmation of Mechanical Items for Servicing Report

Hi Sarith/Chuck,

Thank you for the information below and in our meetings. I understand all these items have been discussed before but we need to submit something as part of our report. Can you just re-confirm the following questions below and then we will attach your confirmation to the Report.

1. Please confirm that the sanitary service size of 200mm diameter for the Site Plan Blocks (Block 14, 15 and 17) is preferred by the mechanical engineer on file;
2. Please confirm that a sprinkler flow of 25 L/s can be assumed for the Site Plan Blocks (Block 14, 15 and 17) at this stage.

Thanks
Mahad



Mahad Musse, B.Eng., EIT
Civil Engineering Graduate

1000-343 Preston Street
Ottawa, ON, K1S 1N4

Work: [343-633-1501](tel:343-633-1501)
mmusse@jlrichards.ca

William Rugamba

From: William Rugamba
Sent: July 15, 2024 4:00 PM
To: William Rugamba
Subject: FW: Navan Subdivision - Boundary Condition Request
Attachments: NavanSubdivision_Boundary Condition(4july2024).docx

William Rugamba, M.Eng., B.A.Sc., EIT

Civil Engineering Graduate

Ottawa, ON

Work: [343-804-4374](tel:343-804-4374)

From: Polyak, Alex <alex.polyak@ottawa.ca>
Sent: Monday, July 15, 2024 10:12 AM
To: Mahad Musse <mmusse@jlrichards.ca>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>; Armstrong, Justin <justin.armstrong@ottawa.ca>; Tatyana Roumie <troumie@jlrichards.ca>
Subject: RE: Navan Subdivision - Boundary Condition Request

[CAUTION] This email originated from outside JLR. Do not click links or open attachments unless you recognize the sender and know the content is safe. Do not forward suspicious emails, if you are unsure, please send a separate message to Helpdesk.

Good morning Mahad,

Please find the boundary conditions attached.

Regards,

Oleksandr (Alex) Polyak, B.Eng., C.E.T., P.Eng. 

Project Manager, Infrastructure Approvals, Development Review East Branch | Gestionnaire de projet, Direction de l'examen des projets d'aménagement – Est.
Planning, Development and Building Services Department (PDBS) | Direction générale des services de la planification, de l'aménagement et du bâtiment (DGSPAB)

City of Ottawa | Ville d'Ottawa
110 Laurier Ave., 4th Fl East, Ottawa ON K1P 1J1
Email: alex.polyak@ottawa.ca
Cell : 613-857-4380
www.Ottawa.ca



From: Mahad Musse <mmusse@jlrichards.ca>
Sent: July 12, 2024 1:31 PM
To: Polyak, Alex <alex.polyak@ottawa.ca>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>; Armstrong, Justin <justin.armstrong@ottawa.ca>; Tatyana Roumie <troumie@jlrichards.ca>
Subject: RE: Navan Subdivision - Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Alex,

Just wondering if you have a status update for the boundary conditions for Navan.

Thanks
Mahad



Mahad Musse, B.Eng., EIT
Civil Engineering Graduate

1000-343 Preston Street
Ottawa, ON, K1S 1N4



Work: [343-633-1501](tel:343-633-1501)
mmusse@jlrichards.ca



From: Mahad Musse <mmusse@jlrichards.ca>

Sent: Wednesday, July 3, 2024 11:02 AM

To: Polyak, Alex <alex.polyak@ottawa.ca>

Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>; Armstrong, Justin <justin.armstrong@ottawa.ca>; Tatyana Roumie <troumie@jlrichards.ca>

Subject: RE: Navan Subdivision - Boundary Condition Request

Good morning Alex,

As we discussed last week our Client is looking into the option of converting the row townhouse units into duplex units (townhouse units with apartments in the basement). As a result, this will increase the total demand on the site and we will therefore require new water boundary conditions. We'd like to note that the footprint of the blocks will not change and neither will their layout or any of the offsets.

As a summary:

- Domestic demands were calculated based on a daily consumption rate of 280 L/cap/day with peaking factors consistent with City of Ottawa Guidelines
- Required Fire Flow (RFF) was calculated in accordance to the Fire Underwriters Survey (FUS) Water Supply for Public Fire Protection and the City of Ottawa FUS protocol (Bulletin ISDTB-2014-02 & Bulletin ISDTB-2018-02), which considers material, expose distance & height. We have attached the calculation spreadsheet and the figure.

We request boundary conditions under high pressure, peak hour, and maximum day + fire flow conditions (for each of the below fire flows). Domestic demand and fire flow calculations are attached. Please provide the boundary conditions at the proposed connection locations as shown in the attached figure.

Average Day Demand: 6.74 L/s

Maximum Day Demand: 10.53 L/s

Peak Hour Demand: 18.17 L/s

Required Fire Flow (per FUS): 6,000 L/min (100 L/s)

Required Fire Flow (per FUS): 10,000 L/min (167 L/s)

Required Fire Flow (per FUS): 14,000 L/min (233 L/s)

Required Fire Flow (per FUS): 15,000 L/min (250 L/s)

For your reference, the previous boundary condition received from the City is attached and below is the email chain.

If you have any questions or comments please let us know.

Thanks
Mahad



Mahad Musse, B.Eng., EIT
Civil Engineering Graduate

1000-343 Preston Street
Ottawa, ON, K1S 1N4

Work: [343-633-1501](tel:343-633-1501)
mmusse@jlrichards.ca

From: Polyak, Alex <alex.polyak@ottawa.ca>
Sent: Thursday, August 17, 2023 3:01 PM
To: William Rugamba <wrugamba@jlrichards.ca>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>; Shahira Jalal <sjalal@jlrichards.ca>
Subject: RE: Navan Subdivision - Boundary Condition Request

[CAUTION] This email originated from outside JLR. Do not click links or open attachments unless you recognize the sender and know the content is safe. Do not forward suspicious emails, if you are unsure, please send a separate message to Helpdesk.

Hello William,

Sorry that I missed your call, I was in a meeting. The boundary conditions are attached.

Regards,

Oleksandr (Alex) Polyak, B.Eng., P.Eng

Project Manager, Infrastructure Approvals, Development Review East Branch | Gestionnaire de projet, Direction de l'examen des projets d'aménagement – Est.
Planning, Real Estate and Economic Development Department | Direction générale de la planification, des biens immobiliers et du développement économique

City of Ottawa | Ville d'Ottawa
110 Laurier Ave., 4th Fl East, Ottawa ON K1P 1J1
Email: alex.polyak@ottawa.ca
Cell : 613-857-4380
www.Ottawa.ca



From: William Rugamba <wrugamba@jlrichards.ca>
Sent: August 15, 2023 9:26 AM
To: Polyak, Alex <alex.polyak@ottawa.ca>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>; Shahira Jalal <sjalal@jlrichards.ca>
Subject: RE: Navan Subdivision - Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Good morning Alex,

Just wanted to follow up on the status of this boundary request. Please let me know if you need anything else from us.

Thanks,
William

William Rugamba, M.Eng.
Civil Engineering Intern

J.L. Richards & Associates Limited
1000-343 Preston Street, Ottawa, ON K1S 1N4
Direct: 343-804-4374



Platinum
member

From: Tatyana Roumie
Sent: Tuesday, July 25, 2023 3:53 PM
To: 'alex.polyak@ottawa.ca' <alex.polyak@ottawa.ca>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; carmine <carmine@zayoungroup.com>; Shahira Jalal <sjalal@jlrichards.ca>
Subject: Navan Subdivision - Boundary Condition Request

Hello Alex.

To support our upcoming detailed design for the site, we are requesting updated boundary conditions for the 3079 Navan Road Development.

As a brief history, we received boundary conditions from the City in July 2021 (attached, but with incorrect connection locations) and again in April 2022 (also attached) in support of the functional servicing design. We understand from the April 2022 boundary conditions that the maximum available fire flow for the site is 250 L/s.

We are currently requesting updated boundary conditions for this site as we are commencing the detailed servicing design and this request will accommodate the recent site plan changes and proposed connection points. This request is also applicable to the upcoming site plan designs which will be submitted as separate applications.

We request boundary conditions under high pressure, peak hour, and maximum day + fire flow conditions (for each of the below fire flows). Domestic demand and fire flow calculations are attached. Please provide the boundary conditions at the proposed connection locations as shown in the attached figure.

Average Day Demand: 6.44 L/s

Maximum Day Demand: 9.77 L/s

Peak Hour Demand: 16.50 L/s

Required Fire Flow (per FUS): 6,000 L/min (100 L/s)

Required Fire Flow (per FUS): 10,000 L/min (167 L/s)

Required Fire Flow (per FUS): 14,000 L/min (233 L/s)

Required Fire Flow (per FUS): 15,000 L/min (250 L/s)

Thanks,
Tatyana

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

Boundary Conditions Navan Subdivision

Provided Information

Scenario	Demand	
	L/min	L/s
Average Daily Demand	404	6.74
Maximum Daily Demand	632	10.53
Peak Hour	1,090	18.17
Fire Flow Demand #1	6,000	100.00
Fire Flow Demand #2	10,000	166.67
Fire Flow Demand #3	14,000	233.33
Fire Flow Demand #4	15,000	250.00

Location



Results

Connection 1 - Page Road

Demand Scenario	Head (m)	Pressure ¹ (psi)
Maximum HGL	130.7	64.0
Peak Hour	127.0	58.6
Max Day plus Fire Flow #1	128.2	60.4
Max Day plus Fire Flow #2	126.8	58.3
Max Day plus Fire Flow #3	124.9	55.7
Max Day plus Fire Flow #4	124.4	55.0

¹ Ground Elevation = 85.7 m

Connection 2 - Navan Road East

Demand Scenario	Head (m)	Pressure ¹ (psi)
Maximum HGL	130.7	71.4
Peak Hour	126.8	65.9
Max Day plus Fire Flow #1	127.7	67.1
Max Day plus Fire Flow #2	125.5	64.1
Max Day plus Fire Flow #3	122.7	60.1
Max Day plus Fire Flow #4	121.9	58.9

¹ Ground Elevation = 80.5 m

Connection 3 - Navan Road West

Demand Scenario	Head (m)	Pressure ¹ (psi)
Maximum HGL	130.7	69.3
Peak Hour	126.8	63.8
Max Day plus Fire Flow #1	127.3	64.5
Max Day plus Fire Flow #2	124.6	60.6
Max Day plus Fire Flow #3	120.9	55.3
Max Day plus Fire Flow #4	119.8	53.8


¹ Ground Elevation = 81.9 m

Disclaimer

The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of water mains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation. Fire Flow analysis is a reflection of available flow in the watermain; there may be additional restrictions that occur between the watermain and the hydrant that the model cannot take into account.

Mixed-Use Site Plan (Block 14)


Model Schematic



Mixed-Use Site Plan (Block 14)


Model Schematic

Elevation Model



Mixed-Use Site Plan (Block 14)

Peak Hour Demand



Mixed-Use Site Plan (Block 14)
Peak Hour Demand
Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
J-22	86.25	2.78	126.76	396
J-5	85.80	0.00	126.78	401
J-16	85.77	0.00	126.85	402
J-2	85.90	0.58	127.00	402
J-7	85.50	4.95	126.77	404
J-23	85.30	2.74	126.76	406
J-1	85.50	0.00	127.00	406
J-4	85.17	0.00	126.78	407
J-6	85.03	0.00	126.77	409
J-8	84.46	1.90	126.77	414
J-9	84.25	1.46	126.77	416
J-10	82.76	0.00	126.78	431
J-25	82.55	3.08	126.76	433


Mixed-Use Site Plan (Block 14)

Peak Hour Demand

Pipe Table

ID	Label	Length (Scaled) (m)	Diameter (mm)	Material	Hazen-Williams C	Flow (L/s)	Velocity (m/s)
114	P-1(2)	19	297	PVC	120.0	-1	0.01
49	P-2	168	204	PVC	110.0	10	0.32
52	P-5	31	204	PVC	110.0	-5	0.15
82	P-6	64	204	PVC	110.0	-10	0.32
85	P-7	26	204	PVC	110.0	5	0.17
86	P-8	16	204	PVC	110.0	5	0.17
54	P-9	48	204	PVC	110.0	3	0.08
91	P-10	41	204	PVC	110.0	-2	0.07
92	P-11	36	204	PVC	110.0	-2	0.07
104	P-12	59	204	PVC	110.0	2	0.07
105	P-13	11	204	PVC	110.0	2	0.07
108	P-15	70	204	PVC	110.0	-3	0.10
109	P-16	23	204	PVC	110.0	-3	0.10
97	P-17	50	204	PVC	110.0	-6	0.20
110	P-23	17	204	PVC	110.0	10	0.32
129	P-24(1)	56	155	PVC	100.0	1	0.03
130	P-24(2)	18	155	PVC	100.0	1	0.03
123	P-26	53	204	PVC	110.0	0	0.01
154	P-27(1)	16	155	PVC	100.0	3	0.15
155	P-27(2)	20	155	PVC	100.0	3	0.15
171	P-28(1)	32	155	PVC	100.0	3	0.15
183	P-29	47	155	PVC	100.0	3	0.16

Mixed-Use Site Plan (Block 14) Max Day + Fire Flow Requirement




Mixed-Use Site Plan (Block 14)
Max Day + Fire Flow Requirement

Label	Satisfies Fire Flow Constraints?	Fire Flow (Available) (L/s)	Flow (Total Available) (L/s)	Pressure (Residual Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated System Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)
H-1	True	250	250	140	152	177	J-16
H-2	True	237	237	140	140	151	J-23
H-4	True	245	245	140	140	144	J-7
H-3	True	232	232	140	140	155	J-22
H-5	True	250	250	140	256	238	J-22
H-12	True	132	132	140	142	140	J-2
H-17	True	145	145	140	147	140	J-22

Mixed-Use Site Plan (Block 14)

Maximum Pressure Analysis



Mixed-Use Site Plan (Block 14)
Maximum Pressure Analysis
Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
J-22	86.25	0	130.70	435
J-2	85.90	0	130.70	438
J-5	85.80	0	130.70	439
J-16	85.77	0	130.70	440
J-7	85.50	0	130.70	442
J-1	85.50	0	130.70	442
J-23	85.30	0	130.70	444
J-4	85.17	0	130.70	446
J-6	85.11	0	130.70	446
J-8	84.46	0	130.70	453
J-9	84.25	0	130.70	455
J-10	82.76	0	130.70	469
J-25	82.55	0	130.70	471

Mixed-Use Site Plan (Block 14)
Maximum Pressure Analysis

Pipe Table

ID	Label	Length (Scaled) (m)	Diameter (mm)	Material	Hazen-Williams C	Flow (L/s)	Velocity (m/s)
114	P-1(2)	19	297	PVC	120.0	0	0.00
49	P-2	168	204	PVC	110.0	0	0.00
52	P-5	31	204	PVC	110.0	0	0.00
82	P-6	64	204	PVC	110.0	0	0.00
85	P-7	26	204	PVC	110.0	0	0.00
86	P-8	16	204	PVC	110.0	0	0.00
54	P-9	48	204	PVC	110.0	0	0.00
91	P-10	41	204	PVC	110.0	0	0.00
92	P-11	36	204	PVC	110.0	0	0.00
104	P-12	59	204	PVC	110.0	0	0.00
105	P-13	11	204	PVC	110.0	0	0.00
108	P-15	70	204	PVC	110.0	0	0.00
109	P-16	23	204	PVC	110.0	0	0.00
97	P-17	50	204	PVC	110.0	0	0.00
110	P-23	17	204	PVC	110.0	0	0.00
129	P-24(1)	56	155	PVC	100.0	0	0.00
130	P-24(2)	18	155	PVC	100.0	0	0.00
123	P-26	53	204	PVC	110.0	0	0.00
154	P-27(1)	16	155	PVC	100.0	0	0.00
155	P-27(2)	20	155	PVC	100.0	0	0.00
171	P-28(1)	32	155	PVC	100.0	0	0.00
183	P-29	47	155	PVC	100.0	0	0.00




Site Servicing Report
2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario

Appendix D

Stormwater Management

PIPE REACH			Peak Flow Estimation							Sewer Data						Upstream Geometry				Downstream Geometry				Self Cleaning Velocities													
LOCATION	From MH	To MH	C Factor (1:2 Year)		Cum. Total Area (ha)	Inlet Time (min.)	In Pipe Flow Time (min.)	Total Time	1.2 Year Storm (RATIONAL METHOD)			ICD Flow ⁽¹⁾ 2.78A/R CB100	ICD Flow ⁽²⁾ EXST MH527 CB100	Roof Drain Flow (L/s)	Cistern Flow (L/s)	Total Peak Flow ⁽³⁾ (L/s)	Type	Nominal Dia. (mm)	Actual Dia. (mm)	Slope	Length (m)	Q Full (L/s)	V Full (m/s)	Residual Capacity ⁽⁴⁾ (L/s)	% Full	TG From	Obvert	Invert	Cover	TG To	Obvert	Invert	Cover	Q/D Ratio	Flow Depth (mm)	Actual Velocity ⁽⁵⁾ (m/s)	Flow Depth to Dia. Ratio (d/D)
			Cum. Total Area (ha)	Inlet Time (min.)					1.2 Year Peak Flow (L/s)	1.2 Year Intensity (L/s)	1.2 Year Peak Flow (L/s)																										
EAST ORLEANS RIDGE SUBDIVISION	UPSTREAM ⁽⁶⁾ EXIST MH527	EXIST MH527	Refer to Note 8	0.14	10.90	0.54	10.84	0.26	76.81	10.73	Refer to Note 8	CONCRETE	478	695.80	0.95%	57.39	690.35	1.76	639.62	3%	Refer to Note 8																
BLOCK 14	EXIST MH527	EXIST MH526	0.00	0.01	0.10	0.24	10.54	1.80	12.34	0.07	0.33	74.79	24.41	14.00	14.00	PVC	300	304.80	0.36%	89.06	60.19	0.82	35.78	41%	85.31	82.30	81.61	3.91	85.83	81.98	81.30	3.84					
BLOCK 14	EXIST MH526	EXIST MH525	0.06	0.18	0.01	0.23	0.47	12.34	0.65	12.89	0.16	0.51	68.85	35.14	38.00	52.66	PVC	300	304.80	0.36%	29.56	53.29	0.76	26.11	64%	85.83	81.98	81.66	3.84	85.65	81.67	81.36	4.02	235.00	0.86	0.77	
BLOCK 14	BLOCK 14	EXIST MH525	0.02	0.36	0.38	0.05	10.00	0.05	10.05	0.91	0.91	76.81	70.00	4.00	10.00	PVC	300	304.80	2.05%	5.80	142.67	1.96	72.67	49%	85.85	81.54	81.24	2.31	85.75	81.42	81.12	4.33	0.10	64.31	1.22	0.21	
EAST ORLEANS RIDGE SUBDIVISION	EXIST MH525	EXIST MH524			0.04	12.99	0.21	12.29	0.00	1.42	66.95	95.20			66.09	CONCRETE	469	457.20	0.25%	11.53	148.72	0.91	63.92	64%	85.70	81.58	81.12	2.17	84.90	81.09	3.39	0.44	213.06	0.88	0.47		
Design Parameters (Per OSDG)			Drainage Areas Breakdown							Notes on Plug Flows																											
										(1) Flow rate controlled downstream of EXST MH527 as part of the East Orleans Ridge Subdivision																											
			Total Site Area: 0.57 ha							(2) ICD Flow Rate at CB100																											
			Controlled Area Within Site Boundary: 0.55 ha --							(3) Total flow rates of roof drains for Buildings A and B																											
			Existing Areas Captured Within Site Boundary: 0.55 ha							(4) Cistern Outflow Rate																											
			This area is part of the total site area (0.57 ha)							Notes on Peak Flow and Pipe Sizing																											
										(5) Note that peak flow (68 L/s) is a sum of the roof drain release rate of 68 L/s from CS101, 10 L/s from Cistern A, 10 L/s from Drain A and 10 L/s from CB100 as well as the remaining control from upstream of MH527																											
										(6) Peak Flow Rate: 1.2 Year Peak Flow Rate																											
										(7) Actual Velocities based on actual peak flows from Note 5																											
										(8) Details from Existing Sewers Upstream of EXST MH527 can be found within East Orleans Ridge Subdivision Details: This site is only used to carry over the upstream values for time of concentration and 1.2 year peak flow.																											
										This area is part of the total site area (0.57 ha)																											
			Uncontrolled Area - Outlet to Subdivision: 0.02 ha --							This area is part of the total site area (0.57 ha)																											

REAR YARD CATCH BASIN TABLE														
LOCATION	CB ID Number	T/G	Inlet					Outlet					CATCH BASIN TYPE	ICD TYPE
			Pipe Dia. (mm)	Pipe Length (m)	Pipe Slope (%)	Invert	COVER (m)	Pipe Dia. (mm)	Pipe Length (m)	Pipe Slope (%)	Invert	COVER (m)		
BLOCK 14	CB102	85.60	-	-	-	-	-	250	29.7	1.0	84.20	1.15	CATCH BASIN ELBOW PER CITY STANDARD S30	NO ICD
	CB101	85.65	250	29.7	1.0	83.90	1.50	250	5.75	0.5	83.90	1.50	600 mm x 600 mm CATCH BASIN PER OPSD 705.010	Vortex_ICD_70
	CB100	85.05	-	-	-	-	-	250	4.6	0.5	83.09	1.71	600 mm x 600 mm CATCH BASIN PER OPSD 705.010	MHF_IPEX_TYPE_B



150 m

NAVAN RESIDENTIAL AND COMMERCIAL SITE PLAN - BLOCK 14


Ottawa, ON

Overall System Model Schematic

J.L.Richards
ENGINEERS · ARCHITECTS · PLANNERS

This drawing is copyright protected and
may not be reproduced or used for purposes
other than execution of the described work
without the express written consent of J.L.
Richards & Associates Limited.

DESIGN:	ML	JLR NO.:	29899-002
DRAWN:	ML	DRAWING NO.:	
CHECKED:	BP		Figure 1



Legend

IMP

- Landscaped Areas (C-Factor - 0.2)
 - Pavement Areas (C-Factor - 0.9)
 - Area Tributary to Subdivision (C-Factor - 0.3)

PROJECT:

NAVAN RESIDENTIAL AND COMMERCIAL BLOCK 14

OTTAWA, ONTARIO

DRAWING:

OVERALL SITE IMPERVIOUSNESS



This drawing is copyright protected and may not be reproduced or used for purposes other than execution of the described work without express written consent of J.L. Richards & Associates Limited

SIGN: ML

LR NO: 29899-002

AWN: ML

DRAWING NO:

~~ECKED: RD~~

Figure

Post-Development 3-hour Chicago 1:2 year Event

[TITLE]
;;Project Title/Notes

[OPTIONS]
;;Option Value
FLOW_UNITS CMS
INFILTRATION HORTON
FLOW_MODEL DYNWAVE
LINK_OFFSETS ELEVATION
MIN_SLOPE 0
ALLOW_PONDING NO
SKIP_STEADY_STATE NO

START_DATE 01/01/2000
START_TIME 00:00:00
REPORT_START_DATE 01/01/2000
REPORT_START_TIME 00:00:00
END_DATE 01/01/2000
END_TIME 06:00:00
SWEEP_START 01/01
SWEEP_END 12/31
DRY_DAYS 0
REPORT_STEP 00:01:00
WET_STEP 00:01:00
DRY_STEP 00:01:00
ROUTING_STEP 1
RULE_STEP 00:00:00

INERTIAL_DAMPING PARTIAL
NORMAL_FLOW_LIMITED BOTH
FORCE_MAIN_EQNATION H-W
VARIABLE_STEP 0.75
LENGTHENING_STEP 0
MIN_SURFAREA 0
MAX_TRIALS 8
HEAD_TOLERANCE 0.0015
SYS_FLOW_TOL 5
LAT_FLOW_TOL 5
MINIMUM_STEP 0.5
THREADS 12

[EVAPORATION]
;;Data Source Parameters
;;
CONSTANT 0.0
DRY_ONLY NO

[RAINGAGES]
;;Name Format Interval SCF Source
;;
Rainfall INTENSITY 0:10 1.0 TIMESERIES 3CH12

[SUBCATCHMENTS]
;;Name Rain Gage Outlet Area %Imperv Width %Slope CurbLen
;;
L1_1 Rainfall St_L1 0.0599 10.014 134.062 2 0
L1_2 Rainfall St_L1 0.0581 8.447 15.82 2 0
L1_3 Rainfall St_L2 0.0324 3.893 77.605 2 0
S1 Rainfall St_L3 0.1577 14.286 38.49 2 0
S2 Rainfall St_P2 0.0607 90.737 16.17 2 0
S3_1 Rainfall SU1 0.0391 99.287 10.808 2 0
S3_2 Rainfall St_B1 0.048 98.957 13.267 2 0
S5 Rainfall Roof2 0.053 100.003 22.118 1 0
S6 Rainfall Roof1 0.0983 100 22.118 1 0
S7 Rainfall St_UnGrd 0.0317 72.194 28.53 15 0

[SUBAREAS]
;;Subcatchment N-Imperv N-Perv S-Imperv S-Perv PctZero RouteTo PctRouted
;;
L1_1 0.013 0.25 1.57 4.67 0 PERVIOUS 100
L1_2 0.013 0.25 1.57 4.67 0 PERVIOUS 100
L1_3 0.013 0.25 1.57 4.67 0 PERVIOUS 100
S1 0.013 0.25 1.57 4.67 0 PERVIOUS 80
S2 0.013 0.25 1.57 4.67 0 OUTLET
S3_1 0.013 0.25 1.57 4.67 0 OUTLET
S3_2 0.013 0.25 1.57 4.67 0 OUTLET
S5 0.013 0.25 1.57 4.67 0 OUTLET
S6 0.013 0.25 1.57 4.67 0 OUTLET
S7 0.013 0.25 1.57 4.67 0 OUTLET

[INFILTRATION]
;;Subcatchment Param1 Param2 Param3 Param4 Param5
;;
L1_1 76.2 13.2 4.14 7 0
L1_2 76.2 13.2 4.14 7 0
L1_3 76.2 13.2 4.14 7 0
S1 76.2 13.2 4.14 7 0
S2 76.2 13.2 4.14 7 0
S3_1 76.2 13.2 4.14 7 0
S3_2 76.2 13.2 4.14 7 0
S5 76.2 13.2 4.14 7 0
S6 76.2 13.2 4.14 7 0
S7 76.2 13.2 4.14 7 0

[OUTFALLS]
;;Name Elevation Type Stage Data Gated Route To
;;
S27_1 (P-Stm) 81.228 TIMESERIES 507_CH12yr NO
OF1 80.67 FIXED 81.17 NO
OF2 80.911 FIXED 81.46 NO
OF3 80.67 FIXED 81.17 NO
OF7 80.67 FIXED 81.17 NO

[STORAGE]
;;Name Elev. MaxDepth Ksat InitDepth Shape Curve Name/Params
;;
Roof1 96.85 0.15 0 FUNCTIONAL 0 0 559.44 0
0 Roof2 96.85 0.15 0 FUNCTIONAL 0 0 559.44 0
0 St_L1 84.2 1.7 0 TABULAR St_L1 0
0 St_L2 83.9 2.1 0 TABULAR St_L2 0
0 St_L3 83.09 2.21 0 TABULAR St_L3 0
0 St_P1 85.7 0.31 0 TABULAR St_P1 0
0 St_P2 85.5 0.15 0 TABULAR St_P2 0
0 St_UnGrd 81.971 1 0 FUNCTIONAL 0 0 64 0
0 SU1 85.7 0.25 0 TABULAR St_P3 0

[CONDUTS]
;;Name From Node To Node Length Roughness InOffset OutOffset
;;
InitFlow MaxFlow
;;
C1 St_L1 St_L2 33.149 0.013 84.2 83.9
0 0.04

[WEIRS]
;;Name EndCon EndCoeff From Node Surcharge To Node RoadWidth RoadSurf Type CrestHt Qcoeff Curve Gated
;;
W_L1 St_L2 St_L1 TRANSVERSE 85.95 1.84 NO

W1 0 St_P1 St_P2 TRANSVERSE 85.85 1.84 NO
W2 0 SU1 St_P1 TRANSVERSE 85.87 1.84 NO

[OUTLETS]
;;Name Qexpon Gated From Node To Node Offset Type QTable/Qcoeff
;;
O_St_L3 St_L3 OF2 83.09 TABULAR/HEAD MHF_IPEX_TYPE_B
NO NO
OL1 SU1 St_UnGrd 85.7 TABULAR/HEAD ZURN_Z150F-6NH
NO NO
OL2 St_P1 St_UnGrd 85.7 TABULAR/HEAD ZURN_Z150F-6NH
NO NO
OL3 St_P2 St_UnGrd 85.5 TABULAR/HEAD ZURN_Z150F-6NH
NO NO
OL4 St_L2 S27_1(P-Stm) 83.9 TABULAR/HEAD Vortex_ICD_70
NO NO
OR1 St_UnGrd OF1 81.971 TABULAR/HEAD O_St_UnGrd
NO NO
ROOF1 Roof1 OF3 96.85 TABULAR/HEAD O_Roof1
NO NO
ROOF2 Roof2 OF7 96.85 TABULAR/HEAD O_Roof2
NO NO

[XSECTIONS]
;;Link Culvert Shape Geom1 Geom2 Geom3 Geom4 Barrels
;;
C1 CIRCULAR 0.25 0 0 0 1
W_L1 RECT_OPEN 0.05 3 0 0 0
W1 RECT_OPEN 0.16 15 0 0 0
W2 RECT_OPEN 0.08 15 0 0 0

[LOSSES]
;;Link Kentry Kexit Kavg Flap Gate Seepage
;;
St_UnGrd FLOW InfiltratedInflow FLOW 1.0 1 0

[CURVES]
;;Name Type X-Value Y-Value
;;
CBMH Inlet Capture Curve based on the OSDG Appendix 7-A
CBMH Rating 0 0
CBMH 0.122 0.06
CBMH 0.183 0.073
CBMH 0.2 0.076
CBMH 0.243 0.084
CBMH 0.305 0.094

[INFLOWS]
;;Node Constituent Time Series Type Mfactor Sfactor Baseline Pattern
;;
St_UnGrd FLOW InfiltratedInflow FLOW 1.0 1 0

[CMBH]
;;Name Ltée Rating
;;
CBMH Ltée Rating 0 0
CBMH 0.0127 4E-05
CBMH 0.0554 0.00019
CBMH 0.0381 0.00032
CBMH 0.0508 0.00051
CBMH 0.0635 0.00064
CBMH 0.0762 0.00083
CBMH 0.0889 0.00093
CBMH 0.1016 0.00101
CBMH 0.1443 0.0011
Les Produits MURPHCO Ltée 0.127 0.0012
Les Produits MURPHCO Ltée 0.1397 0.00128
Les Produits MURPHCO Ltée 0.1524 0.00135

[MURPHCO]
;;Name Ltée Rating
;;
MURPHCO Ltée Rating 0 0
MURPHCO Ltée 0.11 0
MURPHCO Ltée 0.2 0.187
MURPHCO Ltée 0.3 0.395
MURPHCO Ltée 0.4 0.602
MURPHCO Ltée 0.5 0.81
MURPHCO Ltée 0.6 1.018
MURPHCO Ltée 0.7 1.225
MURPHCO Ltée 0.8 1.433
MURPHCO Ltée 0.9 1.641
MURPHCO Ltée 1 1.848

[Reversed Flow from rear yard manhole_lid to the Street]
Manhole_lid Rating 0 0
Manhole_lid 0.11 0
Manhole_lid 0.2 0.187
Manhole_lid 0.3 0.395
Manhole_lid 0.4 0.602
Manhole_lid 0.5 0.81
Manhole_lid 0.6 1.018
Manhole_lid 0.7 1.225
Manhole_lid 0.8 1.433
Manhole_lid 0.9 1.641
Manhole_lid 1 1.848

[Tempest Rating Curve for MHF IPEX TYPE A, No grate allowance]
MHF_IPEX_TYPE_A Rating 0 0
MHF_IPEX_TYPE_A 0.1 0.0057
MHF_IPEX_TYPE_A 0.2 0.0081
MHF_IPEX_TYPE_A 0.3 0.0099
MHF_IPEX_TYPE_A 0.4 0.0114
MHF_IPEX_TYPE_A 0.5 0.0128
MHF_IPEX_TYPE_A 0.6 0.014
MHF_IPEX_TYPE_A 0.7 0.0151
MHF_IPEX_TYPE_A 0.8 0.0162
MHF_IPEX_TYPE_A 0.9 0.0172
MHF_IPEX_TYPE_A 1 0.0181
MHF_IPEX_TYPE_A 1.2 0.0198
MHF_IPEX_TYPE_A 1.4 0.0214
MHF_IPEX_TYPE_A 1.6 0.0229
MHF_IPEX_TYPE_A 1.8 0.0243
MHF_IPEX_TYPE_A 2 0.0256
MHF_IPEX_TYPE_A 2.5 0.0286
MHF_IPEX_TYPE_A 3 0.0313

[Tempest Rating Curve for MHF IPEX TYPE B, No grate allowance]
MHF_IPEX_TYPE_B Rating 0 0
MHF_IPEX_TYPE_B 0.1 0.0081
MHF_IPEX_TYPE_B 0.2 0.0115
MHF_IPEX_TYPE_B 0.3 0.011
MHF_IPEX_TYPE_B 0.4 0.0162
MHF_IPEX_TYPE_B 0.5 0.0182
MHF_IPEX_TYPE_B 0.6 0.0199
MHF_IPEX_TYPE_B 0.7 0.0215
MHF_IPEX_TYPE_B 0.8 0.023
MHF_IPEX_TYPE_B 0.9 0.0244
MHF_IPEX_TYPE_B 1 0.0257
MHF_IPEX_TYPE_B 1.2 0.0281
MHF_IPEX_TYPE_B 1.4 0.0304
MHF_IPEX_TYPE_B 1.6 0.0325
MHF_IPEX_TYPE_B 1.8 0.0344
MHF_IPEX_TYPE_B 2 0.0363
MHF_IPEX_TYPE_B 2.5 0.0406
MHF_IPEX_TYPE_B 3 0.0445

[Tempest Rating Curve for MHF IPEX TYPE C, No grate allowance]
MHF_IPEX_TYPE_C Rating 0 0

MHF_IPEX_TYPE_C Rating 0 0
 MFH_IPEX_TYPE_C 0.1 0.0106
 MFH_IPEX_TYPE_C 0.2 0.015
 MFH_IPEX_TYPE_C 0.3 0.0183
 MFH_IPEX_TYPE_C 0.4 0.0212
 MFH_IPEX_TYPE_C 0.5 0.0237
 MFH_IPEX_TYPE_C 0.6 0.0259
 MFH_IPEX_TYPE_C 0.7 0.028
 MFH_IPEX_TYPE_C 0.8 0.0299
 MFH_IPEX_TYPE_C 0.9 0.0317
 MFH_IPEX_TYPE_C 1 0.0335
 MFH_IPEX_TYPE_C 1.2 0.0366
 MFH_IPEX_TYPE_C 1.4 0.0396
 MFH_IPEX_TYPE_C 1.6 0.0423
 MFH_IPEX_TYPE_C 1.8 0.0449
 MFH_IPEX_TYPE_C 2 0.0473
 MFH_IPEX_TYPE_C 2.5 0.0529
 MFH_IPEX_TYPE_C 3 0.0579
 ;Tempest Rating Curve for MFH IPEX TYPE C, No grate allowance
 MFH_IPEX_TYPE_C Rating 0 0
 MFH_IPEX_TYPE_C 0.1 0.0154
 MFH_IPEX_TYPE_C 0.2 0.0217
 MFH_IPEX_TYPE_C 0.3 0.0266
 MFH_IPEX_TYPE_C 0.4 0.0307
 MFH_IPEX_TYPE_C 0.5 0.0343
 MFH_IPEX_TYPE_C 0.6 0.0376
 MFH_IPEX_TYPE_C 0.7 0.0406
 MFH_IPEX_TYPE_C 0.8 0.0434
 MFH_IPEX_TYPE_C 0.9 0.0461
 MFH_IPEX_TYPE_C 1 0.0485
 MFH_IPEX_TYPE_C 1.2 0.0532
 MFH_IPEX_TYPE_C 1.4 0.0574
 MFH_IPEX_TYPE_C 1.6 0.0614
 MFH_IPEX_TYPE_C 1.8 0.0651
 MFH_IPEX_TYPE_C 2 0.0687
 MFH_IPEX_TYPE_C 2.5 0.0768
 MFH_IPEX_TYPE_C 3 0.0841
 ;Tempest Rating Curve for MFH IPEX TYPE D, No grate allowance
 MFH_IPEX_TYPE_D Rating 0 0
 MFH_IPEX_TYPE_D 0.1 0.0205
 MFH_IPEX_TYPE_D 0.2 0.0289
 MFH_IPEX_TYPE_D 0.3 0.0355
 MFH_IPEX_TYPE_D 0.4 0.0399
 MFH_IPEX_TYPE_D 0.5 0.0458
 MFH_IPEX_TYPE_E 0.6 0.0501
 MFH_IPEX_TYPE_E 0.7 0.0542
 MFH_IPEX_TYPE_E 0.8 0.0579
 MFH_IPEX_TYPE_E 0.9 0.0614
 MFH_IPEX_TYPE_E 1 0.067
 MFH_IPEX_TYPE_E 1.2 0.0709
 MFH_IPEX_TYPE_E 1.4 0.0766
 MFH_IPEX_TYPE_E 1.6 0.0819
 MFH_IPEX_TYPE_E 1.8 0.0868
 MFH_IPEX_TYPE_E 2 0.0915
 MFH_IPEX_TYPE_E 2.5 0.1023
 MFH_IPEX_TYPE_E 3 0.1121
 O_Roof1 Rating 0 0
 O_Roof1 0.001 0.002
 O_Roof1 0.15 0.002
 O_Roof2 Rating 0 0
 O_Roof2 0.001 0.002
 O_Roof2 0.15 0.002
 O_St_L1 Rating 0 0
 O_St_L1 0.001 0.003
 O_St_L1 0.35 0.003
 O_St_L2 Rating 0 0
 O_St_L2 0.001 0.002
 O_St_L2 0.35 0.002
 O_St_L3 Rating 0 0
 O_St_L3 0.001 0.0137
 O_St_L3 0.35 0.0137
 O_St_UnGrd Rating 0 0
 O_St_UnGrd 0.01 0.01
 O_St_UnGrd 1 0.01
 ;Tempest Rating Curve for Vortex ICD 100, No grate allowance
 Vortex_ICD_100 Rating 0 0
 Vortex_ICD_100 0.1 0.0028
 Vortex_ICD_100 0.2 0.004
 Vortex_ICD_100 0.3 0.0049
 Vortex_ICD_100 0.4 0.0056
 Vortex_ICD_100 0.5 0.0063
 Vortex_ICD_100 0.6 0.0069
 Vortex_ICD_100 0.7 0.0075
 Vortex_ICD_100 0.8 0.008
 Vortex_ICD_100 0.9 0.0085
 Vortex_ICD_100 1 0.0089
 Vortex_ICD_100 1.2 0.0098
 Vortex_ICD_100 1.4 0.0106
 Vortex_ICD_100 1.6 0.0113
 Vortex_ICD_100 1.8 0.012
 Vortex_ICD_100 2 0.0126
 Vortex_ICD_100 2.5 0.0141
 Vortex_ICD_100 3 0.0155
 ;Tempest Rating Curve for Vortex ICD 105, No grate allowance
 Vortex_ICD_105 Rating 0 0
 Vortex_ICD_105 0.1 0.0031
 Vortex_ICD_105 0.2 0.004
 Vortex_ICD_105 0.3 0.0054
 Vortex_ICD_105 0.4 0.0062
 Vortex_ICD_105 0.5 0.0069
 Vortex_ICD_105 0.6 0.0076
 Vortex_ICD_105 0.7 0.0082
 Vortex_ICD_105 0.8 0.0088
 Vortex_ICD_105 0.9 0.0093
 Vortex_ICD_105 1 0.0098
 Vortex_ICD_105 1.2 0.0107
 Vortex_ICD_105 1.4 0.0116
 Vortex_ICD_105 1.6 0.0124
 Vortex_ICD_105 1.8 0.0131
 Vortex_ICD_105 2 0.0139
 Vortex_ICD_105 2.5 0.0155
 Vortex_ICD_105 3 0.017
 ;Tempest Rating Curve for Vortex ICD 40, No grate allowance
 Vortex_ICD_40 Rating 0 0
 Vortex_ICD_40 0.1 0.0004
 Vortex_ICD_40 0.2 0.0006
 Vortex_ICD_40 0.3 0.0007
 Vortex_ICD_40 0.4 0.0009
 Vortex_ICD_40 0.5 0.001
 Vortex_ICD_40 0.6 0.001
 Vortex_ICD_40 0.7 0.0011
 Vortex_ICD_40 0.8 0.0012
 Vortex_ICD_40 0.9 0.0013
 Vortex_ICD_40 1 0.0014
 Vortex_ICD_40 1.2 0.0015
 Vortex_ICD_40 1.4 0.0016
 Vortex_ICD_40 1.6 0.0017
 Vortex_ICD_40 1.8 0.0018
 Vortex_ICD_40 2 0.0019
 Vortex_ICD_40 2.5 0.0022
 Vortex_ICD_40 3 0.0024
 ;Tempest Rating Curve for Vortex ICD 45, No grate allowance
 Vortex_ICD_45 Rating 0 0
 Vortex_ICD_45 0.1 0.0006
 Vortex_ICD_45 0.2 0.0008
 Vortex_ICD_45 0.3 0.001
 Vortex_ICD_45 0.4 0.0011
 Vortex_ICD_45 0.5 0.0013
 Vortex_ICD_45 0.6 0.0014
 Vortex_ICD_45 0.7 0.0015
 Vortex_ICD_45 0.8 0.0016
 Vortex_ICD_45 0.9 0.0017
 Vortex_ICD_45 1 0.0018
 Vortex_ICD_45 1.2 0.002
 Vortex_ICD_45 1.4 0.0021
 Vortex_ICD_45 1.6 0.0023
 Vortex_ICD_45 1.8 0.0024
 Vortex_ICD_45 2 0.0026
 Vortex_ICD_45 2.5 0.0029
 Vortex_ICD_45 3 0.0031
 ;Tempest Rating Curve for Vortex ICD 50, No grate allowance
 Vortex_ICD_50 Rating 0 0
 Vortex_ICD_50 0.1 0.0007
 Vortex_ICD_50 0.2 0.001
 Vortex_ICD_50 0.3 0.0012
 Vortex_ICD_50 0.4 0.0014
 Vortex_ICD_50 0.5 0.0016
 Vortex_ICD_50 0.6 0.0017
 Vortex_ICD_50 0.7 0.0019
 Vortex_ICD_50 0.8 0.002
 Vortex_ICD_50 0.9 0.0021
 Vortex_ICD_50 1 0.0023
 Vortex_ICD_50 1.2 0.0025
 Vortex_ICD_50 1.4 0.0027
 Vortex_ICD_50 1.6 0.0029
 Vortex_ICD_50 1.8 0.0032
 Vortex_ICD_50 2 0.0032
 Vortex_ICD_50 2.5 0.0036
 Vortex_ICD_50 3 0.0039
 ;Tempest Rating Curve for Vortex ICD 55, No grate allowance
 Vortex_ICD_55 Rating 0 0
 Vortex_ICD_55 0.1 0.0009
 Vortex_ICD_55 0.2 0.0012
 Vortex_ICD_55 0.3 0.0015
 Vortex_ICD_55 0.4 0.0017
 Vortex_ICD_55 0.5 0.0019
 Vortex_ICD_55 0.6 0.0021
 Vortex_ICD_55 0.7 0.0023
 Vortex_ICD_55 0.8 0.0024
 Vortex_ICD_55 0.9 0.0026
 Vortex_ICD_55 1 0.0027
 Vortex_ICD_55 1.2 0.003
 Vortex_ICD_55 1.4 0.0032
 Vortex_ICD_55 1.6 0.0034
 Vortex_ICD_55 1.8 0.0036
 Vortex_ICD_55 2 0.0038
 Vortex_ICD_55 2.5 0.0043
 Vortex_ICD_55 3 0.0047
 ;Tempest Rating Curve for Vortex ICD 60, No grate allowance
 Vortex_ICD_60 Rating 0 0
 Vortex_ICD_60 0.1 0.0011
 Vortex_ICD_60 0.2 0.0015
 Vortex_ICD_60 0.3 0.0018
 Vortex_ICD_60 0.4 0.0021
 Vortex_ICD_60 0.5 0.0023
 Vortex_ICD_60 0.6 0.0025
 Vortex_ICD_60 0.7 0.0027
 Vortex_ICD_60 0.8 0.0029
 Vortex_ICD_60 0.9 0.0031
 Vortex_ICD_60 1 0.0032
 Vortex_ICD_60 1.2 0.0036
 Vortex_ICD_60 1.4 0.0038
 Vortex_ICD_60 1.6 0.0041
 Vortex_ICD_60 1.8 0.0043
 Vortex_ICD_60 2 0.0046
 Vortex_ICD_60 2.5 0.0051
 Vortex_ICD_60 3 0.0056
 ;Tempest Rating Curve for Vortex ICD 65, No grate allowance
 Vortex_ICD_65 Rating 0 0
 Vortex_ICD_65 0.1 0.0012
 Vortex_ICD_65 0.2 0.0016
 Vortex_ICD_65 0.3 0.002
 Vortex_ICD_65 0.4 0.0023
 Vortex_ICD_65 0.5 0.0025
 Vortex_ICD_65 0.6 0.0028
 Vortex_ICD_65 0.7 0.003
 Vortex_ICD_65 0.8 0.0032
 Vortex_ICD_65 0.9 0.0034
 Vortex_ICD_65 1 0.0036
 Vortex_ICD_65 1.2 0.004
 Vortex_ICD_65 1.4 0.0043
 Vortex_ICD_65 1.6 0.0046
 Vortex_ICD_65 1.8 0.0049
 Vortex_ICD_65 2 0.0051
 Vortex_ICD_65 2.5 0.0057
 Vortex_ICD_65 3 0.0063
 ;Tempest Rating Curve for Vortex ICD 70, No grate allowance
 Vortex_ICD_70 Rating 0 0
 Vortex_ICD_70 0.1 0.0013
 Vortex_ICD_70 0.2 0.0019
 Vortex_ICD_70 0.3 0.0023
 Vortex_ICD_70 0.4 0.0027
 Vortex_ICD_70 0.5 0.003
 Vortex_ICD_70 0.6 0.0033
 Vortex_ICD_70 0.7 0.0036
 Vortex_ICD_70 0.8 0.0038
 Vortex_ICD_70 0.9 0.0041
 Vortex_ICD_70 1 0.0043
 Vortex_ICD_70 1.2 0.0047
 Vortex_ICD_70 1.4 0.0051
 Vortex_ICD_70 1.6 0.0055
 Vortex_ICD_70 1.8 0.0058
 Vortex_ICD_70 2 0.0061
 Vortex_ICD_70 2.5 0.0068
 Vortex_ICD_70 3 0.0075
 ;Tempest Rating Curve for Vortex ICD 75, No grate allowance
 Vortex_ICD_75 Rating 0 0
 Vortex_ICD_75 0.1 0.0016
 Vortex_ICD_75 0.2 0.0022
 Vortex_ICD_75 0.3 0.0027
 Vortex_ICD_75 0.4 0.0032
 Vortex_ICD_75 0.5 0.0035
 Vortex_ICD_75 0.6 0.0039
 Vortex_ICD_75 0.7 0.0042
 Vortex_ICD_75 0.8 0.0045
 Vortex_ICD_75 0.9 0.0048
 Vortex_ICD_75 1 0.005
 Vortex_ICD_75 1.2 0.0055
 Vortex_ICD_75 1.4 0.0059
 Vortex_ICD_75 1.6 0.0063
 Vortex_ICD_75 1.8 0.0067
 Vortex_ICD_75 2 0.0071
 Vortex_ICD_75 2.5 0.0079
 Vortex_ICD_75 3 0.0087
 ;Tempest Rating Curve for Vortex ICD 80, No grate allowance
 Vortex_ICD_80 Rating 0 0
 Vortex_ICD_80 0.1 0.0018
 Vortex_ICD_80 0.2 0.0026
 Vortex_ICD_80 0.3 0.0031
 Vortex_ICD_80 0.4 0.0036
 Vortex_ICD_80 0.5 0.004
 Vortex_ICD_80 0.6 0.0044
 Vortex_ICD_80 0.7 0.0048
 Vortex_ICD_80 0.8 0.0051
 Vortex_ICD_80 0.9 0.0054
 Vortex_ICD_80 1 0.0057
 Vortex_ICD_80 1.2 0.0063
 Vortex_ICD_80 1.4 0.0068
 Vortex_ICD_80 1.6 0.0072
 Vortex_ICD_80 1.8 0.0077

Vortex_ICD_80 2 0.0081
Vortex_ICD_80 2.5 0.009
Vortex_ICD_80 3 0.0099

;Tempest Rating Curve for Vortex ICD 85, No grate allowance
Vortex_ICD_85 Rating 0 0
Vortex_ICD_85 0.1 0.002
Vortex_ICD_85 0.2 0.0029
Vortex_ICD_85 0.3 0.0035
Vortex_ICD_85 0.4 0.0041
Vortex_ICD_85 0.5 0.0045
Vortex_ICD_85 0.6 0.005
Vortex_ICD_85 0.7 0.0054
Vortex_ICD_85 0.8 0.0057
Vortex_ICD_85 0.9 0.0061
Vortex_ICD_85 1 0.0064
Vortex_ICD_85 1.2 0.007
Vortex_ICD_85 1.4 0.0076
Vortex_ICD_85 1.6 0.0081
Vortex_ICD_85 1.8 0.0086
Vortex_ICD_85 2 0.0091
Vortex_ICD_85 2.5 0.0101
Vortex_ICD_85 3 0.0111

;Tempest Rating Curve for Vortex ICD 90, No grate allowance
Vortex_ICD_90 Rating 0 0
Vortex_ICD_90 0.1 0.0022
Vortex_ICD_90 0.2 0.0022
Vortex_ICD_90 0.3 0.0039
Vortex_ICD_90 0.4 0.0045
Vortex_ICD_90 0.5 0.0051
Vortex_ICD_90 0.6 0.0055
Vortex_ICD_90 0.7 0.006
Vortex_ICD_90 0.8 0.0064
Vortex_ICD_90 0.9 0.0068
Vortex_ICD_90 1 0.0072
Vortex_ICD_90 1.2 0.0079
Vortex_ICD_90 1.4 0.0085
Vortex_ICD_90 1.6 0.0091
Vortex_ICD_90 1.8 0.0096
Vortex_ICD_90 2 0.0102
Vortex_ICD_90 2.5 0.0114
Vortex_ICD_90 3 0.0125

;Tempest Rating Curve for Vortex ICD 95, No grate allowance
Vortex_ICD_95 Rating 0 0
Vortex_ICD_95 0.1 0.0026
Vortex_ICD_95 0.2 0.0036
Vortex_ICD_95 0.3 0.0044
Vortex_ICD_95 0.4 0.0051
Vortex_ICD_95 0.5 0.0057
Vortex_ICD_95 0.6 0.0062
Vortex_ICD_95 0.7 0.0067
Vortex_ICD_95 0.8 0.0071
Vortex_ICD_95 0.9 0.0076
Vortex_ICD_95 1 0.008
Vortex_ICD_95 1.2 0.0087
Vortex_ICD_95 1.4 0.0094
Vortex_ICD_95 1.6 0.0101
Vortex_ICD_95 1.8 0.0107
Vortex_ICD_95 2 0.0113
Vortex_ICD_95 2.5 0.0126
Vortex_ICD_95 3 0.0138

;From Zurn Manual RD178
ZURN_Z150F-6NH Rating 0 0
ZURN_Z150F-6NH 0.0127 0.00503838308477861
ZURN_Z150F-6NH 0.0257 0.0132420013231177
ZURN_Z150F-6NH 0.0384 0.0234992054543888
ZURN_Z150F-6NH 0.0508 0.0357128365761305
ZURN_Z150F-6NH 0.0765 0.045501972611045
ZURN_Z150F-6NH 0.1024 0.0433196215564931

St_L1 Storage 0 0.073
St_L1 1.4 0.073
St_L1 1.7 198.79

St_L2 Storage 0 0.36
St_L2 1.75 0.36
St_L2 2.05 129.41
St_L2 2.1 129.41

St_L3 Storage 0 0.36
St_L3 1.96 0.36
St_L3 2.21 62.31

St_P1 Storage 0 0.36
St_P1 0.15 114.4
St_P1 0.31 114.4

St_P2 Storage 0 0.36
St_P2 0.15 100.57

St_P3 Storage 0 0.36
St_P3 0.15 92.14
St_P3 0.25 92.14

[TIMESERIES]
;;Name Date Time Value

;Rainfall (mm/hr)
24SCS10 01/01/2000 00:00:00 1.08
24SCS10 01/01/2000 00:15:00 1.08
24SCS10 01/01/2000 00:30:00 1.08
24SCS10 01/01/2000 00:45:00 1.08
24SCS10 01/01/2000 01:00:00 0.504
24SCS10 01/01/2000 01:15:00 0.504
24SCS10 01/01/2000 01:30:00 0.504
24SCS10 01/01/2000 01:45:00 0.504
24SCS10 01/01/2000 02:00:00 0.936
24SCS10 01/01/2000 02:15:00 0.936
24SCS10 01/01/2000 02:30:00 0.936
24SCS10 01/01/2000 02:45:00 0.936
24SCS10 01/01/2000 03:00:00 0.936
24SCS10 01/01/2000 03:15:00 0.936
24SCS10 01/01/2000 03:30:00 0.936
24SCS10 01/01/2000 03:45:00 0.936
24SCS10 01/01/2000 04:00:00 1.224
24SCS10 01/01/2000 04:15:00 1.224
24SCS10 01/01/2000 04:30:00 1.224
24SCS10 01/01/2000 04:45:00 1.224
24SCS10 01/01/2000 05:00:00 1.08
24SCS10 01/01/2000 05:15:00 1.08
24SCS10 01/01/2000 05:30:00 1.08
24SCS10 01/01/2000 05:45:00 1.08
24SCS10 01/01/2000 06:00:00 1.44
24SCS10 01/01/2000 06:15:00 1.44
24SCS10 01/01/2000 06:30:00 1.44
24SCS10 01/01/2000 06:45:00 1.44
24SCS10 01/01/2000 07:00:00 1.44
24SCS10 01/01/2000 07:15:00 1.44
24SCS10 01/01/2000 07:30:00 1.44
24SCS10 01/01/2000 07:45:00 1.44
24SCS10 01/01/2000 08:00:00 1.44
24SCS10 01/01/2000 08:15:00 1.44
24SCS10 01/01/2000 08:30:00 1.44
24SCS10 01/01/2000 08:45:00 1.944
24SCS10 01/01/2000 09:00:00 2.304
24SCS10 01/01/2000 09:15:00 2.304
24SCS10 01/01/2000 09:30:00 2.592
24SCS10 01/01/2000 09:45:00 2.592
24SCS10 01/01/2000 10:00:00 3.12
24SCS10 01/01/2000 10:15:00 3.12
24SCS10 01/01/2000 10:30:00 4.464
24SCS10 01/01/2000 10:45:00 4.464
24SCS10 01/01/2000 11:00:00 6.912
24SCS10 01/01/2000 11:15:00 6.912
24SCS10 01/01/2000 11:30:00 29.952
24SCS10 01/01/2000 11:45:00 79.488

24SCS10 01/01/2000 12:00:00 10.368
24SCS10 01/01/2000 12:15:00 10.368
24SCS10 01/01/2000 12:30:00 5.328
24SCS10 01/01/2000 12:45:00 5.328
24SCS10 01/01/2000 13:00:00 3.888
24SCS10 01/01/2000 13:15:00 3.888
24SCS10 01/01/2000 13:30:00 3.024
24SCS10 01/01/2000 13:45:00 3.024
24SCS10 01/01/2000 14:00:00 3.204
24SCS10 01/01/2000 14:15:00 2.304
24SCS10 01/01/2000 14:30:00 2.304
24SCS10 01/01/2000 14:45:00 2.304
24SCS10 01/01/2000 15:00:00 2.016
24SCS10 01/01/2000 15:15:00 2.016
24SCS10 01/01/2000 15:30:00 2.016
24SCS10 01/01/2000 15:45:00 2.016
24SCS10 01/01/2000 16:00:00 1.584
24SCS10 01/01/2000 16:15:00 1.584
24SCS10 01/01/2000 16:30:00 1.584
24SCS10 01/01/2000 16:45:00 1.584
24SCS10 01/01/2000 17:00:00 1.656
24SCS10 01/01/2000 17:15:00 1.656
24SCS10 01/01/2000 17:30:00 1.656
24SCS10 01/01/2000 17:45:00 1.656
24SCS10 01/01/2000 18:00:00 1.08
24SCS10 01/01/2000 18:15:00 1.08
24SCS10 01/01/2000 18:30:00 1.08
24SCS10 01/01/2000 18:45:00 1.08
24SCS10 01/01/2000 19:00:00 0.864
24SCS10 01/01/2000 19:15:00 0.864
24SCS10 01/01/2000 19:30:00 0.864
24SCS10 01/01/2000 19:45:00 0.864
24SCS10 01/01/2000 20:00:00 1.224
24SCS10 01/01/2000 20:15:00 1.224
24SCS10 01/01/2000 20:30:00 1.224
24SCS10 01/01/2000 20:45:00 1.224
24SCS10 01/01/2000 21:00:00 1.224
24SCS10 01/01/2000 21:15:00 1.224
24SCS10 01/01/2000 21:30:00 1.224
24SCS10 01/01/2000 21:45:00 1.224
24SCS10 01/01/2000 22:00:00 1.224
24SCS10 01/01/2000 22:15:00 1.224
24SCS10 01/01/2000 22:30:00 1.224
24SCS10 01/01/2000 22:45:00 1.224
24SCS10 01/01/2000 23:00:00 1.224
24SCS10 01/01/2000 23:15:00 1.224
24SCS10 01/01/2000 23:30:00 1.224
24SCS10 01/01/2000 23:45:00 1.224
24SCS10 01/02/2000 00:00:00 0

;Rainfall (mm/hr)
24SCS100 01/01/2000 00:00:00 1.548
24SCS100 01/01/2000 00:15:00 1.548
24SCS100 01/01/2000 00:30:00 1.548
24SCS100 01/01/2000 00:45:00 1.548
24SCS100 01/01/2000 01:00:00 0.7224
24SCS100 01/01/2000 01:15:00 0.7224
24SCS100 01/01/2000 01:30:00 0.7224
24SCS100 01/01/2000 01:45:00 0.7224
24SCS100 01/01/2000 02:00:00 1.3416
24SCS100 01/01/2000 02:15:00 1.3416
24SCS100 01/01/2000 02:30:00 1.3416
24SCS100 01/01/2000 02:45:00 1.3416
24SCS100 01/01/2000 03:00:00 1.3416
24SCS100 01/01/2000 03:15:00 1.3416
24SCS100 01/01/2000 03:30:00 1.3416
24SCS100 01/01/2000 03:45:00 1.3416
24SCS100 01/01/2000 04:00:00 1.7544
24SCS100 01/01/2000 04:15:00 1.7544
24SCS100 01/01/2000 04:30:00 1.7544
24SCS100 01/01/2000 04:45:00 1.7544
24SCS100 01/01/2000 05:00:00 1.548
24SCS100 01/01/2000 05:15:00 1.548
24SCS100 01/01/2000 05:30:00 1.548
24SCS100 01/01/2000 05:45:00 1.548
24SCS100 01/01/2000 06:00:00 2.064
24SCS100 01/01/2000 06:15:00 2.064
24SCS100 01/01/2000 06:30:00 2.064
24SCS100 01/01/2000 06:45:00 2.064
24SCS100 01/01/2000 07:00:00 2.064
24SCS100 01/01/2000 07:15:00 2.064
24SCS100 01/01/2000 07:30:00 2.064
24SCS100 01/01/2000 07:45:00 2.064
24SCS100 01/01/2000 08:00:00 2.7864
24SCS100 01/01/2000 08:15:00 2.7864
24SCS100 01/01/2000 08:30:00 2.7864
24SCS100 01/01/2000 08:45:00 2.7864
24SCS100 01/01/2000 09:00:00 3.3024
24SCS100 01/01/2000 09:15:00 3.3024
24SCS100 01/01/2000 09:30:00 3.7152
24SCS100 01/01/2000 09:45:00 3.7152
24SCS100 01/01/2000 10:00:00 4.1472
24SCS100 01/01/2000 10:15:00 4.1472
24SCS100 01/01/2000 10:30:00 6.3984
24SCS100 01/01/2000 10:45:00 6.3984
24SCS100 01/01/2000 11:00:00 9.9072
24SCS100 01/01/2000 11:15:00 9.9072
24SCS100 01/01/2000 11:30:00 42.9312
24SCS100 01/01/2000 11:45:00 113.9328
24SCS100 01/01/2000 12:00:00 14.8608
24SCS100 01/01/2000 12:15:00 7.6368
24SCS100 01/01/2000 12:30:00 7.6368
24SCS100 01/01/2000 12:45:00 7.6368
24SCS100 01/01/2000 13:00:00 5.5728
24SCS100 01/01/2000 13:15:00 5.5728
24SCS100 01/01/2000 13:30:00 4.3344
24SCS100 01/01/2000 13:45:00 4.3344
24SCS100 01/01/2000 14:00:00 3.3024
24SCS100 01/01/2000 14:15:00 3.3024
24SCS100 01/01/2000 14:30:00 3.3024
24SCS100 01/01/2000 14:45:00 3.3024
24SCS100 01/01/2000 15:00:00 2.8896
24SCS100 01/01/2000 15:15:00 2.8896
24SCS100 01/01/2000 15:30:00 2.8896
24SCS100 01/01/2000 15:45:00 2.8896
24SCS100 01/01/2000 16:00:00 2.2704
24SCS100 01/01/2000 16:15:00 2.2704
24SCS100 01/01/2000 16:30:00 2.2704
24SCS100 01/01/2000 16:45:00 2.2704
24SCS100 01/01/2000 17:00:00 2.3736
24SCS100 01/01/2000 17:15:00 2.3736
24SCS100 01/01/2000 17:30:00 2.3736
24SCS100 01/01/2000 17:45:00 2.3736
24SCS100 01/01/2000 18:00:00 1.548
24SCS100 01/01/2000 18:15:00 1.548
24SCS100 01/01/2000 18:30:00 1.548
24SCS100 01/01/2000 18:45:00 1.548
24SCS100 01/01/2000 19:00:00 1.548
24SCS100 01/01/2000 19:15:00 1.2384
24SCS100 01/01/2000 19:30:00 1.2384
24SCS100 01/01/2000 19:45:00 1.2384
24SCS100 01/01/2000 20:00:00 1.7544
24SCS100 01/01/2000 20:15:00 1.7544
24SCS100 01/01/2000 20:30:00 1.7544
24SCS100 01/01/2000 20:45:00 1.7544
24SCS100 01/01/2000 21:00:00 1.1352
24SCS100 01/01/2000 21:15:00 1.1352
24SCS100 01/01/2000 21:30:00 1.1352
24SCS100 01/01/2000 21:45:00 1.1352
24SCS100 01/01/2000 22:00:00 1.032
24SCS100 01/01/2000 22:15:00 1.032
24SCS100 01/01/2000 22:30:00 1.032
24SCS100 01/01/2000 22:45:00 1.032
24SCS100 01/01/2000 23:00:00 1.032
24SCS100 01/01/2000 23:15:00 1.032
24SCS100 01/01/2000 23:30:00 1.032
24SCS100 01/01/2000 23:45:00 1.032
24SCS100 01/02/2000 00:00:00 0

;Rainfall (mm/hr)					
24SCS120	01/01/2000	00:00:00	1.8576	24SCS2	01/01/2000 12:15:00
24SCS120	01/01/2000	00:15:00	1.8576	24SCS2	01/01/2000 12:30:00
24SCS120	01/01/2000	00:30:00	1.8576	24SCS2	01/01/2000 12:45:00
24SCS120	01/01/2000	00:45:00	1.8576	24SCS2	01/01/2000 13:00:00
24SCS120	01/01/2000	01:00:00	0.86688	24SCS2	01/01/2000 13:15:00
24SCS120	01/01/2000	01:15:00	0.86688	24SCS2	01/01/2000 13:30:00
24SCS120	01/01/2000	01:30:00	0.86688	24SCS2	01/01/2000 13:45:00
24SCS120	01/01/2000	01:45:00	0.86688	24SCS2	01/01/2000 14:00:00
24SCS120	01/01/2000	02:00:00	1.60992	24SCS2	01/01/2000 14:15:00
24SCS120	01/01/2000	02:15:00	1.60992	24SCS2	01/01/2000 14:30:00
24SCS120	01/01/2000	02:30:00	1.60992	24SCS2	01/01/2000 14:45:00
24SCS120	01/01/2000	02:45:00	1.60992	24SCS2	01/01/2000 15:00:00
24SCS120	01/01/2000	03:00:00	1.60992	24SCS2	01/01/2000 15:15:00
24SCS120	01/01/2000	03:15:00	1.60992	24SCS2	01/01/2000 15:30:00
24SCS120	01/01/2000	03:30:00	1.60992	24SCS2	01/01/2000 15:45:00
24SCS120	01/01/2000	03:45:00	1.60992	24SCS2	01/01/2000 16:00:00
24SCS120	01/01/2000	04:00:00	2.10528	24SCS2	01/01/2000 16:15:00
24SCS120	01/01/2000	04:15:00	2.10528	24SCS2	01/01/2000 16:30:00
24SCS120	01/01/2000	04:30:00	2.10528	24SCS2	01/01/2000 16:45:00
24SCS120	01/01/2000	04:45:00	2.10528	24SCS2	01/01/2000 17:00:00
24SCS120	01/01/2000	05:00:00	1.8576	24SCS2	01/01/2000 17:15:00
24SCS120	01/01/2000	05:15:00	1.8576	24SCS2	01/01/2000 17:30:00
24SCS120	01/01/2000	05:30:00	1.8576	24SCS2	01/01/2000 17:45:00
24SCS120	01/01/2000	05:45:00	1.8576	24SCS2	01/01/2000 18:00:00
24SCS120	01/01/2000	06:00:00	2.4768	24SCS2	01/01/2000 18:15:00
24SCS120	01/01/2000	06:15:00	2.4768	24SCS2	01/01/2000 18:30:00
24SCS120	01/01/2000	06:30:00	2.4768	24SCS2	01/01/2000 18:45:00
24SCS120	01/01/2000	06:45:00	2.4768	24SCS2	01/01/2000 19:00:00
24SCS120	01/01/2000	07:00:00	2.4768	24SCS2	01/01/2000 19:15:00
24SCS120	01/01/2000	07:15:00	2.4768	24SCS2	01/01/2000 19:30:00
24SCS120	01/01/2000	07:30:00	2.4768	24SCS2	01/01/2000 20:00:00
24SCS120	01/01/2000	07:45:00	2.4768	24SCS2	01/01/2000 20:15:00
24SCS120	01/01/2000	08:00:00	3.34368	24SCS2	01/01/2000 20:30:00
24SCS120	01/01/2000	08:15:00	3.34368	24SCS2	01/01/2000 20:45:00
24SCS120	01/01/2000	08:30:00	3.34368	24SCS2	01/01/2000 21:00:00
24SCS120	01/01/2000	08:45:00	3.34368	24SCS2	01/01/2000 21:15:00
24SCS120	01/01/2000	09:00:00	3.96288	24SCS2	01/01/2000 21:30:00
24SCS120	01/01/2000	09:15:00	3.96288	24SCS2	01/01/2000 21:45:00
24SCS120	01/01/2000	09:30:00	4.45824	24SCS2	01/01/2000 22:00:00
24SCS120	01/01/2000	09:45:00	4.45824	24SCS2	01/01/2000 22:15:00
24SCS120	01/01/2000	10:00:00	5.69664	24SCS2	01/01/2000 22:30:00
24SCS120	01/01/2000	10:15:00	5.69664	24SCS2	01/01/2000 22:45:00
24SCS120	01/01/2000	10:30:00	7.67808	24SCS2	01/01/2000 23:00:00
24SCS120	01/01/2000	10:45:00	7.67808	24SCS2	01/01/2000 23:15:00
24SCS120	01/01/2000	11:00:00	11.88864	24SCS2	01/01/2000 23:30:00
24SCS120	01/01/2000	11:15:00	11.88864	24SCS2	01/01/2000 23:45:00
24SCS120	01/01/2000	11:30:00	51.51744	24SCS2	01/02/2000 00:00:00
24SCS120	01/01/2000	11:45:00	136.7193		
24SCS120	01/01/2000	12:00:00	1.78326		
24SCS120	01/01/2000	12:15:00	1.78326		
24SCS120	01/01/2000	12:30:00	9.16416		
24SCS120	01/01/2000	12:45:00	9.16416		
24SCS120	01/01/2000	13:00:00	6.68736		
24SCS120	01/01/2000	13:15:00	6.68736		
24SCS120	01/01/2000	13:30:00	5.20128		
24SCS120	01/01/2000	13:45:00	5.20128		
24SCS120	01/01/2000	14:00:00	3.96288		
24SCS120	01/01/2000	14:15:00	3.96288		
24SCS120	01/01/2000	14:30:00	3.96288		
24SCS120	01/01/2000	14:45:00	3.96288		
24SCS120	01/01/2000	15:00:00	3.46752		
24SCS120	01/01/2000	15:15:00	3.46752		
24SCS120	01/01/2000	15:30:00	3.46752		
24SCS120	01/01/2000	15:45:00	3.46752		
24SCS120	01/01/2000	16:00:00	2.72448		
24SCS120	01/01/2000	16:15:00	2.72448		
24SCS120	01/01/2000	16:30:00	2.72448		
24SCS120	01/01/2000	16:45:00	2.72448		
24SCS120	01/01/2000	17:00:00	2.84832		
24SCS120	01/01/2000	17:15:00	2.84832		
24SCS120	01/01/2000	17:30:00	2.84832		
24SCS120	01/01/2000	17:45:00	2.84832		
24SCS120	01/01/2000	18:00:00	1.8576		
24SCS120	01/01/2000	18:15:00	1.8576		
24SCS120	01/01/2000	18:30:00	1.8576		
24SCS120	01/01/2000	18:45:00	1.8576		
24SCS120	01/01/2000	19:00:00	1.48608		
24SCS120	01/01/2000	19:15:00	1.48608		
24SCS120	01/01/2000	19:30:00	1.48608		
24SCS120	01/01/2000	19:45:00	1.48608		
24SCS120	01/01/2000	20:00:00	2.10528		
24SCS120	01/01/2000	20:15:00	2.10528		
24SCS120	01/01/2000	20:30:00	2.10528		
24SCS120	01/01/2000	20:45:00	2.10528		
24SCS120	01/01/2000	21:00:00	1.36224		
24SCS120	01/01/2000	21:15:00	1.36224		
24SCS120	01/01/2000	21:30:00	1.36224		
24SCS120	01/01/2000	21:45:00	1.36224		
24SCS120	01/01/2000	22:00:00	1.2384		
24SCS120	01/01/2000	22:15:00	1.2384		
24SCS120	01/01/2000	22:30:00	1.2384		
24SCS120	01/01/2000	22:45:00	1.2384		
24SCS120	01/01/2000	23:00:00	1.2384		
24SCS120	01/01/2000	23:15:00	1.2384		
24SCS120	01/01/2000	23:30:00	1.2384		
24SCS120	01/01/2000	23:45:00	1.2384		
24SCS120	01/02/2000	00:00:00	0		
;Rainfall (mm/hr)					
24SCS2	01/01/2000	00:00:00	0.72		
24SCS2	01/01/2000	00:15:00	0.72		
24SCS2	01/01/2000	00:30:00	0.72		
24SCS2	01/01/2000	00:45:00	0.72		
24SCS2	01/01/2000	01:00:00	0.336		
24SCS2	01/01/2000	01:15:00	0.336		
24SCS2	01/01/2000	01:30:00	0.336		
24SCS2	01/01/2000	01:45:00	0.336		
24SCS2	01/01/2000	02:00:00	0.624		
24SCS2	01/01/2000	02:15:00	0.624		
24SCS2	01/01/2000	02:30:00	0.624		
24SCS2	01/01/2000	02:45:00	0.624		
24SCS2	01/01/2000	03:00:00	0.624		
24SCS2	01/01/2000	03:15:00	0.624		
24SCS2	01/01/2000	03:30:00	0.624		
24SCS2	01/01/2000	03:45:00	0.624		
24SCS2	01/01/2000	04:00:00	0.816		
24SCS2	01/01/2000	04:15:00	0.816		
24SCS2	01/01/2000	04:30:00	0.816		
24SCS2	01/01/2000	04:45:00	0.816		
24SCS2	01/01/2000	05:00:00	0.72		
24SCS2	01/01/2000	05:15:00	0.72		
24SCS2	01/01/2000	05:30:00	0.72		
24SCS2	01/01/2000	05:45:00	0.72		
24SCS2	01/01/2000	06:00:00	0.96		
24SCS2	01/01/2000	06:15:00	0.96		
24SCS2	01/01/2000	06:30:00	0.96		
24SCS2	01/01/2000	06:45:00	0.96		
24SCS2	01/01/2000	07:00:00	0.96		
24SCS2	01/01/2000	07:15:00	0.96		
24SCS2	01/01/2000	07:30:00	0.96		
24SCS2	01/01/2000	07:45:00	0.96		
24SCS2	01/01/2000	08:00:00	1.296		
24SCS2	01/01/2000	08:15:00	1.296		
24SCS2	01/01/2000	08:30:00	1.296		
24SCS2	01/01/2000	08:45:00	1.296		
24SCS2	01/01/2000	09:00:00	1.536		
24SCS2	01/01/2000	09:15:00	1.536		
24SCS2	01/01/2000	09:30:00	1.728		
24SCS2	01/01/2000	09:45:00	1.728		
24SCS2	01/01/2000	10:00:00	2.208		
24SCS2	01/01/2000	10:15:00	2.208		
24SCS2	01/01/2000	10:30:00	2.976		
24SCS2	01/01/2000	10:45:00	2.976		
24SCS2	01/01/2000	11:00:00	4.608		
24SCS2	01/01/2000	11:15:00	4.608		
24SCS2	01/01/2000	11:30:00	19.968		
24SCS2	01/01/2000	11:45:00	52.992		
24SCS2	01/01/2000	12:00:00	6.912		
;Rainfall (mm/hr)					

24SCS5	01/01/2000 00:00:00	0.936	24SCS50	01/01/2000 12:30:00	6.9264
24SCS5	01/01/2000 00:15:00	0.936	24SCS50	01/01/2000 12:45:00	6.9264
24SCS5	01/01/2000 00:30:00	0.936	24SCS50	01/01/2000 13:00:00	5.0544
24SCS5	01/01/2000 00:45:00	0.936	24SCS50	01/01/2000 13:15:00	5.0544
24SCS5	01/01/2000 01:00:00	0.4368	24SCS50	01/01/2000 13:30:00	3.9312
24SCS5	01/01/2000 01:15:00	0.4368	24SCS50	01/01/2000 13:45:00	3.9312
24SCS5	01/01/2000 01:30:00	0.4368	24SCS50	01/01/2000 14:00:00	2.9952
24SCS5	01/01/2000 01:45:00	0.3368	24SCS50	01/01/2000 14:15:00	2.9952
24SCS5	01/01/2000 02:00:00	0.8112	24SCS50	01/01/2000 14:30:00	2.9952
24SCS5	01/01/2000 02:15:00	0.8112	24SCS50	01/01/2000 14:45:00	2.9952
24SCS5	01/01/2000 02:30:00	0.8112	24SCS50	01/01/2000 15:00:00	2.6208
24SCS5	01/01/2000 02:45:00	0.8112	24SCS50	01/01/2000 15:15:00	2.6208
24SCS5	01/01/2000 03:00:00	0.8112	24SCS50	01/01/2000 15:30:00	2.6208
24SCS5	01/01/2000 03:15:00	0.8112	24SCS50	01/01/2000 15:45:00	2.6208
24SCS5	01/01/2000 03:30:00	0.8112	24SCS50	01/01/2000 16:00:00	2.6208
24SCS5	01/01/2000 03:45:00	0.8112	24SCS50	01/01/2000 16:15:00	2.0592
24SCS5	01/01/2000 04:00:00	1.0608	24SCS50	01/01/2000 16:30:00	2.0592
24SCS5	01/01/2000 04:15:00	1.0608	24SCS50	01/01/2000 16:45:00	2.0592
24SCS5	01/01/2000 04:30:00	1.0608	24SCS50	01/01/2000 17:00:00	2.1528
24SCS5	01/01/2000 04:45:00	1.0608	24SCS50	01/01/2000 17:15:00	2.1528
24SCS5	01/01/2000 05:00:00	0.936	24SCS50	01/01/2000 17:30:00	2.1528
24SCS5	01/01/2000 05:15:00	0.3368	24SCS50	01/01/2000 17:45:00	2.1528
24SCS5	01/01/2000 05:30:00	0.936	24SCS50	01/01/2000 18:00:00	1.404
24SCS5	01/01/2000 05:45:00	0.936	24SCS50	01/01/2000 18:15:00	1.404
24SCS5	01/01/2000 06:00:00	1.248	24SCS50	01/01/2000 18:30:00	1.404
24SCS5	01/01/2000 06:15:00	1.248	24SCS50	01/01/2000 18:45:00	1.404
24SCS5	01/01/2000 06:30:00	1.248	24SCS50	01/01/2000 19:00:00	1.1232
24SCS5	01/01/2000 06:45:00	1.248	24SCS50	01/01/2000 19:15:00	1.1232
24SCS5	01/01/2000 07:00:00	1.248	24SCS50	01/01/2000 19:30:00	1.1232
24SCS5	01/01/2000 07:15:00	1.248	24SCS50	01/01/2000 19:45:00	1.1232
24SCS5	01/01/2000 07:30:00	1.248	24SCS50	01/01/2000 20:00:00	1.5912
24SCS5	01/01/2000 07:45:00	1.248	24SCS50	01/01/2000 20:15:00	1.5912
24SCS5	01/01/2000 08:00:00	1.6848	24SCS50	01/01/2000 20:30:00	1.5912
24SCS5	01/01/2000 08:15:00	1.6848	24SCS50	01/01/2000 20:45:00	1.5912
24SCS5	01/01/2000 08:30:00	1.6848	24SCS50	01/01/2000 21:00:00	1.0236
24SCS5	01/01/2000 08:45:00	1.6848	24SCS50	01/01/2000 21:15:00	1.0236
24SCS5	01/01/2000 09:00:00	1.9968	24SCS50	01/01/2000 21:30:00	1.0236
24SCS5	01/01/2000 09:15:00	1.9968	24SCS50	01/01/2000 21:45:00	1.0296
24SCS5	01/01/2000 09:30:00	2.2464	24SCS50	01/01/2000 22:00:00	0.936
24SCS5	01/01/2000 09:45:00	2.2464	24SCS50	01/01/2000 22:15:00	0.936
24SCS5	01/01/2000 10:00:00	2.8704	24SCS50	01/01/2000 22:30:00	0.936
24SCS5	01/01/2000 10:15:00	2.8704	24SCS50	01/01/2000 22:45:00	0.936
24SCS5	01/01/2000 10:30:00	3.0668	24SCS50	01/01/2000 23:00:00	0.936
24SCS5	01/01/2000 10:45:00	3.0668	24SCS50	01/01/2000 23:15:00	0.936
24SCS5	01/01/2000 11:00:00	5.9904	24SCS50	01/01/2000 23:30:00	0.936
24SCS5	01/01/2000 11:15:00	5.9904	24SCS50	01/01/2000 23:45:00	0.936
24SCS5	01/01/2000 11:30:00	25.9584	24SCS50	01/02/2000 00:00:00	0
24SCS5	01/01/2000 11:45:00	68.8896			
			;Rainfall (mm/hr)		
3CH110	01/01/2000 00:00:00		3CH110	01/01/2000 00:00:00	3.755
3CH110	01/01/2000 00:10:00		3CH110	01/01/2000 00:10:00	4.478
3CH110	01/01/2000 00:20:00		3CH110	01/01/2000 00:20:00	5.593
3CH110	01/01/2000 00:30:00		3CH110	01/01/2000 00:30:00	7.551
3CH110	01/01/2000 00:40:00		3CH110	01/01/2000 00:40:00	11.936
3CH110	01/01/2000 00:50:00		3CH110	01/01/2000 00:50:00	30.856
3CH110	01/01/2000 01:00:00		3CH110	01/01/2000 01:00:00	122.142
3CH110	01/01/2000 01:10:00		3CH110	01/01/2000 01:10:00	35.57
3CH110	01/01/2000 01:20:00		3CH110	01/01/2000 01:20:00	18.159
3CH110	01/01/2000 01:30:00		3CH110	01/01/2000 01:30:00	12.238
3CH110	01/01/2000 01:40:00		3CH110	01/01/2000 01:40:00	9.269
3CH110	01/01/2000 01:50:00		3CH110	01/01/2000 01:50:00	7.492
3CH110	01/01/2000 02:00:00		3CH110	01/01/2000 02:00:00	6.309
3CH110	01/01/2000 02:10:00		3CH110	01/01/2000 02:10:00	5.465
3CH110	01/01/2000 02:20:00		3CH110	01/01/2000 02:20:00	4.833
3CH110	01/01/2000 02:30:00		3CH110	01/01/2000 02:30:00	4.338
3CH110	01/01/2000 02:40:00		3CH110	01/01/2000 02:40:00	3.942
3CH110	01/01/2000 02:50:00		3CH110	01/01/2000 02:50:00	3.617
3CH110	01/01/2000 03:00:00		3CH110	01/01/2000 03:00:00	0
			;Rainfall (mm/hr)		
3CH1120	01/01/2000 00:00:00		3CH1120	01/01/2000 00:00:00	5.339
3CH1120	01/01/2000 00:10:00		3CH1120	01/01/2000 00:10:00	6.376
3CH1120	01/01/2000 00:20:00		3CH1120	01/01/2000 00:20:00	7.977
3CH1120	01/01/2000 00:30:00		3CH1120	01/01/2000 00:30:00	10.797
3CH1120	01/01/2000 00:40:00		3CH1120	01/01/2000 00:40:00	17.136
3CH1120	01/01/2000 00:50:00		3CH1120	01/01/2000 00:50:00	45.128
3CH1120	01/01/2000 01:00:00		3CH1120	01/01/2000 01:00:00	178.107
3CH1120	01/01/2000 01:10:00		3CH1120	01/01/2000 01:10:00	51.056
3CH1120	01/01/2000 01:20:00		3CH1120	01/01/2000 01:20:00	26.93
3CH1120	01/01/2000 01:30:00		3CH1120	01/01/2000 01:30:00	17.571
3CH1120	01/01/2000 01:40:00		3CH1120	01/01/2000 01:40:00	13.277
3CH1120	01/01/2000 01:50:00		3CH1120	01/01/2000 01:50:00	10.712
3CH1120	01/01/2000 02:00:00		3CH1120	01/01/2000 02:00:00	9.008
3CH1120	01/01/2000 02:10:00		3CH1120	01/01/2000 02:10:00	7.793
3CH1120	01/01/2000 02:20:00		3CH1120	01/01/2000 02:20:00	6.893
3CH1120	01/01/2000 02:30:00		3CH1120	01/01/2000 02:30:00	6.174
3CH1120	01/01/2000 02:40:00		3CH1120	01/01/2000 02:40:00	5.607
3CH1120	01/01/2000 02:50:00		3CH1120	01/01/2000 02:50:00	5.142
3CH1120	01/01/2000 03:00:00		3CH1120	01/01/2000 03:00:00	0
			;Rainfall (mm/hr)		
3CH120	01/01/2000 00:00:00		3CH120	01/01/2000 00:00:00	6.405801
3CH120	01/01/2000 00:10:00		3CH120	01/01/2000 00:10:00	7.6512
3CH120	01/01/2000 00:20:00		3CH120	01/01/2000 00:20:00	9.572401
3CH120	01/01/2000 00:30:00		3CH120	01/01/2000 00:30:00	12.9564
3CH120	01/01/2000 00:40:00		3CH120	01/01/2000 00:40:00	20.5632
3CH120	01/01/2000 00:50:00		3CH120	01/01/2000 00:50:00	54.1536
3CH120	01/01/2000 01:00:00		3CH120	01/01/2000 01:00:00	213.7284
3CH120	01/01/2000 01:10:00		3CH120	01/01/2000 01:10:00	61.1772
3CH120	01/01/2000 01:20:00		3CH120	01/01/2000 01:20:00	31.3956
3CH120	01/01/2000 01:30:00		3CH120	01/01/2000 01:30:00	21.0852
3CH120	01/01/2000 01:40:00		3CH120	01/01/2000 01:40:00	15.9324
3CH120	01/01/2000 01:50:00		3CH120	01/01/2000 01:50:00	12.8544
3CH120	01/01/2000 02:00:00		3CH120	01/01/2000 02:00:00	10.8096
3CH120	01/01/2000 02:10:00		3CH120	01/01/2000 02:10:00	9.351601
3CH120	01/01/2000 02:20:00		3CH120	01/01/2000 02:20:00	8.259601
3CH120	01/01/2000 02:30:00		3CH120	01/01/2000 02:30:00	7.4958
3CH120	01/01/2000 02:40:00		3CH120	01/01/2000 02:40:00	6.17284
3CH120	01/01/2000 02:50:00		3CH120	01/01/2000 02:50:00	6.170401
3CH120	01/01/2000 03:00:00		3CH120	01/01/2000 03:00:00	0
			;Rainfall (mm/hr)		
3CH125	01/01/2000 00:00:00		3CH125	01/01/2000 00:00:00	2.491
3CH125	01/01/2000 00:10:00		3CH125	01/01/2000 00:10:00	2.966
3CH125	01/01/2000 00:20:00		3CH125	01/01/2000 00:20:00	3.696
3CH125	01/01/2000 00:30:00		3CH125	01/01/2000 00:30:00	4.976
3CH125	01/01/2000 00:40:00		3CH125	01/01/2000 00:40:00	7.828
3CH125	01/01/2000 00:50:00		3CH125	01/01/2000 00:50:00	19.966
3CH125	01/01/2000 01:00:00		3CH125	01/01/2000 01:00:00	76.805
3CH125	01/01/2000 01:10:00		3CH125	01/01/2000 01:10:00	22.777
3CH125	01/01/2000 01:20:00		3CH125	01/01/2000 01:20:00	16.562
3CH125	01/01/2000 01:30:00		3CH125	01/01/2000 01:30:00	8.025
3CH125	01/01/2000 01:40:00		3CH125	01/01/2000 01:40:00	6.096
3CH125	01/01/2000 01:50:00		3CH125	01/01/2000 01:50:00	4.938
3CH125	01/01/2000 02:00:00		3CH125	01/01/2000 02:00:00	4.165
3CH125	01/01/2000 02:10:00		3CH125	01/01/2000 02:10:00	3.613
3CH125	01/01/2000 02:20:00		3CH125	01/01/2000 02:20:00	3.197
3CH125	01/01/2000 02:30:00		3CH125	01/01/2000 02:30:00	2.873
3CH125	0				

Post-Development 3-hour Chicago 1:2 year Event

October 2024

[MAP]
 DIMENSIONS 381360.7266 5033019.65495 381502.5034 5033143.67005
 UNITS Meters

[COORDINATES]
 ;; Node X-Coord Y-Coord
 ;;-----
 S2_7_(P-Stm) 381424.754 5033138.033
 OP1 381401.916 5033025.292
 OP2 381462.548 5033049.302
 OP3 381403.805 5033026.688
 OP7 381448.424 5033041.047
 Roof1 381447.098 5033044.455
 Roof2 381448.424 5033041.047
 St_L1 381395.548 5033108.811
 St_L2 381417.381 5033128.938
 St_L3 381450.027 5033054.56
 St_P1 381406.853 5033073.521
 St_P2 381416.312 5033051.852
 St_UnGrd 381396.599 5033036.713
 SUI 381400.429 5033088.237

[VERTICES]
 ;; Link X-Coord Y-Coord
 ;;-----
 W_LL 381414.65 5033129.488
 W_LL 381395.979 5033112.147

[POLYGONS]
 ;; Subcatchment X-Coord Y-Coord
 ;;-----
 L1_1 381426.561 5033106.239
 L1_1 381433.371 5033109.212
 L1_1 381435.156 5033095.96
 L1_1 381435.156 5033095.96
 L1_1 381435.928 5033041.204
 L1_1 381430.376 5033033.492
 L1_1 381429.744 5033033.928
 L1_1 381429.096 5033034.342
 L1_1 381428.435 5033034.734
 L1_1 381427.76 5033035.102
 L1_1 381427.074 5033035.446
 L1_1 381426.375 5033037.77
 L1_1 381425.758 5033036.025
 L1_1 381425.134 5033036.264
 L1_1 381424.503 5033036.484
 L1_1 381423.865 5033036.685
 L1_1 381423.221 5033036.865
 L1_1 381422.515 5033037.128
 L1_1 381422.218 5033037.301
 L1_1 381423.23 5033037.654
 L1_1 381423.251 5033037.916
 L1_1 381423.281 5033038.178
 L1_1 381423.32 5033038.438
 L1_1 381423.368 5033038.696
 L1_1 381423.425 5033038.953
 L1_1 381423.49 5033039.208
 L1_1 381423.564 5033039.46
 L1_1 381423.647 5033039.71
 L1_1 381423.738 5033039.957
 L1_1 381423.838 5033040.2
 L1_1 381423.946 5033040.44
 L1_1 381423.962 5033040.676
 L1_1 381424.036 5033040.908
 L1_1 381424.318 5033041.136
 L1_1 381424.458 5033041.359
 L1_1 381424.605 5033041.577
 L1_1 381424.76 5033041.79
 L1_1 381424.921 5033041.997
 L1_1 381424.989 5033042.189
 L1_1 381425.056 5033042.305
 L1_1 381425.448 5033042.584
 L1_1 381425.637 5033042.768
 L1_1 381425.831 5033042.945
 L1_1 381426.032 5033043.115
 L1_1 381426.239 5033043.278
 L1_1 381426.435 5033043.434
 L1_1 381426.628 5033043.622
 L1_1 381426.89 5033043.723
 L1_1 381427.116 5033043.857
 L1_1 381427.348 5033043.982
 L1_1 381427.583 5033044.1
 L1_1 381427.822 5033044.209
 L1_1 381428.054 5033044.391
 L1_1 381441.12 5033050.021
 L1_1 381441.401 5033050.162
 L1_1 381441.677 5033050.313
 L1_1 381441.947 5033050.472
 L1_1 381442.212 5033050.642
 L1_1 381442.471 5033050.82
 L1_1 381442.73 5033051.008
 L1_1 381442.969 5033051.204
 L1_1 381443.207 5033051.408
 L1_1 381443.438 5033051.621
 L1_1 381443.662 5033051.841
 L1_1 381443.878 5033052.07
 L1_1 381444.086 5033052.305
 L1_1 381444.285 5033052.548
 L1_1 381444.486 5033052.789
 L1_1 381444.658 5033053.054
 L1_1 381444.831 5033053.316
 L1_1 381444.995 5033053.585
 L1_1 381445.149 5033053.858
 L1_1 381445.294 5033054.137
 L1_1 381445.448 5033054.421
 L1_1 381445.653 5033054.71
 L1_1 381445.668 5033055.002
 L1_1 381445.772 5033055.299
 L1_1 381445.866 5033055.598
 L1_1 381445.95 5033055.901
 L1_1 381446.022 5033056.207
 L1_1 381446.085 5033056.515
 L1_1 381446.156 5033056.815
 L1_1 381446.176 5033057.137
 L1_1 381446.206 5033057.449
 L1_1 381446.224 5033057.763
 L1_1 381446.232 5033058.077
 L1_1 381446.229 5033058.392
 L1_1 381446.245 5033058.705
 L1_1 381446.189 5033058.919
 L1_1 381446.153 5033059.331
 L1_1 381446.106 5033059.641
 L1_1 381446.048 5033059.95
 L1_1 381445.98 5033060.257
 L1_1 381445.901 5033060.561
 L1_1 381445.811 5033060.862
 L1_1 381445.711 5033061.157
 L1_1 381445.6 5033061.454
 L1_1 381445.479 5033061.744
 L1_1 381442.344 5033068.909
 L1_1 381442.775 5033069.097
 L1_1 381426.561 5033106.239
 L1_2 381446.635 5033124.034
 L1_2 381446.533 5033124.377
 L1_2 381404.547 5033110.503
 L1_2 381408.488 5033101.475
 L1_2 381404.701 5033099.821
 L1_2 381405.665 5033097.614
 L1_2 381401.22 5033095.674
 L1_2 381400.599 5033097.094
 L1_2 381394.888 5033098.444
 L1_2 381394.298 5033093.034
 L1_2 381389.532 5033090.954
 L1_2 381389.672 5033090.633
 L1_2 381386.265 5033089.146
 L1_2 381386.988 5033087.5
 L1_2 381370.061 5033080.111
 L1_2 381367.171 5033086.731

[REPORT]
 ;Reporting Options
 INPUT YES
 CONTROLS NO
 SUBCATCHMENTS ALL
 NODES ALL
 LINKS ALL

[TAGS]
 Subcatch L1_1 Landscape
 Subcatch L1_2 Landscape
 Subcatch L1_3 Landscape
 Subcatch S2 Parking_Lot
 Subcatch S3_1 Parking_Lot
 Subcatch S3_2 Parking_Lot
 Subcatch S5 Building
 Subcatch S6 Building
 Subcatch S7 Ramp
 Node St_L1 RYCB
 Node St_L2 RYCB
 Node St_L3 RYCB
 Node St_UnGrd Uncderground_Storage
 Link C1 RY_Storm

			S7	381427.822	5033044.209
L1_2	381373.676	5033092.727	S7	381425.421	5033049.708
L1_2	381375.266	5033094.193	S7	381430.118	5033051.785
L1_2	381382.117	5033100.508	S7	381425.847	5033061.708
L1_2	381407.635	5033124.034	;;Storage Node X-Coord Y-Coord		
L1_3	381425.929	5033107.688	;-----		
L1_3	381421.474	5033117.892	[SYMBOLS]		
L1_3	381415.643	5033115.347	;;Gage X-Coord Y-Coord		
L1_3	381421.65	5033124.44	;-----		
L1_3	381421.373	5033136.698			
L1_3	381433.371	5033109.212			
L1_3	381426.561	5033106.239			
L1_3	381425.929	5033107.688			
S1	381496.059	5033067.453			
S1	381458.119	5033060.155			
S1	381482.156	5033095.436			
S1	381483.973	5033094.136			
S1	381494.933	5033069.433			
S1	381496.059	5033067.453			
S2	381422.855	5033068.564			
S2	381425.847	5033061.708			
S2	381430.118	5033051.785			
S2	381421.65	5033107.688			
S2	381427.822	5033044.209			
S2	381427.583	5033044.099			
S2	381427.347	5033043.982			
S2	381427.116	5033043.856			
S2	381426.889	5033043.723			
S2	381426.667	5033043.582			
S2	381426.45	5033043.433			
S2	381426.338	5033043.378			
S2	381426.032	5033043.114			
S2	381425.831	5033042.944			
S2	381425.636	5033042.768			
S2	381425.448	5033042.584			
S2	381425.266	5033042.395			
S2	381424.09	5033041.219			
S2	381424.921	5033041.997			
S2	381424.759	5033041.789			
S2	381424.605	5033041.577			
S2	381424.458	5033041.359			
S2	381424.318	5033041.136			
S2	381424.186	5033040.908			
S2	381424.062	5033040.676			
S2	381424.016	5033040.444			
S2	381423.838	5033040.2			
S2	381423.738	5033039.957			
S2	381423.647	5033039.71			
S2	381423.564	5033039.46			
S2	381423.49	5033039.208			
S2	381423.425	5033039.13			
S2	381423.368	5033038.696			
S2	381423.32	5033038.438			
S2	381423.281	5033038.177			
S2	381423.251	5033037.916			
S2	381423.23	5033037.654			
S2	381423.218	5033037.391			
S2	381423.215	5033037.228			
S2	381423.221	5033036.865			
S2	381422.554	5033037.03			
S2	381421.883	5033037.174			
S2	381421.207	5033037.296			
S2	381420.528	5033037.397			
S2	381419.846	5033037.477			
S2	381419.612	5033037.335			
S2	381418.476	5033037.171			
S2	381417.789	5033037.586			
S2	381417.102	5033037.579			
S2	381408.289	5033038.705			
S2	381399.672	5033058.444			
S2	381422.855	5033068.564			
S3_1	381386.588	5033069.146			
S3_1	381389.672	5033090.633			
S3_1	381389.532	5033090.954			
S3_1	381394.298	5033093.034			
S3_1	381393.818	5033094.134			
S3_1	381400.599	5033097.094			
S3_1	381404.22	5033095.774			
S3_1	381405.665	5033099.614			
S3_1	381404.701	5033099.821			
S3_1	381408.488	5033101.475			
S3_1	381415.264	5033085.953			
S3_1	381392.081	5033075.833			
S3_1	381386.988	5033087.133			
S3_2	381415.081	5033087.833			
S3_2	381415.644	5033085.953			
S3_2	381422.855	5033068.564			
S3_2	381399.672	5033058.444			
S3_2	381392.081	5033075.833			
S5	381421.474	5033117.892			
S5	381432.346	5033092.987			
S5	381442.145	5033069.097			
S5	381442.847	5033069.098			
S5	381404.547	5033110.503			
S5	381421.474	5033117.892			
S6	381386.988	5033087.5			
S6	381408.289	5033038.705			
S6	381391.361	5033031.316			
S6	381393.061	5033080.111			
S6	381392.958	5033099.515			
S7	381425.847	5033061.708			
S7	381436.845	5033066.509			
S7	381442.344	5033068.909			
S7	381445.479	5033061.744			
S7	381445.6	5033061.494			
S7	381445.711	5033061.16			
S7	381445.811	5033060.52			
S7	381445.901	5033060.561			
S7	381445.98	5033060.257			
S7	381446.048	5033059.95			
S7	381446.106	5033059.641			
S7	381446.153	5033059.331			
S7	381446.19	5033059.119			
S7	381446.215	5033058.705			
S7	381446.229	5033058.392			
S7	381446.232	5033058.077			
S7	381446.224	5033057.763			
S7	381446.206	5033057.449			
S7	381446.176	5033057.137			
S7	381446.136	5033056.825			
S7	381446.105	5033056.515			
S7	381446.022	5033056.207			
S7	381445.95	5033055.901			
S7	381445.866	5033055.598			
S7	381445.772	5033055.299			
S7	381445.668	5033055.002			
S7	381445.553	5033054.71			
S7	381445.421	5033054.421			
S7	381445.294	5033054.137			
S7	381445.149	5033053.858			
S7	381444.995	5033053.585			
S7	381444.831	5033053.316			
S7	381444.658	5033053.054			
S7	381444.476	5033052.798			
S7	381444.385	5033052.518			
S7	381444.086	5033052.305			
S7	381443.878	5033052.07			
S7	381443.662	5033051.841			
S7	381443.438	5033051.621			
S7	381443.207	5033051.408			
S7	381442.969	5033051.204			
S7	381442.733	5033051.008			
S7	381442.471	5033050.82			
S7	381442.212	5033050.642			
S7	381441.947	5033050.472			
S7	381441.677	5033050.313			
S7	381441.401	5033050.162			
S7	381441.12	5033050.021			
S7	381440.834	5033049.891			

Post-Development 3-hour Chicago 1:2 year Event

October 2024

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.3)

***** Element Count *****

Number of rain gages 1
Number of subcatchments ... 10
Number of nodes 14
Number of links 12
Number of pollutants 0
Number of land uses 0

***** Raingage Summary *****

Name	Data Source	Data Type	Recording Interval
Rainfall	3CH12	INTENSITY	10 min.

***** Subcatchment Summary *****

Name	Area	Width	%Imperv	%Slope	Rain Gage	Outlet
L1_1	0.07	134.06	10.01	2.0000	Rainfall	St_L3
L1_2	0.07	15.82	8.45	2.0000	Rainfall	St_L1
L1_3	0.03	71.61	1.39	2.0000	Rainfall	St_L2
S1	0.16	38.19	14.29	2.0000	Rainfall	St_L3
S2	0.06	16.17	90.74	2.0000	Rainfall	St_P2
S3_1	0.04	10.81	99.29	2.0000	Rainfall	SU1
S3_2	0.05	13.27	98.96	2.0000	Rainfall	St_P1
S5	0.10	22.12	100.00	1.0000	Rainfall	Roof2
S6	0.10	22.12	100.00	1.0000	Rainfall	Roof1
S7	0.03	28.53	72.19	15.0000	Rainfall	St_UnGrd

***** Node Summary *****

Name	Type	Invert Elev.	Max. Depth	Ponded Area	External Inflow
527_(P-Stm)	OUTFALL	81.23	0.00	0.0	
OF1	OUTFALL	80.67	0.00	0.0	
OF2	OUTFALL	80.91	0.00	0.0	
OF3	OUTFALL	80.67	0.00	0.0	
OF7	OUTFALL	80.67	0.00	0.0	
Roof1	STORAGE	95.85	0.15	0.0	
Roof2	STORAGE	96.85	0.15	0.0	
St_L1	STORAGE	84.20	1.70	0.0	
St_L2	STORAGE	83.90	2.10	0.0	
St_L3	STORAGE	83.09	2.21	0.0	
St_P1	STORAGE	85.70	0.31	0.0	
St_P2	STORAGE	85.50	0.15	0.0	
St_UnGrd	STORAGE	81.97	1.00	Yes	
SU1	STORAGE	85.70	0.25	0.0	

***** Link Summary *****

Name	From Node	To Node	Type	Length	%Slope
Roughness					
C1	St_L1	St_L2	CONDUIT	33.1	0.9050
0.0130	W_L1	St_L2	WEIR		
W1	St_P1	St_P2	WEIR		
W2	SU1	St_P1	WEIR		
O_St_L3	St_L3	OF2	OUTLET		
O_L1	SU1	St_UnGrd	OUTLET		
O_L2	St_P1	St_UnGrd	OUTLET		
O_L3	St_P2	St_UnGrd	OUTLET		
O_L4	St_L2	527_(P-Stm)	OUTLET		
OR1	St_UnGrd	OF1	OUTLET		
ROOF1	Roof1	OF3	OUTLET		
ROOF2	Roof2	OF7	OUTLET		

***** Cross Section Summary *****

Conduit	Shape	Full Depth	Full Area	Hyd. Rad.	Max. Width	No. of Barrels	Full Flow
C1	CIRCULAR	0.25	0.05	0.06	0.25	1	0.06

***** Analysis Options *****

Flow Units CMS

Process Models:

Rainfall/Runoff YES
RDI NO
Snowmelt NO
Groundwater NO
Flow Routing YES
Ponding Allowed NO
Water Quality NO
Infiltration Method HORTON
Flow Routing Method DYNWAVE
Subcatchment Method EXTRAN
Starting Date 01/01/2000 00:00:00
Ending Date 01/01/2000 06:00:00
Antecedent Dry Days 0.0
Report Time Step 00:01:00
Wet Time Step 00:01:00
Dry Time Step 00:01:00
Routing Time Step 0.00 sec
Variable Time Step YES
Maximum Trials 8
Number of Threads 1
Head Tolerance 0.001500 m

***** Runoff Quantity Continuity hectare-m

Total Precipitation	0.022	31.879
Evaporation Loss	0.000	0.000
Infiltration Loss	0.010	14.896
Surface Runoff	0.011	16.108
Final Storage	0.001	0.893
Continuity Error (%)	-0.053	

***** Flow Routing Continuity hectare-m

Dry Weather Inflow	0.000	0.000
Wet Weather Inflow	0.011	0.113
Groundwater Inflow	0.000	0.000
RDI Inflow	0.000	0.000
External Inflow	0.000	0.000
External Outflow	0.011	0.114
Flooding Loss	0.000	0.000
Evaporation Loss	0.000	0.000
Exfiltration Loss	0.000	0.000

Initial Stored Volume	0.000	0.000
Final Stored Volume	0.000	0.000
Continuity Error (%)	-0.053	

***** Time-Step Critical Elements *****

None

***** Highest Flow Instability Indexes *****

Link ROOF1 (3)
Link ROOF2 (3)

***** Most Frequent Nonconverging Nodes *****

Convergence obtained at all time steps.

***** Routing Time Step Summary *****

Minimum Time Step	: 0.50 sec
Average Time Step	: 1.00 sec
Maximum Time Step	: 1.00 sec
% of Time in Steady State	: 0.00
Average Iterations per Step	: 2.00
% of Steps Not Converging	: 0.00

***** Time Step Frequencies *****

1.55 - 0.87 sec : 100.00 %

0.571 - 0.758 sec : 0.00 %

0.578 - 0.660 sec : 0.00 %

0.660 - 0.574 sec : 0.00 %

0.574 - 0.500 sec : 0.00 %

***** Subcatchment Runoff Summary *****

Total Runoff	Total Runoff	Total Runoff	Total Runon	Total Evap	Total Infil	Imperv	Perv
Subcatchment mm	Runoff mm	Runoff mm	Runon mm	Evap mm	Infil mm	Runoff mm	Runoff mm
-----	-----	-----	-----	-----	-----	-----	-----
L1_1	1.55	0.00	0.00	0.048	31.88	0.00	30.21
L1_2	0.37	0.00	0.00	0.012	31.88	0.00	31.38
L1_3	0.69	0.00	0.00	0.022	31.88	0.00	31.14
S1	1.53	0.00	0.00	0.048	31.88	0.00	30.14
S2	2.154	0.02	0.01	0.864	31.88	0.00	27.52
S3_1	30.11	0.01	0.01	0.945	31.88	0.00	30.11
S3_2	30.02	0.01	0.01	0.942	31.88	0.00	30.01
S5	30.31	0.03	0.02	0.951	31.88	0.00	30.31
S7	30.31	0.03	0.02	0.951	31.88	0.00	30.31

***** Node Depth Summary *****

Average Depth Meters	Maximum Depth Meters	Maximum Depth Meters	Time of Max HGL days hr:min	Reported Max Depth Meters
Node Type				
527_(P-Stm)	OUTFALL	0.43	1.04	82.27 0 01:34
OF1	OUTFALL	0.50	0.50	81.17 0 00:00
OF2	OUTFALL	0.55	0.55	81.46 0 00:00
OF3	OUTFALL	0.50	0.50	81.17 0 00:00
OF7	OUTFALL	0.50	0.50	81.17 0 00:00
Roof1	STORAGE	0.01	0.03	96.88 0 01:43
Roof2	STORAGE	0.01	0.01	84.21 0 01:11
St_L1	STORAGE	0.00	0.05	83.95 0 01:13
St_L2	STORAGE	0.00	0.05	83.95 0 01:13
St_L3	STORAGE	0.00	0.06	83.15 0 01:10
St_P1	STORAGE	0.00	0.02	85.72 0 01:10
St_P2	STORAGE	0.00	0.02	85.52 0 01:10
St_UnGrd	STORAGE	0.03	0.25	82.22 0 01:20
SU1	STORAGE	0.00	0.02	85.72 0 01:10

Flow	Maximum Lateral Inflow	Maximum Total Inflow	Time of Max Occurrence	Total Inflow
Balance	Inflow	Inflow	Volume	Volume
Error Node Percent	Type	CMS	days hr:min	10^6 ltr
-----	-----	-----	-----	-----
527_(P-Stm)	OUTFALL	0.000	0.001	0 01:13
OF1	OUTFALL	0.000	0.010	0 01:00
OF2	OUTFALL	0.000	0.005	0 01:10
OF3	OUTFALL	0.000	0.002	0 00:52
OF7	OUTFALL	0.000	0.002	0 00:52
Roof1	STORAGE	0.021	0.021	0 01:10
Roof2	STORAGE	0.021	0.021	0 01:10
St_L1	STORAGE	0.000	0.000	0 01:10
St_L2	STORAGE	0.001	0.001	0 01:10
St_L3	STORAGE	0.005	0.005	0 01:10
St_P1	STORAGE	0.010	0.010	0 01:10
St_P2	STORAGE	0.012	0.012	0 01:10
St_UnGrd	STORAGE	0.005	0.036	0 01:10
SU1	STORAGE	0.008	0.008	0 01:10

Post-Development 3-hour Chicago 1:2 year Event

October 2024

Node Surcharge Summary

No nodes were surcharged.

Node Flooding Summary

No nodes were flooded.

Storage Volume Summary

	Average	Avg	Evap	Exfil	Maximum	Max	Time of Max
Maximum	Volume	Pcnt	Pcnt	Pcnt	Volume	Pcnt	Occurrence
Outflow					1000 m ³		
Storage Unit	1000 m ³	Full	Loss	Loss	1000 m ³	Full	days hr:min
CMS							

Roof1	0.007	8.4	0.0	0.0	0.017	20.5	0 01:43
Roof2	0.007	8.4	0.0	0.0	0.017	20.5	0 01:43
St_L1	0.000	0.0	0.0	0.0	0.000	0.0	0 01:11
St_L2	0.000	0.0	0.0	0.0	0.000	0.1	0 01:13
Ss_L3	0.000	0.0	0.0	0.0	0.000	0.3	0 01:10
St_P1	0.000	0.0	0.0	0.0	0.000	0.6	0 01:10
St_P2	0.000	0.1	0.0	0.0	0.000	2.5	0 01:10
St_UnGrd	0.002	2.7	0.0	0.0	0.016	24.8	0 01:20
SU1	0.000	0.0	0.0	0.0	0.000	0.6	0 01:10
SU8	0.008						

Outfall Loading Summary

Outfall Node	Flow Freq	Avg Flow CMS	Max Flow CMS	Total Volume 10 ⁶ ltr
S27_(P-Stm)	6.86	0.000	0.001	0.000
OF1	56.63	0.004	0.010	0.050
OF2	40.99	0.000	0.005	0.003
OF3	77.70	0.002	0.002	0.030
OF7	77.70	0.002	0.002	0.030
System	51.98	0.008	0.019	0.114

Link Flow Summary

Link	Type	Maximum Flow CMS	Time of Max Occurrence days hr:min	Maximum Velocity m/sec	Max/ Full Flow	Max/ Full Depth
C1	CONDUIT	0.000	0 01:11	0.16	0.01	0.12
W_L1	WEIR	0.000	0 00:00			0.00
W1	WEIR	0.000	0 00:00			0.00
W2	WEIR	0.000	0 00:00			0.00
O_St_L3	DUMMY	0.005	0 01:10			
OL1	DUMMY	0.008	0 01:10			
OL2	DUMMY	0.010	0 01:10			
OL3	DUMMY	0.012	0 01:10			
OL4	DUMMY	0.001	0 01:13			
OR1	DUMMY	0.010	0 01:00			
ROOF1	DUMMY	0.002	0 00:52			
ROOF2	DUMMY	0.002	0 00:52			

Flow Classification Summary

Conduit	Adjusted /Actual Length	Fraction of Time in Flow Class							
		Up Dry	Up Dry	Down Sub Dry	Sup Crit	Up Crit	Down Crit	Norm Crit	Inlet Ltd Ctrl
C1	1.00	0.19	0.00	0.00	0.81	0.00	0.00	0.00	0.06 0.00

Conduit Surcharge Summary

No conduits were surcharged.

Analysis begun on: Mon Oct 7 14:30:32 2024
 Analysis ended on: Mon Oct 7 14:30:32 2024
 Total elapsed time: < 1 sec

Post-Development 3-hour Chicago 1:100 year Event

[TITLE]
 ;;Project Title/Notes

[OPTIONS]
 ;;Option Value
 FLOW_UNITS CMS
 INFILTRATION HORTON
 FLOW_ROUTING DYNWAVE
 LINK_OFSETS ELEVATION
 MIN_SLOPE 0
 ALLOW_PONDING NO
 SKIP_STEADY_STATE NO

START_DATE 01/01/2000
 START_TIME 00:00:00
 REPORT_START_DATE 01/01/2000
 REPORT_START_TIME 00:00:00
 END_DATE 01/01/2000
 END_TIME 06:00:00
 SWEEP_START 00:01:00
 SWEEP_END 12/31
 DRY_DAYS 0
 REPORT_STEP 00:01:00
 WET_STEP 00:01:00
 DRY_STEP 00:01:00
 ROUTING_STEP 00:00:00
 RULE_STEP 00:00:00

INERTIAL_DAMPING PARTIAL
 NORMAL_FLOW_LIMITED BOTH
 FORCE_MAIN_EQUATION H-W
 VARIABLE_STEP 0.75
 LENGTHENING_STEP 0
 MIN_SURFACE 0
 MAX_TRIALS 8
 HEAD_TOLERANCE 0.0015
 SYS_FLOW_TOL 5
 LAT_FLOW_TOL 5
 MINIMUM_STEP 0.5
 THREADS 12

[EVAPORATION]
 ;;Data Source Parameters
 ;;
 CONSTANT 0.0
 DRY_ONLY NO

[RAINGAGES]
 ;;Name Format Interval SCF Source
 Rainfall INTENSITY 0:10 1.0 TIMESERIES 3CHI100

[SUBCATCHMENTS]
 ;;Name Rain Gage Outlet Area %Imperv Width %Slope CurbLen
 ShowPack Rainfall St_L1 0.0699 10.014 134.062 2 0

LL_1 Rainfall St_L3 0.0699 10.014 134.062 2 0
 LL_2 Rainfall St_L1 0.0681 8.447 15.82 2 0
 LL_3 Rainfall St_L2 0.0324 3.893 77.605 2 0
 S1 Rainfall St_L3 0.1577 14.286 38.49 2 0
 S2 Rainfall St_P2 0.0391 90.287 10.808 2 0
 S3_1 Rainfall St_U1 0.0391 99.287 10.808 2 0
 S3_2 Rainfall St_P1 0.048 98.957 13.267 2 0
 S5 Rainfall Roof2 0.0983 100 22.118 1 0
 S6 Rainfall Roof1 0.0983 100 22.118 1 0
 S7 Rainfall St_UnGrd 0.0317 72.194 28.53 15 0

[SQUAREAS]
 ;;Subcatchment N-Imperv N-Perv S-Imperv S-Perv PctZero RouteTo PctRouted
 ;;
 LL_1 0.013 0.25 1.57 4.67 0 PERVIOUS 100
 LL_2 0.013 0.25 1.57 4.67 0 PERVIOUS 100
 LL_3 0.013 0.25 1.57 4.67 0 PERVIOUS 80
 S1 0.013 0.25 1.57 4.67 0 OUTLET
 S2 0.013 0.25 1.57 4.67 0 OUTLET
 S3_1 0.013 0.25 1.57 4.67 0 OUTLET
 S3_2 0.013 0.25 1.57 4.67 0 OUTLET
 S5 0.013 0.25 1.57 4.67 0 OUTLET
 S6 0.013 0.25 1.57 4.67 0 OUTLET
 S7 0.013 0.25 1.57 4.67 0 OUTLET

[INFILTRATION]
 ;;Subcatchment Param1 Param2 Param3 Param4 Param5
 ;;
 LL_1 76.2 13.2 4.14 7 0
 LL_2 76.2 13.2 4.14 7 0
 LL_3 76.2 13.2 4.14 7 0
 S1 76.2 13.2 4.14 7 0
 S2 76.2 13.2 4.14 7 0
 S3_1 76.2 13.2 4.14 7 0
 S3_2 76.2 13.2 4.14 7 0
 S5 76.2 13.2 4.14 7 0
 S6 76.2 13.2 4.14 7 0
 S7 76.2 13.2 4.14 7 0

[OUTFALLS]
 ;;Name Elevation Type Stage Data Gated Route To
 527_(P-Stm) 81.228 TIMESERIES 527_CHI100yr NO
 OF1 80.67 FIXED 81.17 NO
 OF2 80.911 FIXED 81.46 NO
 OF3 80.67 FIXED 81.17 NO
 OF7 80.67 FIXED 81.17 NO

[STORAGE]
 ;;Name Elev. MaxDepth Ksat IMD Shape Curve Name/Params
 ;;
 Roof1 96.85 0.15 0 FUNCTIONAL 0 0 559.44 0
 Roof2 96.85 0.15 0 FUNCTIONAL 0 0 559.44 0
 St_L1 84.2 1.7 0 TABULAR St_L1 0
 St_L2 83.9 2.1 0 TABULAR St_L2 0
 St_L3 83.09 2.21 0 TABULAR St_L3 0
 St_P1 85.7 0.31 0 TABULAR St_P1 0
 St_P2 85.5 0.15 0 TABULAR St_P2 0
 St_UnGrd 81.971 1 0 FUNCTIONAL 0 0 64 0
 St_U1 85.7 0.25 0 TABULAR St_P3 0

[CONDUTTS]
 ;;Name From Node To Node Length Roughness InOffset OutOffset
 InitFlow MaxFlow
 ;;
 C1 0.04 St_L1 St_L2 33.149 0.013 84.2 83.9

[WEIRS]
 ;;Name EndCoeff From Node To Node Type CrestHt Qcoeff Gated
 EndCon RoadSurf RoadWidth Coeff. Curve

W_L1 0 0 NO St_L2 St_P1 St_P2 TRANSVERSE 85.95 1.84 NO
 W1 0 0 NO St_P1 St_UnGrd TRANSVERSE 85.85 1.84 NO
 W2 0 0 YES St_P1 St_UnGrd TRANSVERSE 85.87 1.84 NO

[OUTLETS]
 ;;Name Qexpon Gated From Node To Node Offset Type QTable/Qcoeff
 ;;
 O_St_L3 St_L3 OF2 83.09 TABULAR/HEAD MHF_IPEX_TYPE_B
 NO SU1 St_UnGrd 85.7 TABULAR/HEAD ZURN_Z150F-6NH
 OL1 St_P1 St_UnGrd 85.7 TABULAR/HEAD ZURN_Z150F-6NH
 NO OL2 St_P2 St_UnGrd 85.5 TABULAR/HEAD ZURN_Z150F-6NH
 NO OL3 St_P2 St_UnGrd 85.5 TABULAR/HEAD ZURN_Z150F-6NH
 NO OL4 St_L2 527_(P-Stm) 83.9 TABULAR/HEAD Vortex_ICD_70
 NO OR1 St_UnGrd OF1 81.971 TABULAR/HEAD O_St_UnGrd
 NO ROOF1 Roof1 OF3 96.85 TABULAR/HEAD O_Roof1
 NO ROOF2 Roof2 OF7 96.85 TABULAR/HEAD O_Roof2

[XSECTIONS]
 ;;Link Culvert Shape Geom1 Geom2 Geom3 Geom4 Barrels
 ;;
 C1 CIRCULAR 0.25 0 0 0 1
 W_L1 RECT_OPEN 0.05 3 0 0 0
 W1 RECT_OPEN 0.16 15 0 0 0
 W2 RECT_OPEN 0.08 15 0 0 0

[LOSSES]
 ;;Link Kentry Kexit Kavg Flap Gate Seepage
 ;;
 St_UnGrd FLOW InfiltratedInflow FLOW 1.0 1 0

[INFLows]
 ;;Node Constituent Time Series Type Mfactor Sfactor Baseline Pattern
 ;;
 St_UnGrd FLOW InfiltratedInflow FLOW 1.0 1 0

[CURVES]
 ;;Name Type X-Value Y-Value
 ;;
 CBMH Inlet Capture Curve based on the OSDG Appendix 7-A
 CBMH Rating 0 0.122 0.06
 CBMH Rating 0.183 0.073
 CBMH Rating 0.2 0.076
 CBMH Rating 0.243 0.084
 CBMH Rating 0.305 0.094

D1_GRATE_A_OPSD403.01 Rating 0.02 0.00762
 D1_GRATE_A_OPSD403.01 Rating 0.04 0.01524
 D1_GRATE_A_OPSD403.01 Rating 0.08 0.0381
 D1_GRATE_A_OPSD403.01 Rating 0.12 0.06858
 D1_GRATE_A_OPSD403.01 Rating 0.2 0.1524
 D1_GRATE_A_OPSD403.01 Rating 0.26 0.23622
 D1_GRATE_A_OPSD403.01 Rating 0.36 0.4572
 D1_GRATE_A_OPSD403.01 Rating 0.46 0.6858

D1_GRATE_C_OPSD403.01 Rating 0 0.01465
 D1_GRATE_C_OPSD403.01 Rating 0.04 0.0293
 D1_GRATE_C_OPSD403.01 Rating 0.08 0.07325
 D1_GRATE_C_OPSD403.01 Rating 0.12 0.13185
 D1_GRATE_C_OPSD403.01 Rating 0.2 0.22815
 D1_GRATE_C_OPSD403.01 Rating 0.26 0.45415
 D1_GRATE_C_OPSD403.01 Rating 0.36 0.879
 D1_GRATE_C_OPSD403.01 Rating 0.46 1.3185

Les Produits MURPHCO Ltée Rating 0 0.0127 4E-05
 Les Produits MURPHCO Ltée Rating 0 0.0044 0.00019
 Les Produits MURPHCO Ltée Rating 0 0.0508 0.00051
 Les Produits MURPHCO Ltée Rating 0 0.0635 0.00064
 Les Produits MURPHCO Ltée Rating 0.0762 0.00083
 Les Produits MURPHCO Ltée Rating 0.0889 0.00093
 Les Produits MURPHCO Ltée Rating 0.1016 0.00101
 Les Produits MURPHCO Ltée Rating 0.1143 0.00111
 Les Produits MURPHCO Ltée Rating 0.127 0.0012
 Les Produits MURPHCO Ltée Rating 0.1397 0.00128
 Les Produits MURPHCO Ltée Rating 0.1524 0.00135

Reversed Flow from rear yard manhole_lid to the Street
 Manhole_Lid Rating 0 0
 Manhole_Lid Rating 0.11 0
 Manhole_Lid Rating 0.2 0.187
 Manhole_Lid Rating 0.3 0.395
 Manhole_Lid Rating 0.4 0.602
 Manhole_Lid Rating 0.5 0.81
 Manhole_Lid Rating 0.6 1.018
 Manhole_Lid Rating 0.7 1.225
 Manhole_Lid Rating 0.8 1.433
 Manhole_Lid Rating 0.9 1.641
 Manhole_Lid Rating 1 1.848

Tempest Rating Curve for MHF IPEX TYPE A, No grate allowance
 MHF_IPEX_TYPE_A Rating 0 0
 MHF_IPEX_TYPE_A Rating 0.1 0.0057
 MHF_IPEX_TYPE_A Rating 0.2 0.0081
 MHF_IPEX_TYPE_A Rating 0.3 0.0099
 MHF_IPEX_TYPE_A Rating 0.4 0.0114
 MHF_IPEX_TYPE_A Rating 0.5 0.0128
 MHF_IPEX_TYPE_A Rating 0.6 0.014
 MHF_IPEX_TYPE_A Rating 0.7 0.0151
 MHF_IPEX_TYPE_A Rating 0.8 0.0162
 MHF_IPEX_TYPE_A Rating 0.9 0.0172
 MHF_IPEX_TYPE_A Rating 1 0.0181
 MHF_IPEX_TYPE_A Rating 1.2 0.0198
 MHF_IPEX_TYPE_A Rating 1.4 0.0214
 MHF_IPEX_TYPE_A Rating 1.6 0.0229
 MHF_IPEX_TYPE_A Rating 1.8 0.0243
 MHF_IPEX_TYPE_A Rating 2 0.0256
 MHF_IPEX_TYPE_A Rating 2.5 0.0286
 MHF_IPEX_TYPE_A Rating 3 0.0313

Tempest Rating Curve for MHF IPEX TYPE B, No grate allowance
 MHF_IPEX_TYPE_B Rating 0 0
 MHF_IPEX_TYPE_B Rating 0.1 0.0081
 MHF_IPEX_TYPE_B Rating 0.2 0.0115
 MHF_IPEX_TYPE_B Rating 0.3 0.0141
 MHF_IPEX_TYPE_B Rating 0.4 0.0162
 MHF_IPEX_TYPE_B Rating 0.5 0.0182
 MHF_IPEX_TYPE_B Rating 0.6 0.0199
 MHF_IPEX_TYPE_B Rating 0.7 0.0215
 MHF_IPEX_TYPE_B Rating 0.8 0.023
 MHF_IPEX_TYPE_B Rating 0.9 0.0244
 MHF_IPEX_TYPE_B Rating 1 0.0257
 MHF_IPEX_TYPE_B Rating 1.2 0.0281
 MHF_IPEX_TYPE_B Rating 1.4 0.0304

MHF_IPEX_TYPE_B Rating 1.6 0.0325
MHF_IPEX_TYPE_B Rating 1.8 0.0344
MHF_IPEX_TYPE_B Rating 2 0.0363
MHF_IPEX_TYPE_B Rating 2.5 0.0406
MHF_IPEX_TYPE_B Rating 3 0.0445

;Tempest Rating Curve for MHF IPEX TYPE C, No grate allowance
MHF_IPEX_TYPE_C Rating 0.1 0.0106
MHF_IPEX_TYPE_C Rating 0.2 0.015
MHF_IPEX_TYPE_C Rating 0.3 0.0183
MHF_IPEX_TYPE_C Rating 0.4 0.0212
MHF_IPEX_TYPE_C Rating 0.5 0.0237
MHF_IPEX_TYPE_C Rating 0.6 0.0259
MHF_IPEX_TYPE_C Rating 0.7 0.028
MHF_IPEX_TYPE_C Rating 0.8 0.0299
MHF_IPEX_TYPE_C Rating 0.9 0.0317
MHF_IPEX_TYPE_C Rating 1 0.0335
MHF_IPEX_TYPE_C Rating 1.2 0.0366
MHF_IPEX_TYPE_C Rating 1.4 0.0396
MHF_IPEX_TYPE_C Rating 1.6 0.0423
MHF_IPEX_TYPE_C Rating 1.8 0.0459
MHF_IPEX_TYPE_C Rating 2 0.0473
MHF_IPEX_TYPE_C Rating 2.5 0.0529
MHF_IPEX_TYPE_C Rating 3 0.0579

;Tempest Rating Curve for MHF IPEX TYPE D, No grate allowance
MHF_IPEX_TYPE_D Rating 0 0
MHF_IPEX_TYPE_D Rating 0.1 0.0154
MHF_IPEX_TYPE_D Rating 0.2 0.0217
MHF_IPEX_TYPE_D Rating 0.3 0.0266
MHF_IPEX_TYPE_D Rating 0.4 0.0307
MHF_IPEX_TYPE_D Rating 0.5 0.0343
MHF_IPEX_TYPE_D Rating 0.6 0.0376
MHF_IPEX_TYPE_D Rating 0.7 0.0406
MHF_IPEX_TYPE_D Rating 0.8 0.044
MHF_IPEX_TYPE_D Rating 0.9 0.0461
MHF_IPEX_TYPE_D Rating 1 0.0485
MHF_IPEX_TYPE_D Rating 1.2 0.0532
MHF_IPEX_TYPE_D Rating 1.4 0.0574
MHF_IPEX_TYPE_D Rating 1.6 0.0614
MHF_IPEX_TYPE_D Rating 1.8 0.0651
MHF_IPEX_TYPE_D Rating 2 0.0687
MHF_IPEX_TYPE_D Rating 2.5 0.0768
MHF_IPEX_TYPE_D Rating 3 0.0841

;Tempest Rating Curve for MHF IPEX TYPE E, No grate allowance
MHF_IPEX_TYPE_E Rating 0 0
MHF_IPEX_TYPE_E Rating 0.1 0.0205
MHF_IPEX_TYPE_E Rating 0.2 0.0289
MHF_IPEX_TYPE_E Rating 0.3 0.0355
MHF_IPEX_TYPE_E Rating 0.4 0.0409
MHF_IPEX_TYPE_E Rating 0.5 0.0458
MHF_IPEX_TYPE_E Rating 0.6 0.0501
MHF_IPEX_TYPE_E Rating 0.7 0.0542
MHF_IPEX_TYPE_E Rating 0.8 0.0579
MHF_IPEX_TYPE_E Rating 0.9 0.0614
MHF_IPEX_TYPE_E Rating 1 0.0647
MHF_IPEX_TYPE_E Rating 1.2 0.0709
MHF_IPEX_TYPE_E Rating 1.4 0.0766
MHF_IPEX_TYPE_E Rating 1.6 0.0819
MHF_IPEX_TYPE_E Rating 1.8 0.0868
MHF_IPEX_TYPE_E Rating 2 0.0915
MHF_IPEX_TYPE_E Rating 2.5 0.1023
MHF_IPEX_TYPE_E Rating 3 0.1121

O_Roof1 Rating 0 0
O_Roof1 Rating 0.001 0.002
O_Roof1 Rating 0.15 0.002

O_Roof2 Rating 0 0
O_Roof2 Rating 0.001 0.002
O_Roof2 Rating 0.15 0.002

O_St_L1 Rating 0 0
O_St_L1 Rating 0.001 0.003
O_St_L1 Rating 0.35 0.003

O_St_L2 Rating 0 0
O_St_L2 Rating 0.001 0.002
O_St_L2 Rating 0.35 0.002

O_St_L3 Rating 0 0
O_St_L3 Rating 0.001 0.0137
O_St_L3 Rating 0.35 0.0137

O_St_UnGrd Rating 0 0
O_St_UnGrd Rating 0.01 0.01
O_St_UnGrd Rating 1 0.01

;Tempest Rating Curve for Vortex ICD 100, No grate allowance
Vortex_ICD_100 Rating 0 0
Vortex_ICD_100 Rating 0.1 0.0028
Vortex_ICD_100 Rating 0.2 0.004
Vortex_ICD_100 Rating 0.3 0.0049
Vortex_ICD_100 Rating 0.4 0.0056
Vortex_ICD_100 Rating 0.5 0.0063
Vortex_ICD_100 Rating 0.6 0.0069
Vortex_ICD_100 Rating 0.7 0.0075
Vortex_ICD_100 Rating 0.8 0.0082
Vortex_ICD_100 Rating 0.9 0.0085
Vortex_ICD_100 Rating 1 0.0089
Vortex_ICD_100 Rating 1.2 0.0098
Vortex_ICD_100 Rating 1.4 0.0106
Vortex_ICD_100 Rating 1.6 0.0113
Vortex_ICD_100 Rating 1.8 0.012
Vortex_ICD_100 Rating 2 0.0126
Vortex_ICD_100 Rating 2.5 0.0141
Vortex_ICD_100 Rating 3 0.0155

;Tempest Rating Curve for Vortex ICD 105, No grate allowance
Vortex_ICD_105 Rating 0 0
Vortex_ICD_105 Rating 0.1 0.0031
Vortex_ICD_105 Rating 0.2 0.0044
Vortex_ICD_105 Rating 0.3 0.0054
Vortex_ICD_105 Rating 0.4 0.0062
Vortex_ICD_105 Rating 0.5 0.0069
Vortex_ICD_105 Rating 0.6 0.0076
Vortex_ICD_105 Rating 0.7 0.0082
Vortex_ICD_105 Rating 0.8 0.0088
Vortex_ICD_105 Rating 0.9 0.0093
Vortex_ICD_105 Rating 1 0.0098
Vortex_ICD_105 Rating 1.2 0.0107
Vortex_ICD_105 Rating 1.4 0.0116
Vortex_ICD_105 Rating 1.6 0.0124
Vortex_ICD_105 Rating 1.8 0.0131
Vortex_ICD_105 Rating 2 0.0139
Vortex_ICD_105 Rating 2.5 0.0155
Vortex_ICD_105 Rating 3 0.017

;Tempest Rating Curve for Vortex ICD 40, No grate allowance
Vortex_ICD_40 Rating 0 0
Vortex_ICD_40 Rating 0.1 0.0004
Vortex_ICD_40 Rating 0.2 0.0006
Vortex_ICD_40 Rating 0.3 0.0007
Vortex_ICD_40 Rating 0.4 0.0009
Vortex_ICD_40 Rating 0.5 0.001
Vortex_ICD_40 Rating 0.6 0.001
Vortex_ICD_40 Rating 0.7 0.0011
Vortex_ICD_40 Rating 0.8 0.0012
Vortex_ICD_40 Rating 0.9 0.0013
Vortex_ICD_40 Rating 1 0.0014
Vortex_ICD_40 Rating 1.2 0.0015
Vortex_ICD_40 Rating 1.4 0.0016
Vortex_ICD_40 Rating 1.6 0.0017
Vortex_ICD_40 Rating 1.8 0.0018
Vortex_ICD_40 Rating 2 0.0019
Vortex_ICD_40 Rating 2.5 0.0022
Vortex_ICD_40 Rating 3 0.0024

;Tempest Rating Curve for Vortex ICD 45, No grate allowance
Vortex_ICD_45 Rating 0 0
Vortex_ICD_45 Rating 0.1 0.0006
Vortex_ICD_45 Rating 0.2 0.0008
Vortex_ICD_45 Rating 0.3 0.001
Vortex_ICD_45 Rating 0.4 0.0011
Vortex_ICD_45 Rating 0.5 0.0013
Vortex_ICD_45 Rating 0.6 0.0014
Vortex_ICD_45 Rating 0.7 0.0015
Vortex_ICD_45 Rating 0.8 0.0016
Vortex_ICD_45 Rating 0.9 0.0017
Vortex_ICD_45 Rating 1 0.0018
Vortex_ICD_45 Rating 1.2 0.002
Vortex_ICD_45 Rating 1.4 0.0021
Vortex_ICD_45 Rating 1.6 0.0023
Vortex_ICD_45 Rating 1.8 0.0024
Vortex_ICD_45 Rating 2 0.0026
Vortex_ICD_45 Rating 2.5 0.0029
Vortex_ICD_45 Rating 3 0.0031

;Tempest Rating Curve for Vortex ICD 50, No grate allowance
Vortex_ICD_50 Rating 0 0
Vortex_ICD_50 Rating 0.1 0.0007
Vortex_ICD_50 Rating 0.2 0.001
Vortex_ICD_50 Rating 0.3 0.0012
Vortex_ICD_50 Rating 0.4 0.0014
Vortex_ICD_50 Rating 0.5 0.0016
Vortex_ICD_50 Rating 0.6 0.0018
Vortex_ICD_50 Rating 0.7 0.0019
Vortex_ICD_50 Rating 0.8 0.002
Vortex_ICD_50 Rating 0.9 0.0021
Vortex_ICD_50 Rating 1 0.0023
Vortex_ICD_50 Rating 1.2 0.0025
Vortex_ICD_50 Rating 1.4 0.0027
Vortex_ICD_50 Rating 1.6 0.0029
Vortex_ICD_50 Rating 1.8 0.003
Vortex_ICD_50 Rating 2 0.0032
Vortex_ICD_50 Rating 2.5 0.0036
Vortex_ICD_50 Rating 3 0.0039

;Tempest Rating Curve for Vortex ICD 55, No grate allowance
Vortex_ICD_55 Rating 0 0
Vortex_ICD_55 Rating 0.1 0.0009
Vortex_ICD_55 Rating 0.2 0.0012
Vortex_ICD_55 Rating 0.3 0.0015
Vortex_ICD_55 Rating 0.4 0.0017
Vortex_ICD_55 Rating 0.5 0.0019
Vortex_ICD_55 Rating 0.6 0.0021
Vortex_ICD_55 Rating 0.7 0.0023
Vortex_ICD_55 Rating 0.8 0.0024
Vortex_ICD_55 Rating 0.9 0.0026
Vortex_ICD_55 Rating 1 0.0027
Vortex_ICD_55 Rating 1.2 0.003
Vortex_ICD_55 Rating 1.4 0.0032
Vortex_ICD_55 Rating 1.6 0.0034
Vortex_ICD_55 Rating 1.8 0.0036
Vortex_ICD_55 Rating 2 0.0038
Vortex_ICD_55 Rating 2.5 0.0043
Vortex_ICD_55 Rating 3 0.0047

;Tempest Rating Curve for Vortex ICD 60, No grate allowance
Vortex_ICD_60 Rating 0 0
Vortex_ICD_60 Rating 0.1 0.0011
Vortex_ICD_60 Rating 0.2 0.0015
Vortex_ICD_60 Rating 0.3 0.0018
Vortex_ICD_60 Rating 0.4 0.0021
Vortex_ICD_60 Rating 0.5 0.0023
Vortex_ICD_60 Rating 0.6 0.0025
Vortex_ICD_60 Rating 0.7 0.0027
Vortex_ICD_60 Rating 0.8 0.0029
Vortex_ICD_60 Rating 0.9 0.0031
Vortex_ICD_60 Rating 1 0.0032
Vortex_ICD_60 Rating 1.2 0.0036
Vortex_ICD_60 Rating 1.4 0.0038
Vortex_ICD_60 Rating 1.6 0.0041
Vortex_ICD_60 Rating 1.8 0.0043
Vortex_ICD_60 Rating 2 0.0046
Vortex_ICD_60 Rating 2.5 0.0051
Vortex_ICD_60 Rating 3 0.0056

;Tempest Rating Curve for Vortex ICD 65, No grate allowance
Vortex_ICD_65 Rating 0 0
Vortex_ICD_65 Rating 0.1 0.0012
Vortex_ICD_65 Rating 0.2 0.0016
Vortex_ICD_65 Rating 0.3 0.002
Vortex_ICD_65 Rating 0.4 0.0023
Vortex_ICD_65 Rating 0.5 0.0025
Vortex_ICD_65 Rating 0.6 0.0028
Vortex_ICD_65 Rating 0.7 0.003
Vortex_ICD_65 Rating 0.8 0.0032
Vortex_ICD_65 Rating 0.9 0.0034
Vortex_ICD_65 Rating 1 0.0036
Vortex_ICD_65 Rating 1.2 0.004
Vortex_ICD_65 Rating 1.4 0.0043
Vortex_ICD_65 Rating 1.6 0.0046
Vortex_ICD_65 Rating 1.8 0.0049
Vortex_ICD_65 Rating 2 0.0051
Vortex_ICD_65 Rating 2.5 0.0057
Vortex_ICD_65 Rating 3 0.0063

;Tempest Rating Curve for Vortex ICD 70, No grate allowance
Vortex_ICD_70 Rating 0 0
Vortex_ICD_70 Rating 0.1 0.0013
Vortex_ICD_70 Rating 0.2 0.0019
Vortex_ICD_70 Rating 0.3 0.0023
Vortex_ICD_70 Rating 0.4 0.0027
Vortex_ICD_70 Rating 0.5 0.003
Vortex_ICD_70 Rating 0.6 0.0033
Vortex_ICD_70 Rating 0.7 0.0036
Vortex_ICD_70 Rating 0.8 0.0038
Vortex_ICD_70 Rating 0.9 0.0041
Vortex_ICD_70 Rating 1 0.0043
Vortex_ICD_70 Rating 1.2 0.0046
Vortex_ICD_70 Rating 1.4 0.0049
Vortex_ICD_70 Rating 1.6 0.0046
Vortex_ICD_70 Rating 1.8 0.0049
Vortex_ICD_70 Rating 2 0.0051
Vortex_ICD_70 Rating 2.5 0.0057
Vortex_ICD_70 Rating 3 0.0063

;Tempest Rating Curve for Vortex ICD 75, No grate allowance
Vortex_ICD_75 Rating 0 0
Vortex_ICD_75 Rating 0.1 0.0016
Vortex_ICD_75 Rating 0.2 0.0022
Vortex_ICD_75 Rating 0.3 0.0027
Vortex_ICD_75 Rating 0.4 0.0032
Vortex_ICD_75 Rating 0.5 0.0035
Vortex_ICD_75 Rating 0.6 0.0039
Vortex_ICD_75 Rating 0.7 0.0042
Vortex_ICD_75 Rating 0.8 0.0045
Vortex_ICD_75 Rating 0.9 0.0048
Vortex_ICD_75 Rating 1 0.0051
Vortex_ICD_75 Rating 1.2 0.0047
Vortex_ICD_75 Rating 1.4 0.0051
Vortex_ICD_75 Rating 1.6 0.0055
Vortex_ICD_75 Rating 1.8 0.0058
Vortex_ICD_75 Rating 2 0.0061
Vortex_ICD_75 Rating 2.5 0.0068
Vortex_ICD_75 Rating 3 0.0075

;Tempest Rating Curve for Vortex ICD 80, No grate allowance
Vortex_ICD_80 Rating 0 0
Vortex_ICD_80 Rating 0.1 0.0018
Vortex_ICD_80 Rating 0.2 0.0026
Vortex_ICD_80 Rating 0.3 0.0031
Vortex_ICD_80 Rating 0.4 0.0036
Vortex_ICD_80 Rating 0.5 0.004
Vortex_ICD_80 Rating 0.6 0.0044

Post-Development 3-hour Chicago 1:100-year Event

July 2024

```

Vortex_ICD_80 0.7 0.0048
Vortex_ICD_80 0.8 0.0051
Vortex_ICD_80 0.9 0.0054
Vortex_ICD_80 1 0.0057
Vortex_ICD_80 1.2 0.0063
Vortex_ICD_80 1.4 0.0068
Vortex_ICD_80 1.6 0.0072
Vortex_ICD_80 1.8 0.0077
Vortex_ICD_80 2 0.0081
Vortex_ICD_80 2.5 0.009
Vortex_ICD_80 3 0.0099

;Tempest Rating Curve for Vortex ICD 85, No grate allowance
Vortex_ICD_85 Rating 0 0
Vortex_ICD_85 0.1 0.002
Vortex_ICD_85 0.2 0.0029
Vortex_ICD_85 0.3 0.0035
Vortex_ICD_85 0.4 0.0041
Vortex_ICD_85 0.5 0.0045
Vortex_ICD_85 0.6 0.005
Vortex_ICD_85 0.7 0.0054
Vortex_ICD_85 0.8 0.0057
Vortex_ICD_85 0.9 0.0061
Vortex_ICD_85 1 0.0064
Vortex_ICD_85 1.2 0.007
Vortex_ICD_85 1.4 0.0076
Vortex_ICD_85 1.6 0.0081
Vortex_ICD_85 1.8 0.0086
Vortex_ICD_85 2 0.0091
Vortex_ICD_85 2.5 0.0101
Vortex_ICD_85 3 0.0111

;Tempest Rating Curve for Vortex ICD 90, No grate allowance
Vortex_ICD_90 Rating 0 0
Vortex_ICD_90 0.1 0.0022
Vortex_ICD_90 0.2 0.0032
Vortex_ICD_90 0.3 0.0039
Vortex_ICD_90 0.4 0.0045
Vortex_ICD_90 0.5 0.0051
Vortex_ICD_90 0.6 0.0055
Vortex_ICD_90 0.7 0.006
Vortex_ICD_90 0.8 0.0064
Vortex_ICD_90 0.9 0.0068
Vortex_ICD_90 1 0.0072
Vortex_ICD_90 1.2 0.0079
Vortex_ICD_90 1.4 0.0085
Vortex_ICD_90 1.6 0.0091
Vortex_ICD_90 1.8 0.0096
Vortex_ICD_90 2 0.0102
Vortex_ICD_90 2.5 0.0114
Vortex_ICD_90 3 0.0125

;Tempest Rating Curve for Vortex ICD 95, No grate allowance
Vortex_ICD_95 Rating 0 0
Vortex_ICD_95 0.1 0.0026
Vortex_ICD_95 0.2 0.0036
Vortex_ICD_95 0.3 0.0044
Vortex_ICD_95 0.4 0.0051
Vortex_ICD_95 0.5 0.0057
Vortex_ICD_95 0.6 0.0062
Vortex_ICD_95 0.7 0.0067
Vortex_ICD_95 0.8 0.0071
Vortex_ICD_95 0.9 0.0076
Vortex_ICD_95 1 0.008
Vortex_ICD_95 1.2 0.0087
Vortex_ICD_95 1.4 0.0094
Vortex_ICD_95 1.6 0.0101
Vortex_ICD_95 1.8 0.0107
Vortex_ICD_95 2 0.0113
Vortex_ICD_95 2.5 0.0126
Vortex_ICD_95 3 0.0138

;From Zurn Manual RD178
ZURN_Z150F-GNH Rating 0 0
ZURN_Z150F-GNH 0.0127 0.00503838308477861
ZURN_Z150F-GNH 0.0257 0.0132420013231177
ZURN_Z150F-GNH 0.0384 0.0234992054543888
ZURN_Z150F-GNH 0.0508 0.0357128365761305
ZURN_Z150F-GNH 0.0635 0.042501972111045
ZURN_Z150F-GNH 0.1024 0.0433196215564931

St_L1 Storage 0 0.073
St_L1 1.4 0.073
St_L1 1.7 198.79

St_L2 Storage 0 0.36
St_L2 1.75 0.36
St_L2 2.05 129.41
St_L2 2.1 129.41

St_L3 Storage 0 0.36
St_L3 1.96 0.36
St_L3 2.21 62.31

St_P1 Storage 0 0.36
St_P1 0.15 114.4
St_P1 0.31 114.4

St_P2 Storage 0 0.36
St_P2 0.15 100.57

St_P3 Storage 0 0.36
St_P3 0.15 92.14
St_P3 0.25 92.14

[TIMESERIES]
;Name Date Time Value
;-----
;Rainfall (mm/hr)
24SCS10 01/01/2000 00:00:00 1.08
24SCS10 01/01/2000 00:15:00 1.08
24SCS10 01/01/2000 00:30:00 1.08
24SCS10 01/01/2000 00:45:00 1.08
24SCS10 01/01/2000 01:00:00 0.504
24SCS10 01/01/2000 01:15:00 0.504
24SCS10 01/01/2000 01:30:00 0.504
24SCS10 01/01/2000 01:45:00 0.504
24SCS10 01/01/2000 02:00:00 0.936
24SCS10 01/01/2000 02:15:00 0.936
24SCS10 01/01/2000 02:30:00 0.936
24SCS10 01/01/2000 02:45:00 0.936
24SCS10 01/01/2000 03:00:00 0.936
24SCS10 01/01/2000 03:15:00 0.936
24SCS10 01/01/2000 03:30:00 0.936
24SCS10 01/01/2000 03:45:00 0.936
24SCS10 01/01/2000 04:00:00 1.224
24SCS10 01/01/2000 04:15:00 1.224
24SCS10 01/01/2000 04:30:00 1.224
24SCS10 01/01/2000 04:45:00 1.224
24SCS10 01/01/2000 05:00:00 1.08
24SCS10 01/01/2000 05:15:00 1.08
24SCS10 01/01/2000 05:30:00 1.08
24SCS10 01/01/2000 05:45:00 1.08
24SCS10 01/01/2000 06:00:00 1.44
24SCS10 01/01/2000 06:15:00 1.44
24SCS10 01/01/2000 06:30:00 1.44
24SCS10 01/01/2000 06:45:00 1.44
24SCS10 01/01/2000 07:00:00 1.44
24SCS10 01/01/2000 07:15:00 1.44
24SCS10 01/01/2000 07:30:00 1.44
24SCS10 01/01/2000 07:45:00 1.44
24SCS10 01/01/2000 08:00:00 1.44
24SCS10 01/01/2000 08:15:00 1.44
24SCS10 01/01/2000 08:30:00 1.44
24SCS10 01/01/2000 08:45:00 1.44
24SCS10 01/01/2000 09:00:00 2.304
24SCS10 01/01/2000 09:15:00 2.304
24SCS10 01/01/2000 09:30:00 2.592
24SCS10 01/01/2000 09:45:00 2.592
24SCS10 01/01/2000 10:00:00 2.592
24SCS10 01/01/2000 10:15:00 2.592
24SCS10 01/01/2000 10:30:00 2.592
24SCS10 01/01/2000 10:45:00 2.592
24SCS10 01/01/2000 11:00:00 6.912
24SCS10 01/01/2000 11:15:00 6.912
24SCS10 01/01/2000 11:30:00 2.952
24SCS10 01/01/2000 11:45:00 7.9488
24SCS10 01/01/2000 12:00:00 10.368
24SCS10 01/01/2000 12:15:00 10.368
24SCS10 01/01/2000 12:30:00 5.328
24SCS10 01/01/2000 12:45:00 5.328
24SCS10 01/01/2000 13:00:00 3.888
24SCS10 01/01/2000 13:15:00 3.888
24SCS10 01/01/2000 13:30:00 3.024
24SCS10 01/01/2000 13:45:00 3.024
24SCS10 01/01/2000 14:00:00 2.304
24SCS10 01/01/2000 14:15:00 2.304
24SCS10 01/01/2000 14:30:00 2.304
24SCS10 01/01/2000 14:45:00 2.304
24SCS10 01/01/2000 15:00:00 2.016
24SCS10 01/01/2000 15:15:00 2.016
24SCS10 01/01/2000 15:30:00 2.016
24SCS10 01/01/2000 15:45:00 2.016
24SCS10 01/01/2000 16:00:00 1.584
24SCS10 01/01/2000 16:30:00 1.584
24SCS10 01/01/2000 16:45:00 1.584
24SCS10 01/01/2000 17:00:00 1.656
24SCS10 01/01/2000 17:15:00 1.656
24SCS10 01/01/2000 17:30:00 1.656
24SCS10 01/01/2000 17:45:00 1.656
24SCS10 01/01/2000 18:00:00 1.08
24SCS10 01/01/2000 18:15:00 1.08
24SCS10 01/01/2000 18:30:00 1.08
24SCS10 01/01/2000 18:45:00 1.08
24SCS10 01/01/2000 19:00:00 0.864
24SCS10 01/01/2000 19:15:00 0.864
24SCS10 01/01/2000 19:30:00 0.864
24SCS10 01/01/2000 19:45:00 0.864
24SCS10 01/01/2000 20:00:00 1.224
24SCS10 01/01/2000 20:15:00 1.224
24SCS10 01/01/2000 20:30:00 1.224
24SCS10 01/01/2000 20:45:00 1.224
24SCS10 01/01/2000 21:00:00 0.792
24SCS10 01/01/2000 21:15:00 0.792
24SCS10 01/01/2000 21:30:00 0.792
24SCS10 01/01/2000 21:45:00 0.792
24SCS10 01/01/2000 22:00:00 0.72
24SCS10 01/01/2000 22:15:00 0.72
24SCS10 01/01/2000 22:30:00 0.72
24SCS10 01/01/2000 22:45:00 0.72
24SCS10 01/01/2000 23:00:00 0.72
24SCS10 01/01/2000 23:15:00 0.72
24SCS10 01/01/2000 23:30:00 0.72
24SCS10 01/01/2000 23:45:00 0.72
24SCS10 01/02/2000 00:00:00 0

;Rainfall (mm/hr)
24SCS100 01/01/2000 00:00:00 1.548
24SCS100 01/01/2000 00:15:00 1.548
24SCS100 01/01/2000 00:30:00 1.548
24SCS100 01/01/2000 00:45:00 1.548
24SCS100 01/01/2000 01:00:00 0.544
24SCS100 01/01/2000 01:15:00 0.544
24SCS100 01/01/2000 01:30:00 0.544
24SCS100 01/01/2000 01:45:00 0.544
24SCS100 01/01/2000 02:00:00 0.7224
24SCS100 01/01/2000 02:15:00 0.7224
24SCS100 01/01/2000 02:30:00 0.7224
24SCS100 01/01/2000 02:45:00 0.7224
24SCS100 01/01/2000 03:00:00 0.7224
24SCS100 01/01/2000 03:15:00 0.7224
24SCS100 01/01/2000 03:30:00 0.7224
24SCS100 01/01/2000 03:45:00 1.3416
24SCS100 01/01/2000 04:00:00 1.7548
24SCS100 01/01/2000 04:15:00 1.7548
24SCS100 01/01/2000 04:30:00 1.7548
24SCS100 01/01/2000 04:45:00 1.7548
24SCS100 01/01/2000 05:00:00 1.548
24SCS100 01/01/2000 05:15:00 1.548
24SCS100 01/01/2000 05:30:00 1.548
24SCS100 01/01/2000 05:45:00 1.548
24SCS100 01/01/2000 06:00:00 2.064
24SCS100 01/01/2000 06:15:00 2.064
24SCS100 01/01/2000 06:30:00 2.064
24SCS100 01/01/2000 06:45:00 2.064
24SCS100 01/01/2000 07:00:00 2.064
24SCS100 01/01/2000 07:15:00 2.064
24SCS100 01/01/2000 07:30:00 2.064
24SCS100 01/01/2000 07:45:00 2.064
24SCS100 01/01/2000 08:00:00 2.064
24SCS100 01/01/2000 08:15:00 2.7864
24SCS100 01/01/2000 08:30:00 2.7864
24SCS100 01/01/2000 08:45:00 2.7864
24SCS100 01/01/2000 09:00:00 3.3024
24SCS100 01/01/2000 09:15:00 3.3024
24SCS100 01/01/2000 09:30:00 3.7152
24SCS100 01/01/2000 09:45:00 3.7152
24SCS100 01/01/2000 10:00:00 4.7472
24SCS100 01/01/2000 10:15:00 4.7472
24SCS100 01/01/2000 10:30:00 6.3984
24SCS100 01/01/2000 10:45:00 6.3984
24SCS100 01/01/2000 11:00:00 9.9072
24SCS100 01/01/2000 11:15:00 9.9072
24SCS100 01/01/2000 11:30:00 42.1212
24SCS100 01/01/2000 11:45:00 113.932
24SCS100 01/01/2000 12:00:00 14.8608
24SCS100 01/01/2000 12:15:00 7.6368
24SCS100 01/01/2000 12:30:00 14.8608
24SCS100 01/01/2000 12:45:00 7.6368
24SCS100 01/01/2000 13:00:00 5.5728
24SCS100 01/01/2000 13:15:00 4.3344
24SCS100 01/01/2000 13:30:00 4.3344
24SCS100 01/01/2000 13:45:00 4.3344
24SCS100 01/01/2000 14:00:00 3.3024
24SCS100 01/01/2000 14:15:00 3.3024
24SCS100 01/01/2000 14:30:00 3.3024
24SCS100 01/01/2000 14:45:00 3.3024
24SCS100 01/01/2000 15:00:00 2.8896
24SCS100 01/01/2000 15:15:00 2.8896
24SCS100 01/01/2000 15:30:00 2.8896
24SCS100 01/01/2000 15:45:00 2.8896
24SCS100 01/01/2000 16:00:00 2.2704
24SCS100 01/01/2000 16:15:00 2.2704
24SCS100 01/01/2000 16:30:00 2.2704
24SCS100 01/01/2000 16:45:00 2.2704
24SCS100 01/01/2000 16:50:00 2.2704
24SCS100 01/01/2000 17:00:00 2.2704
24SCS100 01/01/2000 17:15:00 2.3736
24SCS100 01/01/2000 17:30:00 2.3736
24SCS100 01/01/2000 17:45:00 2.3736
24SCS100 01/01/2000 18:00:00 1.548
24SCS100 01/01/2000 18:15:00 1.548
24SCS100 01/01/2000 18:30:00 1.548
24SCS100 01/01/2000 18:45:00 1.548
24SCS100 01/01/2000 19:00:00 1.2384
24SCS100 01/01/2000 19:15:00 1.2384
24SCS100 01/01/2000 19:30:00 1.2384
24SCS100 01/01/2000 19:45:00 1.2384
24SCS100 01/01/2000 20:00:00 1.2384
24SCS100 01/01/2000 20:15:00 1.7544
24SCS100 01/01/2000 20:30:00 1.7544
24SCS100 01/01/2000 20:45:00 1.7544
24SCS100 01/01/2000 21:00:00 1.1352
24SCS100 01/01/2000 21:15:00 1.1352
24SCS100 01/01/2000 21:30:00 1.1352
24SCS100 01/01/2000 21:45:00 1.1352
24SCS100 01/01/2000 22:00:00 1.1352

```

Post-Development 3-hour Chicago 1:100-year Event

July 2024

24SCS100	01/01/2000 22:30:00	1.032	24SCS2	01/01/2000 10:15:00	2.208
24SCS100	01/01/2000 22:45:00	1.032	24SCS2	01/01/2000 10:30:00	2.976
24SCS100	01/01/2000 23:00:00	1.032	24SCS2	01/01/2000 10:45:00	2.976
24SCS100	01/01/2000 23:15:00	1.032	24SCS2	01/01/2000 11:00:00	4.608
24SCS100	01/01/2000 23:30:00	1.032	24SCS2	01/01/2000 11:15:00	4.608
24SCS100	01/01/2000 23:45:00	1.032	24SCS2	01/01/2000 11:30:00	19.968
24SCS100	01/02/2000 00:00:00	0	24SCS2	01/01/2000 11:45:00	52.992
:Rainfall (mm/hr)					
24SCS120	01/01/2000 00:00:00	1.8576	24SCS2	01/01/2000 12:15:00	6.912
24SCS120	01/01/2000 00:15:00	1.8576	24SCS2	01/01/2000 12:30:00	3.552
24SCS120	01/01/2000 00:30:00	1.8576	24SCS2	01/01/2000 12:45:00	3.552
24SCS120	01/01/2000 00:45:00	1.8576	24SCS2	01/01/2000 13:00:00	2.592
24SCS120	01/01/2000 01:00:00	0.86688	24SCS2	01/01/2000 13:15:00	2.592
24SCS120	01/01/2000 01:15:00	0.86688	24SCS2	01/01/2000 13:30:00	2.016
24SCS120	01/01/2000 01:30:00	0.86688	24SCS2	01/01/2000 13:45:00	2.016
24SCS120	01/01/2000 01:45:00	0.86688	24SCS2	01/01/2000 14:00:00	1.536
24SCS120	01/01/2000 02:00:00	1.60992	24SCS2	01/01/2000 14:15:00	1.536
24SCS120	01/01/2000 02:15:00	1.60992	24SCS2	01/01/2000 14:30:00	1.536
24SCS120	01/01/2000 02:30:00	1.60992	24SCS2	01/01/2000 14:45:00	1.536
24SCS120	01/01/2000 02:45:00	1.60992	24SCS2	01/01/2000 15:00:00	1.344
24SCS120	01/01/2000 03:00:00	1.60992	24SCS2	01/01/2000 15:15:00	1.344
24SCS120	01/01/2000 03:15:00	1.60992	24SCS2	01/01/2000 15:30:00	1.344
24SCS120	01/01/2000 03:30:00	1.60992	24SCS2	01/01/2000 15:45:00	1.344
24SCS120	01/01/2000 03:45:00	1.60992	24SCS2	01/01/2000 16:00:00	1.056
24SCS120	01/01/2000 04:00:00	2.10528	24SCS2	01/01/2000 16:15:00	1.056
24SCS120	01/01/2000 04:15:00	2.10528	24SCS2	01/01/2000 16:30:00	1.056
24SCS120	01/01/2000 04:30:00	2.10528	24SCS2	01/01/2000 16:45:00	1.056
24SCS120	01/01/2000 04:45:00	2.10528	24SCS2	01/01/2000 17:00:00	1.104
24SCS120	01/01/2000 05:00:00	1.8576	24SCS2	01/01/2000 17:15:00	1.104
24SCS120	01/01/2000 05:15:00	1.8576	24SCS2	01/01/2000 17:30:00	1.104
24SCS120	01/01/2000 05:30:00	1.8576	24SCS2	01/01/2000 17:45:00	1.104
24SCS120	01/01/2000 05:45:00	1.8576	24SCS2	01/01/2000 18:00:00	0.72
24SCS120	01/01/2000 06:00:00	2.4768	24SCS2	01/01/2000 18:15:00	0.72
24SCS120	01/01/2000 06:15:00	2.4768	24SCS2	01/01/2000 18:30:00	0.72
24SCS120	01/01/2000 06:30:00	2.4768	24SCS2	01/01/2000 18:45:00	0.72
24SCS120	01/01/2000 06:45:00	2.4768	24SCS2	01/01/2000 19:00:00	0.556
24SCS120	01/01/2000 07:00:00	2.4768	24SCS2	01/01/2000 19:15:00	0.576
24SCS120	01/01/2000 07:15:00	2.4768	24SCS2	01/01/2000 19:30:00	0.576
24SCS120	01/01/2000 07:30:00	2.4768	24SCS2	01/01/2000 19:45:00	0.576
24SCS120	01/01/2000 07:45:00	2.4768	24SCS2	01/01/2000 20:00:00	0.816
24SCS120	01/01/2000 08:00:00	3.34368	24SCS2	01/01/2000 20:15:00	0.816
24SCS120	01/01/2000 08:15:00	3.34368	24SCS2	01/01/2000 20:30:00	0.816
24SCS120	01/01/2000 08:30:00	3.34368	24SCS2	01/01/2000 21:00:00	0.528
24SCS120	01/01/2000 08:45:00	3.34368	24SCS2	01/01/2000 21:15:00	0.528
24SCS120	01/01/2000 09:00:00	3.96288	24SCS2	01/01/2000 21:30:00	0.528
24SCS120	01/01/2000 09:15:00	3.96288	24SCS2	01/01/2000 21:45:00	0.528
24SCS120	01/01/2000 09:30:00	4.45824	24SCS2	01/01/2000 22:00:00	0.48
24SCS120	01/01/2000 09:45:00	4.45824	24SCS2	01/01/2000 22:15:00	0.48
24SCS120	01/01/2000 10:00:00	5.69664	24SCS2	01/01/2000 22:30:00	0.48
24SCS120	01/01/2000 10:15:00	5.69664	24SCS2	01/01/2000 22:45:00	0.48
24SCS120	01/01/2000 10:30:00	7.67808	24SCS2	01/01/2000 23:00:00	0.48
24SCS120	01/01/2000 10:45:00	7.67808	24SCS2	01/01/2000 23:15:00	0.48
24SCS120	01/01/2000 11:00:00	11.88864	24SCS2	01/01/2000 23:30:00	0.48
24SCS120	01/01/2000 11:15:00	11.88864	24SCS2	01/01/2000 23:45:00	0.48
24SCS120	01/01/2000 11:30:00	51.51744	24SCS2	01/02/2000 00:00:00	0
:Rainfall (mm/hr)					
24SCS25	01/01/2000 00:00:00	0.26	24SCS25	01/01/2000 00:15:00	1.26
24SCS25	01/01/2000 00:30:00	1.26	24SCS25	01/01/2000 00:45:00	1.26
24SCS25	01/01/2000 01:00:00	0.588	24SCS25	01/01/2000 01:15:00	0.588
24SCS25	01/01/2000 01:30:00	0.588	24SCS25	01/01/2000 01:45:00	0.588
24SCS25	01/01/2000 02:00:00	0.588	24SCS25	01/01/2000 02:15:00	1.092
24SCS25	01/01/2000 02:30:00	0.588	24SCS25	01/01/2000 02:45:00	1.092
24SCS25	01/01/2000 03:00:00	1.26	24SCS25	01/01/2000 03:15:00	1.26
24SCS25	01/01/2000 03:15:00	5.20128	24SCS25	01/01/2000 03:30:00	0.588
24SCS25	01/01/2000 14:00:00	3.96288	24SCS25	01/01/2000 03:45:00	0.588
24SCS25	01/01/2000 14:15:00	3.96288	24SCS25	01/01/2000 04:00:00	1.428
24SCS25	01/01/2000 14:30:00	3.96288	24SCS25	01/01/2000 04:15:00	1.428
24SCS25	01/01/2000 14:45:00	3.96288	24SCS25	01/01/2000 04:30:00	1.428
24SCS25	01/01/2000 15:00:00	3.46752	24SCS25	01/01/2000 04:45:00	1.428
24SCS25	01/01/2000 15:15:00	3.46752	24SCS25	01/01/2000 05:00:00	1.26
24SCS25	01/01/2000 15:30:00	3.46752	24SCS25	01/01/2000 05:15:00	1.26
24SCS25	01/01/2000 15:45:00	3.46752	24SCS25	01/01/2000 05:30:00	1.26
24SCS25	01/01/2000 16:00:00	2.72448	24SCS25	01/01/2000 05:45:00	1.26
24SCS25	01/01/2000 16:15:00	2.72448	24SCS25	01/01/2000 06:00:00	1.68
24SCS25	01/01/2000 16:30:00	2.72448	24SCS25	01/01/2000 06:15:00	1.68
24SCS25	01/01/2000 16:45:00	2.72448	24SCS25	01/01/2000 06:30:00	1.68
24SCS25	01/01/2000 17:00:00	2.94832	24SCS25	01/01/2000 06:45:00	1.68
24SCS25	01/01/2000 17:15:00	2.94832	24SCS25	01/01/2000 07:00:00	1.68
24SCS25	01/01/2000 17:30:00	2.94832	24SCS25	01/01/2000 07:15:00	1.68
24SCS25	01/01/2000 17:45:00	2.84832	24SCS25	01/01/2000 07:30:00	1.68
24SCS25	01/01/2000 18:00:00	1.8576	24SCS25	01/01/2000 07:45:00	1.68
24SCS25	01/01/2000 18:15:00	1.8576	24SCS25	01/01/2000 08:00:00	2.268
24SCS25	01/01/2000 18:30:00	1.8576	24SCS25	01/01/2000 08:15:00	2.268
24SCS25	01/01/2000 18:45:00	1.8576	24SCS25	01/01/2000 08:30:00	2.268
24SCS25	01/01/2000 19:00:00	1.8576	24SCS25	01/01/2000 08:45:00	2.268
24SCS25	01/01/2000 19:15:00	1.48608	24SCS25	01/01/2000 09:00:00	2.688
24SCS25	01/01/2000 19:30:00	1.48608	24SCS25	01/01/2000 09:15:00	2.688
24SCS25	01/01/2000 19:45:00	1.48608	24SCS25	01/01/2000 09:30:00	3.024
24SCS25	01/01/2000 20:00:00	2.10528	24SCS25	01/01/2000 09:45:00	3.024
24SCS25	01/01/2000 20:15:00	2.10528	24SCS25	01/01/2000 10:00:00	3.864
24SCS25	01/01/2000 20:30:00	2.10528	24SCS25	01/01/2000 10:15:00	3.864
24SCS25	01/01/2000 20:45:00	2.10528	24SCS25	01/01/2000 10:30:00	5.208
24SCS25	01/01/2000 21:00:00	1.36224	24SCS25	01/01/2000 10:45:00	5.208
24SCS25	01/01/2000 21:15:00	1.36224	24SCS25	01/01/2000 11:00:00	8.064
24SCS25	01/01/2000 21:30:00	1.36224	24SCS25	01/01/2000 11:15:00	8.064
24SCS25	01/01/2000 21:45:00	1.36224	24SCS25	01/01/2000 11:30:00	34.944
24SCS25	01/01/2000 22:00:00	1.2384	24SCS25	01/01/2000 11:45:00	92.736
24SCS25	01/01/2000 22:15:00	1.2384	24SCS25	01/01/2000 12:00:00	12.06
24SCS25	01/01/2000 22:30:00	1.2384	24SCS25	01/01/2000 12:15:00	12.096
24SCS25	01/01/2000 22:45:00	1.2384	24SCS25	01/01/2000 12:30:00	6.216
24SCS25	01/01/2000 23:00:00	1.2384	24SCS25	01/01/2000 12:45:00	6.216
24SCS25	01/01/2000 23:15:00	1.2384	24SCS25	01/01/2000 13:00:00	4.536
24SCS25	01/01/2000 23:30:00	0.624	24SCS25	01/01/2000 13:15:00	4.536
24SCS25	01/01/2000 23:45:00	0.624	24SCS25	01/01/2000 13:30:00	3.528
24SCS25	01/01/2000 23:50:00	0.624	24SCS25	01/01/2000 13:45:00	3.528
24SCS25	01/01/2000 00:15:00	0.624	24SCS25	01/01/2000 14:00:00	2.688
24SCS25	01/01/2000 00:30:00	0.624	24SCS25	01/01/2000 14:15:00	2.688
24SCS25	01/01/2000 00:45:00	0.624	24SCS25	01/01/2000 14:30:00	2.688
24SCS25	01/01/2000 01:00:00	0.816	24SCS25	01/01/2000 14:45:00	2.688
24SCS25	01/01/2000 01:15:00	0.816	24SCS25	01/01/2000 15:00:00	2.352
24SCS25	01/01/2000 01:30:00	0.816	24SCS25	01/01/2000 15:15:00	2.352
24SCS25	01/01/2000 01:45:00	0.816	24SCS25	01/01/2000 15:30:00	2.352
24SCS25	01/01/2000 02:00:00	0.624	24SCS25	01/01/2000 15:45:00	2.352
24SCS25	01/01/2000 02:15:00	0.624	24SCS25	01/01/2000 16:00:00	2.352
24SCS25	01/01/2000 02:30:00	0.624	24SCS25	01/01/2000 16:15:00	1.848
24SCS25	01/01/2000 02:45:00	0.624	24SCS25	01/01/2000 16:30:00	1.848
24SCS25	01/01/2000 03:00				

Post-Development 3-hour Chicago 1:100-year Event

July 2024

24SCS25	01/01/2000	22:45:00	0.84	24SCS50	01/01/2000	10:30:00	5.803199
24SCS25	01/01/2000	23:00:00	0.84	24SCS50	01/01/2000	10:45:00	5.803199
24SCS25	01/01/2000	23:15:00	0.84	24SCS50	01/01/2000	11:00:00	8.9856
24SCS25	01/01/2000	23:30:00	0.84	24SCS50	01/01/2000	11:15:00	8.9856
24SCS25	01/01/2000	23:45:00	0.84	24SCS50	01/01/2000	11:30:00	38.9376
24SCS25	01/02/2000	00:00:00	0	24SCS50	01/01/2000	11:45:00	103.3344
;Rainfall (mm/hr)							
24SCS5	01/01/2000	00:00:00	0.936	24SCS50	01/01/2000	12:00:00	13.4784
24SCS5	01/01/2000	00:15:00	0.936	24SCS50	01/01/2000	12:15:00	1.84484
24SCS5	01/01/2000	00:30:00	0.936	24SCS50	01/01/2000	12:30:00	6.9264
24SCS5	01/01/2000	00:45:00	0.936	24SCS50	01/01/2000	12:45:00	6.9264
24SCS5	01/01/2000	01:00:00	0.4368	24SCS50	01/01/2000	13:00:00	5.0544
24SCS5	01/01/2000	01:15:00	0.4368	24SCS50	01/01/2000	13:15:00	5.0544
24SCS5	01/01/2000	01:30:00	0.4368	24SCS50	01/01/2000	13:30:00	3.9312
24SCS5	01/01/2000	01:45:00	0.4368	24SCS50	01/01/2000	13:45:00	3.9312
24SCS5	01/01/2000	02:00:00	0.8112	24SCS50	01/01/2000	14:00:00	2.9952
24SCS5	01/01/2000	02:15:00	0.8112	24SCS50	01/01/2000	14:15:00	2.9952
24SCS5	01/01/2000	02:30:00	0.8112	24SCS50	01/01/2000	14:30:00	2.9952
24SCS5	01/01/2000	02:45:00	0.8112	24SCS50	01/01/2000	15:00:00	2.6208
24SCS5	01/01/2000	03:00:00	0.8112	24SCS50	01/01/2000	15:15:00	2.6208
24SCS5	01/01/2000	03:15:00	0.8112	24SCS50	01/01/2000	15:30:00	2.6208
24SCS5	01/01/2000	03:30:00	0.8112	24SCS50	01/01/2000	16:00:00	2.6568
24SCS5	01/01/2000	03:45:00	0.8112	24SCS50	01/01/2000	16:15:00	2.0592
24SCS5	01/01/2000	04:00:00	1.0608	24SCS50	01/01/2000	16:30:00	2.0592
24SCS5	01/01/2000	04:15:00	1.0608	24SCS50	01/01/2000	16:45:00	2.0592
24SCS5	01/01/2000	04:30:00	1.0608	24SCS50	01/01/2000	17:00:00	2.1528
24SCS5	01/01/2000	04:45:00	1.0608	24SCS50	01/01/2000	17:15:00	2.1528
24SCS5	01/01/2000	05:00:00	0.936	24SCS50	01/01/2000	17:30:00	2.1528
24SCS5	01/01/2000	05:15:00	0.936	24SCS50	01/01/2000	17:45:00	2.1528
24SCS5	01/01/2000	05:30:00	0.936	24SCS50	01/01/2000	18:00:00	1.404
24SCS5	01/01/2000	05:45:00	0.936	24SCS50	01/01/2000	18:15:00	1.404
24SCS5	01/01/2000	06:00:00	1.248	24SCS50	01/01/2000	18:30:00	1.404
24SCS5	01/01/2000	06:15:00	1.248	24SCS50	01/01/2000	18:45:00	1.404
24SCS5	01/01/2000	06:30:00	1.248	24SCS50	01/01/2000	19:00:00	1.1232
24SCS5	01/01/2000	06:45:00	1.248	24SCS50	01/01/2000	19:15:00	1.1232
24SCS5	01/01/2000	07:00:00	1.248	24SCS50	01/01/2000	19:30:00	1.1232
24SCS5	01/01/2000	07:15:00	1.248	24SCS50	01/01/2000	19:45:00	1.1232
24SCS5	01/01/2000	07:30:00	1.248	24SCS50	01/01/2000	20:00:00	1.5912
24SCS5	01/01/2000	07:45:00	1.248	24SCS50	01/01/2000	20:15:00	1.5912
24SCS5	01/01/2000	08:00:00	1.6848	24SCS50	01/01/2000	20:30:00	1.5912
24SCS5	01/01/2000	08:15:00	1.6848	24SCS50	01/01/2000	20:45:00	1.5912
24SCS5	01/01/2000	08:30:00	1.6848	24SCS50	01/01/2000	21:00:00	1.0236
24SCS5	01/01/2000	08:45:00	1.6848	24SCS50	01/01/2000	21:15:00	1.0236
24SCS5	01/01/2000	09:00:00	1.9968	24SCS50	01/01/2000	21:30:00	1.0236
24SCS5	01/01/2000	09:15:00	1.9968	24SCS50	01/01/2000	21:45:00	1.0236
24SCS5	01/01/2000	09:30:00	2.2464	24SCS50	01/01/2000	22:00:00	0.936
24SCS5	01/01/2000	09:45:00	2.2464	24SCS50	01/01/2000	22:15:00	0.936
24SCS5	01/01/2000	10:00:00	2.8704	24SCS50	01/01/2000	22:30:00	0.936
24SCS5	01/01/2000	10:15:00	2.04	24SCS50	01/01/2000	22:45:00	0.936
24SCS5	01/01/2000	10:30:00	3.8688	24SCS50	01/01/2000	23:00:00	0.936
24SCS5	01/01/2000	10:45:00	3.8688	24SCS50	01/01/2000	23:15:00	0.936
24SCS5	01/01/2000	11:00:00	5.9904	24SCS50	01/01/2000	23:30:00	0.936
24SCS5	01/01/2000	11:15:00	5.9904	24SCS50	01/01/2000	23:45:00	0.936
24SCS5	01/01/2000	11:30:00	25.9584	24SCS50	01/02/2000	00:00:00	0
;Rainfall (mm/hr)							
24SCS5	01/01/2000	00:00:00	8.936	3CH110	01/01/2000	00:00:00	3.755
24SCS5	01/01/2000	12:15:00	8.936	3CH110	01/01/2000	00:10:00	4.478
24SCS5	01/01/2000	12:30:00	4.6176	3CH110	01/01/2000	00:20:00	5.593
24SCS5	01/01/2000	12:45:00	4.6176	3CH110	01/01/2000	00:30:00	7.551
24SCS5	01/01/2000	13:00:00	3.3696	3CH110	01/01/2000	00:40:00	11.936
24SCS5	01/01/2000	13:15:00	3.3696	3CH110	01/01/2000	00:50:00	30.856
24SCS5	01/01/2000	13:30:00	2.6208	3CH110	01/01/2000	01:00:00	12.2142
24SCS5	01/01/2000	13:45:00	2.6208	3CH110	01/01/2000	01:10:00	36.237
24SCS5	01/01/2000	14:00:00	1.9968	3CH110	01/01/2000	01:20:00	18.159
24SCS5	01/01/2000	14:15:00	1.9968	3CH110	01/01/2000	01:30:00	12.238
24SCS5	01/01/2000	14:30:00	1.9968	3CH110	01/01/2000	01:40:00	9.269
24SCS5	01/01/2000	14:45:00	1.9968	3CH110	01/01/2000	01:50:00	7.492
24SCS5	01/01/2000	15:00:00	1.7472	3CH110	01/01/2000	02:00:00	6.309
24SCS5	01/01/2000	15:15:00	1.7472	3CH110	01/01/2000	02:10:00	5.465
24SCS5	01/01/2000	15:30:00	1.7472	3CH110	01/01/2000	02:20:00	4.431
24SCS5	01/01/2000	15:45:00	1.7472	3CH110	01/01/2000	02:30:00	4.338
24SCS5	01/01/2000	16:00:00	1.3728	3CH110	01/01/2000	02:40:00	3.942
24SCS5	01/01/2000	16:15:00	1.3728	3CH110	01/01/2000	02:50:00	3.617
24SCS5	01/01/2000	16:30:00	1.3728	3CH110	01/01/2000	03:00:00	0
;Rainfall (mm/hr)							
24SCS5	01/01/2000	17:15:00	1.4352	3CH110	01/01/2000	00:00:00	5.339
24SCS5	01/01/2000	17:30:00	1.4352	3CH110	01/01/2000	00:10:00	6.376
24SCS5	01/01/2000	18:00:00	0.936	3CH110	01/01/2000	00:20:00	7.977
24SCS5	01/01/2000	18:15:00	0.936	3CH110	01/01/2000	00:30:00	10.797
24SCS5	01/01/2000	18:30:00	0.936	3CH110	01/01/2000	00:40:00	17.136
24SCS5	01/01/2000	18:45:00	0.936	3CH110	01/01/2000	00:50:00	45.128
24SCS5	01/01/2000	19:00:00	0.7488	3CH110	01/01/2000	01:00:00	178.07
24SCS5	01/01/2000	19:15:00	0.7488	3CH110	01/01/2000	01:10:00	51.056
24SCS5	01/01/2000	19:30:00	0.7488	3CH110	01/01/2000	01:20:00	26.163
24SCS5	01/01/2000	19:45:00	0.7488	3CH110	01/01/2000	01:30:00	17.571
24SCS5	01/01/2000	20:00:00	1.0608	3CH110	01/01/2000	01:40:00	13.277
24SCS5	01/01/2000	20:15:00	1.0608	3CH110	01/01/2000	01:50:00	10.712
24SCS5	01/01/2000	20:30:00	1.0608	3CH110	01/01/2000	02:00:00	9.008
24SCS5	01/01/2000	20:45:00	1.0608	3CH110	01/01/2000	02:10:00	7.793
24SCS5	01/01/2000	21:00:00	0.6864	3CH110	01/01/2000	02:20:00	6.653
24SCS5	01/01/2000	21:15:00	0.6864	3CH110	01/01/2000	02:30:00	6.174
24SCS5	01/01/2000	21:30:00	0.6864	3CH110	01/01/2000	02:40:00	5.607
24SCS5	01/01/2000	21:45:00	0.6864	3CH110	01/01/2000	02:50:00	5.142
24SCS5	01/01/2000	22:00:00	0.624	3CH110	01/01/2000	03:00:00	0
;Rainfall (mm/hr)							
24SCS5	01/01/2000	22:15:00	0.624	3CH112	01/01/2000	00:00:00	6.406801
24SCS5	01/01/2000	22:30:00	0.624	3CH112	01/01/2000	00:10:00	7.6512
24SCS5	01/01/2000	23:15:00	0.624	3CH112	01/01/2000	00:20:00	9.572401
24SCS5	01/01/2000	23:30:00	0.624	3CH112	01/01/2000	00:30:00	12.9564
24SCS5	01/01/2000	23:45:00	0.624	3CH112	01/01/2000	00:40:00	20.5632
24SCS5	01/01/2000	00:00:00	0	3CH112	01/01/2000	00:50:00	54.1536
24SCS5	01/02/2000	00:00:00	0	3CH112	01/01/2000	01:00:00	213.284
;Rainfall (mm/hr)							
24SCS5	01/01/2000	00:15:00	1.404	3CH12	01/01/2000	01:20:00	31.3956
24SCS50	01/01/2000	00:15:00	1.404	3CH12	01/01/2000	01:30:00	21.0852
24SCS50	01/01/2000	00:30:00	1.404	3CH12	01/01/2000	01:40:00	15.9324
24SCS50	01/01/2000	00:45:00	1.404	3CH12	01/01/2000	01:50:00	12.8544
24SCS50	01/01/2000	01:00:00	0.6552	3CH12	01/01/2000	02:00:00	10.8096
24SCS50	01/01/2000	01:15:00	0.6552	3CH12	01/01/2000	02:10:00	9.31601

Post-Development 3-hour Chicago 1:100-year Event

July 2024

3CHI25	01/01/2000	01:20:00	21.286	InfiltratedInflow	01/01/2000	01:19:00	6.991814E-05
3CHI25	01/01/2000	01:30:00	14.308	InfiltratedInflow	01/01/2000	01:20:00	6.865804E-05
3CHI25	01/01/2000	01:40:00	10.818	InfiltratedInflow	01/01/2000	01:21:00	6.748195E-05
3CHI25	01/01/2000	01:50:00	8.732	InfiltratedInflow	01/01/2000	01:22:00	6.638427E-05
3CHI25	01/01/2000	02:00:00	7.345	InfiltratedInflow	01/01/2000	01:23:00	6.535978E-05
3CHI25	01/01/2000	02:10:00	6.356	InfiltratedInflow	01/01/2000	01:24:00	6.44036E-05
3CHI25	01/01/2000	02:20:00	5.615	InfiltratedInflow	01/01/2000	01:25:00	6.351116E-05
3CHI25	01/01/2000	02:30:00	5.038	InfiltratedInflow	01/01/2000	01:26:00	6.272567E-05
3CHI25	01/01/2000	02:40:00	4.576	InfiltratedInflow	01/01/2000	01:27:00	6.190084E-05
3CHI25	01/01/2000	02:50:00	4.197	InfiltratedInflow	01/01/2000	01:28:00	6.117527E-05
3CHI25	01/01/2000	03:00:00	0	InfiltratedInflow	01/01/2000	01:29:00	6.049809E-05
;Rainfall (mm/hr)				InfiltratedInflow	01/01/2000	01:30:00	5.986604E-05
3CH15	01/01/2000	00:00:00	3.256	InfiltratedInflow	01/01/2000	01:31:00	5.927615E-05
3CH15	01/01/2000	00:10:00	3.981	InfiltratedInflow	01/01/2000	01:32:00	5.872558E-05
3CH15	01/01/2000	00:20:00	4.844	InfiltratedInflow	01/01/2000	01:33:00	5.818714E-05
3CH15	01/01/2000	00:30:00	6.532	InfiltratedInflow	01/01/2000	01:34:00	5.773212E-05
3CH15	01/01/2000	00:40:00	10.308	InfiltratedInflow	01/01/2000	01:35:00	5.728449E-05
3CH15	01/01/2000	00:50:00	26.792	InfiltratedInflow	01/01/2000	01:36:00	5.686672E-05
3CH15	01/01/2000	01:00:00	103.93	InfiltratedInflow	01/01/2000	01:37:00	5.647668E-05
3CH15	01/01/2000	01:10:00	30.286	InfiltratedInflow	01/01/2000	01:38:00	5.611287E-05
3CH15	01/01/2000	01:20:00	15.655	InfiltratedInflow	01/01/2000	01:39:00	5.577321E-05
3CH15	01/01/2000	01:30:00	10.568	InfiltratedInflow	01/01/2000	01:41:00	5.516031E-05
3CH15	01/01/2000	01:40:00	8.013	InfiltratedInflow	01/01/2000	01:42:00	5.488416E-05
3CH15	01/01/2000	01:50:00	6.482	InfiltratedInflow	01/01/2000	01:43:00	5.462642E-05
3CH15	01/01/2000	02:00:00	5.462	InfiltratedInflow	01/01/2000	01:44:00	5.438587E-05
3CH15	01/01/2000	02:10:00	4.733	InfiltratedInflow	01/01/2000	01:45:00	5.416135E-05
3CH15	01/01/2000	02:20:00	4.186	InfiltratedInflow	01/01/2000	01:46:00	5.395188E-05
3CH15	01/01/2000	02:30:00	3.76	InfiltratedInflow	01/01/2000	01:47:00	5.357693E-05
3CH15	01/01/2000	02:40:00	3.418	InfiltratedInflow	01/01/2000	01:49:00	5.340332E-05
3CH15	01/01/2000	02:50:00	3.137	InfiltratedInflow	01/01/2000	01:50:00	5.324431E-05
3CH15	01/01/2000	03:00:00	0	InfiltratedInflow	01/01/2000	01:51:00	5.309591E-05
;Rainfall (mm/hr)				InfiltratedInflow	01/01/2000	01:52:00	5.29754E-05
3CH150	01/01/2000	00:00:00	4.828	InfiltratedInflow	01/01/2000	01:53:00	5.282812E-05
3CH150	01/01/2000	00:10:00	5.666	InfiltratedInflow	01/01/2000	01:54:00	5.240195E-05
3CH150	01/01/2000	00:20:00	7.214	InfiltratedInflow	01/01/2000	01:55:00	5.259485E-05
3CH150	01/01/2000	00:30:00	9.763	InfiltratedInflow	01/01/2000	01:56:00	5.248975E-05
3CH150	01/01/2000	00:40:00	15.496	InfiltratedInflow	01/01/2000	01:57:00	5.239165E-05
3CH150	01/01/2000	00:50:00	40.401	InfiltratedInflow	01/01/2000	01:58:00	5.230018E-05
3CH150	01/01/2000	01:00:00	161.471	InfiltratedInflow	01/01/2000	01:59:00	5.221464E-05
3CH150	01/01/2000	01:10:00	46.17	InfiltratedInflow	01/01/2000	02:00:00	5.213489E-05
3CH150	01/01/2000	01:20:00	23.66	InfiltratedInflow	01/01/2000	02:01:00	5.202592E-05
3CH150	01/01/2000	01:30:00	18.88	InfiltratedInflow	01/01/2000	02:02:00	5.190998E-05
3CH150	01/01/2000	01:40:00	12.006	InfiltratedInflow	01/01/2000	02:03:00	5.192613E-05
3CH150	01/01/2000	01:50:00	9.687	InfiltratedInflow	01/01/2000	02:04:00	5.186562E-05
3CH150	01/01/2000	02:00:00	8.146	InfiltratedInflow	01/01/2000	02:05:00	5.180913E-05
3CH150	01/01/2000	02:10:00	7.047	InfiltratedInflow	01/01/2000	02:06:00	5.176542E-05
3CH150	01/01/2000	02:20:00	6.224	InfiltratedInflow	01/01/2000	02:17:00	5.170721E-05
3CH150	01/01/2000	02:30:00	5.583	InfiltratedInflow	01/01/2000	02:18:00	5.139485E-05
3CH150	01/01/2000	02:40:00	5.07	InfiltratedInflow	01/01/2000	02:09:00	5.161843E-05
3CH150	01/01/2000	02:50:00	4.649	InfiltratedInflow	01/01/2000	02:10:00	5.157843E-05
3CH150	01/01/2000	03:00:00	0	InfiltratedInflow	01/01/2000	02:11:00	5.154109E-05
;Head (m)				InfiltratedInflow	01/01/2000	02:12:00	5.150625E-05
527_CH100Yr	01/01/2000	00:01:00	81.228	InfiltratedInflow	01/01/2000	02:13:00	5.147372E-05
527_CH100Yr	01/01/2000	00:02:00	81.228	InfiltratedInflow	01/01/2000	02:14:00	5.144337E-05
527_CH100Yr	01/01/2000	00:03:00	81.228	InfiltratedInflow	01/01/2000	02:15:00	5.141404E-05
527_CH100Yr	01/01/2000	00:04:00	81.228	InfiltratedInflow	01/01/2000	02:16:00	5.138866E-05
527_CH100Yr	01/01/2000	00:05:00	81.228	InfiltratedInflow	01/01/2000	02:17:00	5.136392E-05
527_CH100Yr	01/01/2000	00:06:00	81.228	InfiltratedInflow	01/01/2000	02:18:00	5.131938E-05
527_CH100Yr	01/01/2000	00:07:00	81.228	InfiltratedInflow	01/01/2000	02:20:00	5.129932E-05
527_CH100Yr	01/01/2000	00:08:00	81.228	InfiltratedInflow	01/01/2000	02:21:00	5.128065E-05
527_CH100Yr	01/01/2000	00:09:00	81.228	InfiltratedInflow	01/01/2000	02:22:00	5.126352E-05
527_CH100Yr	01/01/2000	00:10:00	81.228	InfiltratedInflow	01/01/2000	02:23:00	5.125818E-05
527_CH100Yr	01/01/2000	00:11:00	81.228	InfiltratedInflow	01/01/2000	02:24:00	5.123158E-05
527_CH100Yr	01/01/2000	00:12:00	81.228	InfiltratedInflow	01/01/2000	02:25:00	5.121737E-05
527_CH100Yr	01/01/2000	00:13:00	81.228	InfiltratedInflow	01/01/2000	02:26:00	5.120411E-05
527_CH100Yr	01/01/2000	00:14:00	81.228	InfiltratedInflow	01/01/2000	02:27:00	5.119173E-05
527_CH100Yr	01/01/2000	00:15:00	81.228	InfiltratedInflow	01/01/2000	02:28:00	5.118017E-05
527_CH100Yr	01/01/2000	00:16:00	81.228	InfiltratedInflow	01/01/2000	02:29:00	5.116935E-05
527_CH100Yr	01/01/2000	00:17:00	81.228	InfiltratedInflow	01/01/2000	02:30:00	5.114933E-05
527_CH100Yr	01/01/2000	00:18:00	81.228	InfiltratedInflow	01/01/2000	02:31:00	5.114993E-05
527_CH100Yr	01/01/2000	00:19:00	81.228	InfiltratedInflow	01/01/2000	02:32:00	5.114117E-05
527_CH100Yr	01/01/2000	00:20:00	81.228	InfiltratedInflow	01/01/2000	02:33:00	5.113299E-05
527_CH100Yr	01/01/2000	00:21:00	81.228	InfiltratedInflow	01/01/2000	02:34:00	5.112535E-05
527_CH100Yr	01/01/2000	00:22:00	81.228	InfiltratedInflow	01/01/2000	02:35:00	5.111822E-05
527_CH100Yr	01/01/2000	00:23:00	81.228	InfiltratedInflow	01/01/2000	02:36:00	5.110534E-05
527_CH100Yr	01/01/2000	00:24:00	81.228	InfiltratedInflow	01/01/2000	02:38:00	5.109957E-05
527_CH100Yr	01/01/2000	00:25:00	81.228	InfiltratedInflow	01/01/2000	02:39:00	5.109416E-05
527_CH100Yr	01/01/2000	00:26:00	81.228	InfiltratedInflow	01/01/2000	02:40:00	5.108911E-05
527_CH100Yr	01/01/2000	00:27:00	81.228	InfiltratedInflow	01/01/2000	02:41:00	5.10844E-05
527_CH100Yr	01/01/2000	00:28:00	81.228	InfiltratedInflow	01/01/2000	02:42:00	4.413902E-05
527_CH100Yr	01/01/2000	00:29:00	81.228	InfiltratedInflow	01/01/2000	02:43:00	4.167125E-05
527_CH100Yr	01/01/2000	00:30:00	81.228	InfiltratedInflow	01/01/2000	02:44:00	4.167125E-05
527_CH100Yr	01/01/2000	00:31:00	81.228	InfiltratedInflow	01/01/2000	02:45:00	4.167125E-05
527_CH100Yr	01/01/2000	00:32:00	81.228	InfiltratedInflow	01/01/2000	02:46:00	4.167125E-05
527_CH100Yr	01/01/2000	00:33:00	81.228	InfiltratedInflow	01/01/2000	02:47:00	4.167125E-05
527_CH100Yr	01/01/2000	00:34:00	81.228	InfiltratedInflow	01/01/2000	02:48:00	4.167125E-05
527_CH100Yr	01/01/2000	00:35:00	81.228	InfiltratedInflow	01/01/2000	02:49:00	4.167125E-05
527_CH100Yr	01/01/2000	00:36:00	81.228	InfiltratedInflow	01/01/2000	02:50:00	4.167125E-05
527_CH100Yr	01/01/2000	00:37:00	81.228	InfiltratedInflow	01/01/2000	02:52:00	4.167125E-05
527_CH100Yr	01/01/2000	00:38:00	81.228	InfiltratedInflow	01/01/2000	02:53:00	4.167125E-05
527_CH100Yr	01/01/2000	00:39:00	81.228	InfiltratedInflow	01/01/2000	02:54:00	4.167125E-05
527_CH100Yr	01/01/2000	00:40:00	81.228	InfiltratedInflow	01/01/2000	02:55:00	4.167125E-05
527_CH100Yr	01/01/2000	00:41:00	81.228	InfiltratedInflow	01/01/2000	02:56:00	4.167125E-05
527_CH100Yr	01/01/2000	00:42:00	81.228	InfiltratedInflow	01/01/2000	02:57:00	4.167125E-05
527_CH100Yr	01/01/2000	00:43:00	81.228	InfiltratedInflow	01/01/2000	02:58:00	4.167125E-05
527_CH100Yr	01/01/2000	00:44:00	81.228	InfiltratedInflow	01/01/2000	02:59:00	4.167125E-05
527_CH100Yr	01/01/2000	00:45:00	81.228	InfiltratedInflow	01/01/2000	03:00:00	4.167125E-05
527_CH100Yr	01/01/2000	00:46:00	81.228	InfiltratedInflow	01/01/2000	03:01:00	0
527_CH100Yr	01/01/2000	00:47:00	81.228	InfiltratedInflow	01/01/2000	03:02:00	0
527_CH100Yr	01/01/2000	00:48:00	81.228	InfiltratedInflow	01/01/2000	03:03:00	0
527_CH100Yr	01/01/2000	00:49:00	81.228	InfiltratedInflow	01/01/2000	03:04:00	0
527_CH100Yr	01/01/2000	00:50:00	81.228	InfiltratedInflow	01/01/2000	03:05:00	0
527_CH100Yr	01/01/2000	00:51:00	81.228	InfiltratedInflow	01/01/2000		

Post-Development 3-hour Chicago 1:100-year Event

July 2024

```

InfiltratedInflow 01/01/2000 03:48:00 0
InfiltratedInflow 01/01/2000 03:49:00 0
InfiltratedInflow 01/01/2000 03:50:00 0
InfiltratedInflow 01/01/2000 03:51:00 0
InfiltratedInflow 01/01/2000 03:52:00 0
InfiltratedInflow 01/01/2000 03:53:00 0
InfiltratedInflow 01/01/2000 03:54:00 0
InfiltratedInflow 01/01/2000 03:55:00 0
InfiltratedInflow 01/01/2000 03:56:00 0
InfiltratedInflow 01/01/2000 03:57:00 0
InfiltratedInflow 01/01/2000 03:58:00 0
InfiltratedInflow 01/01/2000 03:59:00 0
InfiltratedInflow 01/01/2000 04:00:00 0
InfiltratedInflow 01/01/2000 04:01:00 0
InfiltratedInflow 01/01/2000 04:02:00 0
InfiltratedInflow 01/01/2000 04:03:00 0
InfiltratedInflow 01/01/2000 04:04:00 0
InfiltratedInflow 01/01/2000 04:05:00 0
InfiltratedInflow 01/01/2000 04:06:00 0
InfiltratedInflow 01/01/2000 04:07:00 0
InfiltratedInflow 01/01/2000 04:08:00 0
InfiltratedInflow 01/01/2000 04:09:00 0
InfiltratedInflow 01/01/2000 04:10:00 0
InfiltratedInflow 01/01/2000 04:11:00 0
InfiltratedInflow 01/01/2000 04:12:00 0
InfiltratedInflow 01/01/2000 04:13:00 0
InfiltratedInflow 01/01/2000 04:14:00 0
InfiltratedInflow 01/01/2000 04:15:00 0
InfiltratedInflow 01/01/2000 04:16:00 0
InfiltratedInflow 01/01/2000 04:17:00 0
InfiltratedInflow 01/01/2000 04:18:00 0
InfiltratedInflow 01/01/2000 04:19:00 0
InfiltratedInflow 01/01/2000 04:20:00 0
InfiltratedInflow 01/01/2000 04:21:00 0
InfiltratedInflow 01/01/2000 04:22:00 0
InfiltratedInflow 01/01/2000 04:23:00 0
InfiltratedInflow 01/01/2000 04:24:00 0
InfiltratedInflow 01/01/2000 04:25:00 0
InfiltratedInflow 01/01/2000 04:26:00 0
InfiltratedInflow 01/01/2000 04:27:00 0
InfiltratedInflow 01/01/2000 04:28:00 0
InfiltratedInflow 01/01/2000 04:29:00 0
InfiltratedInflow 01/01/2000 04:30:00 0
InfiltratedInflow 01/01/2000 04:31:00 0
InfiltratedInflow 01/01/2000 04:32:00 0
InfiltratedInflow 01/01/2000 04:33:00 0
InfiltratedInflow 01/01/2000 04:34:00 0
InfiltratedInflow 01/01/2000 04:35:00 0
InfiltratedInflow 01/01/2000 04:36:00 0
InfiltratedInflow 01/01/2000 04:37:00 0
InfiltratedInflow 01/01/2000 04:38:00 0
InfiltratedInflow 01/01/2000 04:39:00 0
InfiltratedInflow 01/01/2000 04:40:00 0
InfiltratedInflow 01/01/2000 04:41:00 0
InfiltratedInflow 01/01/2000 04:42:00 0
InfiltratedInflow 01/01/2000 04:43:00 0
InfiltratedInflow 01/01/2000 04:44:00 0
InfiltratedInflow 01/01/2000 04:45:00 0
InfiltratedInflow 01/01/2000 04:46:00 0
InfiltratedInflow 01/01/2000 04:47:00 0
InfiltratedInflow 01/01/2000 04:48:00 0
InfiltratedInflow 01/01/2000 04:49:00 0
InfiltratedInflow 01/01/2000 04:50:00 0
InfiltratedInflow 01/01/2000 04:51:00 0
InfiltratedInflow 01/01/2000 04:52:00 0
InfiltratedInflow 01/01/2000 04:53:00 0
InfiltratedInflow 01/01/2000 04:54:00 0
InfiltratedInflow 01/01/2000 04:55:00 0
InfiltratedInflow 01/01/2000 04:56:00 0
InfiltratedInflow 01/01/2000 04:57:00 0
InfiltratedInflow 01/01/2000 04:58:00 0
InfiltratedInflow 01/01/2000 04:59:00 0
InfiltratedInflow 01/01/2000 05:00:00 0
InfiltratedInflow 01/01/2000 05:01:00 0
InfiltratedInflow 01/01/2000 05:02:00 0
InfiltratedInflow 01/01/2000 05:03:00 0
InfiltratedInflow 01/01/2000 05:04:00 0
InfiltratedInflow 01/01/2000 05:05:00 0
InfiltratedInflow 01/01/2000 05:06:00 0
InfiltratedInflow 01/01/2000 05:07:00 0
InfiltratedInflow 01/01/2000 05:08:00 0
InfiltratedInflow 01/01/2000 05:09:00 0
InfiltratedInflow 01/01/2000 05:10:00 0
InfiltratedInflow 01/01/2000 05:11:00 0
InfiltratedInflow 01/01/2000 05:12:00 0
InfiltratedInflow 01/01/2000 05:13:00 0
InfiltratedInflow 01/01/2000 05:14:00 0
InfiltratedInflow 01/01/2000 05:15:00 0
InfiltratedInflow 01/01/2000 05:16:00 0
InfiltratedInflow 01/01/2000 05:17:00 0
InfiltratedInflow 01/01/2000 05:18:00 0
InfiltratedInflow 01/01/2000 05:19:00 0
InfiltratedInflow 01/01/2000 05:20:00 0
InfiltratedInflow 01/01/2000 05:21:00 0
InfiltratedInflow 01/01/2000 05:22:00 0
InfiltratedInflow 01/01/2000 05:23:00 0
InfiltratedInflow 01/01/2000 05:24:00 0
InfiltratedInflow 01/01/2000 05:25:00 0
InfiltratedInflow 01/01/2000 05:26:00 0
InfiltratedInflow 01/01/2000 05:27:00 0
InfiltratedInflow 01/01/2000 05:28:00 0
InfiltratedInflow 01/01/2000 05:29:00 0
InfiltratedInflow 01/01/2000 05:30:00 0
InfiltratedInflow 01/01/2000 05:31:00 0
InfiltratedInflow 01/01/2000 05:32:00 0
InfiltratedInflow 01/01/2000 05:33:00 0
InfiltratedInflow 01/01/2000 05:34:00 0
InfiltratedInflow 01/01/2000 05:35:00 0
InfiltratedInflow 01/01/2000 05:36:00 0
InfiltratedInflow 01/01/2000 05:37:00 0
InfiltratedInflow 01/01/2000 05:38:00 0
InfiltratedInflow 01/01/2000 05:39:00 0
InfiltratedInflow 01/01/2000 05:40:00 0
InfiltratedInflow 01/01/2000 05:41:00 0
InfiltratedInflow 01/01/2000 05:42:00 0
InfiltratedInflow 01/01/2000 05:43:00 0
InfiltratedInflow 01/01/2000 05:44:00 0
InfiltratedInflow 01/01/2000 05:45:00 0
InfiltratedInflow 01/01/2000 05:46:00 0
InfiltratedInflow 01/01/2000 05:47:00 0
InfiltratedInflow 01/01/2000 05:48:00 0
InfiltratedInflow 01/01/2000 05:49:00 0
InfiltratedInflow 01/01/2000 05:50:00 0
InfiltratedInflow 01/01/2000 05:51:00 0
InfiltratedInflow 01/01/2000 05:52:00 0
InfiltratedInflow 01/01/2000 05:53:00 0
InfiltratedInflow 01/01/2000 05:54:00 0
InfiltratedInflow 01/01/2000 05:55:00 0
InfiltratedInflow 01/01/2000 05:56:00 0
InfiltratedInflow 01/01/2000 05:57:00 0
InfiltratedInflow 01/01/2000 05:58:00 0
InfiltratedInflow 01/01/2000 05:59:00 0
InfiltratedInflow 01/01/2000 06:00:00 0

[REPORT]
;; Reporting Options
INPUT YES
CONTROLS NO
SUBCATCHMENTS ALL
NODES ALL
LINKS ALL

[TAGS]
Subcatch L1_1 Landscape
Subcatch L1_2 Landscape
Subcatch L1_3 Landscape
Subcatch S2 Parking_Lot
Subcatch S3_1 Parking_Lot
Subcatch S3_2 Parking_Lot

Subcatch S5 Building
Subcatch S6 Building
Subcatch S7 Ramp
Node St_L1 RYCB
Node St_L2 RYCB
Node St_L3 RYCB
Node St_UnGrd Uncderground_Storage
Link C1 RY_Storm

[MAP]
DIMENSIONS 381360.7266 5033019.65495 381502.5034 5033143.67005
UNITS Meters

[COORDINATES]
; ; Node X-Coord Y-Coord
; ;-----;
527_(P-Stm) 381424.754 5033138.033
OF1 381401.916 5033025.292
OF2 381462.548 5033049.302
OF3 381403.805 5033026.688
OF7 381448.424 5033041.047
Roof1 381428.968 5033077.455
Roof2 381428.95 5033077.454
St_L1 381395.548 5033108.811
St_L2 381417.381 5033128.938
St_L3 381450.027 5033054.56
St_P1 381406.853 5033073.521
St_P2 381416.312 5033051.852
St_UnGrd 381396.599 5033036.713
S01 381400.429 5033088.237

[VERTICES]
; ; Link X-Coord Y-Coord
; ;-----;
W_L1 381414.65 5033129.488
W_L1 381395.979 5033112.147

[POLYGONS]
; ; Subcatchment X-Coord Y-Coord
; ;-----;
L1_1 381426.561 5033106.239
L1_1 381433.371 5033109.212
L1_1 381441.156 5033055.96
L1_1 381450.139 5033056.155
L1_1 381435.928 5033041.204
L1_1 381430.376 5033033.492
L1_1 381429.744 5033033.928
L1_1 381429.096 5033034.342
L1_1 381428.435 5033034.734
L1_1 381427.96 5033035.402
L1_1 381427.074 5033034.446
L1_1 381426.375 5033035.767
L1_1 381425.758 5033036.025
L1_1 381425.134 5033036.264
L1_1 381424.503 5033036.484
L1_1 381423.865 5033036.685
L1_1 381423.221 5033036.865
L1_1 381423.155 5033037.19
L1_1 381423.218 5033037.391
L1_1 381423.223 5033037.654
L1_1 381423.251 5033037.916
L1_1 381423.281 5033038.178
L1_1 381423.32 5033038.438
L1_1 381423.368 5033038.606
L1_1 381423.425 5033038.953
L1_1 381423.49 5033039.208
L1_1 381423.564 5033039.46
L1_1 381423.647 5033039.71
L1_1 381423.738 5033039.957
L1_1 381423.838 5033040.2
L1_1 381423.946 5033040.44
L1_1 381424.062 5033040.76
L1_1 381424.186 5033040.908
L1_1 381424.318 5033041.136
L1_1 381424.458 5033041.359
L1_1 381424.605 5033041.577
L1_1 381424.76 5033041.79
L1_1 381424.921 5033041.99
L1_1 381424.99 5033041.99
L1_1 381425.266 5033042.395
L1_1 381425.448 5033042.584
L1_1 381425.637 5033042.768
L1_1 381425.831 5033042.945
L1_1 381426.032 5033043.115
L1_1 381426.239 5033043.278
L1_1 381426.435 5033043.434
L1_1 381426.668 5033043.582
L1_1 381426.89 5033043.723
L1_1 381427.116 5033043.857
L1_1 381427.348 5033043.982
L1_1 381427.583 5033044.1
L1_1 381427.822 5033044.209
L1_1 381428.034 5033044.891
L1_1 381441.12 5033050.021
L1_1 381441.401 5033050.162
L1_1 381441.677 5033050.313
L1_1 381441.947 5033050.472
L1_1 381442.212 5033050.642
L1_1 381442.411 5033050.82
L1_1 381442.733 5033051.008
L1_1 381442.969 5033051.204
L1_1 381443.207 5033051.408
L1_1 381443.438 5033051.621
L1_1 381443.662 5033051.841
L1_1 381443.878 5033052.07
L1_1 381444.086 5033052.305
L1_1 381444.245 5033052.448
L1_1 381444.476 5033052.798
L1_1 381444.658 5033053.054
L1_1 381444.831 5033053.316
L1_1 381444.995 5033053.585
L1_1 381445.149 5033053.858
L1_1 381445.244 5033054.137
L1_1 381445.428 5033054.421
L1_1 381445.553 5033054.71
L1_1 381445.668 5033055.002
L1_1 381445.772 5033055.299
L1_1 381445.866 5033055.598
L1_1 381445.95 5033055.901
L1_1 381446.022 5033056.207
L1_1 381446.065 5033056.415
L1_1 381446.136 5033056.825
L1_1 381446.176 5033057.137
L1_1 381446.206 5033057.449
L1_1 381446.224 5033057.763
L1_1 381446.232 5033058.077
L1_1 381446.229 5033058.392
L1_1 381446.245 5033058.605
L1_1 381446.189 5033059.019
L1_1 381446.153 5033059.331
L1_1 381446.106 5033059.641
L1_1 381446.048 5033059.95
L1_1 381445.98 5033060.257
L1_1 381445.901 5033060.561
L1_1 381445.811 5033060.862
L1_1 381445.711 5033061.16
L1_1 381445.6 5033061.454
L1_1 381445.479 5033061.744
L1_1 381442.344 5033068.909
L1_1 381442.775 5033069.097
L1_1 381442.561 5033106.239
L1_2 381445.635 5033115.444
L1_2 381445.643 5033115.347
L1_2 381404.547 5033110.503
L1_2 381408.488 5033110.475
L1_2 381404.701 5033099.821
L1_2 381405.665 5033097.614
L1_2 381401.22 5033095.674
L1_2 381400.599 5033097.094

[REPORT]
;; Reporting Options
INPUT YES
CONTROLS NO
SUBCATCHMENTS ALL
NODES ALL
LINKS ALL

[TAGS]

```

			S7	381442.723	5033051.008
L1_2	381393.818	5033094.134	S7	381442.471	5033050.82
L1_2	381394.298	5033093.034	S7	381442.212	5033050.642
L1_2	381389.532	5033090.954	S7	381441.947	5033050.472
L1_2	381389.672	5033090.633	S7	381441.677	5033050.313
L1_2	381386.265	5033089.146	S7	381441.401	5033050.162
L1_2	381386.988	5033087.5	S7	381441.12	5033050.021
L1_2	381370.061	5033080.111	S7	381440.84	5033050.81
L1_2	381371.111	5033081.11	S7	381427.822	5033044.209
L1_2	381373.576	5033092.727	S7	381425.421	5033049.708
L1_2	381375.266	5033094.193	S7	381430.18	5033051.785
L1_2	381382.117	5033100.508	S7	381425.847	5033061.708
L1_2	381407.635	5033124.034			
L1_3	381425.929	5033107.688	;;Storage Node	X-Coord	Y-Coord
L1_3	381426.474	5033117.892	-----	-----	-----
L1_3	381426.53	5033117.77	[SYMBOLS]	X-Coord	Y-Coord
L1_3	381407.635	5033124.034	-----	-----	-----
L1_3	381421.373	5033136.698			
L1_3	381433.371	5033109.212			
L1_3	381426.561	5033106.239			
L1_3	381425.929	5033107.688			
S1	381496.059	5033067.453			
S1	381496.159	5033068.155			
S1	381439.156	5033095.96			
S1	381483.973	5033094.136			
S1	381494.933	5033069			
S1	381496.059	5033067.453			
S2	381422.855	5033068.564			
S2	381425.847	5033061.708			
S2	381426.118	5033062.155			
S2	381425.821	5033049.708			
S2	381427.822	5033044.209			
S2	381427.583	5033044.099			
S2	381427.347	5033043.982			
S2	381427.116	5033043.856			
S2	381426.889	5033043.723			
S2	381426.65	5033042.62			
S2	381426.45	5033043.433			
S2	381426.238	5033043.278			
S2	381426.032	5033043.114			
S2	381425.831	5033042.944			
S2	381425.636	5033042.768			
S2	381425.448	5033042.584			
S2	381425.266	5033042.405			
S2	381425.19	5033042.199			
S2	381424.921	5033041.997			
S2	381424.759	5033041.789			
S2	381424.605	5033041.577			
S2	381424.458	5033041.359			
S2	381424.318	5033041.136			
S2	381424.16	5033040.908			
S2	381424.062	5033040.676			
S2	381423.946	5033040.44			
S2	381423.838	5033040.2			
S2	381423.738	5033039.957			
S2	381423.647	5033039.71			
S2	381423.564	5033039.46			
S2	381423.49	5033039.208			
S2	381423.325	5033038.953			
S2	381423.368	5033038.696			
S2	381423.32	5033038.438			
S2	381423.281	5033038.177			
S2	381423.251	5033037.916			
S2	381423.23	5033037.654			
S2	381423.218	5033037.41			
S2	381423.215	5033037.128			
S2	381423.221	5033036.865			
S2	381422.554	5033037.03			
S2	381421.883	5033037.174			
S2	381421.207	5033037.296			
S2	381420.528	5033037.397			
S2	381420.846	5033037.477			
S2	381419.752	5033037.545			
S2	381418.476	5033037.571			
S2	381417.789	5033037.586			
S2	381417.102	5033037.579			
S2	381408.289	5033038.705			
S2	381399.672	5033058.444			
S2	381422.855	5033058.564			
S3_1	381394.898	5033091.5			
S3_1	381386.265	5033099.146			
S3_1	381389.672	5033090.633			
S3_1	381389.532	5033090.954			
S3_1	381394.298	5033093.034			
S3_1	381393.818	5033094.134			
S3_1	381405.599	5033095.44			
S3_1	381401.22	5033095.674			
S3_1	381405.665	5033097.614			
S3_1	381404.701	5033099.821			
S3_1	381408.488	5033101.475			
S3_1	381415.264	5033085.953			
S3_1	381392.081	5033075.833			
S3_1	381398.388	5033077.5			
S3_2	381415.101	5033078.833			
S3_2	381415.264	5033085.953			
S3_2	381422.855	5033068.564			
S3_2	381399.672	5033058.444			
S3_2	381392.081	5033075.833			
S5	381421.474	5033117.892			
S5	381445.346	5033061.77			
S5	381425.847	5033062.097			
S5	381404.547	5033110.503			
S5	381421.474	5033117.892			
S6	381386.988	5033087.5			
S6	381408.289	5033038.705			
S6	381391.361	5033031.316			
S6	381407.611	5033089.111			
S6	381386.988	5033087.5			
S7	381425.847	5033061.708			
S7	381436.845	5033066.509			
S7	381442.344	5033068.909			
S7	381445.479	5033061.744			
S7	381445.6	5033061.454			
S7	381445.711	5033061.16			
S7	381445.811	5033060.862			
S7	381445.901	5033060.561			
S7	381445.98	5033060.257			
S7	381446.048	5033059.95			
S7	381446.106	5033059.641			
S7	381446.153	5033059.331			
S7	381446.19	5033059.19			
S7	381446.215	5033058.705			
S7	381446.229	5033058.392			
S7	381446.232	5033058.077			
S7	381446.224	5033057.763			
S7	381446.206	5033057.449			
S7	381446.176	5033057.137			
S7	381446.156	5033057.157			
S7	381446.085	5033056.515			
S7	381446.022	5033056.207			
S7	381445.95	5033055.901			
S7	381445.866	5033055.598			
S7	381445.772	5033055.299			
S7	381445.668	5033055.002			
S7	381445.553	5033054.71			
S7	381445.428	5033054.421			
S7	381445.294	5033054.137			
S7	381445.149	5033053.858			
S7	381444.995	5033053.585			
S7	381444.831	5033053.316			
S7	381444.658	5033053.054			
S7	381444.476	5033052.79			
S7	381444.285	5033052.548			
S7	381444.086	5033052.305			
S7	381443.878	5033052.07			
S7	381443.662	5033051.841			
S7	381443.438	5033051.621			
S7	381443.207	5033051.408			
S7	381442.969	5033051.204			

Post-Development 3-hour Chicago 1:100-year Event

July 2024

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.3)

Element Count

Number of rain gages 1
Number of subcatchments ... 10
Number of nodes 14
Number of links 12
Number of Pollutants 0
Number of land uses 0

Initial Stored Volume	0.000	0.000
Final Stored Volume	0.006	0.058
Continuity Error (%)	0.000	

Raingage Summary

Name	Data Source	Data Type	Recording Interval
Rainfall	3CH1100	INTENSITY	10 min.

Subcatchment Summary

Name	Area	Width	%Imperv	%Slope	Rain Gage	Outlet
L1_1	0.07	134.06	10.01	2.0000	Rainfall	St_L3
L1_2	0.07	15.82	8.45	2.0000	Rainfall	St_L1
L1_3	0.03	71.61	9.39	2.0000	Rainfall	St_L2
S1	0.16	38.19	14.29	2.0000	Rainfall	St_L3
S2	0.06	16.17	90.74	2.0000	Rainfall	St_P2
S3_1	0.04	10.81	99.29	2.0000	Rainfall	SU1
S3_2	0.05	13.27	98.96	2.0000	Rainfall	St_P1
S5	0.10	22.12	100.00	1.0000	Rainfall	Roof2
S6	0.10	22.12	100.00	1.0000	Rainfall	Roof1
S7	0.03	28.53	72.19	15.0000	Rainfall	St_UnGrd

Time-Step Critical Elements

None

Highest Flow Instability Indexes

All links are stable.

Most Frequent Nonconverging Nodes

Convergence obtained at all time steps.

Routing Time Step Summary

Minimum Time Step : 0.50 sec
Average Time Step : 1.00 sec
Maximum Time Step : 1.00 sec
% of Time in Steady State : 0.00
Average Iterations per Step : 2.00
% of Steps Not Converging : 0.00
Time Step Frequencies :
1.000 - 0.871 sec : 100.00 %
0.871 - 0.758 sec : 0.00 %
0.758 - 0.669 sec : 0.00 %
0.669 - 0.570 sec : 0.00 %
0.574 - 0.500 sec : 0.00 %

Subcatchment Runoff Summary

Node Summary

Name	Type	Invert Elev.	Max. Depth	Ponded Area	External Inflow
527_(P-Stm)	OUTFALL	81.23	0.00	0.0	
OF1	OUTFALL	80.67	0.00	0.0	
OF2	OUTFALL	80.67	0.00	0.0	
OF3	OUTFALL	80.67	0.00	0.0	
OF7	OUTFALL	80.67	0.00	0.0	
Roof1	STORAGE	95.85	0.15	0.0	
Roof2	STORAGE	96.85	0.15	0.0	
St_L1	STORAGE	84.20	1.70	0.0	
St_L2	STORAGE	83.90	2.10	0.0	
St_L3	STORAGE	83.09	2.21	0.0	
St_P1	STORAGE	85.70	0.31	0.0	
St_P2	STORAGE	85.50	0.15	0.0	
St_UnGrd	STORAGE	81.97	1.00	0.0	Yes
SU1	STORAGE	85.70	0.25	0.0	

Total Runoff	Total Runoff	Total Runoff	Total Runoff	Total Runoff	Total Runoff	Total Runoff
Subcatchment mm	Runoff 10^6 ltr	Runoff CMS	Runoff mm	Runoff mm	Evap mm	Infill mm
L1_1	31.27	0.02	0.03	0.436	71.71	0.00
L1_2	28.03	0.02	0.01	0.391	71.71	0.00
L1_3	29.46	0.01	0.01	0.411	71.71	0.00
S1	30.65	0.05	0.04	0.427	71.71	0.00
S2	66.33	0.04	0.03	0.925	71.71	0.00
S3_1	69.91	0.03	0.02	0.975	71.71	0.00
S3_2	69.77	0.03	0.02	0.973	71.71	0.00
S5	70.17	0.07	0.05	0.979	71.71	0.00
S6	70.17	0.07	0.05	0.979	71.71	0.00
S7	58.68	0.02	0.02	0.818	71.71	0.00
					40.38	7.03
					43.58	5.93
					42.30	2.73
					40.87	10.04
					4.03	63.70
					0.31	69.70
					0.45	69.47
					0.00	0.30
					0.00	70.17
					0.00	0.00
					0.00	70.17
					0.00	50.69
					12.02	7.98

Link Summary

Name	From Node	To Node	Type	Length	%Slope
Roughness	-	-	-	-	-
C1	St_L1	St_L2	CONDUIT	33.1	0.9050
0_0130	W_L1	St_L2	St_L1	WEIR	
W1	St_P1	St_P2	WEIR		
W2	SU1	St_P1	WEIR		
O_St_L3	St_L3	F2	OUTLET		
Oll1	SU1	St_UnGrd	OUTLET		
OL2	St_P1	St_UnGrd	OUTLET		
OL3	St_P2	St_UnGrd	OUTLET		
OL4	St_L2	527_(P-Stm)	OUTLET		
OR1	St_UnGrd	OF1	OUTLET		
Roof1	Roof2	OF3	OUTLET		
Roof2	OF7	OUTLET			

Node Depth Summary

Conduit	Shape	Full Depth	Full Area	Hyd. Rad.	Max. Width	No. of Barrels	Full Flow
C1	CIRCULAR	0.25	0.05	0.06	0.25	1	0.06

Node	Type	Average Meters	Maximum Meters	Maximum HGL Meters	Time of Max days	Time of Max hr:min	Reported Max Depth Meters
527_(P-Stm)	OUTFALL	1.63	3.88	85.11	0	01:57	3.88
OF1	OUTFALL	0.50	0.50	81.17	0	00:00	0.50
OF2	OUTFALL	0.55	0.55	81.46	0	00:00	0.55
OF3	OUTFALL	0.50	0.50	81.17	0	00:00	0.50
OF7	OUTFALL	0.50	0.50	81.17	0	00:00	0.50
Roof1	STORAGE	0.06	0.09	96.94	0	02:24	0.09
Roof2	STORAGE	0.06	0.09	96.94	0	02:24	0.09
St_L1	STORAGE	0.10	0.13	85.73	0	01:35	1.53
St_L2	STORAGE	0.51	1.83	85.73	0	01:36	1.83
St_L3	STORAGE	0.14	2.19	85.28	0	01:14	2.19
St_P1	STORAGE	0.00	0.04	85.74	0	01:10	0.04
St_P2	STORAGE	0.00	0.04	85.54	0	01:10	0.04
St_UnGrd	STORAGE	0.30	0.98	82.95	0	01:32	0.98
SU1	STORAGE	0.00	0.03	85.73	0	01:10	0.03

Analysis Options

Flow Units CMS

Process Models:

- Rainfall/Runoff YES
- RDI NO
- Snowmelt NO
- Groundwater NO
- Flow Routing YES
- Ponding Allowed NO
- Water Quality NO
- Infiltration Method HORTON
- Flow Routing Method DYNWAVE
- Surcharge Method EXTRAN
- Starting Date 01/01/2000 00:00:00
- Ending Date 01/01/2000 06:00:00
- Antecedent Dry Days 0.0
- Report Time Step 00:01:00
- Wet Time Step 00:01:00
- Dry Time Step 00:01:00
- Routing Time Step 0.00 sec
- Variable Time Step YES
- Maximum Trials 8
- Number of Threads 1
- Head Tolerance 0.001500 m

Node Inflow Summary

Runoff Quantity	Continuity	Volume hectare-m	Depth mm
Total Precipitation		0.050	71.708
Evaporation Loss		0.000	0.000
Infiltration Loss		0.014	20.257
Surface Runoff		0.036	50.621
Final Storage		0.001	0.893
Continuity Error (%)		-0.089	

Flow	Maximum Lateral	Maximum Total	Lateral	Total
Balance	Inflow	Inflow	Occurrence	Volume
Error Node Percent	Type	CMS	CMS days	10^6 ltr
527_(P-Stm)	OUTFALL	0.000	0.006	0 01:24
OF1	OUTFALL	0.000	0.010	0 00:51
OF2	OUTFALL	0.000	0.038	0 01:14
OF3	OUTFALL	0.000	0.002	0 00:36
OF7	OUTFALL	0.000	0.002	0 00:36
Roof1	STORAGE	0.049	0.049	0 01:10
Roof2	STORAGE	0.049	0.049	0 01:10
St_L1	STORAGE	0.013	0.021	0 01:11
St_L2	STORAGE	0.014	0.019	0 01:09
St_L3	STORAGE	0.066	0.066	0 01:10
St_P1	STORAGE	0.024	0.024	0 01:10
St_P2	STORAGE	0.030	0.030	0 01:10
St_UnGrd	STORAGE	0.015	0.088	0 01:10
SU1	STORAGE	0.019	0.019	0 01:10

Node Surcharge Summary

Post-Development 3-hour Chicago 1:100-year Event

July 2024

No nodes were surcharged.

Node Flooding Summary

No nodes were flooded.

Storage Volume Summary

	Average	Avg	Evap	Exfil	Maximum	Max	Time of Max
Maximum	Volume	Pcnt	Pcnt	Pcnt	Volume	Pcnt	Occurrence
Outflow Storage Unit CMS	1000 m ³	Full	Loss	Loss	1000 m ³	Full	days hr:min
Roof1	0.035	42.0	0.0	0.0	0.051	60.3	0 02:24
Roof2	0.035	42.0	0.0	0.0	0.051	60.3	0 02:24
St_L1	0.001	3.1	0.0	0.0	0.006	19.7	0 01:35
St_L2	0.000	1.4	0.0	0.0	0.002	7.8	0 01:36
St_L3	0.000	3.2	0.0	0.0	0.007	86.0	0 01:14
St_P1	0.000	0.1	0.0	0.0	0.001	2.2	0 01:10
St_P2	0.000	0.4	0.0	0.0	0.001	9.0	0 01:10
St_UnGrd	0.019	30.3	0.0	0.0	0.063	98.3	0 01:32
SU1	0.000	0.1	0.0	0.0	0.000	2.2	0 01:10
SU2	0.019						

Outfall Loading Summary

Outfall Node	Flow Freq Pcnt	Avg Flow CMS	Max Flow CMS	Total Volume 10^6 ltr
S27_(P-Stm)	40.19	0.003	0.006	0.029
OP1	65.18	0.003	0.006	0.020
OP2	41.47	0.007	0.038	0.070
OP3	94.60	0.002	0.002	0.040
OP7	94.60	0.002	0.002	0.040
System	68.01	0.023	0.058	0.299

Link Flow Summary

Link	Type	Maximum Flow CMS	Time of Max Occurrence days hr:min	Maximum Velocity m/sec	Max Full Flow	Max Full Depth
C1	CONDUIT	0.008	0 01:05	0.21	0.14	1.00
W_L1	WEIR	0.000	0 00:00		0.00	
W1	WEIR	0.000	0 00:00		0.00	
W2	WEIR	0.000	0 00:00		0.00	
O_St_L3	DUMMY	0.018	0 01:10			
OL1	DUMMY	0.019	0 01:10			
OL2	DUMMY	0.024	0 01:10			
OL3	DUMMY	0.030	0 01:10			
OL4	DUMMY	0.006	0 01:24			
OR1	DUMMY	0.010	0 00:51			
ROOF1	DUMMY	0.002	0 00:36			
ROOF2	DUMMY	0.002	0 00:36			

Flow Classification Summary

Conduit	Adjusted /Actual Length	Fraction of Time in Flow Class									
		Dry	Dry	Up Dry	Up Dry	Sub Up	Sup Up	Down Crit	Down Crit	Norm Crit	Inlet Ctrl
C1	1.00	0.17	0.00	0.00	0.83	0.00	0.00	0.00	0.00	0.07	0.00

Conduit Surcharge Summary

Conduit	Both Ends	Hours Full Upstream	Hours Full Dnstream	Above Normal Flow	Hours Capacity Limited
C1	1.81	1.81	2.07	0.01	0.01

Analysis begun on: Tue Oct 8 09:00:27 2024
 Analysis ended on: Tue Oct 8 09:00:28 2024
 Total elapsed time: 00:00:01

Post-Development 24-hour SCS 1:100-year Event

```

[TITLE]
;;Project Title/Notes

[OPTIONS]
;;Option Value
FLOW_UNITS CMS
INFILTRATION HORTON
FLOW_ROUTING DYNWAVE
LINK_OFFSETS ELEVATION
MIN_SLOPE 0
ALLOW_PONDING NO
SKIP_STEADY_STATE NO

START_DATE 01/01/2000
START_TIME 00:00:00
REPORT_START_DATE 01/01/2000
REPORT_START_TIME 00:00:00
END_DATE 01/02/2000
END_TIME 00:00:00
SWEEP_START 00:01
SWEEP_END 12/31
DRY_DAYS 0
REPORT_STEP 00:01:00
WET_STEP 00:01:00
DRY_STEP 00:01:00
ROUTING_STEP RULE_STEP 00:00:00

INERTIAL_DAMPING PARTIAL
NORMAL_FLOW_LIMITED BOTH
FORCE_MAIN_EQUATION H-W
VARIABLE_STEP 0.75
LEVENBERG_STEP 0
MIN_SURFACE 0
MAX_TRIALS 8
HEAD_TOLERANCE 0.0015
SYS_FLOW_TOL 5
LAT_FLOW_TOL 5
MINIMUM_STEP 0.5
THREADS 12

[EVAPORATION]
;;Data Source Parameters
;;Data Source NO

CONSTANT 0.0
DRY_ONLY NO

[RAINGAGES]
;;Name Format Interval SCF Source
Rainfall INTENSITY 0:15 1.0 TIMESERIES 24SCS100

[SUBCATCHMENTS]
;;Name Rain Gage Outlet Area %Imperv Width %Slope CurbLen
ShowPack ;;

L1_1 Rainfall St_L3 0.0699 10.014 134.062 2 0
L1_2 Rainfall St_L1 0.0681 8.447 15.82 2 0
L1_3 Rainfall St_L2 0.0324 3.893 77.605 2 0
S1 Rainfall St_L3 0.1577 14.286 38.49 2 0
S2 Rainfall St_P2 0.0391 90.287 11.17 2 0
S3_1 Rainfall St_U 0.0391 99.287 10.808 2 0
S3_2 Rainfall St_P1 0.048 98.957 13.267 2 0
S5 Rainfall Roof2 0.0983 100 22.118 1 0
S6 Rainfall Roof1 0.0983 100 22.118 1 0
S7 Rainfall St_UnGrd 0.0317 72.194 28.53 15 0

[SUBAREAS]
;;Subcatchment N-Imperv N-Perv S-Imperv S-Perv PctZero RouteTo PctRouted
L1_1 0.013 0.25 1.57 4.67 0 PERVIOUS 100
L1_2 0.013 0.25 1.57 4.67 0 PERVIOUS 100
L1_3 0.013 0.25 1.57 4.67 0 PERVIOUS 80
S1 0.013 0.25 1.57 4.67 0 OUTLET
S2 0.013 0.25 1.57 4.67 0 OUTLET
S3_1 0.013 0.25 1.57 4.67 0 OUTLET
S3_2 0.013 0.25 1.57 4.67 0 OUTLET
S5 0.013 0.25 1.57 4.67 0 OUTLET
S6 0.013 0.25 1.57 4.67 0 OUTLET
S7 0.013 0.25 1.57 4.67 0 OUTLET

[INFILTRATION]
;;Subcatchment Param1 Param2 Param3 Param4 Param5
L1_1 76.2 13.2 4.14 7 0
L1_2 76.2 13.2 4.14 7 0
L1_3 76.2 13.2 4.14 7 0
S1 76.2 13.2 4.14 7 0
S2 76.2 13.2 4.14 7 0
S3_1 76.2 13.2 4.14 7 0
S3_2 76.2 13.2 4.14 7 0
S5 76.2 13.2 4.14 7 0
S6 76.2 13.2 4.14 7 0
S7 76.2 13.2 4.14 7 0

[OUTFALLS]
;;Name Elevation Type Stage Data Gated Route To
527_(P-Stm) 81.228 TIMESERIES 527_24SCS100 NO
OF1 80.67 FIXED 81.17 NO
OF2 80.911 FIXED 81.46 NO
OF3 80.67 FIXED 81.17 NO
OF7 80.67 FIXED 81.17 NO

[STORAGE]
;;Name Elev. MaxDepth Ksat IMD Shape Curve Name/Params
Surf_Fevap Psi. Ksat InitDepth IMD ;;

Roof1 96.85 0.15 0 FUNCTIONAL 0 0 559.44 0
Roof2 96.85 0.15 0 FUNCTIONAL 0 0 559.44 0
St_L1 84.2 1.7 0 TABULAR St_L1 0
St_L2 83.9 2.1 0 TABULAR St_L2 0
St_L3 83.09 2.21 0 TABULAR St_L3 0
St_P1 85.7 0.31 0 TABULAR St_P1 0
St_P2 85.5 0.15 0 TABULAR St_P2 0
St_UnGrd 81.971 1 0 FUNCTIONAL 0 0 64 0
SUI 85.7 0.25 0 TABULAR St_P3 0
0 ;;

[CONDUTTS]
;;Name From Node To Node Length Roughness InOffset OutOffset
InitFlow MaxFlow ;;

C1 0.04 St_L1 St_L2 33.149 0.013 84.2 83.9

[WEIRS]
;;Name EndCoef From Node To Node Type CrestHt Qcoeff Gated
EndCon Surcharge RoadWidth RoadSurf Coeff. Curve ;;

;Tempest Rating Curve for MHF IPEX TYPE A, No grate allowance
MHF_IPEX_TYPE_A Rating 0 0
MHF_IPEX_TYPE_A Rating 0.1 0.0057
MHF_IPEX_TYPE_A 0.2 0.0081
MHF_IPEX_TYPE_A 0.3 0.0099
MHF_IPEX_TYPE_A 0.4 0.0114
MHF_IPEX_TYPE_A 0.5 0.0128
MHF_IPEX_TYPE_A 0.6 0.014
MHF_IPEX_TYPE_A 0.7 0.0151
MHF_IPEX_TYPE_A 0.8 0.0162
MHF_IPEX_TYPE_A 0.9 0.0172
MHF_IPEX_TYPE_B Rating 0 0
MHF_IPEX_TYPE_B Rating 0.1 0.0081
MHF_IPEX_TYPE_B 0.2 0.0115
MHF_IPEX_TYPE_B 0.3 0.0141
MHF_IPEX_TYPE_B 0.4 0.0162
MHF_IPEX_TYPE_B 0.5 0.0182
MHF_IPEX_TYPE_B 0.6 0.0199
MHF_IPEX_TYPE_B 0.7 0.0215
MHF_IPEX_TYPE_B 0.8 0.023
MHF_IPEX_TYPE_B 0.9 0.0244
MHF_IPEX_TYPE_B 1 0.0257
MHF_IPEX_TYPE_B 1.2 0.0281
MHF_IPEX_TYPE_B 1.4 0.0304
MHF_IPEX_TYPE_B 1.6 0.0325
MHF_IPEX_TYPE_B 1.8 0.0344
MHF_IPEX_TYPE_B 2 0.0363
MHF_IPEX_TYPE_B 2.5 0.0406
MHF_IPEX_TYPE_B 3 0.0445

;Tempest Rating Curve for MHF IPEX TYPE C, No grate allowance
MHF_IPEX_TYPE_C Rating 0 0

```

MHF_IPEX_TYPE_C Rating 0.1 0.0106
MHF_IPEX_TYPE_C 0.2 0.015
MHF_IPEX_TYPE_C 0.3 0.0183
MHF_IPEX_TYPE_C 0.4 0.0212
MHF_IPEX_TYPE_C 0.5 0.0237
MHF_IPEX_TYPE_C 0.6 0.0259
MHF_IPEX_TYPE_C 0.7 0.028
MHF_IPEX_TYPE_C 0.8 0.0299
MHF_IPEX_TYPE_C 0.9 0.0317
MHF_IPEX_TYPE_C 1 0.0335
MHF_IPEX_TYPE_C 1.2 0.0366
MHF_IPEX_TYPE_C 1.4 0.0396
MHF_IPEX_TYPE_C 1.6 0.0423
MHF_IPEX_TYPE_C 1.8 0.0449
MHF_IPEX_TYPE_C 2 0.0473
MHF_IPEX_TYPE_C 2.5 0.0529
MHF_IPEX_TYPE_C 3 0.0579

;Tempest Rating Curve for MHF IPEX TYPE C, No grate allowance
MHF_IPEX_TYPE_C Rating 0 0
MHF_IPEX_TYPE_C 0.1 0.0154
MHF_IPEX_TYPE_C 0.2 0.0217
MHF_IPEX_TYPE_C 0.3 0.0266
MHF_IPEX_TYPE_C 0.4 0.0307
MHF_IPEX_TYPE_C 0.5 0.0343
MHF_IPEX_TYPE_C 0.6 0.0376
MHF_IPEX_TYPE_C 0.7 0.0406
MHF_IPEX_TYPE_C 0.8 0.0434
MHF_IPEX_TYPE_C 0.9 0.0461
MHF_IPEX_TYPE_C 1 0.0485
MHF_IPEX_TYPE_C 1.2 0.0532
MHF_IPEX_TYPE_C 1.4 0.0574
MHF_IPEX_TYPE_C 1.6 0.0614
MHF_IPEX_TYPE_C 1.8 0.0651
MHF_IPEX_TYPE_C 2 0.0687
MHF_IPEX_TYPE_C 2.5 0.0768
MHF_IPEX_TYPE_C 3 0.0841

;Tempest Rating Curve for MHF IPEX TYPE D, No grate allowance
MHF_IPEX_TYPE_D Rating 0 0
MHF_IPEX_TYPE_D 0.1 0.0205
MHF_IPEX_TYPE_D 0.2 0.0289
MHF_IPEX_TYPE_D 0.3 0.0355
MHF_IPEX_TYPE_D 0.4 0.0399
MHF_IPEX_TYPE_D 0.5 0.0458
MHF_IPEX_TYPE_D 0.6 0.0501
MHF_IPEX_TYPE_D 0.7 0.0542
MHF_IPEX_TYPE_D 0.8 0.0579
MHF_IPEX_TYPE_D 0.9 0.0614
MHF_IPEX_TYPE_D 1 0.067
MHF_IPEX_TYPE_D 1.2 0.0709
MHF_IPEX_TYPE_D 1.4 0.0766
MHF_IPEX_TYPE_D 1.6 0.0819
MHF_IPEX_TYPE_D 1.8 0.0868
MHF_IPEX_TYPE_D 2 0.0915
MHF_IPEX_TYPE_D 2.5 0.1023
MHF_IPEX_TYPE_D 3 0.1121

O_Roof1 Rating 0 0
O_Roof1 0.001 0.002
O_Roof1 0.15 0.002

O_Roof2 Rating 0 0
O_Roof2 0.001 0.002
O_Roof2 0.15 0.002

O_St_L1 Rating 0 0
O_St_L1 0.001 0.003
O_St_L1 0.35 0.003

O_St_L2 Rating 0 0
O_St_L2 0.001 0.002
O_St_L2 0.35 0.002

O_St_L3 Rating 0 0
O_St_L3 0.001 0.0137
O_St_L3 0.35 0.0137

O_St_UnGrd Rating 0 0
O_St_UnGrd 0.01 0.01
O_St_UnGrd 1 0.01

;Tempest Rating Curve for Vortex ICD 100, No grate allowance
Vortex_ICD_100 Rating 0 0
Vortex_ICD_100 0.1 0.0028
Vortex_ICD_100 0.2 0.004
Vortex_ICD_100 0.3 0.0049
Vortex_ICD_100 0.4 0.0056
Vortex_ICD_100 0.5 0.0063
Vortex_ICD_100 0.6 0.0069
Vortex_ICD_100 0.7 0.0075
Vortex_ICD_100 0.8 0.008
Vortex_ICD_100 0.9 0.0085
Vortex_ICD_100 1 0.0089
Vortex_ICD_100 1.2 0.0098
Vortex_ICD_100 1.4 0.0106
Vortex_ICD_100 1.6 0.0113
Vortex_ICD_100 1.8 0.012
Vortex_ICD_100 2 0.0126
Vortex_ICD_100 2.5 0.0141
Vortex_ICD_100 3 0.0155

;Tempest Rating Curve for Vortex ICD 105, No grate allowance
Vortex_ICD_105 Rating 0 0
Vortex_ICD_105 0.1 0.0031
Vortex_ICD_105 0.2 0.004
Vortex_ICD_105 0.3 0.0054
Vortex_ICD_105 0.4 0.0062
Vortex_ICD_105 0.5 0.0069
Vortex_ICD_105 0.6 0.0076
Vortex_ICD_105 0.7 0.0082
Vortex_ICD_105 0.8 0.0088
Vortex_ICD_105 0.9 0.0093
Vortex_ICD_105 1 0.0098
Vortex_ICD_105 1.2 0.0107
Vortex_ICD_105 1.4 0.0116
Vortex_ICD_105 1.6 0.0124
Vortex_ICD_105 1.8 0.0131
Vortex_ICD_105 2 0.0139
Vortex_ICD_105 2.5 0.0155
Vortex_ICD_105 3 0.017

;Tempest Rating Curve for Vortex ICD 40, No grate allowance
Vortex_ICD_40 Rating 0 0
Vortex_ICD_40 0.1 0.0004
Vortex_ICD_40 0.2 0.0006
Vortex_ICD_40 0.3 0.0007
Vortex_ICD_40 0.4 0.0009
Vortex_ICD_40 0.5 0.001
Vortex_ICD_40 0.6 0.001
Vortex_ICD_40 0.7 0.0011
Vortex_ICD_40 0.8 0.0012
Vortex_ICD_40 0.9 0.0013
Vortex_ICD_40 1 0.0014
Vortex_ICD_40 1.2 0.0015
Vortex_ICD_40 1.4 0.0016
Vortex_ICD_40 1.6 0.0017
Vortex_ICD_40 1.8 0.0018
Vortex_ICD_40 2 0.0019
Vortex_ICD_40 2.5 0.0022
Vortex_ICD_40 3 0.0024

;Tempest Rating Curve for Vortex ICD 45, No grate allowance
Vortex_ICD_45 Rating 0 0
Vortex_ICD_45 0.1 0.0006
Vortex_ICD_45 0.2 0.0008
Vortex_ICD_45 0.3 0.001
Vortex_ICD_45 0.4 0.0011
Vortex_ICD_45 0.5 0.0013

Vortex_ICD_45 Rating 0.6 0.0014
Vortex_ICD_45 0.7 0.0015
Vortex_ICD_45 0.8 0.0016
Vortex_ICD_45 0.9 0.0017
Vortex_ICD_45 1 0.0018
Vortex_ICD_45 1.2 0.002
Vortex_ICD_45 1.4 0.0023
Vortex_ICD_45 1.6 0.0024
Vortex_ICD_45 1.8 0.0026
Vortex_ICD_45 2 0.0026
Vortex_ICD_45 2.5 0.0029
Vortex_ICD_45 3 0.0031

Vortex_ICD_50 Rating 0 0
Vortex_ICD_50 0.1 0.0007
Vortex_ICD_50 0.2 0.001
Vortex_ICD_50 0.3 0.0012
Vortex_ICD_50 0.4 0.0014
Vortex_ICD_50 0.5 0.0016
Vortex_ICD_50 0.6 0.0018
Vortex_ICD_50 0.7 0.0019
Vortex_ICD_50 0.8 0.002
Vortex_ICD_50 0.9 0.0021
Vortex_ICD_50 1 0.0023
Vortex_ICD_50 1.2 0.0025
Vortex_ICD_50 1.4 0.0027
Vortex_ICD_50 1.6 0.0029
Vortex_ICD_50 1.8 0.0032
Vortex_ICD_50 2 0.0032
Vortex_ICD_50 2.5 0.0036
Vortex_ICD_50 3 0.0039

;Tempest Rating Curve for Vortex ICD 55, No grate allowance
Vortex_ICD_55 Rating 0 0
Vortex_ICD_55 0.1 0.0009
Vortex_ICD_55 0.2 0.0012
Vortex_ICD_55 0.3 0.0015
Vortex_ICD_55 0.4 0.0017
Vortex_ICD_55 0.5 0.0019
Vortex_ICD_55 0.6 0.0021
Vortex_ICD_55 0.7 0.0023
Vortex_ICD_55 0.8 0.0024
Vortex_ICD_55 0.9 0.0026
Vortex_ICD_55 1 0.0027
Vortex_ICD_55 1.2 0.003
Vortex_ICD_55 1.4 0.0032
Vortex_ICD_55 1.6 0.0034
Vortex_ICD_55 1.8 0.0036
Vortex_ICD_55 2 0.0038
Vortex_ICD_55 2.5 0.0043
Vortex_ICD_55 3 0.0047

;Tempest Rating Curve for Vortex ICD 60, No grate allowance
Vortex_ICD_60 Rating 0 0
Vortex_ICD_60 0.1 0.0011
Vortex_ICD_60 0.2 0.0015
Vortex_ICD_60 0.3 0.0018
Vortex_ICD_60 0.4 0.0021
Vortex_ICD_60 0.5 0.0023
Vortex_ICD_60 0.6 0.0025
Vortex_ICD_60 0.7 0.0027
Vortex_ICD_60 0.8 0.0029
Vortex_ICD_60 0.9 0.0031
Vortex_ICD_60 1 0.0032
Vortex_ICD_60 1.2 0.0036
Vortex_ICD_60 1.4 0.0038
Vortex_ICD_60 1.6 0.0041
Vortex_ICD_60 1.8 0.0043
Vortex_ICD_60 2 0.0046
Vortex_ICD_60 2.5 0.0051
Vortex_ICD_60 3 0.0056

;Tempest Rating Curve for Vortex ICD 65, No grate allowance
Vortex_ICD_65 Rating 0 0
Vortex_ICD_65 0.1 0.0012
Vortex_ICD_65 0.2 0.0016
Vortex_ICD_65 0.3 0.002
Vortex_ICD_65 0.4 0.0023
Vortex_ICD_65 0.5 0.0025
Vortex_ICD_65 0.6 0.0028
Vortex_ICD_65 0.7 0.003
Vortex_ICD_65 0.8 0.0032
Vortex_ICD_65 0.9 0.0034
Vortex_ICD_65 1 0.0036
Vortex_ICD_65 1.2 0.004
Vortex_ICD_65 1.4 0.0043
Vortex_ICD_65 1.6 0.0046
Vortex_ICD_65 1.8 0.0049
Vortex_ICD_65 2 0.0051
Vortex_ICD_65 2.5 0.0057
Vortex_ICD_65 3 0.0063

;Tempest Rating Curve for Vortex ICD 70, No grate allowance
Vortex_ICD_70 Rating 0 0
Vortex_ICD_70 0.1 0.0013
Vortex_ICD_70 0.2 0.0019
Vortex_ICD_70 0.3 0.0023
Vortex_ICD_70 0.4 0.0027
Vortex_ICD_70 0.5 0.003
Vortex_ICD_70 0.6 0.0033
Vortex_ICD_70 0.7 0.0036
Vortex_ICD_70 0.8 0.0038
Vortex_ICD_70 0.9 0.0041
Vortex_ICD_70 1 0.0043
Vortex_ICD_70 1.2 0.0047
Vortex_ICD_70 1.4 0.0051
Vortex_ICD_70 1.6 0.0055
Vortex_ICD_70 1.8 0.0058
Vortex_ICD_70 2 0.0061
Vortex_ICD_70 2.5 0.0068
Vortex_ICD_70 3 0.0075

;Tempest Rating Curve for Vortex ICD 75, No grate allowance
Vortex_ICD_75 Rating 0 0
Vortex_ICD_75 0.1 0.0016
Vortex_ICD_75 0.2 0.0022
Vortex_ICD_75 0.3 0.0027
Vortex_ICD_75 0.4 0.0032
Vortex_ICD_75 0.5 0.0035
Vortex_ICD_75 0.6 0.0039
Vortex_ICD_75 0.7 0.0042
Vortex_ICD_75 0.8 0.0045
Vortex_ICD_75 0.9 0.0048
Vortex_ICD_75 1 0.005
Vortex_ICD_75 1.2 0.0055
Vortex_ICD_75 1.4 0.0059
Vortex_ICD_75 1.6 0.0063
Vortex_ICD_75 1.8 0.0067
Vortex_ICD_75 2 0.0071
Vortex_ICD_75 2.5 0.0079
Vortex_ICD_75 3 0.0087

;Tempest Rating Curve for Vortex ICD 80, No grate allowance
Vortex_ICD_80 Rating 0 0
Vortex_ICD_80 0.1 0.0018
Vortex_ICD_80 0.2 0.0026
Vortex_ICD_80 0.3 0.0031
Vortex_ICD_80 0.4 0.0036
Vortex_ICD_80 0.5 0.004
Vortex_ICD_80 0.6 0.0044
Vortex_ICD_80 0.7 0.0048
Vortex_ICD_80 0.8 0.0051
Vortex_ICD_80 0.9 0.0054
Vortex_ICD_80 1 0.0057
Vortex_ICD_80 1.2 0.0063
Vortex_ICD_80 1.4 0.0068
Vortex_ICD_80 1.6 0.0072
Vortex_ICD_80 1.8 0.0077

Vortex_ICD_80 2 0.0081
Vortex_ICD_80 2.5 0.009
Vortex_ICD_80 3 0.0099

;Tempest Rating Curve for Vortex ICD 85, No grate allowance
Vortex_ICD_85 Rating 0 0
Vortex_ICD_85 0.1 0.002
Vortex_ICD_85 0.2 0.0029
Vortex_ICD_85 0.3 0.0035
Vortex_ICD_85 0.4 0.0041
Vortex_ICD_85 0.5 0.0045
Vortex_ICD_85 0.6 0.005
Vortex_ICD_85 0.7 0.0054
Vortex_ICD_85 0.8 0.0057
Vortex_ICD_85 0.9 0.0061
Vortex_ICD_85 1 0.0064
Vortex_ICD_85 1.2 0.007
Vortex_ICD_85 1.4 0.0076
Vortex_ICD_85 1.6 0.0081
Vortex_ICD_85 1.8 0.0086
Vortex_ICD_85 2 0.0091
Vortex_ICD_85 2.5 0.0101
Vortex_ICD_85 3 0.0111

;Tempest Rating Curve for Vortex ICD 90, No grate allowance
Vortex_ICD_90 Rating 0 0
Vortex_ICD_90 0.1 0.0022
Vortex_ICD_90 0.2 0.0022
Vortex_ICD_90 0.3 0.0039
Vortex_ICD_90 0.4 0.0045
Vortex_ICD_90 0.5 0.0051
Vortex_ICD_90 0.6 0.0055
Vortex_ICD_90 0.7 0.006
Vortex_ICD_90 0.8 0.0064
Vortex_ICD_90 0.9 0.0068
Vortex_ICD_90 1 0.0072
Vortex_ICD_90 1.2 0.0079
Vortex_ICD_90 1.4 0.0085
Vortex_ICD_90 1.6 0.0091
Vortex_ICD_90 1.8 0.0096
Vortex_ICD_90 2 0.0102
Vortex_ICD_90 2.5 0.0114
Vortex_ICD_90 3 0.0125

;Tempest Rating Curve for Vortex ICD 95, No grate allowance
Vortex_ICD_95 Rating 0 0
Vortex_ICD_95 0.1 0.0026
Vortex_ICD_95 0.2 0.0036
Vortex_ICD_95 0.3 0.0044
Vortex_ICD_95 0.4 0.0051
Vortex_ICD_95 0.5 0.0057
Vortex_ICD_95 0.6 0.0062
Vortex_ICD_95 0.7 0.0067
Vortex_ICD_95 0.8 0.0071
Vortex_ICD_95 0.9 0.0076
Vortex_ICD_95 1 0.008
Vortex_ICD_95 1.2 0.0087
Vortex_ICD_95 1.4 0.0094
Vortex_ICD_95 1.6 0.0101
Vortex_ICD_95 1.8 0.0107
Vortex_ICD_95 2 0.0113
Vortex_ICD_95 2.5 0.0126
Vortex_ICD_95 3 0.0138

;From Zurn Manual RD178
ZURN_2150F-6NH Rating 0 0
ZURN_2150F-6NH 0.0127 0.00503838308477861
ZURN_2150F-6NH 0.0257 0.0132420013231177
ZURN_2150F-6NH 0.0384 0.0234992054543888
ZURN_2150F-6NH 0.0508 0.0357128365761305
ZURN_2150F-6NH 0.0765 0.04501972611045
ZURN_2150F-6NH 0.1024 0.0433196215564931

St_L1 Storage 0 0.073
St_L1 1.4 0.073
St_L1 1.7 198.79

St_L2 Storage 0 0.36
St_L2 1.75 0.36
St_L2 2.05 129.41
St_L2 2.1 129.41

St_L3 Storage 0 0.36
St_L3 1.96 0.36
St_L3 2.21 62.31

St_P1 Storage 0 0.36
St_P1 0.15 114.4
St_P1 0.31 114.4

St_P2 Storage 0 0.36
St_P2 0.15 100.57

St_P3 Storage 0 0.36
St_P3 0.15 92.14
St_P3 0.25 92.14

[TIMESERIES]
;;Name Date Time Value

;Rainfall (mm/hr)
24SCS10 01/01/2000 00:00:00 1.08
24SCS10 01/01/2000 00:15:00 1.08
24SCS10 01/01/2000 00:30:00 1.08
24SCS10 01/01/2000 00:45:00 1.08
24SCS10 01/01/2000 01:00:00 0.504
24SCS10 01/01/2000 01:15:00 0.504
24SCS10 01/01/2000 01:30:00 0.504
24SCS10 01/01/2000 01:45:00 0.504
24SCS10 01/01/2000 02:00:00 0.936
24SCS10 01/01/2000 02:15:00 0.936
24SCS10 01/01/2000 02:30:00 0.936
24SCS10 01/01/2000 02:45:00 0.936
24SCS10 01/01/2000 03:00:00 0.936
24SCS10 01/01/2000 03:15:00 0.936
24SCS10 01/01/2000 03:30:00 0.936
24SCS10 01/01/2000 03:45:00 0.936
24SCS10 01/01/2000 04:00:00 1.224
24SCS10 01/01/2000 04:15:00 1.224
24SCS10 01/01/2000 04:30:00 1.224
24SCS10 01/01/2000 04:45:00 1.224
24SCS10 01/01/2000 05:00:00 1.08
24SCS10 01/01/2000 05:15:00 1.08
24SCS10 01/01/2000 05:30:00 1.08
24SCS10 01/01/2000 05:45:00 1.08
24SCS10 01/01/2000 06:00:00 1.44
24SCS10 01/01/2000 06:15:00 1.44
24SCS10 01/01/2000 06:30:00 1.44
24SCS10 01/01/2000 06:45:00 1.44
24SCS10 01/01/2000 07:00:00 1.44
24SCS10 01/01/2000 07:15:00 1.44
24SCS10 01/01/2000 07:30:00 1.44
24SCS10 01/01/2000 07:45:00 1.44
24SCS10 01/01/2000 08:00:00 1.44
24SCS10 01/01/2000 08:15:00 1.44
24SCS10 01/01/2000 08:30:00 1.44
24SCS10 01/01/2000 08:45:00 1.944
24SCS10 01/01/2000 09:00:00 2.304
24SCS10 01/01/2000 09:15:00 2.304
24SCS10 01/01/2000 09:30:00 2.592
24SCS10 01/01/2000 09:45:00 2.592
24SCS10 01/01/2000 10:00:00 3.12
24SCS10 01/01/2000 10:15:00 3.12
24SCS10 01/01/2000 10:30:00 4.464
24SCS10 01/01/2000 10:45:00 4.464
24SCS10 01/01/2000 11:00:00 6.912
24SCS10 01/01/2000 11:15:00 6.912
24SCS10 01/01/2000 11:30:00 29.952
24SCS10 01/01/2000 11:45:00 79.488

24SCS10 01/01/2000 12:00:00 10.368
24SCS10 01/01/2000 12:15:00 10.368
24SCS10 01/01/2000 12:30:00 5.328
24SCS10 01/01/2000 12:45:00 5.328
24SCS10 01/01/2000 13:00:00 3.888
24SCS10 01/01/2000 13:15:00 3.888
24SCS10 01/01/2000 13:30:00 3.024
24SCS10 01/01/2000 13:45:00 3.024
24SCS10 01/01/2000 14:00:00 3.204
24SCS10 01/01/2000 14:15:00 2.304
24SCS10 01/01/2000 14:30:00 2.304
24SCS10 01/01/2000 14:45:00 2.304
24SCS10 01/01/2000 15:00:00 2.016
24SCS10 01/01/2000 15:15:00 2.016
24SCS10 01/01/2000 15:30:00 2.016
24SCS10 01/01/2000 15:45:00 2.016
24SCS10 01/01/2000 16:00:00 1.584
24SCS10 01/01/2000 16:15:00 1.584
24SCS10 01/01/2000 16:30:00 1.584
24SCS10 01/01/2000 16:45:00 1.584
24SCS10 01/01/2000 17:00:00 1.656
24SCS10 01/01/2000 17:15:00 1.656
24SCS10 01/01/2000 17:30:00 1.656
24SCS10 01/01/2000 17:45:00 1.656
24SCS10 01/01/2000 18:00:00 1.08
24SCS10 01/01/2000 18:15:00 1.08
24SCS10 01/01/2000 18:30:00 1.08
24SCS10 01/01/2000 18:45:00 1.08
24SCS10 01/01/2000 19:00:00 0.864
24SCS10 01/01/2000 19:15:00 0.864
24SCS10 01/01/2000 19:30:00 0.864
24SCS10 01/01/2000 19:45:00 0.864
24SCS10 01/01/2000 20:00:00 1.224
24SCS10 01/01/2000 20:15:00 1.224
24SCS10 01/01/2000 20:30:00 1.224
24SCS10 01/01/2000 20:45:00 1.224
24SCS10 01/01/2000 21:00:00 1.224
24SCS10 01/01/2000 21:15:00 1.224
24SCS10 01/01/2000 21:30:00 1.224
24SCS10 01/01/2000 21:45:00 1.224
24SCS10 01/01/2000 22:00:00 1.224
24SCS10 01/01/2000 22:15:00 1.224
24SCS10 01/01/2000 22:30:00 1.224
24SCS10 01/01/2000 22:45:00 1.224
24SCS10 01/01/2000 23:00:00 1.224
24SCS10 01/01/2000 23:15:00 1.224
24SCS10 01/01/2000 23:30:00 1.224
24SCS10 01/01/2000 23:45:00 1.224
24SCS10 01/02/2000 00:00:00 0

;Rainfall (mm/hr)
24SCS100 01/01/2000 00:00:00 1.548
24SCS100 01/01/2000 00:15:00 1.548
24SCS100 01/01/2000 00:30:00 1.548
24SCS100 01/01/2000 00:45:00 1.548
24SCS100 01/01/2000 01:00:00 0.7224
24SCS100 01/01/2000 01:15:00 0.7224
24SCS100 01/01/2000 01:30:00 0.7224
24SCS100 01/01/2000 01:45:00 0.7224
24SCS100 01/01/2000 02:00:00 1.3416
24SCS100 01/01/2000 02:15:00 1.3416
24SCS100 01/01/2000 02:30:00 1.3416
24SCS100 01/01/2000 02:45:00 1.3416
24SCS100 01/01/2000 03:00:00 1.3416
24SCS100 01/01/2000 03:15:00 1.3416
24SCS100 01/01/2000 03:30:00 1.3416
24SCS100 01/01/2000 03:45:00 1.3416
24SCS100 01/01/2000 04:00:00 1.7544
24SCS100 01/01/2000 04:15:00 1.7544
24SCS100 01/01/2000 04:30:00 1.7544
24SCS100 01/01/2000 04:45:00 1.7544
24SCS100 01/01/2000 05:00:00 1.548
24SCS100 01/01/2000 05:15:00 1.548
24SCS100 01/01/2000 05:30:00 1.548
24SCS100 01/01/2000 05:45:00 1.548
24SCS100 01/01/2000 06:00:00 2.064
24SCS100 01/01/2000 06:15:00 2.064
24SCS100 01/01/2000 06:30:00 2.064
24SCS100 01/01/2000 06:45:00 2.064
24SCS100 01/01/2000 07:00:00 2.064
24SCS100 01/01/2000 07:15:00 2.064
24SCS100 01/01/2000 07:30:00 2.064
24SCS100 01/01/2000 07:45:00 2.064
24SCS100 01/01/2000 08:00:00 2.7864
24SCS100 01/01/2000 08:15:00 2.7864
24SCS100 01/01/2000 08:30:00 2.7864
24SCS100 01/01/2000 08:45:00 2.7864
24SCS100 01/01/2000 09:00:00 3.3024
24SCS100 01/01/2000 09:15:00 3.3024
24SCS100 01/01/2000 09:30:00 3.7152
24SCS100 01/01/2000 09:45:00 3.7152
24SCS100 01/01/2000 10:00:00 4.1472
24SCS100 01/01/2000 10:15:00 4.1472
24SCS100 01/01/2000 10:30:00 6.3984
24SCS100 01/01/2000 10:45:00 6.3984
24SCS100 01/01/2000 11:00:00 9.9072
24SCS100 01/01/2000 11:15:00 9.9072
24SCS100 01/01/2000 11:30:00 42.9312
24SCS100 01/01/2000 11:45:00 113.9328
24SCS100 01/01/2000 12:00:00 14.8608
24SCS100 01/01/2000 12:15:00 7.6368
24SCS100 01/01/2000 12:30:00 7.6368
24SCS100 01/01/2000 12:45:00 7.6368
24SCS100 01/01/2000 13:00:00 5.5728
24SCS100 01/01/2000 13:15:00 5.5728
24SCS100 01/01/2000 13:30:00 4.3344
24SCS100 01/01/2000 13:45:00 4.3344
24SCS100 01/01/2000 14:00:00 3.3024
24SCS100 01/01/2000 14:15:00 3.3024
24SCS100 01/01/2000 14:30:00 3.3024
24SCS100 01/01/2000 14:45:00 3.3024
24SCS100 01/01/2000 15:00:00 2.8896
24SCS100 01/01/2000 15:15:00 2.8896
24SCS100 01/01/2000 15:30:00 2.8896
24SCS100 01/01/2000 15:45:00 2.8896
24SCS100 01/01/2000 16:00:00 2.2704
24SCS100 01/01/2000 16:15:00 2.2704
24SCS100 01/01/2000 16:30:00 2.2704
24SCS100 01/01/2000 16:45:00 2.2704
24SCS100 01/01/2000 17:00:00 2.3736
24SCS100 01/01/2000 17:15:00 2.3736
24SCS100 01/01/2000 17:30:00 2.3736
24SCS100 01/01/2000 17:45:00 2.3736
24SCS100 01/01/2000 18:00:00 1.548
24SCS100 01/01/2000 18:15:00 1.548
24SCS100 01/01/2000 18:30:00 1.548
24SCS100 01/01/2000 18:45:00 1.548
24SCS100 01/01/2000 19:00:00 1.548
24SCS100 01/01/2000 19:15:00 1.2384
24SCS100 01/01/2000 19:30:00 1.2384
24SCS100 01/01/2000 19:45:00 1.2384
24SCS100 01/01/2000 20:00:00 1.7544
24SCS100 01/01/2000 20:15:00 1.7544
24SCS100 01/01/2000 20:30:00 1.7544
24SCS100 01/01/2000 20:45:00 1.7544
24SCS100 01/01/2000 21:00:00 1.1352
24SCS100 01/01/2000 21:15:00 1.1352
24SCS100 01/01/2000 21:30:00 1.1352
24SCS100 01/01/2000 21:45:00 1.1352
24SCS100 01/01/2000 22:00:00 1.032
24SCS100 01/01/2000 22:15:00 1.032
24SCS100 01/01/2000 22:30:00 1.032
24SCS100 01/01/2000 22:45:00 1.032
24SCS100 01/01/2000 23:00:00 1.032
24SCS100 01/01/2000 23:15:00 1.032
24SCS100 01/01/2000 23:30:00 1.032
24SCS100 01/01/2000 23:45:00 1.032
24SCS100 01/02/2000 00:00:00 0

;Rainfall (mm/hr)

24SCS120	01/01/2000 00:00:00	1.8576
24SCS120	01/01/2000 00:15:00	1.8576
24SCS120	01/01/2000 00:30:00	1.8576
24SCS120	01/01/2000 00:45:00	1.8576
24SCS120	01/01/2000 01:00:00	0.86688
24SCS120	01/01/2000 01:15:00	0.86688
24SCS120	01/01/2000 01:30:00	0.86688
24SCS120	01/01/2000 01:45:00	0.86688
24SCS120	01/01/2000 02:00:00	1.60992
24SCS120	01/01/2000 02:15:00	1.60992
24SCS120	01/01/2000 02:30:00	1.60992
24SCS120	01/01/2000 02:45:00	1.60992
24SCS120	01/01/2000 03:00:00	1.60992
24SCS120	01/01/2000 03:15:00	1.60992
24SCS120	01/01/2000 03:30:00	1.60992
24SCS120	01/01/2000 03:45:00	1.60992
24SCS120	01/01/2000 04:00:00	2.10528
24SCS120	01/01/2000 04:15:00	2.10528
24SCS120	01/01/2000 04:30:00	2.10528
24SCS120	01/01/2000 04:45:00	2.10528
24SCS120	01/01/2000 05:00:00	1.0716
24SCS120	01/01/2000 05:15:00	1.8576
24SCS120	01/01/2000 05:30:00	1.8576
24SCS120	01/01/2000 05:45:00	1.8576
24SCS120	01/01/2000 06:00:00	2.4768
24SCS120	01/01/2000 06:15:00	2.4768
24SCS120	01/01/2000 06:30:00	2.4768
24SCS120	01/01/2000 06:45:00	2.4768
24SCS120	01/01/2000 07:00:00	2.7668
24SCS120	01/01/2000 07:15:00	2.4768
24SCS120	01/01/2000 07:30:00	2.4768
24SCS120	01/01/2000 07:45:00	2.4768
24SCS120	01/01/2000 08:00:00	3.34368
24SCS120	01/01/2000 08:15:00	3.34368
24SCS120	01/01/2000 08:30:00	3.34368
24SCS120	01/01/2000 08:45:00	3.34368
24SCS120	01/01/2000 09:00:00	3.96288
24SCS120	01/01/2000 09:15:00	3.96288
24SCS120	01/01/2000 09:30:00	4.45824
24SCS120	01/01/2000 09:45:00	4.45824
24SCS120	01/01/2000 10:00:00	5.69664
24SCS120	01/01/2000 10:15:00	5.69664
24SCS120	01/01/2000 10:30:00	7.7808
24SCS120	01/01/2000 10:45:00	7.7808
24SCS120	01/01/2000 11:00:00	11.88864
24SCS120	01/01/2000 11:15:00	11.88864
24SCS120	01/01/2000 11:30:00	51.51744
24SCS120	01/01/2000 11:45:00	136.7193
24SCS120	01/01/2000 12:00:00	1.78536
24SCS120	01/01/2000 12:15:00	17.83226
24SCS120	01/01/2000 12:30:00	9.16416
24SCS120	01/01/2000 12:45:00	9.16416
24SCS120	01/01/2000 13:00:00	6.68736
24SCS120	01/01/2000 13:15:00	6.68736
24SCS120	01/01/2000 13:30:00	5.20128
24SCS120	01/01/2000 13:45:00	5.20128
24SCS120	01/01/2000 14:00:00	3.96288
24SCS120	01/01/2000 14:15:00	3.96288
24SCS120	01/01/2000 14:30:00	3.96288
24SCS120	01/01/2000 14:45:00	3.96288
24SCS120	01/01/2000 15:00:00	3.46752
24SCS120	01/01/2000 15:15:00	3.46752
24SCS120	01/01/2000 15:30:00	3.46752
24SCS120	01/01/2000 15:45:00	3.46752
24SCS120	01/01/2000 16:00:00	2.72448
24SCS120	01/01/2000 16:15:00	2.72448
24SCS120	01/01/2000 16:30:00	2.72448
24SCS120	01/01/2000 16:45:00	2.72448
24SCS120	01/01/2000 17:00:00	2.84832
24SCS120	01/01/2000 17:15:00	2.84832
24SCS120	01/01/2000 17:30:00	2.84832
24SCS120	01/01/2000 17:45:00	2.84832
24SCS120	01/01/2000 18:00:00	1.8576
24SCS120	01/01/2000 18:15:00	1.8576
24SCS120	01/01/2000 18:30:00	1.8576
24SCS120	01/01/2000 18:45:00	1.8576
24SCS120	01/01/2000 19:00:00	1.48608
24SCS120	01/01/2000 19:15:00	1.48608
24SCS120	01/01/2000 19:30:00	1.48608
24SCS120	01/01/2000 19:45:00	1.48608
24SCS120	01/01/2000 20:00:00	2.10528
24SCS120	01/01/2000 20:15:00	2.10528
24SCS120	01/01/2000 20:30:00	2.10528
24SCS120	01/01/2000 20:45:00	2.10528
24SCS120	01/01/2000 21:00:00	1.36224
24SCS120	01/01/2000 21:15:00	1.36224
24SCS120	01/01/2000 21:30:00	1.36224
24SCS120	01/01/2000 21:45:00	1.36224
24SCS120	01/01/2000 22:00:00	1.2384
24SCS120	01/01/2000 22:15:00	1.2384
24SCS120	01/01/2000 22:30:00	1.2384
24SCS120	01/01/2000 22:45:00	1.2384
24SCS120	01/01/2000 23:00:00	1.2384
24SCS120	01/01/2000 23:15:00	1.2384
24SCS120	01/01/2000 23:30:00	1.2384
24SCS120	01/01/2000 23:45:00	1.2384
24SCS120	01/02/2000 00:00:00	0
;	;	;
Rainfall (mm/hr)		
24SCS2	01/01/2000 00:00:00	0.72
24SCS2	01/01/2000 00:15:00	0.72
24SCS2	01/01/2000 00:30:00	0.72
24SCS2	01/01/2000 00:45:00	0.72
24SCS2	01/01/2000 01:00:00	0.336
24SCS2	01/01/2000 01:15:00	0.336
24SCS2	01/01/2000 01:30:00	0.336
24SCS2	01/01/2000 01:45:00	0.336
24SCS2	01/01/2000 02:00:00	0.624
24SCS2	01/01/2000 02:15:00	0.624
24SCS2	01/01/2000 02:30:00	0.624
24SCS2	01/01/2000 02:45:00	0.624
24SCS2	01/01/2000 03:00:00	0.624
24SCS2	01/01/2000 03:15:00	0.624
24SCS2	01/01/2000 03:30:00	0.624
24SCS2	01/01/2000 03:45:00	0.624
24SCS2	01/01/2000 04:00:00	0.816
24SCS2	01/01/2000 04:15:00	0.816
24SCS2	01/01/2000 04:30:00	0.816
24SCS2	01/01/2000 04:45:00	0.72
24SCS2	01/01/2000 05:00:00	0.72
24SCS2	01/01/2000 05:15:00	0.72
24SCS2	01/01/2000 05:30:00	0.72
24SCS2	01/01/2000 05:45:00	0.72
24SCS2	01/01/2000 06:00:00	0.96
24SCS2	01/01/2000 06:15:00	0.96
24SCS2	01/01/2000 06:30:00	0.96
24SCS2	01/01/2000 06:45:00	0.96
24SCS2	01/01/2000 07:00:00	0.96
24SCS2	01/01/2000 07:15:00	0.96
24SCS2	01/01/2000 07:30:00	0.96
24SCS2	01/01/2000 07:45:00	0.96
24SCS2	01/01/2000 08:00:00	1.296
24SCS2	01/01/2000 08:15:00	1.296
24SCS2	01/01/2000 08:30:00	1.296
24SCS2	01/01/2000 08:45:00	1.296
24SCS2	01/01/2000 09:00:00	1.536
24SCS2	01/01/2000 09:15:00	1.536
24SCS2	01/01/2000 09:30:00	1.728
24SCS2	01/01/2000 09:45:00	1.728
24SCS2	01/01/2000 10:00:00	2.208
24SCS2	01/01/2000 10:15:00	2.00
24SCS2	01/01/2000 10:30:00	2.976
24SCS2	01/01/2000 10:45:00	2.976
24SCS2	01/01/2000 11:00:00	4.608
24SCS2	01/01/2000 11:15:00	4.608
24SCS2	01/01/2000 11:30:00	19.968
24SCS2	01/01/2000 11:45:00	59.992
24SCS2	01/01/2000 12:00:00	6.912
;	;	;
Rainfall (mm/hr)		
24SCS2	01/01/2000 12:15:00	6.912
24SCS2	01/01/2000 12:30:00	3.552
24SCS2	01/01/2000 12:45:00	3.552
24SCS2	01/01/2000 13:00:00	2.592
24SCS2	01/01/2000 13:15:00	2.592
24SCS2	01/01/2000 13:30:00	2.016
24SCS2	01/01/2000 13:45:00	2.016
24SCS2	01/01/2000 14:00:00	1.956
24SCS2	01/01/2000 14:15:00	1.956
24SCS2	01/01/2000 14:30:00	1.536
24SCS2	01/01/2000 14:45:00	1.536
24SCS2	01/01/2000 15:00:00	1.344
24SCS2	01/01/2000 15:15:00	1.344
24SCS2	01/01/2000 15:30:00	1.344
24SCS2	01/01/2000 15:45:00	1.344
24SCS2	01/01/2000 16:00:00	1.056
24SCS2	01/01/2000 16:15:00	1.056
24SCS2	01/01/2000 16:30:00	1.056
24SCS2	01/01/2000 16:45:00	1.056
24SCS2	01/01/2000 17:00:00	0.72
24SCS2	01/01/2000 17:15:00	0.72
24SCS2	01/01/2000 17:30:00	0.72
24SCS2	01/01/2000 17:45:00	1.536
24SCS2	01/01/2000 18:00:00	1.536
24SCS2	01/01/2000 18:15:00	1.536
24SCS2	01/01/2000 18:30:00	1.536
24SCS2	01/01/2000 18:45:00	1.536
24SCS2	01/01/2000 19:00:00	1.536
24SCS2	01/01/2000 19:15:00	1.536
24SCS2	01/01/2000 19:30:00	1.536
24SCS2	01/01/2000 19:45:00	1.536
24SCS2	01/01/2000 20:00:00	1.536
24SCS2	01/01/2000 22:00:00	0.84
24SCS2	01/01/2000 22:15:00	0.84
24SCS2	01/01/2000 22:30:00	0.84
24SCS2	01/01/2000 22:45:00	0.84
24SCS2	01/01/2000 23:00:00	0.84
24SCS2	01/01/2000 23:15:00	0.84
24SCS2	01/01/2000 23:30:00	0.84
24SCS2	01/01/2000 23:45:00	0.84
24SCS2	01/02/2000 00:00:00	0
;	;	;
Rainfall (mm/hr)		

24SCS5	01/01/2000 00:00:00	0.936	24SCS50	01/01/2000 12:30:00	6.9264
24SCS5	01/01/2000 00:15:00	0.936	24SCS50	01/01/2000 12:45:00	6.9264
24SCS5	01/01/2000 00:30:00	0.936	24SCS50	01/01/2000 13:00:00	5.0544
24SCS5	01/01/2000 00:45:00	0.936	24SCS50	01/01/2000 13:15:00	5.0544
24SCS5	01/01/2000 01:00:00	0.4368	24SCS50	01/01/2000 13:30:00	3.9312
24SCS5	01/01/2000 01:15:00	0.4368	24SCS50	01/01/2000 13:45:00	3.9312
24SCS5	01/01/2000 01:30:00	0.4368	24SCS50	01/01/2000 14:00:00	2.9952
24SCS5	01/01/2000 01:45:00	0.3368	24SCS50	01/01/2000 14:15:00	2.9952
24SCS5	01/01/2000 02:00:00	0.8112	24SCS50	01/01/2000 14:30:00	2.9952
24SCS5	01/01/2000 02:15:00	0.8112	24SCS50	01/01/2000 14:45:00	2.9952
24SCS5	01/01/2000 02:30:00	0.8112	24SCS50	01/01/2000 15:00:00	2.6208
24SCS5	01/01/2000 02:45:00	0.8112	24SCS50	01/01/2000 15:15:00	2.6208
24SCS5	01/01/2000 03:00:00	0.8112	24SCS50	01/01/2000 15:30:00	2.6208
24SCS5	01/01/2000 03:15:00	0.8112	24SCS50	01/01/2000 15:45:00	2.6208
24SCS5	01/01/2000 03:30:00	0.8112	24SCS50	01/01/2000 16:00:00	2.6208
24SCS5	01/01/2000 03:45:00	0.8112	24SCS50	01/01/2000 16:15:00	2.0592
24SCS5	01/01/2000 04:00:00	1.0608	24SCS50	01/01/2000 16:30:00	2.0592
24SCS5	01/01/2000 04:15:00	1.0608	24SCS50	01/01/2000 16:45:00	2.0592
24SCS5	01/01/2000 04:30:00	1.0608	24SCS50	01/01/2000 17:00:00	2.1528
24SCS5	01/01/2000 04:45:00	1.0608	24SCS50	01/01/2000 17:15:00	2.1528
24SCS5	01/01/2000 05:00:00	0.936	24SCS50	01/01/2000 17:30:00	2.1528
24SCS5	01/01/2000 05:15:00	0.936	24SCS50	01/01/2000 17:45:00	2.1528
24SCS5	01/01/2000 05:30:00	0.936	24SCS50	01/01/2000 18:00:00	1.404
24SCS5	01/01/2000 05:45:00	0.936	24SCS50	01/01/2000 18:15:00	1.404
24SCS5	01/01/2000 06:00:00	1.248	24SCS50	01/01/2000 18:30:00	1.404
24SCS5	01/01/2000 06:15:00	1.248	24SCS50	01/01/2000 18:45:00	1.404
24SCS5	01/01/2000 06:30:00	1.248	24SCS50	01/01/2000 19:00:00	1.1232
24SCS5	01/01/2000 06:45:00	1.248	24SCS50	01/01/2000 19:15:00	1.1232
24SCS5	01/01/2000 07:00:00	1.248	24SCS50	01/01/2000 19:30:00	1.1232
24SCS5	01/01/2000 07:15:00	1.248	24SCS50	01/01/2000 19:45:00	1.1232
24SCS5	01/01/2000 07:30:00	1.248	24SCS50	01/01/2000 20:00:00	1.5912
24SCS5	01/01/2000 07:45:00	1.248	24SCS50	01/01/2000 20:15:00	1.5912
24SCS5	01/01/2000 08:00:00	1.6848	24SCS50	01/01/2000 20:30:00	1.5912
24SCS5	01/01/2000 08:15:00	1.6848	24SCS50	01/01/2000 20:45:00	1.5912
24SCS5	01/01/2000 08:30:00	1.6848	24SCS50	01/01/2000 21:00:00	1.0236
24SCS5	01/01/2000 08:45:00	1.6848	24SCS50	01/01/2000 21:15:00	1.0236
24SCS5	01/01/2000 09:00:00	1.9968	24SCS50	01/01/2000 21:30:00	1.0236
24SCS5	01/01/2000 09:15:00	1.9968	24SCS50	01/01/2000 21:45:00	1.0296
24SCS5	01/01/2000 09:30:00	2.2464	24SCS50	01/01/2000 22:00:00	0.936
24SCS5	01/01/2000 09:45:00	2.2464	24SCS50	01/01/2000 22:15:00	0.936
24SCS5	01/01/2000 10:00:00	2.8704	24SCS50	01/01/2000 22:30:00	0.936
24SCS5	01/01/2000 10:15:00	2.8704	24SCS50	01/01/2000 22:45:00	0.936
24SCS5	01/01/2000 10:30:00	3.0668	24SCS50	01/01/2000 23:00:00	0.936
24SCS5	01/01/2000 10:45:00	3.0668	24SCS50	01/01/2000 23:15:00	0.936
24SCS5	01/01/2000 11:00:00	5.9904	24SCS50	01/01/2000 23:30:00	0.936
24SCS5	01/01/2000 11:15:00	5.9904	24SCS50	01/01/2000 23:45:00	0.936
24SCS5	01/01/2000 11:30:00	25.9584	24SCS50	01/02/2000 00:00:00	0
24SCS5	01/01/2000 11:45:00	68.8896			
			;Rainfall (mm/hr)		
3CH110	01/01/2000 00:00:00	3.755	3CH110	01/01/2000 00:10:00	4.478
3CH110	01/01/2000 00:20:00	5.593	3CH110	01/01/2000 00:30:00	7.551
3CH110	01/01/2000 00:40:00	11.936	3CH110	01/01/2000 00:50:00	30.856
3CH110	01/01/2000 01:00:00	122.142	3CH110	01/01/2000 01:10:00	35.537
3CH110	01/01/2000 01:20:00	18.159	3CH110	01/01/2000 01:30:00	12.238
3CH110	01/01/2000 01:40:00	9.269	3CH110	01/01/2000 01:50:00	7.492
3CH110	01/01/2000 02:00:00	6.309	3CH110	01/01/2000 02:10:00	5.465
3CH110	01/01/2000 02:20:00	4.833	3CH110	01/01/2000 02:30:00	4.338
3CH110	01/01/2000 02:40:00	3.942	3CH110	01/01/2000 02:50:00	3.617
3CH110	01/01/2000 03:00:00	0			
			;Rainfall (mm/hr)		
3CH110	01/01/2000 00:00:00	5.339	3CH110	01/01/2000 00:10:00	6.376
3CH110	01/01/2000 00:20:00	7.977	3CH110	01/01/2000 00:30:00	10.797
3CH110	01/01/2000 00:40:00	17.136	3CH110	01/01/2000 00:50:00	45.128
3CH110	01/01/2000 01:00:00	178.107	3CH110	01/01/2000 01:10:00	51.056
3CH110	01/01/2000 01:20:00	20.539	3CH110	01/01/2000 01:30:00	17.571
3CH110	01/01/2000 01:40:00	13.277	3CH110	01/01/2000 01:50:00	10.712
3CH110	01/01/2000 02:00:00	9.008	3CH110	01/01/2000 02:10:00	7.793
3CH110	01/01/2000 02:20:00	6.893	3CH110	01/01/2000 02:30:00	6.174
3CH110	01/01/2000 02:40:00	5.607	3CH110	01/01/2000 02:50:00	5.142
3CH110	01/01/2000 03:00:00	0			
			;Rainfall (mm/hr)		
3CH1120	01/01/2000 00:00:00	6.40801	3CH1120	01/01/2000 00:10:00	7.6512
3CH1120	01/01/2000 00:20:00	9.572401	3CH1120	01/01/2000 00:30:00	12.9564
3CH1120	01/01/2000 00:40:00	20.5632	3CH1120	01/01/2000 00:50:00	54.1536
3CH1120	01/01/2000 01:00:00	213.7284	3CH1120	01/01/2000 01:10:00	61.1772
3CH1120	01/01/2000 01:20:00	31.3956	3CH1120	01/01/2000 01:30:00	21.0852
3CH1120	01/01/2000 01:40:00	15.9324	3CH1120	01/01/2000 01:50:00	12.8544
3CH1120	01/01/2000 02:00:00	10.8096	3CH1120	01/01/2000 02:10:00	9.351601
3CH1120	01/01/2000 02:20:00	8.259601	3CH1120	01/01/2000 02:30:00	7.4958
3CH1120	01/01/2000 02:40:00	6.17284	3CH1120	01/01/2000 02:50:00	6.170401
3CH1120	01/01/2000 03:00:00	0			
			;Rainfall (mm/hr)		
3CH12	01/01/2000 00:00:00	2.491	3CH12	01/01/2000 00:10:00	2.966
3CH12	01/01/2000 00:20:00	3.696	3CH12	01/01/2000 00:30:00	4.976
3CH12	01/01/2000 00:40:00	7.828	3CH12	01/01/2000 00:50:00	19.966
3CH12	01/01/2000 01:00:00	76.805	3CH12	01/01/2000 01:10:00	22.777
3CH12	01/01/2000 01:20:00	11.652	3CH12	01/01/2000 01:30:00	8.025
3CH12	01/01/2000 01:40:00	6.096	3CH12	01/01/2000 01:50:00	4.938
3CH12	01/01/2000 02:00:00	4.165	3CH12	01/01/2000 02:10:00	3.613
3CH12	01/01/2000 02:20:00	3.197	3CH12	01/01/2000 02:30:00	2.873
3CH12	01/01/2000 02:40:00	2.613	3CH12	01/01/2000 02:50:00	2.4
3CH12	01/01/2000 03:00:00	0			
			;Rainfall (mm/hr)		
3CH125	01/01/2000 00:00:00	4.358	3CH125	01/01/2000 00:10:00	5.202
3CH125	01/01/2000 00:20:00	6.506	3CH125	01/01/2000 00:30:00	8.801
3CH125	01/01/2000 00:40:00	13.954	3CH125	01/01/2000 00:50:00	36.302
3CH125	01/01/2000 01:00:00	144.693	3CH125	01/01/2000 01:10:00	41.479
3CH125	01/01/2000 01:20:00	23.66	3CH125	01/01/2000 01:30:00	14.308
3CH125	01/01/2000 01:40:00	10.818	3CH125	01/01/2000 01:50:00	8.732
3CH125	01/01/2000 02:00:00	7.345	3CH125	01/01/2000 02:10:00	6.356
3CH125	01/01/2000 02:20:00	5.615	3CH125	01/01/2000 02:30:00	5.038
3CH125	01/01/2000 02:40:00	0			

Post-Development 24-hour SCS 1:100-year Event

October 2024

```

3CHI25      01/01/2000 02:40:00   4.576
3CHI25      01/01/2000 02:50:00   4.197
3CHI25      01/01/2000 03:00:00     0

;Rainfall (mm/hr)
3CHI5       01/01/2000 00:00:00   3.256
3CHI5       01/01/2000 00:10:00   3.881
3CHI5       01/01/2000 00:20:00   4.444
3CHI5       01/01/2000 00:30:00   6.932
3CHI5       01/01/2000 00:40:00   10.308
3CHI5       01/01/2000 00:50:00   26.792
3CHI5       01/01/2000 01:00:00   103.93
3CHI5       01/01/2000 01:10:00   30.286
3CHI5       01/01/2000 01:20:00   15.655
3CHI5       01/01/2000 01:30:00   10.568
3CHI5       01/01/2000 01:40:00   8.013
3CHI5       01/01/2000 01:50:00   6.482
3CHI5       01/01/2000 02:00:00   5.462
3CHI5       01/01/2000 02:10:00   4.733
3CHI5       01/01/2000 02:20:00   4.186
3CHI5       01/01/2000 02:30:00   3.76
3CHI5       01/01/2000 02:40:00   3.418
3CHI5       01/01/2000 02:50:00   3.137
3CHI5       01/01/2000 03:00:00     0

;Rainfall (mm/hr)
3CHI50      01/01/2000 00:00:00   4.828
3CHI50      01/01/2000 00:10:00   5.166
3CHI50      01/01/2000 00:20:00   7.214
3CHI50      01/01/2000 00:30:00   9.743
3CHI50      01/01/2000 00:40:00   15.496
3CHI50      01/01/2000 00:50:00   40.401
3CHI50      01/01/2000 01:00:00   161.471
3CHI50      01/01/2000 01:10:00   46.17
3CHI50      01/01/2000 01:20:00   23.66
3CHI50      01/01/2000 01:30:00   15.93
3CHI50      01/01/2000 01:40:00   12.006
3CHI50      01/01/2000 01:50:00   9.687
3CHI50      01/01/2000 02:00:00   8.146
3CHI50      01/01/2000 02:10:00   7.047
3CHI50      01/01/2000 02:20:00   6.224
3CHI50      01/01/2000 02:30:00   5.583
3CHI50      01/01/2000 02:40:00   5.07
3CHI50      01/01/2000 02:50:00   4.649
3CHI50      01/01/2000 03:00:00     0

;Head (m)
527_249CS100 01/01/2000 00:01:00   81.228
527_249CS100 01/01/2000 00:02:00   81.228
527_249CS100 01/01/2000 00:03:00   81.228
527_249CS100 01/01/2000 00:04:00   81.228
527_249CS100 01/01/2000 00:05:00   81.228
527_249CS100 01/01/2000 00:06:00   81.228
527_249CS100 01/01/2000 00:07:00   81.228
527_249CS100 01/01/2000 00:08:00   81.228
527_249CS100 01/01/2000 00:09:00   81.228
527_249CS100 01/01/2000 00:10:00   81.228
527_249CS100 01/01/2000 00:11:00   81.228
.....
Too many data points (1440 in total).

;Sum of Infiltrated flow from above the garage slab calculated from Infiltration graphs for S7
multiplied by the total pervious area above the garage.
InfiltratedInflow 01/01/2000 00:01:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:02:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:03:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:04:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:05:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:06:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:07:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:08:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:10:00   5.983073E-06
InfiltratedInflow 01/01/2000 00:11:00   5.983073E-06
.....
Too many data points (1440 in total).

[REPORT]
;Reporting Options
INPUT YES
CONTROLS NO
SUBCATCHMENTS ALL
NODES ALL
LINKS ALL

[TAGS]
Subcatch L1_1 Landscape
Subcatch L1_2 Landscape
Subcatch L1_3 Landscape
Subcatch S2 Parking_Lot
Subcatch S3_1 Parking_Lot
Subcatch S3_2 Parking_Lot
Subcatch S5 Building
Subcatch S6 Building
Subcatch S7 Ramp
Node St_L1 RYCB
Node St_L2 RYCB
Node St_L3 RYCB
Node St_UnGrd Underground_Storage
Link C1 RY_Storm

[MAP]
DIMENSIONS 381360.7266 5033019.65495 381502.5034 5033143.67005
UNITS Meters

[COORDINATES]
;Node X-Coord Y-Coord
;-----
527_(P-Stm) 381424.754 5033138.033
OP1 381401.916 5033025.292
OP2 381462.548 5033049.302
OP3 381403.805 5033026.688
OP7 381448.444 5033041.047
Roof1 381428.998 5033034.455
Roof2 381428.95 5033077.584
St_L1 381395.548 5033108.811
St_L2 381417.381 5033128.938
St_L3 381450.027 5033054.56
St_P1 381406.853 5033073.521
St_P2 381416.312 5033051.852
St_UnGrd 381396.599 5033036.713
SUL 381400.429 5033088.237

[VERTICES]
;Link X-Coord Y-Coord
;-----
W_L1 381414.65 5033129.488
W_L1 381395.979 5033112.147

[POLYGONS]
;Subcatchment X-Coord Y-Coord
;-----
L1_1 381426.561 5033106.239
381433.311 5033099.112
L1_1 381426.156 5033091.96
L1_1 381458.719 5033051.155
L1_1 381435.928 5033041.204
L1_1 381430.376 5033033.492
L1_1 381429.744 5033033.928
L1_1 381429.096 5033034.342
L1_1 381428.435 5033034.734
L1_1 381427.76 5033035.02
L1_1 381427.074 5033035.446
L1_1 381426.375 5033035.767
L1_1 381425.758 5033036.025
L1_1 381425.134 5033036.264
L1_1 381424.503 5033036.484
L1_1 381423.865 5033036.685
L1_1 381423.221 5033036.865
L1_1 381423.215 5033037.128
381423.218 5033037.391
381423.223 5033037.654
381423.251 5033037.916
381423.281 5033038.178
381423.32 5033038.438
381423.368 5033038.696
381423.425 5033038.953
381423.459 5033039.208
381423.564 5033039.46
381423.647 5033039.71
381423.738 5033039.957
381423.838 5033040.2
381423.946 5033040.44
381424.02 5033040.76
381424.186 5033040.908
381424.318 5033041.136
381424.458 5033041.359
381424.605 5033041.577
381424.76 5033041.79
381424.921 5033041.997
381425.09 5033042.239
381425.266 5033042.395
381425.448 5033042.584
381425.637 5033042.768
381425.831 5033042.945
381426.032 5033043.115
381426.239 5033043.278
381426.435 5033043.44
381426.638 5033043.582
381426.839 5033043.723
381427.116 5033043.857
381427.348 5033043.982
381427.583 5033044.1
381427.822 5033044.209
381428.064 5033044.34
381441.412 5033050.021
381441.401 5033050.162
381441.677 5033050.313
381441.947 5033050.472
381442.212 5033050.642
381442.471 5033050.82
381442.733 5033051.008
381442.969 5033051.204
381443.207 5033051.408
381443.438 5033051.621
381443.662 5033051.841
381443.878 5033052.07
381444.086 5033052.305
381444.285 5033052.538
381444.486 5033052.798
381444.686 5033053.054
381444.881 5033053.316
381444.995 5033053.585
381445.149 5033053.858
381445.294 5033054.137
381445.448 5033054.421
381445.553 5033055.17
381445.668 5033055.002
381445.772 5033055.299
381445.866 5033055.598
381445.95 5033055.901
381446.022 5033056.207
381446.085 5033056.425
381446.156 5033056.825
381446.176 5033057.137
381446.206 5033057.449
381446.224 5033057.763
381446.232 5033058.077
381446.229 5033058.392
381446.235 5033058.605
381446.239 5033058.819
381446.153 5033059.331
381446.106 5033059.641
381446.048 5033059.95
381445.98 5033060.257
381445.901 5033060.561
381445.811 5033060.862
381445.711 5033061.16
381445.6 5033061.454
381445.479 5033061.744
381442.344 5033068.909
381442.775 5033069.097
381442.561 5033106.239
381442.65 5033114.44
381415.643 5033115.347
381404.547 5033110.503
381408.488 5033101.475
381404.701 5033099.821
381405.665 5033097.614
381401.22 5033095.674
381404.59 5033097.094
381405.318 5033097.454
381394.298 5033093.034
381389.532 5033090.954
381389.672 5033090.633
381386.265 5033089.146
381386.988 5033087.5
381387.061 5033080.111
381387.11 5033080.731
381373.676 5033092.727
381375.266 5033094.193
381382.117 5033100.508
381407.635 5033124.034
381425.929 5033107.688
381445.474 5033117.892
381445.153 5033118.177
381421.373 5033124.034
381433.371 5033109.212
381426.561 5033106.239
381425.929 5033107.688
381445.474 5033117.892
381458.159 5033051.155
381439.156 5033095.96
381483.973 5033094.136
381494.933 5033069
381496.059 5033067.453
381422.855 5033068.564
381425.847 5033069.708
381426.15 5033071.15
381425.421 5033049.708
381427.822 5033044.209
381427.583 5033044.099
381427.347 5033043.982
381427.116 5033043.856
381426.889 5033043.723
381426.607 5033043.592
381426.45 5033043.433
381426.238 5033043.278
381426.032 5033043.114
381425.831 5033042.944
381425.636 5033042.768
381424.448 5033042.584
381425.466 5033042.455
381425.09 5033042.199
381424.921 5033041.997
381424.759 5033041.789
381424.605 5033041.577
381424.458 5033041.359
381424.338 5033041.136
381424.106 5033040.908
381424.062 5033040.676
381423.946 5033040.44
381423.838 5033040.2
381423.738 5033039.957
381423.647 5033039.71
381423.564 5033039.46
381423.49 5033039.208

```

S2 381423.425 5033038.953
S2 381423.368 5033038.696
S2 381423.32 5033038.438
S2 381423.281 5033038.177
S2 381423.251 5033037.916
S2 381423.23 5033037.654
S2 381423.218 5033037.391
S2 381423.215 5033037.228
S2 381423.21 5033036.865
S2 381422.554 5033037.03
S2 381421.883 5033037.174
S2 381421.207 5033037.296
S2 381420.528 5033037.397
S2 381419.846 5033037.477
S2 381419.162 5033037.545
S2 381418.476 5033037.571
S2 381417.789 5033037.586
S2 381417.102 5033037.579
S2 381408.289 5033038.705
S2 381399.672 5033058.444
S2 381422.855 5033068.564
S3_1 381398.388 5033090.5
S3_1 381398.255 5033089.146
S3_1 381389.672 5033090.633
S3_1 381389.532 5033090.954
S3_1 381394.298 5033093.034
S3_1 381393.818 5033094.134
S3_1 381400.599 5033097.094
S3_1 381400.22 5033097.474
S3_1 381405.665 5033097.614
S3_1 381404.701 5033099.821
S3_1 381408.488 5033101.475
S3_1 381415.264 5033085.953
S3_1 381392.081 5033075.833
S3_1 381386.988 5033087.111
S3_2 381415.01 5033087.833
S3_2 381415.864 5033088.953
S3_2 381422.855 5033068.564
S3_2 381399.672 5033058.444
S3_2 381392.081 5033075.833
S5 381421.474 5033117.892
S5 381432.346 5033092.987
S5 381421.775 5033069.977
S5 381421.847 5033070.708
S5 381404.547 5033110.503
S5 381421.474 5033117.892
S6 381386.988 5033087.5
S6 381408.289 5033038.705
S6 381391.361 5033031.316
S6 381406.111 5033051.111
S6 381386.988 5033087.5
S7 381425.847 5033061.708
S7 381436.845 5033066.509
S7 381442.344 5033068.909
S7 381445.479 5033061.744
S7 381445.6 5033061.454
S7 381445.711 5033061.5
S7 381445.811 5033060.862
S7 381445.901 5033060.561
S7 381445.98 5033060.257
S7 381446.048 5033059.95
S7 381446.106 5033059.641
S7 381446.153 5033059.333
S7 381446.19 5033059.19
S7 381446.215 5033058.705
S7 381446.229 5033058.392
S7 381446.232 5033058.077
S7 381446.224 5033057.763
S7 381446.206 5033057.449
S7 381446.176 5033057.137
S7 381446.136 5033056.825
S7 381446.15 5033056.515
S7 381446.022 5033056.207
S7 381445.95 5033055.901
S7 381445.866 5033055.598
S7 381445.772 5033055.299
S7 381445.668 5033055.002
S7 381445.553 5033054.71
S7 381445.458 5033054.21
S7 381445.294 5033054.137
S7 381445.149 5033053.858
S7 381444.995 5033053.585
S7 381444.831 5033053.316
S7 381444.658 5033053.054
S7 381444.476 5033052.98
S7 381444.285 5033052.548
S7 381444.086 5033052.305
S7 381443.878 5033052.07
S7 381443.662 5033051.841
S7 381443.438 5033051.621
S7 381443.207 5033051.408
S7 381442.969 5033051.204
S7 381442.723 5033051.008
S7 381442.471 5033050.82
S7 381442.212 5033050.642
S7 381441.947 5033050.472
S7 381441.677 5033050.313
S7 381441.401 5033050.162
S7 381441.2 5033050.021
S7 381440.924 5033049.911
S7 381427.822 5033044.209
S7 381425.421 5033049.708
S7 381430.18 5033051.785
S7 381425.847 5033061.708

;;Storage Node X-Coord Y-Coord

;;Gage X-Coord Y-Coord

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.3)

Element Count

Number of rain gages 1
Number of subcatchments 10
Number of nodes 14
Number of links 12
Number of pollutants 0
Number of land uses 0

Raingage Summary

Name	Data Source	Data Type	Recording Interval
Rainfall	24SCS100	INTENSITY	15 min.

Subcatchment Summary

Name	Area	Width	%Imperv	%Slope	Rain Gage	Outlet
L1_1	0.07	134.06	10.01	2.0000	Rainfall	St_L3
L1_2	0.07	15.82	8.45	2.0000	Rainfall	St_L1
L1_3	0.03	77.61	3.89	2.0000	Rainfall	St_L2
S1	0.16	38.49	14.29	2.0000	Rainfall	St_L3
S2	0.06	16.77	99.44	2.0000	Rainfall	St_P2
S3_1	0.04	1.81	99.29	2.0000	Rainfall	SU1
S3_2	0.05	13.27	98.96	2.0000	Rainfall	St_P1
S5	0.10	22.12	100.00	1.0000	Rainfall	Roof2
S6	0.10	22.12	100.00	1.0000	Rainfall	Roof1
S7	0.03	28.53	72.19	15.0000	Rainfall	St_UnGrd

Node Summary

Name	Type	Invert Elev.	Max. Depth	Ponded Area	External Inflow
527_(P-Stm)	OUTFALL	81.23	0.00	0.0	
OF1	OUTFALL	80.67	0.00	0.0	
OF2	OUTFALL	80.91	0.00	0.0	
OF3	OUTFALL	80.67	0.00	0.0	
OF7	OUTFALL	80.67	0.00	0.0	
Roof1	STORAGE	96.85	0.15	0.0	
Roof2	STORAGE	96.85	0.15	0.0	
St_L1	STORAGE	84.20	1.70	0.0	
St_L2	STORAGE	83.90	2.10	0.0	
St_L3	STORAGE	83.09	2.21	0.0	
St_P1	STORAGE	85.70	0.31	0.0	
St_P2	STORAGE	85.50	0.15	0.0	
St_UnGrd	STORAGE	81.97	1.00	0.0	Yes
SU1	STORAGE	85.70	0.25	0.0	

Link Summary

Name	From Node	To Node	Type	Length	%Slope
C1	St_L1	St_L2	CONDUIT	33.1	0.9050
0.0130	W_L1	St_L2	WEIR		
	W1	St_P1	WEIR		
	W2	St_P1	WEIR		
	O_St_L3	St_L3	OF2		
	O1L	SU1	OUTLET		
	OL2	St_P1	OUTLET		
	OL3	St_P2	OUTLET		
	OL4	St_L2	527_(P-Stm)		
	OR1	St_UnGrd	OF1		
	ROOF1	Roof1	OF3		
	ROOF2	Roof2	OF7		

Cross Section Summary

Conduit	Shape	Full Depth	Full Area	Hyd. Rad.	Max. Width	No. of Barrels	Full Flow
C1	CIRCULAR	0.25	0.05	0.06	0.25	1	0.06

Analysis Options

Flow Units CMS

Process Models:

- Rainfall/Runoff YES
- RDI NO
- Snowmelt NO
- Groundwater NO
- Flow Routing YES
- Ponding Allowed NO
- Water Quality NO

Infiltration Method HORTON

Flow Routing Method DYNWAVE

Surcharge Method EXTRAN

Starting Date 01/01/2000 00:00:00

Ending Date 01/02/2000 00:00:00

Antecedent Dry Days 0.0

Report Time Step 00:01:00

Wet Time Step 00:01:00

Dry Time Step 00:01:00

Routing Time Step 1.00 sec

Variable Time Step YES

Maximum Trials 8

Number of Threads 1

Head Tolerance 0.001500 m

Runoff Quantity Continuity hectare-m

Total Precipitation 0.073

Evaporation Loss 0.000

Infiltration Loss 0.025

Surface Runoff 0.047

Final Storage 0.001

Continuity Error (%) -0.036

Flow Routing Continuity hectare-m

Volume 10^6 ltr

Dry Weather Inflow 0.000

Wet Weather Inflow 0.047

Groundwater Inflow 0.000

RDI Inflow 0.000

External Inflow 0.000

External Outflow 0.047

Flooding Loss 0.000

Evaporation Loss 0.000

Exfiltration Loss 0.000

Initial Stored Volume 0.000

Final Stored Volume 0.000

Post-Development 24-hour SCS 1:100-year Event

October 2024

Continuity Error (%) 0.000

No nodes were surcharged.

Time-Step Critical Elements

None

Node Flooding Summary

No nodes were flooded.

Highest Flow Instability Indexes

All links are stable.

Storage Volume Summary

Most Frequent Nonconverging Nodes

Convergence obtained at all time steps.

Routing Time Step Summary

Minimum Time Step : 0.50 sec
Average Time Step : 1.00 sec
Maximum Time Step : 1.00 sec
% of Time in Steady State : 0.00
Average Iterations per Step : 2.00
% of Steps Not Converging : 0.00
Time Step Frequencies :
1.000 : 0.871 sec 100.00 %
0.871 - 0.756 sec : 0.00 %
0.756 - 0.660 sec : 0.00 %
0.660 - 0.574 sec : 0.00 %
0.574 - 0.500 sec : 0.00 %

Subcatchment Runoff Summary

Total	Total	Peak	Total	Total	Total	Imperv	Perv		
Runoff	Runoff	Runoff	Precip	Runon	Evap	Infil	Runoff		
mm	mm	mm	mm	mm	mm	mm	mm		
mm	10^6 ltr	CMS							
29.88	0.02	0.02	0.289	103.20	0.00	0.00	73.20	10.18	29.88
26.55	0.02	0.01	0.257	103.20	0.00	0.00	76.53	8.59	26.55
28.13	0.01	0.01	0.279	103.20	0.00	0.00	74.35	3.95	28.83
29.73	0.05	0.03	0.288	103.20	0.00	0.00	73.26	14.52	26.83
94.66	0.06	0.02	0.917	103.20	0.00	0.00	6.95	92.05	2.61
S3_1	0.04	0.01	0.978	103.20	0.00	0.00	0.53	100.71	0.20
100.82	0.04	0.01	0.978	103.20	0.00	0.00	0.78	100.38	0.30
100.68	0.05	0.02	0.976	103.20	0.00	0.00	0.00	101.33	0.00
101.33	0.10	0.03	0.982	103.20	0.00	0.00	0.00	101.33	0.00
101.33	0.10	0.03	0.982	103.20	0.00	0.00	20.80	73.39	7.91
81.30	0.03	0.01	0.788						

Node Depth Summary

Node	Type	Average Depth Meters	Maximum Depth Meters	Maximum HGL Meters	Time of Max Occurrence days hr:min	Reported Max Depth Meters
527_(P-Stm)	OUTFALL	0.59	3.67	84.90	0 12:28	3.67
OF1	OUTFALL	0.50	0.50	81.17	0 00:00	0.50
OF2	OUTFALL	0.55	0.55	81.46	0 00:00	0.55
OF3	OUTFALL	0.50	0.50	81.17	0 00:00	0.50
OF7	OUTFALL	0.50	0.50	81.17	0 00:00	0.50
Roof1	STORAGE	0.02	0.07	96.92	0 13:00	0.07
Roof2	STORAGE	0.02	0.07	96.92	0 13:00	0.07
St_L1	STORAGE	0.08	1.53	85.73	0 12:13	1.53
St_L2	STORAGE	0.11	1.83	85.73	0 12:15	1.83
St_P1	STORAGE	0.03	2.00	85.26	0 12:01	2.07
St_P2	STORAGE	0.00	0.03	85.73	0 12:00	0.03
St_UnGrd	STORAGE	0.00	0.03	85.53	0 12:00	0.03
SU1	STORAGE	0.05	0.77	82.75	0 12:05	0.77
		0.00	0.02	85.72	0 12:00	0.02

Node Inflow Summary

Flow	Maximum Lateral	Maximum Total	Lateral	Total
Balance	Inflow	Inflow	Time of Max Occurrence	Inflow
Error Node Percent	Type	CMS	CMS days hr:min	10^6 ltr
				10^6 ltr
0.000	OUTFALL	0.000	0 12:08	0
OF1	OUTFALL	0.000	0 11:32	0
OF2	OUTFALL	0.000	0 12:01	0
OF3	OUTFALL	0.000	0 11:05	0
OF7	OUTFALL	0.000	0 11:05	0
Roof1	STORAGE	0.031	0 12:00	0.0996
Roof2	STORAGE	0.031	0 12:00	0.0996
St_L1	STORAGE	0.014	0 11:56	0.0181
St_P1	STORAGE	0.009	0 11:55	0.00934
St_P2	STORAGE	0.019	0 12:00	0.0575
St_UnGrd	STORAGE	0.010	0 12:00	0.0268
SU1	STORAGE	0.012	0 12:00	0.0395
				0.0395

Node Surcharge Summary

Maximum Outflow Storage Unit CMS	Average Volume 1000 m³	Avg Pcnt Full	Evap Pcnt Loss	Exfil Pcnt Loss	Maximum Volume 1000 m³	Max Pcnt Full	Time of Max Occurrence days hr:min
Roof1	0.010	12.1	0.0	0.0	0.041	48.3	0 13:00
Roof2	0.010	12.1	0.0	0.0	0.041	48.3	0 13:00
St_L1	0.002	0.6	0.0	0.0	0.006	18.8	0 12:13
St_L2	0.006	0.3	0.0	0.0	0.002	7.3	0 12:15
St_L3	0.038	0.5	0.0	0.0	0.006	73.6	0 12:01
St_P1	0.015	0.0	0.0	0.0	0.000	1.2	0 12:00
St_P2	0.019	0.1	0.0	0.0	0.000	4.9	0 12:00
St_UnGrd	0.010	4.8	0.0	0.0	0.050	77.5	0 12:05
SU1	0.012	0.0	0.0	0.0	0.000	1.2	0 12:00

Outfall Loading Summary

Outfall Node	Flow Freq Pcnt	Avg Flow CMS	Max Flow CMS	Total Volume 10^6 ltr
527_(P-Stm)	9.11	0.003	0.006	0.027
OF1	95.58	0.002	0.010	0.172
OF2	41.64	0.002	0.038	0.068
OF3	94.85	0.001	0.002	0.100
OF7	94.85	0.001	0.002	0.100
System	67.21	0.010	0.058	0.466

Link Flow Summary

Link	Type	Maximum Flow CMS	Time of Max Occurrence days hr:min	Maximum Veloc m/sec	Max/Full Flow	Max/Full Depth
C1	CONDUIT	0.006	0 11:56	0.13	0.11	1.00
W_L1	WEIR	0.000	0 00:00	0	0.00	0.00
W1	WEIR	0.000	0 00:00	0	0.00	0.00
W2	WEIR	0.000	0 00:00	0	0.00	0.00
O_St_L3	DUMMY	0.038	0 12:01	0	0.00	0.00
OL1	DUMMY	0.012	0 12:00	0	0.00	0.00
OL2	DUMMY	0.015	0 12:00	0	0.00	0.00
OL3	DUMMY	0.019	0 12:00	0	0.00	0.00
OL4	DUMMY	0.006	0 12:08	0	0.00	0.00
OR1	DUMMY	0.010	0 11:32	0	0.00	0.00
ROOF1	DUMMY	0.002	0 11:05	0	0.00	0.00
ROOF2	DUMMY	0.002	0 11:05	0	0.00	0.00

Flow Classification Summary

Conduit	Adjusted Length	Actual Length	Fraction Up Dry	Fraction Down Dry	Fraction Sub Crit	Fraction Sup Crit	Fraction Up Crit	Fraction Down Crit	Fraction Dnstream Ltd	Time in Flow Class Ctrl
---------	-----------------	---------------	-----------------	-------------------	-------------------	-------------------	------------------	--------------------	-----------------------	-------------------------

C1	1.00	0.48	0.00	0.00	0.52	0.00	0.00	0.00	0.02	0.00
----	------	------	------	------	------	------	------	------	------	------

Conduit Surcharge Summary

Conduit	Both Ends	Hours Upstream	Hours Dnstream	Hours Above Normal Flow	Hours Capacity Limited
---------	-----------	----------------	----------------	-------------------------	------------------------

C1	1.53	1.53	1.76	0.01	0.01
----	------	------	------	------	------

Analysis begun on: Mon Oct 7 14:30:08 2024
Analysis ended on: Mon Oct 7 14:30:08 2024
Total elapsed time: < 1 sec

Engineering Specification

Job Name _____

Contractor _____

Job Location _____

Approval _____

Engineer _____

Contractor's P.O. No. _____

Approval _____

Representative _____

Tag _____

RD-200

Small Area Roof Drain

Specification

Watts RD-200 epoxy coated cast iron roof drain with flashing clamp with integral gravel stop, self-locking polyethylene dome (standard), and no hub (standard) outlet.

Pipe Sizing	
Suffix	Description
2	2"(51) Pipe Size
3	3"(76) Pipe Size
4	4"(102) Pipe Size (NH Only)




Outlet Type	
Suffix	Description
NH	No Hub (MJ)
P	Push On
T	Threaded
X	Inside Caulk

Options	
Suffix	Description
-13	Galvanized Body & Flashing Clamp
-B	Sump Receiver
-D	Underdeck Clamp
-F	Deck Flange/Adj. Extension
-GSS	Stainless Steel Ballast Guard
-K	Ductile Iron Dome
-K13	Galvanized Dome
-K80	Aluminum Dome
-K81	Rough Bronze Dome
-K83	SS Mesh Covered Dome
-L	Vandal Proof Dome
-R	2" External Water Dam
-SO	Side Outlet
-W	Adjustable Internal Water Dam

**Deck Opening 6 1/2"(165)
with Sump Receiver 8"(203)**

Optional Body Material	
Suffix	Description
-60	PVC Body w/Socket Outlet
-61	ABS Body w/Socket Outlet

Free Area	
Sq. In.	
35	



Pipe Size	Std. No Hub	P Push On	T Female Thread	X Inside Caulk	Chart B	
					60/61 PVC/ ABS	
2"(51)	3 5/8"(92)	4 1/4"(108)	4 1/4"(108)	4 1/2"(108)	4"(102)	
3"(76)	3 5/8"(92)	4 1/4"(108)	4 1/4"(108)	4 1/2"(108)	4"(102)	
4"(102)	3 5/8"(92)	4 1/4"(108)	4 1/4"(108)	4 1/2"(108)	4"(102)	

NOTICE

The information contained herein is not intended to replace the full product installation and safety information available or the experience of a trained product installer. You are required to thoroughly read all installation instructions and product safety information before beginning the installation of this product.

Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.

USA: T: (800) 338-2581 • F: (828) 248-3929 • Watts.com
Canada: T: (888) 208-8927 • F: (905) 481-2316 • Watts.ca
Latin America: T: (52) 55-4122-0138 • Watts.com



Adjustable Accutrol Weir
Tag: _____

**Adjustable Flow Control
for Roof Drains**



ADJUSTABLE ACCUTROL (for Large Sump Roof Drains only)

For more flexibility in controlling flow with heads deeper than 2", Watts Drainage offers the Adjustable Accutrol. The Adjustable Accutrol Weir is designed with a single parabolic opening that can be covered to restrict flow above 2" of head to less than 5 gpm per inch, up to 6" of head. To adjust the flow rate for depths over 2" of head, set the slot in the adjustable upper cone according to the flow rate required. Refer to Table 1 below.
Note: Flow rates are directly proportional to the amount of weir opening that is exposed.

EXAMPLE:

For example, if the adjustable upper cone is set to cover 1/2 of the weir opening, flow rates above 2" of head will be restricted to 2-1/2 gpm per inch of head.

Therefore, at 3" of head, the flow rate through the Accutrol Weir that has 1/2 the slot exposed will be:
[5 gpm (per inch of head) x 2 inches of head] + 2-1/2 gpm (for the third inch of head) = 12-1/2 gpm.



1/2 Weir Opening Exposed Shown Above

TABLE 1. Adjustable Accutrol Flow Rate Settings

Weir Opening Exposed	1"	2"	3"	4"	5"	6"
	Flow Rate (gallons per minute)					
Fully Exposed	5	10	15	20	25	30
3/4	5	10	13.75	17.5	21.25	25
1/2	5	10	12.5	15	17.5	20
1/4	5	10	11.25	12.5	13.75	15
Closed	5	5	5	5	5	5

Job Name _____

Contractor _____

Job Location _____

Contractor's P.O. No. _____

Engineer _____

Representative _____

Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.



USA: Tel: (800) 338-2581 • Fax: (828) 248-3929 • Watts.com

A Watts Water Technologies Company

Canada: Tel: (905) 332-4090 • Fax: (905) 332-7068 • Watts.ca

Latin America: Tel: (52) 81-1001-8600 • Fax: (52) 81-8000-7091 • Watts.com



Z150F


FLOFORCE™ HIGH PERFORMANCE PROMENADE DECK

DRAIN WITH ROTATABLE FRAME AND HEEL-PROOF GRATE

SPECIFICATION SHEET

TAG

Design and Dimensional Data (inches and [mm]) are Subject to Manufacturing Tolerances and Change Without Notice



4 [102] No-Hub Illustrated

A Outlet Size In. [mm]	B Body Diameter In [mm]	C Frame Size In [mm]	D Grate Size In [mm]	Weight lbs [kg]	Grate Open Area Sq. In. [cm ²]
2,3,4 [51,76,102]	16-9/16 [421]	14 [356]	12-13/16 [325]	66 [30]	44 [284]
6,8 [152, 203]	20-3/32 [510]	18 [457]	16-13/16 [427]	94 [43]	70 [452]

ENGINEERING SPECIFICATION: ZURN Z150F

FLOFORCE™ High efficient flow performing roof drain for promenade deck roof drain applications. Drain incorporates a smooth funnel-shaped interior surface, providing a seamless transition to outlet connection and eliminating internal obstructions within the body. Complete with Dura-Coated cast iron body with membrane flashing clamp, rotatable square promenade frame, seepage openings, securing clamps, and heavy-duty ductile iron heel-proof grate.

OPTIONS (Check/specify appropriate options)**PIPE SIZE**

2, 3, 4 [51, 76, 102]

6, 8 [152, 203]

2, 3, 4 [51, 76, 102]

6 [152]

2, 3, 4 [51, 76, 102]

6, 8 [152, 203]

3, 4 [76, 102]

6 [152]

(Specify size/type) OUTLET

NH No-Hub

6-15/16 [176]

NH No-Hub

7-7/16 [189]

NL Neo-Loc

7-3/8 [187]

NL Neo-Loc

8-1/32 [204]

IP Threaded

5-15/16, 6-3/16, 6-5/16 [151, 157, 160]

IP Threaded

6-11/16, 6-3/4 [170, 171]

IC Inside Caulk

5-13/16 [148]

IC Inside Caulk

6-1/16 [154]

PREFIXES Z D.C.C.I. Body and Frame with Ductile Iron Grate* ZN D.C.C.I. Body and Frame with Ductile Iron Grate and Polished Nickel Bronze Veneer Finish**SUFFIXES** -AR Acid Resistant Epoxy Coated -R Roof Sump Receiver -C Underdeck Clamp -SC Secondary Clamp Collar -DP Top-Set® Deck Plate (Replaces both the -C and -R) -TC Neo-Loc Test Cap Gasket -DR Top-Set® Drain Riser (2, 3, 4 [51, 76, 102] NL Bottom Outlet Only) -E Static Extension 1 [25] thru 4 [102] (Specify Ht.) -VP Vandal-Proof Secured Top -EA Adjustable Extension Assembly -Y Type 304 [CF8] SS Sediment Bucket 2-1/8 [54] thru 3-1/2 [89] -85 Type 304 [CF8] Stainless Steel Perforated Extension -G Galvanized Cast Iron -89 2 [51] High Overflow Dam and Low-Profile Pedestal -PD Low-Profile Pedestal Paver Dome Paver Dome

* Regularly furnished unless otherwise specified

⚠ WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov**⚠ ADVERTENCIA:** Cáncer y daño reproductivo - www.P65Warnings.ca.gov**⚠ AVERTISSEMENT:** Cancer et effets néfastes sur la reproduction - www.P65Warnings.ca.gov

Site Servicing Report
2983, 3053 and 3079 Navan Road & 2690 Pagé Road, Ottawa, Ontario

Appendix E

Sanitary Servicing

JLR NO. 2889-002 (NAVAN BLOCK 14)

Street Name	Pipe Reach								Commercial/Institutional				Infiltration				Peak Design Flow L/s	Pipe Data								Upstream Geometry				Downstream Geometry				Self Cleansing Velocities			
	From	To	Apartments	Pop.	Cum. Pop.	Peaking Factor	Residential Flow (L/s)	Area (ha)	Cum. Area (ha)	Peaking Factor	Inst. Flow (L/s)	Area (ha)	Cum. Area (ha)	Peak Extr. Flow L/s	Dia	Type	Actual Diameter	Slope	Q Full (L/s)	V Full	Length	Residual Capacity	% Full	TG From	Obvert	Invert	Cover	TG To	Drop	Obvert	Invert	Cover	Q/Q Ratio	Flow Depth (mm)	Actual Velocity (m/s)	Flow Depth to Dia. (d/D)	
	BLOCK 14	BLOCK 14	18	84	151	151	3.55	1.74	0.09	0.09	1.50	0.05	0.57	0.57	0.19	1.97	200	Circular	203.20	1.50%	41.91	1.29	4.50	39.93	5%	85.850	82.815	82.412	3.235	85.840	0.060	82.547	82.344	3.293	0.05	29.87	0.68
EAST ORLEAN RIDGE SUBDIVISION		18	17		151	3.55	1.74	0.09	0.09	1.50	0.05	0.57	0.57	0.19	1.97	200	Circular	203.20	1.50%	41.91	1.29	11.60	39.93	5%	85.840	82.497	82.284	3.353	84.840	0.050	82.313	82.110	2.827	0.05	29.87	0.68	0.15

Design Parameters	
Apartment Population	1.8
Cap/Unit	
Residential Flows	280
L/Cap/Day	
Impervious Area	0.3
Unitless	
Harmon's Correction Factor	0.8
unitless	
Commercial Peak Factor	1.5
unitless	
Institutional/Commercial Average Flow	28000
L/gross hard	
Manning Coefficient	0.013
unitless	

William Rugamba

From: William Rugamba
Sent: July 22, 2024 8:18 AM
To: William Rugamba
Subject: FW: Re-confirmation of Mechanical Items for Servicing Report

William Rugamba, M.Eng., B.A.Sc., EIT
Civil Engineering Graduate
Ottawa, ON
Work: [343-804-4374](tel:343-804-4374)

From: Sarith Lopez <slopez@qmeengineering.com>
Sent: Wednesday, July 17, 2024 8:07 PM
To: Mahad Musse <mmusse@jlrichards.ca>; Chuck Clark <CWC@qmeengineering.com>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>
Subject: RE: Re-confirmation of Mechanical Items for Servicing Report

[CAUTION] This email originated from outside JLR. Do not click links or open attachments unless you recognize the sender and know the content is safe. Do not forward suspicious emails, if you are unsure, please send a separate message to Helpdesk.

Hi Mahad,

All items below confirmed

Regards

Sarith López
Project Manager

9 Gurdwara Road, Unit 200
Ottawa, ON K2E 7X6
T: 613-366-4763 ext. 129
slopez@qmeengineering.com



From: Mahad Musse <mmusse@jlrichards.ca>
Sent: Tuesday, July 16, 2024 3:08 PM
To: Sarith Lopez <slopez@qmeengineering.com>; Chuck Clark <CWC@qmeengineering.com>
Cc: Karla Ferrey <kferrey@jlrichards.ca>; Raad Akrawi <rakrawi@groupeheafey.com>; Carmine Zayoun <carmine@zayoungroup.com>
Subject: Re-confirmation of Mechanical Items for Servicing Report

Hi Sarith/Chuck,

Thank you for the information below and in our meetings. I understand all these items have been discussed before but we need to submit something as part of our report. Can you just re-confirm the following questions below and then we will attach your confirmation to the Report.

1. Please confirm that the sanitary service size of 200mm diameter for the Site Plan Blocks (Block 14, 15 and 17) is preferred by the mechanical engineer on file;
2. Please confirm that a sprinkler flow of 25 L/s can be assumed for the Site Plan Blocks (Block 14, 15 and 17) at this stage.

Thanks
Mahad



Mahad Musse, B.Eng., EIT
Civil Engineering Graduate

1000-343 Preston Street
Ottawa, ON, K1S 1N4

Work: [343-633-1501](tel:343-633-1501)
mmusse@jlrichards.ca



Platinum
member

www.jlrichards.ca

Ottawa

343 Preston Street
Tower II, Suite 1000
Ottawa ON Canada
K1S 1N4
Tel: 613 728-3571
ottawa@jlrichards.ca

Kingston

203-863 Princess Street
Kingston ON Canada
K7L 5N4
Tel: 613 544-1424
kingston@jlrichards.ca

Sudbury

314 Countryside Drive
Sudbury ON Canada
P3E 6G2
Tel: 705 522-8174
sudbury@jlrichards.ca

Timmins

834 Mountjoy Street S
Timmins ON Canada
P4N 7C5
Tel: 705 360-1899
timmins@jlrichards.ca

North Bay

501-555 Oak Street E
North Bay ON Canada
P1B 8E3
Tel: 705 495-7597
northbay@jlrichards.ca

Hawkesbury

326 Bertha Street
Hawkesbury ON Canada
K6A 2A8
Tel: 613 632-0287
hawkesbury@jlrichards.ca

Guelph

107-450 Speedvale Ave. West
Guelph ON Canada
N1H 7Y6
Tel: 519 763-0713
guelph@jlrichards.ca


J.L. Richards
ENGINEERS · ARCHITECTS · PLANNERS