

PARKING LOT STRIPING SPECIFICATIONS:

1. ALWAYS FOLLOW ALL APPLICABLE GOVERNING AUTHORITY'S STANDARDS. 2. SURFACES SHOULD BE CLEAN, DRY, AND FREE FROM LOOSE OR PEELING PAINT. REMOVE ALL OIL, DUST, GREASE, DIRT, AND OTHER FOREIGN MATERIAL TO ENSURE ADEQUATE ADHESION. DO NOT APPLY WHEN AIR OR SURFACE

TEMPERATURES ARE BELOW 40°F. 3. APPLY SHERWIN-WILLIAMS SETFAST PREMIUM ALKYD ZONE MARKING PAINT A300 WHITE OR A303 YELLOW USING EITHER AIRLESS OR CONVENTIONAL LINE STRIPING EQUIPMENT. USE THE FOLLOWING SETTINGS AS A GUIDE-ACTUAL SETTINGS DEPEND ON ATMOSPHERIC CONDITIONS AT THE TIME OF APPLICATION:

AIRLESSPRESSURE HOSETIP

1800-2700 PSI ¼"-<del>3</del>" ID 0.015"-0.017"

 FILTER ONLY IF NECESSARY, UP TO 1PT/GAL REDUCTION VM&P NAPTHA R1K3

FLUID NOZZLE

REDUCTION

BLINKS 21 (BLEEDER) OR EQUIVALENT AIR NOZZLE ATOMIZATION PRESSURE FLUID PRESSURE

INTERNAL MIX, #709 45-80 PSI 40-70 PSI ONLY IF NECESSARY, UP TO 1PT/GAL

VM&P NAPTHA R1K3

 SHERWIN WILLIAMS, H&C SHARK GRIP SLIP RESISTANT ADDITIVE TO BE MEASURED. AND ADDED TO ALL PAINT PER MANUFACTURER'S WRITTEN SPECIFICATIONS. MIX THOROUGHLY PER MANUFACTURER'S RECOMMENDATIONS SO THAT NO CLUMPING IS APPARENT AND UNTIL EVEN DISTRIBUTION IS ACHIEVED. MAINTAIN EVEN

- DISTRIBUTION OF ADDITIVE IN PAINT THROUGHOUT THE APPLICATION PROCESS. MIX PAINT THOROUGHLY BY BOXING, STIRRING, OR POWER AGITATION BEFORE USE. APPLY AT 15 MILS WET TO ACHIEVE A SPREAD RATE OF 400-500 LINEAL FEET OF STANDARD 100mm STRIPE PER GALLON. APPLIED AT THIS RATE AT 70 DEGREES F AND 50% RELATIVE HUMIDITY, PAINT WILL DRY WITH NO TRAFFIC PICKUP AFTER
- GENERAL CONTRACTOR TO RE-STRIPE THE LOT 45 DAYS AFTER OPENING. 4. UTILIZE 1-800 STENCIL FOR SITE PAVEMENT MARKINGS (STOP, DRIVE-THRU, EXIT,

ARROWS, ETC.) 1-800-783-6245 or 1800STENCIL.COM Canada www.exp.com

1595 Clark Boulevard Brampton, ON L6T 4V1

Chick-fil-A

5200 Buffington Road

Atlanta, Georgia 30349-

2998

exp Services Inc.

t: +1.905.793.9800 | f: +1.905.793.0641

• BUILDINGS • EARTH & ENVIRONMENT • ENERGY • • INDUSTRIAL • INFRASTRUCTURE • SUSTAINABILITY •



FSR#30038

XXXXXXXX

**REVISION SCHEDULE** 

NO. DATE DESCRIPTION A 2024-09-20 FOR SPA

CONSULTANT PROJECT #

SEPTEMBER 2024 Information contained on this drawing and in all digital files produced for above named project may not be reproduced in any manner without express written or verbal consent from

GENERIC SITE

**DETAILS** SHEET NUMBER

- LIGHT POLE. SEE ELECT. DWGS

— 3 TIES @ 76mm O.C. AT TOP

- #3 CLOSED TIES @ 305mm O.C.

W/ 305mm MIN. LAP (TYP. U.N.)

POLE SUPPLIER - POLE BASE COVER - 18mm CHAMFER

--- 6 - #6 VERT

– LIGHT PILE BASE PLATE & ANCHOR BOLTS. MATERIAL & DESIGN BY LIGHT

**C9.0** SCALE 1:50

TACTILE WALKING SURFACE **C9.0** SCALE 1:10

**C9.0** SCALE 1:20

MAX. HEIGHT OF LIGHT POLE IS 7.62m ABOVE GRADE.

MAX HEIGHT OF CONCRETE BASE IS .61m ABOVE FINISHED GRADE.

MAX. EXPOSED AREA OF LIGHT FIXTURES IS 0.2 sq.m @ EACH FIXTURE. MAX. 3 FIXTURES PER POLE. . TOTAL EXPOSED AREA OF POLE = 1 sq.m. 12 LIGHT STANDARD BASE