

RSG ENGINEERING INC.
60 Tipperary Pvt. Nepean, Ontario K2J 2T3 Tel: (613) 440-0498
e-mail: goubko@rsgeng.com

February 20, 2025

To:

Jerrica Gilbert
Planner II
Development Review, Rural

Re:

Site Plan Control Application
1386 & 1394 Greely Lane

FILE NO.: D07-12-25-0004

The following is our response to your letter dated February 18, 2025, regarding item "Site Lighting - 33".

The site lighting for this project will be designed using only fixtures having full cut-off classification, as recognized by the Illuminating Engineering Society of North America (IES) and there will be minimal light spillage onto adjacent properties (not exceeding 0.5 foot-candles).

Trusting the above is to your satisfaction, we remain.

Yours truly,
RSG ENGINEERING INC.



Richard Goubko, P.Eng.

