

# NOUVELLE ÉCOLE SECONDAIRE PUBLIQUE À ORLÉANS SUD

2405 & 2419, rue Mer-Bleue,  
Ottawa, ON K4A 3V1



## Zoning Confirmation Report

GRC Project #3024

## Re-Issued for Site Plan Control

April 4th, 2025

## 1. Annex 1 - Zoning Confirmation Report Checklist

A. Project Information			
<b>Review Date:</b>	April 02, 2025	<b>Official Plan designation:</b>	Suburban (East) Transect, Evolving Neighborhood Overlay
<b>Municipal Address(es):</b>	2405 & 2419 Mer Bleue Road, Ottawa, ON, K4A 3V1	<b>Legal Description:</b>	Part of Lot 4 Concession 11, Geographic Township of Cumberland, City of Ottawa
<b>Scope of Work:</b>	Construction of new 3-storey secondary school ESP Orleans-Sud (Mer Bleue) including parking lot, bus loop and basketball court		
<b>Existing Zoning Code:</b>	I1A [2530] / R3Z	<b>By-law Number:</b>	2008-250
<b>Schedule 1 / 1A Area:</b>	Area D (Rural)	<b>Overlays Applicable<sup>1</sup>:</b>	N/A

<sup>1</sup> Mature Neighbourhoods Overlay, Floodplain Overlay, and/or Heritage Overlay.

B. Zoning Review			
For Zoning By-law Amendments, please use the proposed zone and subzone requirements, if different than existing.			
<b>Proposed Zone/Subzone (Zoning By-law Amendments only):</b>	N/A		
<b>Zoning Provisions<sup>1</sup> Table 170A</b>	<b>By-law Requirement or Applicable Section, Exception or Schedule Reference</b>	<b>Proposal</b>	<b>Compliant (Y/N)</b>
<b>Principal Land Use(s)</b>	permit a range of uses including: - school	Secondary School	Y
<b>Lot Width</b>	Min. 15.0 m	190.85 m	Y
<b>Lot Area</b>	Min. 400 m <sup>2</sup>	52,457 m <sup>2</sup>	Y
<b>Front Yard Set Back<sup>2</sup></b>	Min. 6.0 m	> 6 m	Y
<b>Corner Side Yard Setback</b>	Min. 4.5 m	N/A	N/A
<b>Interior Side Yard Setback</b>	Min. 3.0 m	> 3 m	Y
<b>Rear Yard Setback</b>	Min. 7.5 m	> 7.5 m	Y
<b>Lot Coverage Floor Space Index (F.S.I.)</b>	N/A	8.17 %	N/A
<b>Building Height<sup>3</sup></b>	Max. 20 m or four storeys, whichever is less	13 m max height	Y

	(Exception 2530)		
<b>Accessory Buildings Section 55</b>	N/A	N/A	N/A
<b>Projections into Height Limit Section 64</b>	N/A	N/A	N/A
<b>Projections into Required Yards Section 65</b>	N/A	N/A	N/A
<b>Required Parking Spaces Section 101 and 103</b>	93 Spaces [ 3 /classroom x 31 classrooms]	89 <i>Standard Spaces</i> 2 <i>'Type A' Accessible Spaces</i> 2 <i>'Type B' Accessible Spaces</i> <i>Total: 93 spaces</i>	Y
<b>Visitor Parking spaces Section 102</b>	N/A	N/A	N/A
<b>Size of Space Section 105 and 106</b>	(a) min 2.6m wide (b) max 3.1 m wide (c) min 5.2 m long	2.6 m wide x 5.2 m long	Y
<b>Driveway Width Section 107</b>	Min 6.0 wide for a double traffic lane	> 6.0m	Y
<b>Aisle Width Section 107</b>	Min. 6.7m for 90 deg. Parking	>= 6.7m	Y
<b>Location of Parking Section 109</b>	N/A	N/A	N/A
<b>Refuse Collection Section 110</b>	1. located at Min. 9.0m from a lot line abutting a public street and Min. 3.0m from any other lot line 2. an in-ground refuse container screened by soft landscaping	3 x in-ground refuse containers screened by soft landscaping	Y
<b>Bicycle Parking Rates Section 111</b>	1 per 100 m <sup>2</sup> ; 1x [7895/100] = 79 spaces required	80 spaces	Y
<b>Bicycle Space Dimensions Section 111</b>	0.6m x 1.8m with 1.5m access aisle	Provided 0.6 m x 1.8m	Y
<b>Loading Space Rates and Provisions Section 113</b>	Min.1 vehicle loading space required for school with GFA between 5000-9999 m <sup>2</sup>	2 provided	Y
<b>Size of Vehicle Loading Space Section 113, Table 113(b)</b>	Min width = 3.5m and Min length 7m	3.5m x 7m provided	Y

<b>Amenity Space Section 137</b>	N/A	N/A	N/A
<b>Other applicable relevant Provision(s)</b>			
<b>Parking required for person with disabilities Accessibility Standard Parking 3.1</b>	3.1.2 Table 3 Accessible Parking Provision Requirements: For total number parking space between 76-100 -> 4 accessible spaces are required; 2 type A and 2 type B	4 parking spaces provided 2 Type A + 2 Type B	Y
<b>Size of Accessible parking spaces</b>	3.1.3 Design and Layout e. length of 5200mm f. min 3.4m wide for Type A min 2.4m wide for Type B d. provide an access aisle adjacent and parallel to each accessible parking space – min 1.5m wide	Type A = 3.4 m x 5.2 m Type B = 2.6 m x 5.2 m 1.5 m aisle for each	Y

- 1 This template represents a small selection of applicable provisions. Please consider the lot's geography (i.e. corner/through lot, proximity to water, inside/outside Greenbelt) and proposed land use (i.e. drive through operation, outdoor commercial patio, Planned Unit Development, long semi) and consult the by-law to determine which other sections of the By-law must be met. This can be attached in a separate document.
- 2 Note that different performance standards apply to low-rise residential development inside the Greenbelt. Please reference Section 144 for these standards, where applicable.
- 3 This includes maximum building height, minimum building height and stepback provisions, where they exist

*Carolyn Jones*

**CAROLYN JONES, OAA, OAQ, LEED AP**  
ARCHITECT, PARTNER

