



**Stantec**

**Stantec Consulting Ltd.**

400 - 1331 Clyde Avenue, Ottawa ON K2C 3G4

July 18, 2025

**Attention: Jon Baron Area Training Manager - Eastern Ontario**

Carpenters' Union  
8560 Campeau Drive  
Kanata, Ontario K2T 0N7

**Reference: Geotechnical Review of Grading Plan for Proposed Building Addition, 8560 Campeau Drive, Ottawa, ON**

Stantec Consulting Ltd. (Stantec) prepared a geotechnical investigation report for the proposed building addition titled "Proposed Building Addition at 8560 Campeau Drive, Ottawa, ON" dated April 2025.

This letter documents the geotechnical review of the site grading plan for the proposed building addition. The reviewed drawing (No. 123082-GR, "Grading and Erosion & Sediment Control Plan," dated July 14, 2025) shows a finished floor slab elevation of 102.8 m, matching the existing building and includes minor grading near the addition. Stantec has no concerns with the proposed site grades with respect to the settlement of the underlying clay soils.

## CLOSURE

We trust that this proposal meets your current requirements. Should you have any questions or require further clarification regarding this proposal, please do not hesitate to contact our office.

Regards,

**STANTEC CONSULTING LTD.**

Chris McGrath, P.Eng.  
Senior Associate, Geotechnical Engineer



v:\01216\active\1216263xx\121626324\_campeau\05\_report\_deliv\deliverables\report\ltr\_8560\_campeau\_response\_20250414.docx